



Designation: B855 – 17

# Standard Test Method for Volumetric Flow Rate of Metal Powders Using the Arnold Meter and Hall Flowmeter Funnel<sup>1</sup>

This standard is issued under the fixed designation B855; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

## 1. Scope\*

1.1 This test method covers a laboratory procedure for the quantitative determination of the flow rate of a specific volume of a free-flowing metal powder or lubricated powder mixture.

1.2 With the exception of the values for mass, volume and density, for which the use of the gram and the cubic centimetre unit is long-standing industry practice, the values stated in inch-pound units are to be regarded as standard. The values given in parenthesis are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

## 2. Referenced Documents

2.1 *ASTM Standards:*<sup>2</sup>

**B213** Test Methods for Flow Rate of Metal Powders Using the Hall Flowmeter Funnel

**B215** Practices for Sampling Metal Powders

**B243** Terminology of Powder Metallurgy

**B703** Test Method for Apparent Density of Metal Powders and Related Compounds Using the Arnold Meter

**E456** Terminology Relating to Quality and Statistics

<sup>1</sup> This test method is under the jurisdiction of ASTM Committee B09 on Metal Powders and Metal Powder Products and is the direct responsibility of Subcommittee B09.02 on Base Metal Powders.

Current edition approved April 1, 2017. Published April 2017. Originally approved in 1994. Last previous edition approved in 2011 as B855 – 11. DOI: 10.1520/B0855-17.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

2.2 *MPIF Standard*<sup>3</sup>

**MPIF Standard 48** Determination of Apparent Density of Metal Powders using the Arnold Meter

## 3. Terminology

3.1 *Definitions*—Useful definitions of terms for metal powders and powder metallurgy used in this standard are found in Terminology **B243**. Additional descriptive PM information is available in the Related Material section of Vol 02.05 of the *Annual Book of ASTM Standards*.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *volumetric flow rate*—the relation between time and volume of a free-flowing metal powder determined by measuring the time for a specific volume to flow through the orifice in a Hall Flowmeter Funnel and expressing the ratio in seconds per 20 cubic centimetres. ( $s/20\text{ cm}^3$ ).

## 4. Summary of Test Method

4.1 A  $20\text{ cm}^3$  test portion of powder is prepared from the lot to be tested following the procedures in Test Methods **B215** and **B703**.

4.2 This  $20\text{ cm}^3$  test portion is timed as it flows through the orifice in a Hall Flowmeter Funnel following the procedure in Test Method **B213**.

4.3 The volumetric flow rate is calculated and reported in seconds per 20 cubic centimetres. ( $s/20\text{ cm}^3$ )

## 5. Significance and Use

5.1 The volumetric flow rate is a measure of the flow characteristics of a metal powder. Measuring flow by volume as compared with flow per unit mass eliminates the variable of the powder density and relates to the production practice of die filling by volume.

5.2 The ability of a powder to flow and pack is a function of interparticle friction. As the surface area increases, the amount of friction in a powder mass also increases. Consequently, the friction between particles increases, giving less efficient flow and packing.

<sup>3</sup> Available from ASTM or Metal Powder Industries Federation, 105 College Road East, Princeton, NJ 08540 and initially reported in MPIF Standard 48

\*A Summary of Changes section appears at the end of this standard

5.3 Knowledge of the volumetric flow rate permits the part producer to estimate the number of parts that can be compacted per hour.

5.4 This test may be part of the purchase agreement between metal powder manufacturers and powder metallurgy (PM) part producers, or it can be an internal quality control test for any company using metal powders.

## 6. Apparatus

6.1 *Workbench*—A level, vibration-free table or laboratory workbench to support the Arnold Meter and the Hall Flowmeter apparatus.

6.2 *Arnold Meter*<sup>4</sup>—The steel die block and powder delivery cylinder described in Test Method B703 that is used to obtain the 20 cm<sup>3</sup> test portion of powder.

6.3 *Collection Paper*—A 6 by 6 in. square sheet of glazed or waxed paper (~150 by 150 mm) used to collect the 20 cm<sup>3</sup> test portion of powder from the die block of the Arnold Meter.

6.4 *Powder Scoop*—A small nonmagnetic spoonlike laboratory utensil with handle, having a minimum capacity of 25 cm<sup>3</sup>, used for the controlled transfer of the 20 cm<sup>3</sup> test portion of powder from the collection paper into the Hall Flowmeter Funnel.

6.5 *Hall Flowmeter Funnel*<sup>5</sup>—calibrated Hall flowmeter funnel having a nominal orifice of 0.10 inches (2.5 mm) with support stand as is shown in Test Method B213. The funnel is stamped with a correction factor determined by the manufacturer using a Certified Flow Standard.

6.6 *Timing Device*—A stopwatch or other instrumentation capable of measuring the flow time of the powder to the nearest 0.1 second.

## 7. Sampling

7.1 Obtain a sample of approximately 150 cm<sup>3</sup> from the lot that is to be tested following the procedure in Practices B215.

7.2 Using a micro-sample rotary riffler or a micro-splitter, divide the quantity into three samples of approximately 50 cm<sup>3</sup> each.

## 8. Procedure

8.1 Using the Arnold Meter and one of the 50 cm<sup>3</sup> samples, follow the procedure described in Test Method B703 to prepare an exact 20 cm<sup>3</sup> test portion of powder.

8.2 Using the scoop to carefully pour the sample into the center of the funnel, determine the time required for the

powder to flow through the funnel following either of the procedures described in Test Method B213.

8.3 Repeat 8.1 and 8.2 two more times, using a new 50 cm<sup>3</sup> sample each time and record each of the three flow time determinations to the nearest 0.1 second.

## 9. Calculation

9.1 Average the three flow times, multiply by the Correction Factor<sup>6</sup> for the funnel being used, and calculate the Arnold/Hall Volumetric Flow Rate in s/20 cm<sup>3</sup> units as follows:

Arnold/Hall Flow Rate, s/20 cm<sup>3</sup>=

$$\frac{\text{Avg. flow time} \times \text{Funnel Correction Factor}}{20 \text{ cm}^3} \quad (1)$$

## 10. Report

10.1 Report the Arnold/Hall Volumetric Flow Rate as the average of three determinations in s/20 cm<sup>3</sup> units rounded to the nearest second.

10.2 Report the B213 Flow Method, Static or Dynamic, that was used.

## 11. Precision and Bias

11.1 *Interlaboratory Test Program*—An interlaboratory study of the Arnold/Hall Volumetric Flow Rate test method was conducted by ASTM Subcommittee B09.02 in 1991 in conjunction with the Metal Powder Producers Association of the Metal Powder Industries Federation. Each of eight laboratories tested three randomly drawn test samples of both an iron powder and a lubricated bronze powder mixture. The design of the experiment followed the protocol of Practice B855, and an analysis of the within-between laboratory test data is contained in MPIF research report MPIF Standard 48.

11.2 *Test Results*—The precision information presented herein has been calculated for the comparison of two test results, each of which is the average of three individual test determinations.

11.3 *95% Repeatability Limit (within a laboratory)*—The within a laboratory limit, *r*, as defined by Terminology E456, has been determined to be 1 second for the iron powder and 2 seconds for the lubricated bronze powder mixture. At the 95% confidence level, duplicate Arnold/Hall Volumetric Flow test results from the same laboratory should not be considered to be different unless they differ by more than *r*.

11.4 *95% Reproducibility Limit (between laboratories)*—The between laboratories limit, *R*, as defined by Terminology E456, has been determined to be 2 seconds for the iron powder and 3 seconds for the lubricated bronze powder mixture. At the 95% confidence level, two Arnold/Hall Volumetric Flow Rate test results from two different laboratories should not be considered to be different unless they differ by more than *R*.

<sup>4</sup> The sole source of supply of the Arnold Density Meter complete with bushing known to the committee at this time is Arnold P/M Consulting Services, 648 Cedar Road, St. Marys, PA 15857. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee,<sup>1</sup> which you may attend.

<sup>5</sup> The sole source of supply of the complete Hall Flowmeter known to the committee at this time is ACuPowder International LLC, 901 Lehigh Avenue, Union NJ 07083-7632. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee,<sup>1</sup> which you may attend.

<sup>6</sup> The correction factor is a value supplied by the manufacturer of the funnel using a Certified Flow Standard. Periodically, the funnel must be calibrated with the standard powder to compensate for orifice wear. For the calibration procedure, refer to Test Method B213.

11.5 *Bias*—No information can be presented on the bias of the procedure in Test Method B855 for measuring the Arnold/Hall Volumetric Flow Rate because no material having an accepted reference value is available.

11.6 *Measurement Uncertainty*—The precision of this test method shall be considered by those performing the test when reporting Arnold/Hall Volumetric Flow Rate test results.

## 12. Keywords

12.1 Arnold/Hall flow; interparticle friction; metal powders; volumetric flow rate

## SUMMARY OF CHANGES

Committee B09 has identified the location of selected changes to this standard since the last issue (B855 – 11) that may impact the use of this standard.

(1) In 6.3 changed “6.0 by 6.0 in” to “6 by 6 in.”

(2) In 6.5 changed a “calibrated orifice” to “A calibrated Hall flowmeter funnel having a nominal orifice of.”

(3) In 6.5 changed 2.54 mm to 2.5 mm.

(4) In 7.2 changed “test samples” to samples.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>*