



Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics¹

This standard is issued under the fixed designation D2843; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 This fire-test-response test method covers a laboratory procedure for measuring and observing the relative amounts of smoke obscuration produced by the burning or decomposition of plastics. It is intended to be used for measuring the smoke-producing characteristics of plastics under controlled conditions of combustion or decomposition. Correlation with other fire conditions is not implied. The measurements are made in terms of the loss of light transmission through a collected volume of smoke produced under controlled, standardized conditions. The apparatus is constructed so that the flame and smoke is observable during the test.²

1.2 During the course of combustion, gases or vapors, or both, are evolved that are potentially hazardous to personnel. Adequate precautions shall be taken to protect the operator.

1.3 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information purposes only.

1.4 *This standard is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled conditions, but does not by itself incorporate all factors required for fire hazard or fire risk assessment of the materials, products, or assemblies under actual fire conditions.*

1.5 *Fire testing is inherently hazardous. Adequate safeguards for personnel and property shall be employed in conducting these tests. Specific safety warning statements are given in 1.2 and 9.13.*

1.6 *This standard does not purport to address all of the safety problems, if any, associated with its use. It is the responsibility of the user of this standard to establish appro-*

priate safety and health practices and determine the applicability of regulatory limitations prior to use.

NOTE 1—There is no known ISO equivalent to this standard.

2. Referenced Documents

2.1 *ASTM Standards:*³

[D618 Practice for Conditioning Plastics for Testing](#)

[D883 Terminology Relating to Plastics](#)

[D1600 Terminology for Abbreviated Terms Relating to Plastics](#)

[E84 Test Method for Surface Burning Characteristics of Building Materials](#)

[E176 Terminology of Fire Standards](#)

[E662 Test Method for Specific Optical Density of Smoke Generated by Solid Materials](#)

[E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method](#)

[E906 Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using a Thermopile Method](#)

[E1354 Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter](#)

3. Terminology

3.1 *Definitions*—The terminology used in this test method is in accordance with Terminologies [D883](#) and [D1600](#) (terms relating to plastics) and Terminology [E176](#) (terms relating to fire).

4. Summary of Test Method

4.1 The test specimen is exposed to flame for the duration of the test, and the smoke is substantially trapped in the chamber in which combustion occurs. A 25 by 25 by 6-mm (1 by 1 by 1/4-in.) specimen is placed on supporting metal screen and burned in a laboratory test chamber ([Fig. 1](#)) under active flame


¹ This test method is under the jurisdiction of ASTM Committee [D20](#) on Plastics and is the direct responsibility of Subcommittee [D20.30](#) on Thermal Properties- (Section D20.30.03).

Current edition approved May 1, 2016. Published May 2016. Originally approved in 1970. Last previous edition approved in 2010 as D2843 - 10. DOI: 10.1520/D2843-16.

² Anonymous, "A Method of Measuring Smoke Density," *NFPA Quarterly*, QNFPA, Vol 57, January 1964, p. 276. Reprint NFPA Q57-9. Available from NFPA, 60 Batterymarch St., Boston, MA 02110.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard



1. Specimen Holder
 - A Stainless steel screen
 - B Calcium-silicate sheet
 - C Adjusting knob
 - D Quench pan
2. Ignition
 - A Burner
 - B Propane tank
 - C Gas shut-off valve
 - D Pressure regulator adjustment
 - E Pressure indicator
 - F Burner-positioning knob
3. Cabinet (shown without door)
 - A Hinges (door gasketed three sides)
 - B Vents (25-mm (1-in.) high opening four sides)
 - C Blower (damper on mounting side)
 - D Control (blower on when damper is open)
4. Photometer
 - A Visual system (exit sign)
 - B Measuring system
 - 1 Light source and adjusting transformer
 - 2 Photronic cell and grid (to block stray light)
 - 3 Meter (indicating percent of light absorbed)
 - 4 Temperature compensation (if required)
 - 5 Photocell temperature monitor (if required)
 - 6 Range change
5. Timer
 - A Indicator, 0 to 5 min (friction reset)

FIG. 1 Schematic Diagram of Smoke Chamber




FIG. 2 Light Absorption versus Time

conditions using a propane burner operating at a pressure of 276 kPa (40 psi). The 300 by 300 by 790-mm (12 by 12 by 31-in.) test chamber is instrumented with a light source, photoelectric cell, and meter to measure light absorption horizontally across the 300-mm (12-in.) light beam path. The chamber is closed during the 4-min test period except for the 25-mm (1-in.) high ventilation openings around the bottom.

4.2 The light-absorption data are plotted versus time. A typical plot is shown in Fig. 2. Two indexes are used to rate the material: the maximum smoke produced and the smoke-density rating.

5. Significance and Use

5.1 Tests made on a material under conditions herein prescribed are of considerable value in comparing the relative smoke obscuration characteristics of plastics.

5.2 This test method serves to determine the extent to which plastic materials are likely to smoke under conditions of active burning and decomposition in the presence of flame.

NOTE 2—One study⁴ suggested that visual and instrumental observations from this test compare well with the visual observations of the smoke generated by plastic materials when added to a freely burning large outdoor fire.

5.3 The usefulness of this test procedure is in its ability to measure the amount of smoke obscuration produced in a simple, direct, and meaningful manner under the specified conditions. The degree of obscuration of vision by smoke generated by combustibles is known to be affected by changes in quantity and form of material, humidity, draft, temperature, and oxygen supply.

⁴ Bartosic, A. J., and Rarig, F. J., "Evaluation of the XP2 Smoke Density Chamber," *Symposium on Fire Test Methods—Restraint & Smoke*, ASTM STP 422, ASTM, Philadelphia, PA, 1966.

5.4 *Safety Precautions*—Products of combustion are toxic. Care shall be taken to guard the operator from the effects of products of combustion.

6. Apparatus

6.1 The smoke chamber shall be constructed essentially as shown in Fig. 1.⁵

6.1.1 Chamber:

6.1.1.1 The chamber shall consist of a 14-gage (B & S or AWG) 300 by 300 by 790-mm (12 by 12 by 31-in.) aluminum box to which is hinged a heat-resistant glass glazed door. This box shall be mounted on a 350 by 400 by 57-mm (14 by 16 by 2¼-in.) base which houses the controls. Dependent upon the materials tested, the metal will require protection from corrosion.

6.1.1.2 The chamber shall be sealed except for 25 by 230-mm (1 by 9-in.) openings on the four sides of the bottom of the chamber. A 1700-L/min (60-ft³/min) blower shall be mounted on one side of the chamber. The inlet duct to the exhaust blower shall be equipped with a close-fitting hood damper. The outlet of the blower shall be connected through a duct to the laboratory exhaust system. If the chamber is in a ventilated hood, no connection to the lab exhaust system through a duct is needed.

6.1.1.3 The two sides adjacent to the door shall be fitted with 70-mm (2¾ in.) diameter smoke-tight glazed areas centered 480 mm (19¾ in.) above the base. At these locations and outside the chamber, boxes containing the optical equipment and additional controls shall be attached.

6.1.1.4 A removable white plastic plate shall be attached to the back of the chamber. There shall be a 90 by 150-mm (3½

⁵ Detailed drawings of the smoke chamber are also available at a nominal cost from ASTM Headquarters. Order Adjunct: [ADJD2843](#).




FIG. 3 Exploded View of Burner

by 6-in.) clear area centered 480 mm above the bottom of the chamber through which is seen an illuminated white-on-red exit sign. The white background permits observation of the flame, smoke, and burning characteristics of the material. The viewing of the exit sign helps to correlate visibility and measured values.

6.1.2 *Specimen Holder:*

6.1.2.1 The specimen shall be supported on a 64-mm (2½-in.) square of 6 by 6-mm, 0.9-mm gage (¼ by ¼-in., 0.035-in. gage) stainless steel wire cloth 220 mm (8¾ in.) above the base and equidistant from all sides of the chamber. This screen shall lie in a stainless steel bezel supported by a rod through the right side of the chamber. From the same rod, a similar bezel shall be located 76 mm (3 in.) below, and it shall support a square of ¼-in. thick calcium silicate to catch particles that drip from the specimen during the test. At the conclusion of the test, rotate the specimen holder rod and quench the burning specimen in a shallow pan of water positioned below the specimen holder.

6.1.3 *Ignition System:*

6.1.3.1 The specimen shall be ignited by a propane flame from a burner operating at a pressure of 276 kPa (40 psi). The fuel (Note 3) shall be mixed with air that has been propelled through the burner by the Venturi effect of the propane as it passes from a 0.13-mm (0.005-in.) diameter orifice (Note 4), and the burner shall be assembled as shown in the exploded view of the burner in Fig. 3. The burner shall be designed to provide adequate outside air.

NOTE 3—Commercial grade 85.0 % minimum, gross heating value 23 000 cal/litre (2590 Btu/ft³) propane meets the requirements.

NOTE 4—Since the orifice provides the metering effect proportionate to the supply pressure, care must be taken that the orifice is the only means of fuel egress.

6.1.3.2 The burner shall be capable of being positioned quickly under the specimen so that the axis of the burner falls on a line passing through a point 8 mm (3/10 in.) above the base at one back corner of the chamber extending diagonally across the chamber and sloping upward at 45 deg with the base. The exit opening of the burner shall be 260 mm (10¼ in.) from the reference point at the rear of the chamber.


6.1.3.3 A duct having a minimum diameter of 150 mm (6 in.) outside of the chamber shall provide the air piped to the burner.

6.1.3.4 Propane pressure shall be adjustable and preferably automatically regulated. Propane pressure shall be indicated by means of a Bourdon tube gage.

6.1.4 *Photometric System:*

6.1.4.1 A light source, a barrier-layer photoelectric cell, and a temperature compensated meter shall be used to measure the proportion of a light beam which penetrates a 300-mm (12-in.) path through the smoke. The light path shall be arranged horizontally as shown in Fig. 4.

6.1.4.2 The light source shall be mounted in a box (4B1 in Fig. 1) extending from the left side of the chamber at the mean height of 480 mm (19¾ in.) above the base. The light source shall be a compact filament microscope lamp No. 1493



T = Temperature-sensitive winding in or on meter case to increase in resistance in proportion to increase in meter resistance with temperature.
 R = Potentiometer with calibrated scale to reduce resistance in proportion to decrease in photocell output with rise in temperature.
 C = Potentiometer to calibrate total resistance of shunt to change meter sensitivity exactly by 10:1 ratio.

FIG. 4 Smoke Density Test Chamber Photometer

operated at 5.8 V and a spherical reflector, with power supplied by a voltage-regulating transformer. A lens of focal length 60 to 65 mm (2½-in.) shall focus a spot of light on the photocell in the right instrument panel.

6.1.4.3 Another box containing the photometer (4 B2 in Fig. 1) shall be attached to the right side of the chamber. The barrier-layer photoelectric cell shall have standard observer spectral response. An egg-crate grid in front of the photocell shall be used to protect the cell from stray light. The grid shall be finished in dull black and have openings at least twice as deep as they are wide. The current produced by the photocell is indicated in terms of percent light absorption on a meter or on a computer display using software. The photocell linearity decreases as the temperature increases; compensations shall therefore be made. The photocell shall not be operated at temperatures exceeding 50°C.

6.1.4.4 The meter shall have two ranges. The range change shall be accomplished by shunting the meter to one tenth of its sensitivity. When smoke accumulates to absorb 90 percent of the light beam, the meter shall be set to its basic sensitivity, by any appropriate manner (for example, pressing a momentary switch, turning a dia, or automatically controlled by software). By doing this, the scale in the meter will then read from 90 to 100 % absorption instead of reading from 0 to 100 % absorption.

6.1.5 *Timing Device*—A timing device, such as a clock, shall be used to indicate 15-s intervals. If the time intervals are audibly marked it will be convenient for the operator to record all observations. The timing device shall be reset at the start of

a test. The timing device shall start measuring when the burner is swung into test position.

6.1.6 *Planimeter*—A planimeter or other suitable means shall be used for measuring the area under the light-absorption curve.

7. Test Specimen

7.1 The standard specimen shall be 25.4 ± 0.3 by 25.4 ± 0.3 by 6.2 ± 0.3 mm (1 ± 0.01 by 1 ± 0.01 by $\frac{1}{4} \pm 0.01$ in.). Material thinner than 6.2 ± 0.3 mm shall be tested by stacking and forming a composite specimen 6.2 ± 0.3 mm thick. Material thicker than 6.2 mm ($\frac{1}{4}$ in.) shall be tested by machining the material down to a thickness of 6.2 ± 0.3 mm.

7.2 The specimens shall be sanded, machined, or die cut in a manner that produces a cut surface that is free from projecting fibers, chips, and ridges.

7.3 The test sample shall consist of three specimens.

8. Conditioning

8.1 *Conditioning*—Condition the test specimens at $23 \pm 2^\circ\text{C}$ ($73.4 \pm 3.6^\circ\text{F}$) and $50 \pm 5\%$ relative humidity for not less than 40 h prior to test in accordance with Procedure A of Practice D618, for those tests where conditioning is required. In cases of disagreement, the tolerances shall be $\pm 1^\circ\text{C}$ ($\pm 1.8^\circ\text{F}$) and $\pm 2\%$ relative humidity.

8.2 *Test Conditions*—Conduct tests in the standard laboratory atmosphere of $23 \pm 2^\circ\text{C}$ ($73.4 \pm 3.6^\circ\text{F}$) and $50 \pm 5\%$

relative humidity, unless otherwise specified in the test methods or in this test method. In cases of disagreement, the tolerances shall be 1°C (±1.8°F) and ±2 % relative humidity.

8.3 Tests shall be conducted in a hood that has a window for observing the test.

9. Standard Procedure

9.1 Turn on the photometer lamp, exit sign, and exhaust blower.

9.2 Turn on the propane, immediately ignite the burner, and adjust the propane pressure to 276 kPa (40 psi).

9.3 Set the temperature compensation as required.

9.4 If possible, adjust the lamp control to 100 percent light absorption (by blocking the light reaching the photocell with an opaque plate).

9.5 Adjust the lamp control to zero percent light absorption.

9.6 Lay the test specimen flat on the screen in such a position that the burner flame will be directly under the specimen when the burner is swung into position.

9.7 Ensure that the shallow pan of water is positioned below the specimen holder.

9.8 Set the timer to zero.

9.9 Shut off the exhaust blower, close the smoke chamber door, and immediately position the burner under the specimen and start the timer.

9.10 If in a hood, shut off the hood fan and close the hood door to within 50 mm (2 in.) of the bottom of the hood.

9.11 Record the percent light absorbed at intervals as short as possible, but not exceeding 15-s for 4 min.

9.12 Record observations during the conduct of the test. Include the time it takes for the sample to burst into flame, the time for flame extinguishment or specimen consumption, the obscuration of the exit sign by smoke accumulation, and any general or unusual burning characteristics noted such as melting, dripping, foaming, or charring.

9.13 Upon completion of the test, turn on the exhaust blower to ventilate the combustion products from the chamber.

9.14 Rotate the specimen holder rod and quench the burning specimen in the shallow pan of water positioned below the specimen holder.

NOTE 5—All products of combustion are toxic. Care shall be taken to guard the operator from the effects of these gases. This requires the exhaust blower to be turned off and the hood damper to be closed during the test to prevent back draft (see 9.9). The ventilating fan in the hood must be turned on and the damper opened immediately after the test is completed before opening the hood door in order to remove any irritating or toxic products of the test.

9.15 Open the door and clean the combustion deposits from the photometer, exit sign, and door glass with detergent and water. Burn off any material remaining on the screen or replace the screen and square of 6-mm (¼-in.) thick calcium silicate for the next test.

9.16 Run all tests in triplicate.

9.17 At the beginning of each series or at least once a day, check the light absorption of the meter against a calibrated neutral filter of approximately 50 % absorption. Check the 100 % absorption point against an opaque plate.

10. Special Procedure

10.1 For materials that drip, a second or auxiliary burner (with separate propane gas supply) shall be introduced into the chamber. See Fig. 5 and auxiliary burner parts list.

10.2 The auxiliary burner shall be ignited at the same time the standard burner is ignited. The auxiliary burner shall be operated at 138 kPa (20 psi) and it shall be positioned in such a manner that its flame is directed at the center of the collector tray.

10.3 To prevent movement of the burner during the test, place a lightweight, about 1100 g (2.5 lbs), on the aluminum mounting plate (Item 12, Fig. 5).

10.4 In all other respects the procedures of Section 9 shall be followed.

11. Optional Procedures

11.1 Data acquisition hardware or a potentiometric recorder can be employed to record the output of the photocell versus time.

11.2 With a suitably sensitive meter, more than one decade change needs to be used to separate readings in the very dense smoke range.

12. Treatment of Data

12.1 Average the readings at 15-s intervals of light absorption for the three specimens in each group. Plot the average light absorption against time. Fig. 2 is a sample curve.


12.2 Read the maximum smoke density as the highest point on the curve.

12.3 Determine the total smoke produced by measuring the area under the curve of the graph of average light absorption as a function of time, with the time axis ranging from 0 to 4 minutes and the percentage light absorption axis ranging from 0 to 100 %. The smoke density rating represents the total amount of smoke present in the chamber for the 4-min time interval. Measure the smoke density rating (SDR) by dividing the area under the curve of light absorption versus time, by the total area of the graph and multiplying the result by 100.

$$\text{SDR} = 100 \times (\text{Area under Curve of Graph of Light Absorption vs. Time}) / (\text{Total Graph Area})$$

NOTE 6—Example—In the light absorption-time plot in Fig. 2, the plot has been made using 10 mm (0.39 in.) equal to 10 % as the ordinate and 10 mm (0.39 in.) equal to 0.25 min as the abscissa. The total graph area for 4 min is found to be 16 000 mm² (24.80 in.²). The area under the curve is found to be 12 610 mm² (19.55 in.²). The smoke density rating, %, is then computed as follows:

$$\begin{aligned} \text{Smoke density rating} &= (12610/16000) \times 100 = 78.8 \\ &\quad (\text{dimensions in millimetres}) \\ &= (19.55/24.80) \times 100 = 78.8 \\ &\quad (\text{dimensions in inches}) \end{aligned}$$



Auxiliary Burner Parts List

1. Low pressure propane gas regulator (0 to 60 psi gage).
2. Propane fuel tank.
3. Flexible gas line.
4. Aluminum support bracket.
5. 1/8 in. O.D. copper tube (flexible).
6. 1/2 in. diameter copper tube 8 in. long.
7. 45° extruded and expanded copper fitting.
8. 90° extruded and expanded copper fitting. (4 in. from bend to end of burner head)
9. Sliding sleeve.
10. Burner head. (Same as standard burner head)
11. S.S. collector tray (2 1/2 by 2 1/2 by 3/8 in. deep with 1/2 in. sq. bottom).
12. Aluminum mounting plate. (3 by 3 1/2 in.)
13. 90° elbow and wall flange. (copper)
14. 1/2 in. diameter copper tube 8 3/4 in. long.

FIG. 5 Auxiliary Burner

13. Report

- 13.1 Report the following information:
- 13.1.1 Identification of the material,
 - 13.1.2 Dimensions of the specimen,
 - 13.1.3 Readings of light absorption at 15-s intervals for each test and average,
 - 13.1.4 Plots of average light absorption versus time,
 - 13.1.5 Maximum smoke density in percent light absorption,

- 13.1.6 Area in percent under the light absorption-time curve (smoke density rating),
- 13.1.7 Observations on behavior of material,
- 13.1.8 Observations on obscuration of exit sign,
- 13.1.9 The details of any departure from the specifications of the method for testing, and
- 13.1.10 The caveat contained in 1.4 herein shall be incorporated in its entirety in the report issued.

TABLE 1 Smoke Density Rating (SDR)

Material	Average, %	S_r^A	S_R^B	r^C	R^D
Polystyrene	90.0	1.94	4.16	5.44	11.64
General purpose polycarbonate	54.7	7.65	15.77	21.41	44.16
Abrasion resistant polycarbonate	44.5	7.00	22.55	19.61	63.13
Impact acrylic	6.1	2.25	6.78	6.29	18.98
PMMA copolymer	3.8	1.46	4.28	4.08	11.98

^A S_r = within-laboratory standard deviation for the indicated material. It is obtained by pooling the laboratory standard deviations of the test results from all of the participating laboratories:

$$S_r = [[(S_1)^2 + (S_2)^2 \dots + (S_n)^2]/n]^{1/2}$$

^B S_R = between-laboratories reproducibility, expressed as standard deviation:

$$S_R = [S_r^2 + S_L^2]^{1/2}$$

^C r = within-laboratory critical interval between two test results = $2.8 \times S_r$.

^D R = between-laboratories critical interval between two test results = $2.8 \times S_R$.

14. Precision and Bias (Standard Procedure)⁶

14.1 **Table 1** is based on a round robin completed in 1998 in accordance with Practice **E691**, involving five materials tested by six laboratories. For each material, all the samples were prepared at one source, but the individual specimens were prepared at the laboratories that tested them. Each test result was the average of three individual determinations.

14.1.1 It is important to note that the Smoke Density Rating (SDR) rating must be a number in the range of 0 and 100. Thus, values that are close to 100 such as material B and those close to 0 such as materials D and E will not have a normal distribution as is assumed in Practice **E691**. The distribution is skewed. If the standard deviation is applied to these numbers, range values exceeding 100 and less than 0 are possible. Practice **E691** does not allow for calculating values outside the normal distribution. Thus, caution shall be used when applying these statistics to numbers near the minimum and maximum of the test method.

14.2 The following explanations of I_r and I_R (**14.3.1 – 14.3.3**) are only intended to present a meaningful way of considering the *approximate* precision of this test method. The data in **Table 1** shall not be rigorously applied to acceptance or rejection of material, as those data are specific to the round robin and are not representative of other lots, conditions, materials, or laboratories.

14.2.1 Apply the principles outlined in Practice **E691** to generate data specific to their laboratory and materials, or between specific laboratories. The principles of **14.3 – 14.3.3** are then valid for such data.

14.3 *Concept of I_r and I_R* —If S_r and S_R have been calculated from a large enough body of data, and for test results that were averages from testing three specimens:

14.3.1 I_r : *Repeatability*—Comparing two test results for the same material, obtained by the same operator using the same equipment on the same day, the two test results shall be judged not equivalent if they differ by more than the I_r value for that material.

14.3.2 I_R : *Reproducibility*—Comparing two test results for the same material, obtained by different operators using different equipment on different days, the two test results shall be judged not equivalent if they differ by more than the I_R value for that material.

14.3.3 Any judgment per **14.3.1** and **14.3.2** has an approximate 95 % (0.95) probability of being correct.

14.4 *Bias*—Bias is a systematic error which contributes to the difference between a test result and a true (or reference) value. There are no recognized standards by which to estimate bias of this test method.

15. Precision and Bias (Special Procedure)⁷

15.1 **Table 2** is based on a round robin conducted in 1982 in accordance with Practice **E691**, involving nine materials tested by six laboratories. For each material, all the samples were prepared at one source, but the individual specimens were prepared at the laboratories which tested them. Each test result was the average of three individual determinations. Each lab obtained five test results for each material.

15.2 The following explanations of I_r and I_R (**15.3.1 – 15.3.3**) are only intended to present a meaningful way of considering the *approximate* precision of this test method. The data in **Table 2** shall not be rigorously applied to acceptance or rejection of material, as those data are specific to the round robin and are not representative of specific lots, conditions, materials, or laboratories.

15.2.1 Apply the principles outlined in Practice **E691** to generate data specific to their laboratory and materials, or between specific laboratories. The principles of **15.3 – 15.3.3** are then valid for such data.

15.3 *Concept of I_r and I_R* —If S_r and S_R have been calculated from a large enough body of data, and for test results that were averages from testing three specimens:

15.3.1 I_r : *Repeatability*—Comparing two test results for the same material, obtained by the same operator using the same equipment on the same day, the two test results shall be judged not equivalent if they differ by more than the I_r value for that material.

15.3.2 I_R : *Reproducibility*—Comparing two test results for the same material, obtained by different operators using different equipment on different days, the two test results shall be judged not equivalent if they differ by more than the I_R value for that material.

15.3.3 Any judgment in accordance with **15.3.1** and **15.3.2** has an approximate 95 % (0.95) probability of being correct.

15.4 *Bias*—Bias is a systematic error which contributes to the difference between a test result and a true (or reference) value. There are no recognized standards by which to estimate bias of this test method.

16. Keywords

16.1 burning; decomposition; plastics; smoke; smoke density; smoke development

⁶ Supporting data are available from ASTM Headquarters. Request RR:D20-1203.

⁷ Supporting data are available from ASTM Headquarters. Request RR:D20-77.

TABLE 2 Precision Data for Special Procedure

Values in Units of Smoke Density Rating, Absolute %					
Material	Average	S_r^A	S_R^B	I_r^C	I_R^C
Molded polystyrene	88.00	2.90	3.72	8.22	10.55
Polystyrene sheet	81.90	3.61	5.26	10.21	14.89
PMMA	3.64	1.50	2.21	4.25	6.25
Polycarbonate	68.73	3.55	9.26	10.03	26.20
LDPE	63.53	4.30	9.24	12.17	26.15
HDPE	46.23	4.09	15.66	11.57	44.33
Modified HDPE	50.38	2.83	16.75	8.02	47.41
Molded acrylic	3.64	1.09	1.35	3.07	3.81
Impact modified acrylic	7.87	1.55	3.28	4.38	9.28

^A S_r = within-laboratory standard deviation of the average.

^B S_R = between-laboratories standard deviation of the average.

^C $I_r = 2.83 S_r$; $I_R = 2.83 S_R$.

APPENDIX

(Nonmandatory Information)

X1. ADDITIONAL INFORMATION

X1.1 Test Method D2843 is used by model code organizations in controlling the use of plastic materials in light transmitting applications. It is allowed as an alternate to the Test Method E84 smoke measurement since Test Method D2843 is suitable for thermoplastic materials that drip and fall out of the Test Method E84 apparatus. Thermoplastic materials

comprise most of the plastics used in light transmitting applications. Many tests are available to measure smoke from burning materials (for example, Test Methods E662, E906, E1354, and others). None of these tests, including Test Method D2843, have shown any extensive correlation with each other.

SUMMARY OF CHANGES

Committee D20 has identified the location of selected changes to this standard since the last issue, D2843 - 10, that may impact the use of this standard. (May 1, 2016)

- | | |
|--|--|
| (1) Added statements of “if required” to Fig. 1. | (6) Updated Section 9, including former Note 6 (now Note 5). |
| (2) Updated Note 2. | (7) Updated 12.3 for clarification, as was former Note 7 (now Note 6). |
| (3) Added 5.4 on safety precautions. | (8) Revised the term “obscurment” to “obscuration” for consistency. |
| (4) Revised 6.1.4.2 through 6.1.5. | |
| (5) Deleted Note 5 and added to 6.1.4.3 as mandatory text. | |

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/