



Standard Test Method for Gamma Alumina Content in Catalysts and Catalyst Carriers Containing Silica and Alumina by X-ray Powder Diffraction¹

This standard is issued under the fixed designation D4926; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the determination of gamma alumina and related transition aluminas in catalysts and catalyst carriers containing silica and alumina by X-ray powder diffraction, using the diffracted intensity of the peak occurring at about $67^\circ 2\theta$ when copper $K\alpha$ radiation is employed.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method

3. Summary of Test Method

3.1 A sample of catalyst or catalyst carrier is calcined and ground, and an X-ray powder diffraction pattern is obtained under specified conditions over the approximate range from 52 to $76^\circ 2\theta$. The diffracted intensity above background for the peak occurring at about $67^\circ 2\theta$ is compared to that of a reference sample, after appropriate adjustments are made for scale settings and peak half-widths.

4. Significance and Use

4.1 This test method is for estimating the relative amount of gamma alumina in calcined catalyst or catalyst carrier samples,

assuming that the X-ray powder diffraction peak occurring at about $67^\circ 2\theta$ is attributable to gamma alumina. Gamma alumina is defined as a transition alumina formed after heating in the range from 500 to 550°C , and may include forms described in the literature as eta, chi, and gamma aluminas. Delta alumina has a diffraction peak in the same region, but is formed above 850°C , a temperature to which most catalysts of this type are not heated. There are other possible components which may cause some interference, such as alpha-quartz and zeolite Y, as well as aluminum-containing spinels formed at elevated temperatures. If the presence of interfering material is suspected, the diffraction pattern should be examined in greater detail. More significant interference may be caused by the presence of large amounts of heavy metals or rare earths, which exhibit strong X-ray absorption and scattering. Comparisons between similar materials, therefore, may be more appropriate than those between widely varying materials.

5. Apparatus

5.1 *X-ray Powder Diffractometer Unit*, with standard sample mount, Cu $K\alpha$ radiation, monochromator, wide divergence and receiving slits (for example, 3° and 0.15° , respectively), goniometer speed of $0.5^\circ/\text{min}$ or equivalent, chart speed of about $0.5\text{ cm}/\text{min}$ or equivalent, and scale or gain factors to provide conveniently measurable peaks. Computerized data acquisition equipment may also be used.

NOTE 1—For diffractometers employing step scanning, convenient corresponding conditions include a step size of 0.02° and a counting time of $2.4\text{ s}/\text{step}$, which is equivalent to a scanning rate of $0.5^\circ/\text{min}$.

5.2 *Calcination Furnace*.

5.3 *Grinding Equipment*, suitable for preparing samples for mounting in the sample holder.

6. Procedure

6.1 Calcine the catalyst or catalyst carrier sample for 3 h at 500°C .

6.2 Grind the sample sufficiently (for example, 200 to 400 mesh) to enable it to be packed into a standard X-ray powder diffractometer sample holder and mounted on the diffractometer.

¹ This test method is under the jurisdiction of ASTM Committee D32 on Catalysts and is the direct responsibility of Subcommittee D32.01 on Physical-Chemical Properties.

Current edition approved Dec. 1, 2015. Published January 2016. Originally approved in 1989. Last previous edition approved in 2011 as D4926-06(2011). DOI: 10.1520/D4926-15.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

6.3 Obtain diffraction patterns for three samples over the approximate range from 52 to 76 °2θ, using the conditions described in 5.1.

6.4 Measure the height of the 67 °2θ peak above background for the sample and the reference material to give $H(\text{sample})$ and $H(\text{reference})$, respectively.

NOTE 2—Reference material may be prepared by calcining a high-purity sample of fine-particle boehmite for 3 h at 550°C.

7. Calculation

7.1 The relative X-ray powder diffraction intensity of three samples, compared to a reference standard and expressed as percent, is calculated by use of the following equation:

$$100 \frac{I(\text{sample})}{I(\text{ref})} = \frac{H(\text{sample})}{H(\text{ref})} \times \frac{W(\text{sample})}{W(\text{ref})} \times \frac{G(\text{ref})}{G(\text{sample})} \times 100$$

where:

- $H(\text{sample})$ = defined in 6.4,
- $H(\text{ref})$ = defined in 6.4,
- $W(\text{sample})/W(\text{ref})$ = ratio of the peak width at half-height for the sample compared to that for the reference, and
- $G(\text{ref})/G(\text{sample})$ = ratio of the instrument gain factor used to record the peak for the sample to the gain factor used to record the peak for the reference. (Gain factor is often defined as the inverse of the product of the diffractometer scale setting and rate multiplier setting.

7.2 The average of the three values calculated in 7.1 can be considered a measure of gamma alumina content in the catalyst or catalyst carrier if the measured sample peak is attributable to gamma alumina, the reference material is essentially pure

gamma alumina, and the sample does not contain large amounts of heavy metals or rare earths. Caution should be observed in comparing results for widely varying materials.

7.3 A working or secondary reference material can be used as a matter of practical convenience. Should such a secondary reference material be available, results as calculated in 7.1 relative to the first or primary reference material can be transformed to relate to the working reference material. Determine the relative X-ray powder diffraction intensity of the primary reference material relative to the secondary reference material, using an equation corresponding to that shown in 7.1 and expressing the ratio I_{R1}/I_{R2} in fractional form. Multiply the result relative to the primary reference material ($100 I/I_{R1}$) by the factor just determined above (I_{R1}/I_{R2}) to get the result ($100 I/I_{R2}$) relative to the secondary reference material. Identify the reference materials when reporting the results.

8. Precision and Bias³

8.1 *Precision*—Based on the results of a multilaboratory, multisample study and using Practice E691, the within-laboratory repeatability was found to be ±15 % (2S %) of the measured value, and the between-laboratory reproducibility was found to be ±24 % (2S %) of the measured value.

8.2 *Bias*—No estimate of the bias of this test method is possible.

9. Keywords

9.1 alumina; catalyst; catalyst carrier; gamma alumina; gamma alumina content; X-ray powder diffraction

³ Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR:D32-1027.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/