

Standard Test Method for Determination of Thermal Conductivity of Soil and Soft Rock by Thermal Needle Probe Procedure¹

This standard is issued under the fixed designation D5334; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope*

- 1.1 This test method presents a procedure for determining the thermal conductivity (λ) of soil and soft rock using a transient heat method. This test method is applicable for both intact and reconstituted soil specimens and soft rock specimens. This test method is suitable only for homogeneous materials.
- 1.2 This test method is applicable to dry or unsaturated materials over temperatures ranging from <0 to >100°C, depending on the suitability of the thermal needle probe construction to temperature extremes. However, care must be taken to prevent significant error from: (1) redistribution of water due to thermal gradients resulting from heating of the needle probe; (2) redistribution of water due to hydraulic gradients (gravity drainage for high degrees of saturation or surface evaporation); (3) phase change of water in specimens with temperatures <0°C or >100°C. These errors can be minimized by adding less total heat to the specimen through either minimizing power applied to the needle probe and/or minimizing the heating duration of the measurement.
- 1.3 *Units*—The values stated in SI units are to be regarded as the standard. No other units of measurements are included in this standard.
- 1.4 All observed and calculated values shall conform to the guidelines for significant digits and rounding established in Practice D6026.
- 1.4.1 The procedure used to specify how data are collected/recorded or calculated in this standard are regarded as the industry standard. In addition, they are representative of the significant digits that generally should be retained. The procedures used do not consider material variation, purpose for obtaining the data, special purpose studies, or any considerations for the user's objectives; and it is common practice to increase or reduce significant digits of reported data to be commensurate with these considerations. It is beyond the scope

of this standard to consider significant digits used in analytical methods for engineering design.

1.5 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

2.1 ASTM Standards:²

D653 Terminology Relating to Soil, Rock, and Contained Fluids

D2216 Test Methods for Laboratory Determination of Water (Moisture) Content of Soil and Rock by Mass

D3740 Practice for Minimum Requirements for Agencies Engaged in Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction

D4439 Terminology for Geosynthetics

D4753 Guide for Evaluating, Selecting, and Specifying Balances and Standard Masses for Use in Soil, Rock, and Construction Materials Testing

D6026 Practice for Using Significant Digits in Geotechnical Data

3. Terminology

- 3.1 *Definitions*—For definitions of common technical terms, refer to Terminology standards D653 and D4439.
 - 3.2 Definitions of Terms Specific to This Standard:
- 3.2.1 *heat input, n*—power consumption of heater wire in watts per unit length that is assumed to be the equivalent of heat output per unit length of wire.
- 3.2.2 *thermal epoxy, n*—any heat conductive resin material having a value of $\lambda > 4$ W/(m·K).
- 3.2.3 thermal grease, n—any heat conductive lubricating material having a value of $\lambda > 4$ W/(m·K).

¹ This test method is under the jurisdiction of ASTM Committee D18 on Soil and Rock and is the direct responsibility of Subcommittee D18.12 on Rock Mechanics. Current edition approved June 1, 2014. Published July 2014. Originally approved in 1992. Last previous edition approved in 2008 as D5334 – 08. DOI: 10.1520/D5334-0814.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

4. Summary of Test Method

4.1 Thermal conductivity is determined by a variation of the line source test method using a needle probe having a large length to diameter ratio to simulate conditions for an infinitely long, infinitely thin heating source. The probe consists of a heating element and a temperature measuring element and is inserted into the specimen. A known current and voltage are applied to the probe and the temperature rise with time is recorded over a period of time. The temperature decay with time after the cessation of heating can also be included in the analysis to minimize effects of temperature drift during measurement. Thermal conductivity is obtained from an analysis of the temperature time series data during the heating cycle and cooling cycle if applicable.

5. Significance and Use

5.1 The thermal conductivity of both intact and reconstituted soil specimens as well as soft rock specimens is used to analyze and design systems used, for example, in underground transmission lines, oil and gas pipelines, radioactive waste disposal, geothermal applications, and solar thermal storage facilities.

Note 1—The quality of the result produced by this standard is dependent on the competence of the personnel performing it, and the suitability of the equipment and facilities used. Agencies that meet the criteria of Practice D3740 are generally considered capable of competent and objective testing. Users of this standard are cautioned that compliance with Practice D3740 does not in itself ensure reliable results. Reliable results depend on many factors; Practice D3740 provides a means of evaluating some of those factors.

6. Apparatus

- 6.1 Thermal Needle Probe—A device that creates a linear heat source and incorporates a thermocouple or thermistor to measure the variation of temperature at a point along the line. The construction of a suitable device is described in Annex A1.
- 6.2 Constant Current Source—A device to produce a constant current.
- 6.3 Temperature Readout Unit or Recorder—A device to record the temperature from the thermocouple or thermistor with a readability of 0.01 K or better.
- 6.4 *Voltage-Ohm-Meter (VOM)*—A device to read voltage and current to the nearest 0.01 V and 0.01 A.
- 6.5 *Timer*—A clock, stopwatch, digital timer, or integrated electronic timer capable of measuring to the nearest 0.1 s or better for the duration of the measurement.
- 6.6 *Drilling Device*—A drill capable of making a straight vertical hole having a diameter as close as possible to that of the needle and to a depth equivalent to the length of the needle.
- 6.7 Balance—A balance that meets the requirements of Guide D4753 and has a readability of 0.01 g for specimens having a mass of up to 200 g and a readability of 0.1 g for specimens with a mass over 200 g. However, the balance used may be controlled by the number of significant digits needed.

7. Specimen Preparation

7.1 Intact Soil Specimens:

- 7.1.1 *Thin-Walled Tube or Drive Specimens*—Cut a 200 \pm 30-mm long section of a sampling tube containing an intact soil specimen. The tube section shall have a minimum diameter of 50 mm.
- 7.1.2 Determine and record the mass of the specimen in a sampling tube or brass ring to the nearest 0.01 gram.
- 7.1.3 Measure and record the length and diameter of the specimen to 0.1 mm. Take a minimum of three length measurements 120° apart and at least three diameter measurements at the quarter points of the height. Determine the average length and diameter of the specimen.
- 7.1.4 Insert the thermal needle probe down the axis of the specimen by either pushing the probe into a predrilled hole (dense specimen) to a depth equal to the length of the probe or pushing the probe into the specimen (loose specimen). Make sure the thermal probe shaft is fully embedded in the specimen and not left partially exposed. See Note 2.

Note 2—To provide better thermal contact between the specimen and the probe, the probe may be coated with a thin layer of thermal grease. If a hole is predrilled for the needle probe, the diameter of the hole should be equivalent to the diameter of the needle probe to make sure there is a tight fit. A device, such as a drill press, may be used to insert the probe to make sure the probe is inserted vertically and that no void spaces are formed between the specimen and the probe.

7.2 Reconstituted Soil Specimens:

7.2.1 Compact the specimen to the desired dry density and gravimetric water content in a thin-walled metal or plastic tube using an appropriate compaction technique. For further guidance on the effect of the various compaction techniques on thermal conductivity, refer to Mitchell et al. (1). The tube shall have a minimum diameter of 50 mm and a length of 200 ± 30 mm

7.2.2 Follow the procedure given 7.1.2, 7.1.3, and 7.1.4.

7.3 Soft Rock Specimens:

- 7.3.1 Determine and record the mass of the specimen to the nearest 0.01 g and follow the procedure given in 7.1.4 to determine the specimen diameter and length. The specimen dimensions shall be no less than those of the calibration standard (8.3).
- 7.3.2 Insert the thermal needle probe into the specimen by predrilling a hole to a depth equivalent to the length of the probe. Make sure the thermal probe shaft is fully embedded in the specimen and not left partially exposed. See Note 2.

8. Calibration

8.1 The thermal needle probe apparatus shall be calibrated before its use. Perform calibration by comparing the experimental determination of the thermal conductivity of a standard material to its known value. A calibration factor, *C*, is calculated as follows:

$$C = \frac{\lambda_{material}}{\lambda_{measured}} \tag{1}$$

where:

 $\lambda_{material}$ = the known thermal conductivity of the calibration material, and

³ The boldface numbers given in parentheses refer to the list of references at the end of this standard.

 $\lambda_{measured}$ = the thermal conductivity of that material measured with the thermal needle probe apparatus.

- 8.1.1 All subsequent measurements with the thermal needle probe apparatus shall be multiplied by C before being reported. Although calibration is mandatory, it is especially important with large diameter needle probes (that is, d > 2.54 mm) where departures from the assumption of an infinitely thin probe cause potentially significant differences in estimation of the thermal conductivity due to non-negligible heat storage and transmission in the needle probe itself.
- 8.1.2 The calibration factor, C, has been shown to be a function of thermal conductivity when using a large diameter needle probe (see Hanson et al., 2004) (2). For users of large diameter probes, it may be necessary to determine C at several thermal conductivities in the range of measurement and construct a calibration function which is then applied to subsequent data collected with the thermal needle probe.
- 8.2 Conduct the test specified in Section 9 using a calibration standard as specified in 8.3.
- 8.3 Calibration Standard—One or more materials with known values of thermal conductivity in the range of the materials being measured, which is typically $0.2 < \lambda < 5$ W/m·K. Suitable materials include dry Ottawa sand, Pyrex 7740, fused silica, Pryoceram 9606 (3), glycerine (glycerol) with a known thermal conductivity of 0.286 W/(m·K at 25°C (3), or water stabilized with 5 g agar per litre (to prevent free convection) with a known thermal conductivity of 0.607 W/m·K at 25°C (3). (See Annex A2 for details on preparation of calibration standards.) The calibration standard shall be in the shape of a cylinder. The diameter of the cylinder shall be at least 40 mm or 10 times the diameter of the thermal needle probe, whichever is larger, and the length shall be at least 20 % longer than the needle probe. On solid specimens, a hole is drilled along the axis of the cylinder to a depth equivalent to the length of the probe. The diameter of the hole shall be equal to the diameter of the probe so that the probe fits tightly into the hole. For drilled specimens the probe shall be coated with thermal grease to minimize contact resistance.
- 8.4 The measured thermal conductivity of the calibration specimen must agree within one standard deviation of the published value of thermal conductivity, or with the value of thermal conductivity determined by an independent method.
- 8.5 For purposes of comparing a measured value with specified limits, the measured value shall be rounded to the nearest decimal given in the specification limits in accordance with the provisions of Practice D6026.

9. Procedure

- 9.1 Allow the specimen to come to equilibrium at the selected testing temperature. This equalization is especially important if only the heating data are to be analyzed as temperature drift will cause a significant error in the thermal conductivity measurement. Errors from small temperature drifts are minimized if both heating and cooling data are used in the analysis.
- 9.2 Connect the heater wire of the thermal probe to the constant current source. (See Fig. 1.)




FIG. 1 Thermal Probe Experimental Setup

- 9.3 Connect the temperature measuring element leads to the readout unit.
- 9.4 Apply a known constant current, for example, equivalent to 1.0 A, to the heater wire such that the temperature change is less than 10 K in 1000 s.
- 9.5 Record time and temperature readings for at least 20–30 steps throughout the heating period. The total heating time should be appropriate to the thermal needle probe size. For a small diameter needle (that is, d < 2.54 mm), a 30 to 60 second heating duration is sufficient to accurately measure thermal conductivity. With a larger diameter needle, a longer heating duration may be necessary. However, this method is only valid if the thermal pulse does not encounter the boundaries of the specimen, so care must be taken not to choose too long a heating duration. Also note that potential errors from redistribution of water in unsaturated specimens increase with heating time as discussed in 1.2.
 - 9.6 Turn off the constant current source.
- 9.7 If cooling data are to be included in the analysis, record the time and temperature readings for at least 20–30 steps throughout a cooling period equivalent in duration to the heating cycle.
- 9.8 Use a suitable inverse method (graphical or statistical) to determine thermal conductivity. (See Section 10, Data Analysis.)
- 9.9 Determine and record the initial gravimetric water content in accordance with Test Method D2216 and calculate the dry density of a representative sample of the specimen.

10. Calculations and Data Analysis

10.1 Theory:

10.1.1 If a constant amount of heat is applied to a zero mass heater over a period of time, the temperature response is:

$$\Delta T = -\frac{Q}{4\pi\lambda} Ei \left(\frac{-r^2}{4Dt}\right) \quad 0 < t \le t_1 \tag{2}$$

where:

t = time from the beginning of heating (s),

 ΔT = change in temperature from time zero (K),

Q = heat input per unit length of heater (W/m),

r = distance from the heated needle (m),

 $D = \text{thermal diffusivity } (\text{m}^2/\text{s}),$

 λ = thermal conductivity (W/(m·K)),

Ei = exponential integral, and

 t_1 = heating time.

10.1.2 The change in temperature after the heat input is turned off is given by:

$$\Delta T = -\frac{Q}{4\pi\lambda} \left[-Ei\left(\frac{-r^2}{4Dt}\right) + Ei\left(\frac{-r^2}{4D(t-t_1)}\right) \right] \quad t > t_1 \quad (3)$$

10.1.3 The behavior of finite diameter and finite length probes can be approximated using these same equations, but D and λ will not represent the actual diffusivity and thermal conductivity, so calibration factors must be obtained for these probes as outlined in Section 8.

10.1.4 The most direct and precise method to calculate thermal conductivity is to use Eq 2 and 3 directly with the time series data collected as described in Section 9. Unfortunately, Eq 2 and 3 cannot be solved for λ and D explicitly, so a non-linear least-squares inversion technique must be used. A simplified analysis, which gives adequate results, approximates the exponential integral in Eq 2 and 3 by the most significant term of its series expansion:

$$\Delta T \cong \frac{Q}{4\pi\lambda} \ln(t) \quad 0 < t \le t_1 \tag{4}$$

$$\Delta T \cong \frac{Q}{4\pi\lambda} \ln\left(\frac{t}{t-t_1}\right) \quad t > t_1 \tag{5}$$

10.2 Simplified Method:

10.2.1 For thermal needle probes with diameter of 2.54 mm or less, exclude from the analysis the first 10 to 30 seconds of data from both the heating and, if used, cooling data. For larger diameter thermal needle probes it will be necessary to plot the data on a semi-log plot as described in 10.2.2 and identify the duration of the non-linear portion of initial data that shall be excluded. These data are most strongly affected by terms ignored in Eq 4 and 5, and will result in decreased accuracy if they are included in the subsequent analysis. The total time duration of the data included in the analysis, and duration of initial values excluded from the analysis, shall be fixed for any thermal needle probe configuration and used during calibration and all subsequent thermal conductivity measurements with that probe type to avoid biasing results due to subjective selection of the time range for analysis.

10.2.2 Using the remaining data, determine the slope, S_h of a straight line representing temperature versus $\ln t$ for the

heating phase, and, if used, the slope, S_c of a straight line representing temperature versus $\ln[t/(t-t_1)]$ for the cooling phase (see Fig. 2). As shown in Fig. 2, the early and late portions of the test (representing transient conditions and boundary effects, respectively) shall not be used for the curve fitting. These slopes can be determined using linear regression with any standard spreadsheet or data analysis software, or manually, by plotting the data and fitting a straight line to the data by eye. If manual methods are used to determine the slope, it may be convenient to use semi-log graph paper with \log_{10} time. If the slope of temperature versus $\log_{10}t$ is used in the analysis, the slopes of the plots are termed S_{h10} for the heating phase, and S_{c10} for the cooling phase.

10.2.3 The data included in the analysis shall be evenly spaced with the logarithm of time (*X*-axis). If data are collected in even time increments and subsequently plotted on a log time scale, then the distribution becomes uneven biasing the analysis too heavily toward the long-term of the testing period. Fig. 2 shows a data set that has been properly filtered to provide an even data distribution along the log time axis.


10.2.4 Compute thermal conductivity using Eq 6, where S is the average of S_h and S_c and S_{10} is the average of S_{h10} and S_{c10} if both heating and cooling data are used for the analysis or just S_h (or S_{h10}) if only heating data are used. Typically, S_h and S_c differ because of specimen temperature drift during the measurement. Averaging the two values minimizes the effects of the drift, which can cause large errors in determination of λ . Note that C is the calibration coefficient determined in Section 8.

$$\lambda = \frac{CQ}{4\pi S} = \frac{2.3CQ}{4\pi S_{10}} \tag{6}$$

where:

$$Q = I^2 \frac{R}{L} = \frac{EI}{L}$$

Q = heat input (W/m),



Note 1—2a shows data from the heating portion of the cycle and 2b shows data from the cooling portion of the cycle.

Note 2—The slopes $(S_h \text{ and } S_c)$ are shown in bold.

Note 3—The data are approximately evenly spaced on the X-axis to avoid bias as discussed in 10.2.2.

FIG. 2 (a & b) Typical Experimental Test Results

C = calibration constant from Section 8,

 λ = thermal conductivity [W/(m·K)],

S = slope used to compute thermal conductivity if ln(t) is used in analysis,

 S_{10} = slope used to compute thermal conductivity if $\log_{10}(t)$ is used in analysis,

t = time (s),

I = current flowing through heater wire (A),

R = total resistance of heater wire (Ω) ,

L = length of heated needle (m), and

E = measured voltage (V).

10.3 Derivations forming the basis of Eq 2 and 3 are presented by Carslaw and Jaeger (4), and adapted to soils by VanRooyen and Winterkorn (5); VanHerzen and Maxwell (6); and Winterkorn (7).

11. Report: Test Data Sheet(s)/Form(s)

- 11.1 The methodology used to specify how data are recorded on the test data sheet(s)/form(s), as given below, is covered in 1.4.1 and Practice D6026.
- 11.2 Record as a minimum the following general information (data):
- 11.2.1 Project information, such as project name, number, source of test specimens, including other pertinent data that helps identify the specimen.
- 11.2.2 Name or initials of the person(s) who prepared and tested the samples, including the date(s) performed.
- 11.2.3 Type of material tested: soil or soft rock, and if soil, indicate if the specimen was intact or reconstituted.
- 11.2.4 Physical description of sample including soil or rock type. If rock, describe location and orientation of apparent weakness planes, bedding planes, and any large inclusions or inhomogeneities.
 - 11.3 Record as a minimum the following test specimen data:
- 11.3.1 Initial gravimetric water content to the nearest 0.01 %
 - 11.3.2 Dry density to the nearest 0.1 g/cm³
 - 11.3.3 The mass of the specimen to the nearest 0.01 g
- 11.3.4 The average diameter and length of the specimen to the nearest 0.01 mm


- 11.3.5 Method of needle insertion: pushed or pre-drilled
- 11.3.6 Calibration factor, if any
- 11.3.7 Time, nearest 0.1 s, and temperature, nearest 0.01 K, readings for heating, cooling, or both as necessary
- 11.3.8 Time versus temperature plot see Fig. 3, is an example of an idealized curve of the data
 - 11.3.9 Thermal conductivity to the nearest 0.01 W/(m·K)

12. Precision and Bias

- 12.1 An interlaboratory study involving line-source methods, including needle probes used for rock and soils, was undertaken by ASTM Committee C16 (8). The materials of known thermal conductivity that were evaluated included Ottawa sand and paraffin wax (having a thermal conductivity similar to certain soil and soft rock types). The results indicated a measurement precision of between ± 10 and ± 15 %, respectively, with a tendency to a positive bias (higher value) over the known values for the materials studied. With careful calibration of thermal needle probes in materials of known thermal conductivity as outlined in Section 8, this precision can be improved upon, and the positive bias should be removed.
- 12.1.1 Subcommittee D18.12 welcomes proposals that would allow for a more comprehensive precision and bias statement covering the full range of soil and rock materials.

13. Keywords

13.1 heat flow; needle probe; temperature; thermal conductivity; thermal probe; thermal properties



(A) IDEALIZED CURVE

FIG. 3 Typical Record of Data (Idealized Curve)

ANNEXES

(Mandatory Information)

A1. COMPONENTS AND ASSEMBLY OF THERMAL NEEDLE

A1.1 The thermal needle consists of a stainless steel hypodermic tubing containing a heater element and a thermocouple as shown in Fig. A1.1. To construct a thermal needle, hypodermic tubing is cut to 115 mm in length. The end to be inserted into the bakelite head of a thermocouple jack is roughened for a length of 15 mm. A copper-constantan thermocouple wire junction previously coated with an insulating varnish is threaded into the hypodermic needle with the

junction 50 mm from the end of the needle (see Note A1.1). At the same time, a manganin heater element is inserted with approximately 75-mm long pigtails extending from the top of the needle as shown in Fig. A1.2. The uncut end of the needle is then inserted into an evacuating flask through a rubber stopper and the other end is placed in a reservoir of thermal epoxy primer as shown in Fig. A1.2. A vacuum pump connected to the evacuating flask is used to draw the thermal






FIG. A1.1 Typical Probe Components




FIG. A1.2 Drawing Thermal Epoxy Into Hypodermic Tubing

epoxy up through the needle. The needle is removed from the reservoir and flask, and a blob of putty is placed at the end of



the needle to hold the thermal epoxy in place for hardening. After the thermal epoxy hardens, the thermocouple wires are soldered to the pins of a polarized thermocouple jack and the roughened end of the needle is placed in the bakelite head of the jack. The heater leads are brought out through two holes in the back of the bakelite head (see Fig. A1.1).

Note A1.1—For soft rock specimens it may not be possible to drill a hole to accommodate a 115-mm long thermal needle. In this case a shorter needle may be used. The length of the needle shall not be less than 25.4 mm to avoid boundary effects.

A2. PREPARATION OF CALIBRATION STANDARDS

A2.1 Glycerol:

A2.1.1 Glycerol (Glycerin) has a published thermal conductivity of 0.286 W/(m·K) at 25°C (3), and therefore falls within the low end of thermal conductivities expected in soil and rock. The thermal conductivity of glycerol is affected by the amount of water present in the glycerol, so only anhydrous (99% or greater) glycerol shall be used for calibration. It should be noted that glycerol will readily take up water in both liquid and vapor phase, so care must be taken to prevent the sorption of water vapor into glycerol stored in improperly sealed containers. Note that glycerol is a fluid, and can be subject to mixing by free convection. Free convection arises from density gradients in fluids caused by thermal gradients in the fluid. If the thermal needle probe is heated too much, free convection could occur. Accordingly, glycerol is only appropriate for thermal needle probes that will heat less than 2°C over the course of the thermal conductivity measurement. 99+% anhydrous glycerol can be obtained from numerous sources, including local drugstores.

A2.2 Water:

A2.2.1 Water (deionized or tap) has a published thermal conductivity of 0.607 W/(m·K) at 25°C (3), and therefore falls within the range of thermal conductivities expected in soil and rock. However, with most thermal needle probes, the heating of the needle will result in free convection in the water that will cause very large errors in the thermal conductivity measurement. To prevent this error, the water specimen must be physically stabilized. The preferred method for stabilizing the water is with a 5 g agar/1 L water mixture. The agar should be added to hot water and stirred well until the mixture is homogenous. The mixture should then be brought to a boil, and then re-homogenized in the container that will be used to hold the specimen during calibration. After cooling back to room temperature, the mixture should be a solid with the consistency of jelly.

REFERENCES

- (1) Mitchell, J. K., Kao, T. C., and Abdel-Hadi, O. N., "Backfill Materials for Underground Power Cables," Department of Civil Engineering, University of California at Berkeley, EPRI EL-506, June 1977.
- (2) Hanson, J., Neuhauser, S., and Yesiller, N. "Development and Calibration of Large-Scale Thermal Conductivity Probe," *Geotechni*cal Testing Journal, ASTM, Vol 27, No. 4, 2004, pp. 393–403.
- (3) CRC Handbook of Chemistry and Physics, 74th Edition, David R. Lide, editor, CRC Press, Ann Arbor, MI, 1994
- (4) Carslaw, H. S., and Jaeger, J. C., *Conduction of Heat in Solids*, Oxford Press, 2nd ed., 1946.
- (5) Van Rooyen, M., and Winterkorn, H. F., "Theoretical and Practical Concepts of the Thermal Conductivity of Soils and Similar Granular Systems," *Highway Research Board, Bulletin 168—Fundamental and*

- Practical Concepts of Soil Freezing, 1957, pp. 143-205.
- (6) Von Herzen, R., and Maxwell, A. E., "The Measurement of Thermal Conductivity of Deep-Sea Sediments by a Needle-Probe Method," *Journal of Geophysical Research*, Vol 64, No. 10, October 1959, pp. 1557–1563.
- (7) Winterkorn, H. K., "Suggested Method of Test for Thermal Resistivity of Soil by the Thermal Probe," Special Procedures for Testing Soil and Rock for Engineering Purposes, ASTM STP 479, ASTM, 1970, pp. 264–270.
- (8) Hust, J. G., and Smith, D. R., "Interlaboratory Comparison of Two Types of Line-Source Thermal Conductivity Apparatus Measuring Five Insulating Materials," NISTIR, 89-3908, 1989.

SUMMARY OF CHANGES

In accordance with Committee D18 policy, this section identifies the location of changes to this standard since the last edition (2008) that may impact the use of this standard. (Approved June 1, 2014)

- (1) Edits to Sections 1 and 3, Note 1 including D18.91 review updates.
- (2) Added Guide D4753 to Section 2.
- (3) Edits to Sections 4, 5, and 6, including the addition of 6.7.
- (4) Edits to Section 7, including the dimensional measurements of the specimen.
- (5) Edits to Sections 8, 9, and 10.
- (6) Removed the data sheet, old Fig. 2.
- (7) Significantly updated Section 11.
- (8) Edits to Section 12.
- (9) Added "needle probe" to Section 13.
- (10) Edits to the Annex and renumbered the references.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/