



# Standard Specification for HFC-125 (Pentafluoroethane, C<sub>2</sub>HF<sub>5</sub>)<sup>1</sup>

This standard is issued under the fixed designation D6231; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

## 1. Scope

1.1 This specification covers the requirements for HFC-125 as a fire-fighting medium.

1.2 This specification does not address the fire-fighting equipment or hardware that employs HFC-125 or the conditions of employing such equipment, for example, hand helds, fixed installations, etc.

1.3 This specification does not address the storage or transportation of HFC-125. Storage, handling, and transportation issues are addressed in Practice D6268.

1.4 The values stated in both inch-pound and SI units are to be regarded separately as the standard. The values given in parentheses are for information only.

1.5 The following safety hazards caveat pertains to the test methods portion, Section 6, of this specification. *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.* Specific hazards statements are given in 4.3.

## 2. Referenced Documents

2.1 *ASTM Standards:*<sup>2</sup>

D6268 Practice for Handling, Transportation, and Storage of HFC-125, Pentafluoroethane (C<sub>2</sub>HF<sub>5</sub>)

D6806 Practice for Analysis of Halogenated Organic Solvents and Their Admixtures by Gas Chromatography

2.2 *ISO Standards:*<sup>3</sup>

ISO 3427 Gaseous Halogenated Hydrocarbons (Liquefied Gases) – Taking a Sample

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee D26 on Halogenated Organic Solvents and Fire Extinguishing Agents and is the direct responsibility of Subcommittee D26.09 on Fire Extinguishing Agents.

Current edition approved June 1, 2015. Published June 2015. Originally approved in 1998. Last previous edition approved in 2011 as D6231-11. DOI: 10.1520/D6231-11R15.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

<sup>3</sup> Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

2.3 *AHRI Standards:*<sup>4</sup>

2008 Appendix C Analytical Procedures for ARI Standard 700-2006

2.4 *U.S. Government Standards:*<sup>5</sup>

Code of Federal Regulations (CFR) Title 49, Part 172.101, Tables of Hazardous Materials and Special Provisions  
Code of Federal Regulations (CFR) Title 49, Part 172 Subpart D, Marking Requirements of Packaging for Transportation

2.5 *American Society of Refrigerating Engineers:*<sup>6</sup>

ASRE Standard 34, Designation of Refrigerants

## 3. Terminology

3.1 *Definitions of Terms Specific to This Standard:*

3.1.1 *halogenated hydrocarbon, n*—the halogenated compound coding terminology system provides a convenient means to reference halogenated hydrocarbons (see ASRE 34). Halogenated hydrocarbons are saturated hydrocarbons in which one or more of the hydrogen atoms have been replaced by atoms of the halogen series: fluorine, chlorine, bromine, and iodine. It is convention to prefix the number with an abbreviation of the compound:

CFC = chlorofluorocarbon  
HCFC = hydrochlorofluorocarbon  
HFC = hydrofluorocarbon  
FC = fluorocarbon  
R = refrigerant

3.1.1.1 *Discussion*—By definition, the right-most digit of the numbering system is the number of fluorine atoms. The second digit from the right is the number of hydrogen atoms plus one (+1). The third digit from the right is one less (-1) than number of carbon atoms in the compound (when this number is zero (0) it is omitted from the number). Unaccounted for valance requirements are assumed to be chlorine atoms. When the compound contains bromine or iodine, the same rules apply except the letter “B” for bromine or “I” for iodine follows the

<sup>4</sup> Available from the Air Conditioning, Heating and Refrigeration Institute (AHRI), 2111 Wilson Blvd., Suite 500, Arlington, VA, 22201, http://www.ahrinet.org.

<sup>5</sup> Available from U.S. Government Publishing Office, 732 N. Capitol St., NW, Washington, DC 20401-0001, http://www.gpo.gov.

<sup>6</sup> Available from American Society of Refrigeration Engineers, *Refrigeration Engineering* 65, 49 (1957).

parent compound designated number and the number of the atoms is placed after the letter.

$$\text{Example: } C_2HF_5 = R - 125 = \text{HFC} - 125 \quad (1)$$

3.1.2 *HFC-125*, *n*—the compound pentafluoroethane;  $C_2HF_5$ .

## 4. Material Requirements

### 4.1 Type I:

4.1.1 The nitrogen ( $N_2$ ) partial pressure shall be such that the safe working pressure of the receiving vessel is not exceeded. To prevent excessive pressure, the fill density of the HFC-125/nitrogen within the container should not exceed that needed to achieve complete filling of the container at the maximum expected storage temperature. For example, the U.S. DOT 4BA500 cylinder partial pressure shall not exceed 24.8 bar at 21°C (360 psig at 70°F) for a 833 kg/m<sup>3</sup> (52 lb/ft<sup>3</sup>) fill density. For this example, the safe working pressure of the 4BA500 cylinder is not exceeded for temperatures below 54°C (130°F).

4.1.2 HFC-125 shall conform to the requirements prescribed in [Table 1](#) when tested by the appropriate test method(s) listed in [Section 6](#).

4.1.3 When material analysis is required, by agreement between the purchaser and the supplier, the total pressure in the HFC-125 container, partial pressure of the nitrogen, the fill density of the HFC-125 within the container, and the maximum safe storage temperature shall be part of the material analysis (certification). The pressure shall be reported in bar (preferred) or pound-force/in.<sup>2</sup> gage (psig). The fill density shall be reported in kg/m<sup>3</sup> at 21°C (preferred) or lb/ft<sup>3</sup> at 70°F. The maximum safe storage temperature of the HFC-125 shall be reported in °C (preferred) or in °F and shall conform to the applicable regulations for the HFC-125 container design and use.

4.2 *Type II*—HFC-125 shall conform to the requirements of Type I as listed in [4.1](#) and shall contain no more than 1.5 % by volume non-absorbable gases in the vapor phase, expressed as air when tested by the appropriate test method(s) listed in [Section 6](#).

4.3 By agreement between the purchaser and the supplier, analysis may be required and limits established for elements or compounds not specified in [Table 1](#). (**Warning**—Exposure to concentrations of HFC-125 in excess of 10 % by volume in air

during periods of elevated adrenaline could produce cardiac arrhythmia in some personnel.)

4.4 Unless otherwise specified, Type I is assumed.

## 5. Sampling

5.1 Samples of HFC-125 taken from the liquid phase, shall be taken from filled containers in accordance with the method specified in ISO 3427. The sampling bottle shall be capable of safely resisting the vapor pressure of the sample at the highest temperature that could be encountered.

5.2 The HFC-125 selected in accordance with [5.1](#) shall be tested for quality conformance in accordance with [Section 6](#). The presence of one or more defects shall be cause for rejection.

## 6. Test Methods

6.1 *Purity*—Determine purity using the method specified in Practice [D6806](#).

6.2 *Acidity*—Determine acidity using the method specified in 2008 Appendix C to ARI Standard 700-200, part 1.

6.3 *Water Content*—Determine water content using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 2.

6.4 *Nonvolatile Residue*—Determine nonvolatile residue using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 3.

6.5 *Non-absorbable Gases*—Determine non-absorbable gases using the method specified in 2008 Appendix C to ARI Standard 700-2006, part 5.

6.6 *Suspended Matter or Sediment*—While performing the nonvolatile residue analysis, examine visually for any suspended matter or sediment. Observation of any suspended matter or sediment shall constitute failure by this test method.

## 7. Container, Packaging, and Package Marking

7.1 Containers used for shipping and storage of HFC-125 conforming to this specification shall be marked in the accordance with Code of Federal Regulations (CFR) Title 49, Part 172 Subpart D. The proper shipping name is UN3220, pentafluoroethane, “nonflammable gas” (49 CFR 172.101). In addition to DOT requirements, containers shall be marked with the following information as a minimum:

7.1.1 Supplier’s name and address.

7.1.2 HFC-125 (pentafluoroethane).


7.1.3 Statement that material conforms to ASTM Specification D6231.

## 8. Keywords

8.1  $C_2HF_5$ ; FE-25™; fire fighting; fire fighting agent; fire protection; fire suppressant; HFC-125; hydrofluorocarbon; hydrofluorocarbon 125; pentafluoroethane

**TABLE 1 Requirements**

Property	Requirement
HFC-125 purity, mol/mol, min, %	99.0
Acidity, ppm by mass, as HCl, max	3.0
Water content, ppm by mass, max	10
Nonvolatile residue, max, % by weight	0.08
Suspended matter or sediment	none visible

 **D6231 – 11 (2015)**

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>*