



Standard Test Method for Solidification Point of Benzene¹

This standard is issued under the fixed designation D852; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope*

1.1 This test method covers the determination of the solidification point of benzene.

1.2 In determining the conformance of the test results using this method to applicable specifications, results shall be rounded off in accordance with the rounding-off method of Practice E29.

1.3 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.* For specific hazard statements, see Section 7.

2. Referenced Documents

2.1 *ASTM Standards:*²

D1015 Test Method for Freezing Points of High-Purity Hydrocarbons

D1016 Test Method for Purity of Hydrocarbons from Freezing Points

D1193 Specification for Reagent Water

D3437 Practice for Sampling and Handling Liquid Cyclic Products

D6809 Guide for Quality Control and Quality Assurance Procedures for Aromatic Hydrocarbons and Related Materials

E1 Specification for ASTM Liquid-in-Glass Thermometers

E29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications

¹ This test method is under the jurisdiction of ASTM Committee D16 on Aromatic Hydrocarbons and Related Chemicals and is the direct responsibility of Subcommittee D16.01 on Benzene, Toluene, Xylenes, Cyclohexane and Their Derivatives.

Current edition approved June 1, 2016. Published July 2016. Originally approved in 1945. Last previous edition approved in 2013 as D852 – 13. DOI: 10.1520/D0852-16.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method

2.2 *Other Document:*

OSHA Regulations, 29 CFR paragraphs 1910.1000 and 1910.1200³

3. Terminology

3.1 *Definitions:*

3.1.1 *solidification point, n*—an empirical constant defined as the temperature at which the liquid phase of a substance is in approximate equilibrium with a relatively small portion of the solid phase.

3.1.1.1 *Discussion*—Solidification point is distinguished from freezing point which is described in Test Method D1015. An interpretation of mol percent purity in terms of freezing point is given in Test Method D1016.

4. Summary of Test Method

4.1 Solidification point is measured by noting the maximum temperature reached during a controlled cooling cycle after the appearance of a solid phase.

5. Significance and Use

5.1 This test method may be used as a criteria for determining the purity of benzene. The closer the solidification point reaches that of pure benzene, the purer the sample.

6. Apparatus

6.1 *Benzene Container (Air Jacketed):*

6.1.1 *Inner Container*, a test tube 15 mm in outside diameter and 125 mm in length.

6.1.2 *Air Jacket*, a standard test tube 25 mm in outside diameter and 150 mm in length.

6.1.3 *Insulation*—Dry absorbent cotton or glass wool.

6.2 *Benzene Container (thick walled)*, a glass test tube 18 mm in outside diameter, 14 mm in inside diameter and 150 mm in length. The thick walled tube is only compatible with the thermistor.

³ Available from U.S. Government Printing Office Superintendent of Documents, 732 N. Capitol St., NW, Mail Stop: SDE, Washington, DC 20401, <http://www.access.gpo.gov>.

*A Summary of Changes section appears at the end of this standard




FIG. 1 Benzene Solidification Point Apparatus Set Up

6.3 *Ice Bath*, a 1-L beaker, or similar suitable container, having an effective depth of at least 127 mm and filled with chipped or shaved ice.

6.4 *Stirrer*, consisting of a 1-mm wire (copper or stainless steel) or a 2-mm glass rod with one end bent into a circular form at right angles to the shaft so that it will move freely in the annular space between the thermometer stem and the wall of the smaller test tube.

6.5 *Temperature Measurement Device*, either device described below has been found satisfactory.

6.5.1 *Thermometer*; an ASTM Benzene Freezing Point Thermometer having a range from 4.0 to 6.0°C and conforming to the requirements for Thermometer 112C as prescribed in Specification E1.

6.5.2 *Thermistor*, in stainless steel housing with resistance greater than 2K ohms at 25°C. Calibration accuracy 0.01°C. Drift in resistance equivalent to less than $\pm 0.01^\circ\text{C}/\text{year}$. Thermistor shall be calibrated to cover the range it is used.

6.6 *Stirring Apparatus (Optional)*, the apparatus illustrated in Fig. 1 has been demonstrated to be an acceptable replacement for manually stirring the benzene solution.

6.7 *Ohmeter*, capable of measuring resistance to the nearest 0.1 ohm in the range 1000 to 10 000 ohms with direct temperature readout.

7. Hazards

7.1 Consult current OSHA regulations, supplier's Safety Data Sheets, and local regulations for all materials used in this test method.

7.2 **Warning**—Mercury has been designated by EPA and many state agencies as a hazardous material that can cause central nervous system, kidney, and liver damage. Mercury, or its vapor, may be hazardous to health and corrosive to materials. Caution should be taken when handling mercury and mercury-containing products. See the applicable product 1 Safety Data Sheet (SDS) for details and EPA's website (<http://www.epa.gov/mercury/faq.htm>) for additional information. Users should be aware that selling mercury or mercury-containing products, or both, in your state may be prohibited by state law.

8. Sampling

8.1 Sample the material in accordance with Practice D3437.

9. Preparation of Apparatus

9.1 Fit the benzene container with a two-hole stopper. Through one hole insert the temperature measurement device. The thermometer should be inserted up to the 4.0°C mark. The thermistor should be inserted, so as to contact the benzene solution. Through the other hole insert the shaft of the stirrer.

9.2 If using the benzene container (air jacketed), place a 3.2-mm layer of dry absorbent cotton or glass wool in the bottom of the larger test tube and insert the inner container up to the lip into a stopper or annular ring that just fits into the mouth of the air jacket.

10. Calibration of Temperature Measuring Device

10.1 Calibration of ASTM thermometer 112C is accomplished with the small scale etched on the lower portion of the thermometer. Prepare an ice bath by filling a small Dewar flask with crushed ice made from Type I or Type II water (as specified in Specification **D1193**) and add just enough chilled Type I or Type II water to make a slurry. Immerse the thermometer in the ice bath, allow 5 min for the system to reach equilibrium and read the thermometer. Solidification point values are subsequently adjusted by adding (or subtracting) the number of degrees the thermometer is below (or above) 0.00°C.

10.2 Calibration of the thermistor is performed by the thermistor manufacturer. Resistance is converted to temperature using an equation supplied by the manufacturer.

11. Procedure

11.1 Saturate the sample of benzene with water as follows: Place 7 to 8 mL of the sample in the benzene container, add 1 drop of water, and shake the tube and contents vigorously.

11.2 Place the stopper and stirring apparatus (if any) into the benzene container.

11.3 When using the benzene container (air jacket), the operator may cool the smaller test tube and contents rapidly to about 6°C in the ice bath, while stirring. Wipe dry the outside of the smaller test tube and insert it into the larger test tube. Place the assembled tubes in the ice bath.

11.4 Stir the benzene continuously and observe the temperature closely. The temperature will fall to a minimum, then rise to a maximum, remain constant at this maximum for approximately 15 s, and then fall again (**Note 1**). The minimum temperature is due to super-cooling before solidification starts and shall not be more than 0.7°C below the maximum when using a thermometer. Record the maximum constant temperature observed to the nearest 0.01°C and designate it as “wet” (**Note 1**).

NOTE 1—If distinct minimum and maximum points are not evident, or if the temperature does not remain constant at the maximum for at least 15 s, the determination shall be repeated. The thermistor reading should remain constant to at least two places to the right of the decimal.

12. Report

12.1 Results shall be reported on the anhydrous basis. Since the determination is actually made on water-saturated benzene,

the solidification point shall be corrected to the anhydrous basis by adding 0.09°C to the observed maximum temperature following the minimum. Corrections for accuracy of the thermometer shall be made.

13. Precision and Bias⁴

13.1 *Thermometer Precision*—The following criteria should be used to judge the acceptability of results obtained by this test method when using a thermometer. The criteria were determined by measuring the solidification point of a sample twelve times at one laboratory using a thermometer. The results of the intralaboratory study were calculated and analyzed using Practice **E691**. Duplicate results in the same laboratory should not be considered suspect unless they differ by more than 0.04°C.

13.2 *Thermistor Precision*—The following criteria should be used to judge the acceptability (95 % probability level) of results obtained by this test method when using a thermistor. The criteria were derived from an interlaboratory study between six laboratories. Three different samples were analyzed in triplicate on two different days using a thermistor and a thick walled glass test tube. The results of the intralaboratory study were calculated and analyzed using Practice **E691**.

13.2.1 *Intermediate Precision*—Results in the same laboratory should not be considered suspect unless they differ more than 0.04°C. On the basis of test error alone, the difference between two results obtained in the same laboratory on the same material will be expected to exceed this value only 5 % of the time.

13.2.2 *Reproducibility*—Results submitted by each of two laboratories should not be considered suspect unless they differ by more than 0.05°C. On the basis of test error alone, the difference between two test results obtained in different laboratories on the same material will be expected to exceed this value only 5 % of the time.

13.3 *Bias*—Since there is no accepted reference material suitable for determining the bias for the procedure, bias has not been determined.

14. Quality Guidelines

14.1 Laboratories shall have a quality control system in place.

14.1.1 Confirm the performance of the test instrument or test method by analyzing a quality control sample following the guidelines of standard statistical quality control practices.

14.1.2 A quality control sample is a stable material isolated from the production process and representative of the sample being analyzed.

14.1.3 When QA/QC protocols are already established in the testing facility, these protocols are acceptable when they confirm the validity of test results.

14.1.4 When there are no QA/QC protocols established in the testing facility, use the guidelines described in Guide **D6809** or similar statistical quality control practices.

⁴ Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR:D16-1028. Contact ASTM Customer Service at service@astm.org.

15. Keywords

15.1 benzene; solidification point

SUMMARY OF CHANGES

Committee D16 has identified the location of selected changes to this standard since the last issue (D852–13) that may impact the use of this standard. (Approved June 1, 2016.)

(1) Footnote referring to a sole source supplier was removed.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>