

**DS 52**



**NUCLEAR  
REACTOR  
NEUTRON  
ENERGY  
SPECTRA**



*by*

C. Z. Serpan, Jr. and B. H. Menke



AMERICAN SOCIETY FOR TESTING AND MATERIALS

# **NUCLEAR REACTOR NEUTRON ENERGY SPECTRA**

**by C. Z. Serpan, Jr. and B. H. Menke  
Naval Research Laboratory  
Washington, D. C.**

**ASTM DATA SERIES PUBLICATION DS 52**

**List price \$26.00  
05-052000-35**



**AMERICAN SOCIETY FOR TESTING AND MATERIALS  
1916 Race Street, Philadelphia, Pa. 19103**

© by AMERICAN SOCIETY FOR TESTING AND MATERIALS 1974  
Library of Congress Catalog Card Number: 74-75129

NOTE

The Society is not responsible, as a body,  
for the statements and opinions  
advanced in this publication.

Printed in Baltimore, Md.  
April 1974

**Data Series DS 52**  
**American Society for Testing and Materials**

## **Related ASTM Publications**

**Analysis of Reactor Vessel Radiation Effects Surveillance Programs, ASTM STP 481 (1970),  
\$26.00 (04-481000-35)**

**Irradiation Effects on Structural Alloys for Nuclear Reactor Applications, ASTM STP 484  
(1971), \$49.25 (04-484000-35)**

**Effects of Radiation on Substructure and Mechanical Properties of Metals and Alloys,  
ASTM STP 529 (1973), \$49.50 (04-529000-35)**

## TABLE OF CONTENTS

<b>Introduction</b>	<b>1</b>
<b>Reactor Physics Spectrum Codes</b>	<b>2</b>
<b>Description of Data in Main Compilation</b>	<b>3</b>
<b>Reactor Description</b>	<b>4</b>
<b>Spectrum Facility Description</b>	<b>4</b>
<b>Spectrum Code</b>	<b>4</b>
<b>Lower Energy Limit</b>	<b>4</b>
<b>Neutron Flux</b>	<b>5</b>
<b>Spectrum-Averaged Cross Sections</b>	<b>5</b>
<b>Lethargy</b>	<b>6</b>
<b>Lower Energy Limit (MeV)</b>	<b>6</b>
<b>Flux Fraction Per Group</b>	<b>6</b>
<b>Normalized Flux Per Lethargy Interval</b>	<b>6</b>
<b>Use of Neutron Spectrum Data</b>	<b>7</b>
<b>Normalized Flux Per Lethargy Interval</b>	<b>7</b>
<b>Normalized Response</b>	<b>9</b>
<b>Spectrum-Averaged Cross Sections</b>	<b>9</b>
<b>Thermal Neutron Flux (at Maxwellian Temperature)</b>	<b>10</b>
<b>Calculation of Fluxes from Cross Sections</b>	<b>11</b>
<b>Flux Fraction Per Group</b>	<b>12</b>
<b>References</b>	<b>13</b>
<b>Main Compilation</b>	<b>17</b>
<b>Light Water Moderated Reactors</b>	<b>17</b>
<b>Research and Test Reactors</b>	<b>17</b>
SP 3       LITR C-53	
SP 4       LITR C-49	
SP 5       LITR C-28	
SP 6       LITR C-18	
SP 7       LITR C-55	
SP 21      LITR C-43	
SP 82      UCRR T-C3	
SP 83      UCRR T-D3	
SP 84      UCRR T-B3	
SP 85      UCRR T-A4	
SP 86      UCRR T-F5	
SP 60      ETR P-12	
SP 61      ATR 1-D North Loop	
<b>Power Reactors</b>	<b>45</b>
SP 23      Big Rock Point -1 inch	
SP 24      Big Rock Point Accelerated Surveillance	
SP 25      Big Rock Point +1 inch	
SP 26      Big Rock Point Vessel Wall Surveillance	
SP 27      Big Rock Point Vessel Wall Cladding Interface	
SP 28      Big Rock Point 1-inch into vessel	

SP 29	Big Rock Point 2-inch into vessel
SP 30	Big Rock Point 3-inch into vessel
SP 31	Big Rock Point 4-inch into vessel
SP 32	Big Rock Point 5-inch into vessel
SP 14	Yankee Inner Surveillance Monitor
SP 15	Yankee Outer Surveillance Monitor
SP 33	Yankee Vessel Wall Cladding Interface
SP 45U	San Onofre Accelerated Surveillance
SP 38	SM-1A Vessel Wall Cladding Interface, Prog.S
SP 81	SM-1A Above Core Surveillance, Program S
SP 58	SM-1A Vessel Wall Cladding, P1MG
SP 59	SM-1A Above Core Surveillance, P1MG
SP 34	PM-2A Vessel Wall Cladding Interface, Prog.S
SP 17U	PM-2A 1/4 t vessel thickness, Program S
SP 16U	PM-2A 3/4 t vessel thickness, Program S
SP 49	PM-2A Vessel Wall Cladding Interface, P1MG
SP 50	PM-2A Vessel Wall Cladding Interface, P3MG
SP 62	SM-1 Dummy Fuel Element, Position 72
SP 63	SM-1 Vessel Wall Cladding Interface

#### Special Experimental Facilities

97

SP 9	IRL-4, 4-5/8 inches
SP 10	IRL-4, 5-5/8 inches
SP 11	IRL-4, 6-5/8 inches
SP 12	IRL-4, 7-5/8 inches
SP 13	IRL-4, 8-5/8 inches
SP 51D	IRL-5, Accelerated Surveillance DTF-IV
SP 52D	IRL-5, Vessel Wall Surveillance, DTF-IV
SP 53D	IRL-5, 1-inch inside wall, DTF-IV
SP 54D	IRL-5, 2-inch inside wall, DTF-IV
SP 55D	IRL-5, 4-inch inside wall, DTF-IV
SP 56D	IRL-5, 6-inch inside wall, DTF-IV
SP 57D	IRL-5, 7-inch inside wall, DTF-IV
SP 51SA	IRL-5, Accelerated Surveillance, SAND-II
SP 52SA	IRL-5, Vessel Wall Surveillance, SAND-II
SP 53SA	IRL-5, 1-inch inside wall, SAND-II
SP 55SA	IRL-5, 4-inch inside wall, SAND-II
SP 57SA	IRL-5, 7-inch inside wall, SAND-II
SP 51DB	IRL-5, Accelerated Surveillance, 2DB
SP 52DB	IRL-5, Vessel Wall Surveillance, 2DB
SP 53DB	IRL-5, 1-inch inside wall, 2DB
SP 54DB	IRL-5, 2-inch inside wall, 2DB
SP 55DB	IRL-5, 4-inch inside wall, 2DB
SP 56DB	IRL-5, 6-inch inside wall, 2DB
SP 57DB	IRL-5, 7-inch inside wall, 2DB
SP 51PM	IRL-5, Accelerated Surveillance, P1MG
SP 52PM	IRL-5, Vessel Wall Surveillance, P1MG
SP 53PM	IRL-5, 1-inch inside wall, P1MG

SP 55PM IRL-5, 4-inch inside wall, P1MG  
SP 57PM IRL-5, 7-inch inside wall, P1MG

Heavy Water Moderated Reactors

157

SP 1       Carolinias-Virginia Tube Reactor, Pos. 10-L  
SP 22      Heavy Water Components Test Reactor, Gray Rod

Graphite Moderated Reactors

163

SP 8       Brookhaven Graphite Reactor, W-44 Position  
SP 39      GMWC, K-East Cold, No Shield  
SP 40      GMWC, K-East Cold, Intermediate Shield  
SP 41      GMWC, K-East Cold, Full Shield  
SP 42C     K-East Cold, Cadmium  
SP 43CB    K-East Cold, Cadmium plus Boron  
SP 39UH    K-East 550°F, "O" Shield  
SP 42UH    K-East 550°F, Cadmium Shield

Organic Moderated Reactor

181

SP 35      Organic Moderated Reactor Exp., Core Center  
SP 36      Organic Moderated Reactor Exp., Grid Plate  
SP 37      Organic Moderated Reactor Exp., Vessel Wall

Fast Breeder Reactor

189

31F24 EBR-II Control Rod Shroud 5D3, R 18cm, Z +16.8cm  
31F25 EBR-II Control Rod Shroud 5D3, R 18cm, Z +31.7cm  
31F26 EBR-II Control Rod Shroud 5D3, R 18cm, Z +44.2cm  
31F27 EBR-II Control Rod Shroud 5D3, R 18cm, Z - 4.6cm  
31F28 EBR-II Control Rod Shroud 5D3, R 18cm, Z -18.3cm  
31F29 EBR-II Control Rod Shroud 5D3, R 18cm, Z -32.6cm  
31F30 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z+16.8cm  
31F31 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z+31.7cm  
31F32 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z+44.2cm  
31F33 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z- 4.6cm  
31F34 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z-18.3cm  
31F35 EBR-II Control Rod Shroud 5A1, R 22.5cm,Z-32.6cm



## NUCLEAR REACTOR NEUTRON ENERGY SPECTRA

C. Z. Serpan, Jr.<sup>a</sup> and B. H. Menke<sup>a</sup>INTRODUCTION

Studies of the effects resulting from exposure of materials to neutron bombardment in nuclear reactors can be made much more quantitative if the energy-level distribution of the neutrons is known. Such a distribution is commonly called a neutron spectrum. The neutron energies range from as low as  $1 \times 10^{-10}$  MeV in the thermal-neutron region, to over 18 MeV in the fast region. This extremely wide range can be conveniently handled, however, using a system of 25 or even fewer groups each defining a precise energy range, with the neutron population within those energy bounds being tabulated as the neutron spectrum.

A very common method in use for defining such a group structure is by quarter-lethargy units (0.25 u) where u is defined by

$$u = \ln \left( \frac{10 \text{ MeV}}{x \text{ MeV}} \right), \quad (1)$$

with 10 MeV typically taken as the highest energy boundary. For example, using 10 MeV as the highest energy level boundary (and noting that all neutrons  $\geq 10$  MeV are included in this group), the next lower energy level boundary would be

$$0.25 u = \ln \left( \frac{10 \text{ MeV}}{7.79 \text{ MeV}} \right). \quad (2)$$

When all the neutrons in a spectrum having energies between any two such energy limits are summed and tabulated for that group, the neutrons are termed a group-integral flux and then the corresponding spectrum (all of the groups) is termed an integral spectrum. The integral spectra presented in this compilation are listed in the column Flux Fraction Per Group.

<sup>a</sup> Reactor Materials Branch, Metallurgy Division, Naval Research Laboratory

Neutron spectra have been and continue to be calculated for specific reactor environments for specific requirements, and on an individual basis, their value is limited to that particular application. If, however, many neutron spectra can be assembled and reviewed simultaneously, it is possible to discern important similarities and differences between spectra and begin to relate them to the specific reactor environment. This is the first reason for this compilation of neutron spectra. The second reason is to document a large body of neutron spectra, which have been calculated at a number of different laboratories and subsequently used at the Naval Research Laboratory, thus making them generally available for reference and for additional research purposes. Such spectra are published herein in tabulated form (under the column Flux Fraction Per Group) and in corresponding graphical form.

#### REACTOR PHYSICS SPECTRUM CODES

As noted above, the neutron spectra in this compilation have been calculated at a number of different laboratories. Because each laboratory has typically used different reactor physics spectrum codes, the spectra in this compilation reflect these different computational methods. In addition to the "pure" spectrum calculation codes, however, another computer code is represented that will "unfold" neutron spectra from multiple activation foil results. The different codes represented in this compilation include "2DXY"<sup>1</sup> (two-dimensional transport theory), "Program S"<sup>2</sup> and "DTF-IV"<sup>3</sup> (one-dimensional transport theory), "2DB"<sup>4</sup> (two-dimensional diffusion theory), "SAND-II"<sup>5</sup> (multiple-foil unfolding), and "P1MG"<sup>6</sup> and "P3MG"<sup>7</sup> (one-dimensional, transport-modified diffusion).

The cross section libraries for the different codes are not necessarily the same, primarily because each laboratory uses a different library. Therefore, the results for the same reactor

facilities but from different codes (and/or laboratories) reveal variations beyond those resulting from the calculational method alone. No attempt is made to adjust or explain such variations in this compilation. In fact, an additional benefit of the compilation is the presentation of such variations for further inspection and consideration. References given for each spectrum show the source of the original calculation. It follows then, that reasonable consistency can be assumed for spectra calculated at the same laboratory because of consistency in the cross section library.

#### DESCRIPTION OF DATA IN MAIN COMPILATION

The information presented for each neutron spectrum in this compilation consists of:

1. A graphical representation of the integral neutron spectrum,
2. A description of the reactor and environment plus dosimetry data (including measured fluxes and cross sections, and
3. A computer listing of the lethargy and energy intervals plus the neutron spectrum normalized in two different ways.

The plotted neutron spectra in the main compilation correspond to the listing titled Flux Fraction Per Group. All of the neutron spectra in the compilation, except the last 12 for the EBR-II, are plotted with the right ordinate at a maximum of six percent; the area under all these curves is equivalent. Because the neutron-energy distribution in the EBR-II is so different from thermal reactors, those 12 reactor spectra are plotted with the right ordinate a maximum of 12 percent; the area under these curves are all equal. In those few cases when a group flux value exceeds the maximum percent of the plot, the graph terminates at the maximum and a digit is printed to indicate the excess. Pictorial representations of reactor facilities or experiments have been inset (where available) to aid the spectrum description.

The spectrum number identification assigned at NRL is shown in the graphical representation (e.g. SP24, meaning SPectrum 24) followed by the short title (e.g. Big Rock Point Accel Surv, meaning the accelerated surveillance location of the Big Rock Point Reactor). A total of six letters and/or numbers can be included in the spectrum identification number. In the compilation the first two letters are SP for thermal reactors, and the next two numbers are generally arbitrary except for several series which are apparent. The last two letters refer to a specific code (e.g. D = DTF-IV, PM = P1MG) or indicate that the reactor physics code spectrum has been adjusted by multiple foils and thus has been unfolded (e.g. U) or that the spectrum has been adjusted to conform to high temperature operations (e.g. H), or the use of shielding materials (e.g. C = Cadmium, B = Boron). A series of spectra from the EBR-II are included, and these are all identified as from the "31F dosimetry test", followed by an arbitrary two digit number, (e.g. 31F24).

A detailed description of each part of the tabulated information in the main compilation follows.

Reactor Description. This includes the name and physical location of the reactor, its type such as a PWR, BWR, test, etc., its full power level in thermal MW, the coolant and the moderator.

Spectrum Facility Description. This provides a brief description of the specific irradiation location within the reactor for which the spectrum was calculated. Special important features are also included, and a statement of the major environment considered which the spectrum represents.

Spectrum Code. The name of the specific code used for the spectrum calculation, the laboratory performing the calculation and a reference to the initial publication of the spectrum information.

Lower Energy Limit. Thresholds typically used for interpretation of results for materials studies. The thermal group is always the last energy group of the tabulated spectrum. The temperature

refers to the moderator temperature and is given as either (a) 20°C which is used when no meaningful activation foil measurement was available, and thus, the thermal value is directly from the calculation, or (b) some higher temperature value which means that a foil measurement was made and that the thermal flux measurement was corrected to the Maxwellian thermal flux at that temperature. In case (b), the tabulated, thermal flux group value is adjusted to conform to the measured Maxwellian thermal flux at the stated temperature. The technique for this calculation is described in a following section (titled Thermal Neutron Flux (at Maxwellian temperature)) page 10.

Neutron Flux. Fast and thermal neutron fluxes measured from irradiations in the spectra are listed. They correspond to full power levels unless indicated otherwise. They have been calculated using the cross sections given in the adjacent column.

Fluxes in parenthesis at the threshold >0.5 MeV are taken directly from the reactor physics computer code calculation output; they have been included only for certain series of spectra wherein it is useful to observe the progressive changes in spectrum shape and intensity among the spectra in the series as calculated by the particular code, and not adjusted in any way by measurements. The values given represent the summation of all integral fluxes equal to and above 0.5 MeV in the spectrum (lethargy  $\leq 3.00$ ). Thus it is possible to normalize the entire spectrum using that sum for flux >0.5 MeV and accordingly all other spectra in the series to their corresponding sums >0.5 MeV. If no fluxes are given, no measurements are available.

Spectrum-Averaged Cross Sections. These are cross sections for activation in the spectrum of interest using the  $^{54}\text{Fe}(\text{n},\text{p})^{54}\text{Mn}$  reaction determined with Helm's<sup>8</sup> model. The procedure is discussed in a following section (titled Spectrum-Averaged Cross Sections) page 9. Other cross section models could also be used,

of course, such as those of Simons and McElroy<sup>9</sup> or Shure<sup>10</sup>; the effect of the differences incurred using alternate models is discussed elsewhere.<sup>11</sup>

Lethargy. The lower lethargy limit of the group. One lethargy interval in this compilation is taken to be 0.25 u. Therefore, for example, 1.0 u equals 4 lethargy intervals.

Lower Energy Limit (MeV). The lower-energy limit of the group in MeV.

Flux Fraction Per Group. This listing is the integral spectrum, and is normalized to one neutron. Tabulated values are the relative, integral fluxes between the energy limits. Because of the normalization to one neutron, the tabulated values clearly do not correspond to the actual, absolute flux values in the reactor environment.

All the spectra in the main compilation are plotted directly from these values for all groups having a lethargy interval of 0.25 u; groups having more than one quarter-lethargy interval are plotted by dividing the listed group-integral flux value by the number of quarter-lethargy intervals in that group. For example, fluxes in the group  $u = 5.0$  typically are bounded between  $u = 4.0$  and  $u = 5.0$ , wherein there are four quarter-lethargy intervals. Thus, for plotting, the tabulated flux must be divided by 4 and that average value plotted between  $u = 4.0$  and  $u = 5.0$ .

Normalized Flux Per Lethargy Interval. The integral spectrum above (Flux Fraction Per Group) has been renormalized in this column to equivalent activation by the  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction using the activation cross sections of Helm;<sup>8</sup> the procedure is described in the first two subsections of the following section titled Use of Neutron Spectrum Data. This is an integral spectrum for fluxes in groups having one quarter-lethargy interval; for groups having more than one quarter-lethargy interval, the tabulated values are already divided by the number of quarter-lethargy intervals, and may be plotted directly between the listed

energy or lethargy limits, as has been done in Fig. 1.

#### USE OF NEUTRON SPECTRUM DATA

A clearer understanding of the tabulated data of this compilation and its use may be gained from the following examples, which are keyed to Fig. 1. The figure shows the spectrum for the accelerated surveillance location of the Big Rock Point reactor (the histogram) plotted from "Normalized Flux Per Lethargy Interval" values. Superimposed on this histogram is a representation of the fission spectrum as the smooth curve. The overall intensity values of both the fission spectrum and the Big Rock Point reactor spectrum are normalized to equal activation by the  $^{54}\text{Fe}(\text{n},\text{p})^{54}\text{Mn}$  reaction using Helm's cross section values.<sup>8</sup> The response functions, consisting of group flux values for both the fission spectrum and the Big Rock Point spectrum times the group activation cross section values of Helm, are plotted between 130 and 140 on the right ordinate as the smooth curve and the histogram respectively. It is pointed out that this is the only plot in this compilation made directly from values of the listing "Normalized Flux Per Lethargy Interval" and has been included to show how to use this particular spectrum listing. All other plots in this compilation are made directly from the "Flux Fraction Per Group" listing.

Additional detailed descriptions of the data listings in Fig. 1 follow.

Normalized Flux Per Lethargy Interval. This spectrum is renormalized in relative intensity to a specific level of activation with respect to the  $^{54}\text{Fe}(\text{n},\text{p})^{54}\text{Mn}$  reaction using the activation cross section model of Helm.<sup>8</sup> These values  $\sigma_i^{\text{act}}$  are shown in the column Activation Cross-Fe and are in units of Barns, (B). The activation level or "Normalized Response," is  $32.7876 \text{ n/cm}^2 \cdot \text{sec}^{-1} \times B$ , and simply comes from multiplying each group flux  $\phi_i$  times the corresponding cross section  $\sigma_i^{\text{act}}$  and summing the products, e.g. for group having lower lethargy 0.25 u in Fig. 1.




Fig. 1 - Graphical representation and tabulated neutron spectrum for the accelerated surveillance location, position 124, of the Big Rock Point Reactor.

$$3.45167 \text{ n/cm}^2 \cdot \text{sec}^{-1} \times 0.450 \text{ B} = 1.55325 \text{ n/cm}^2 \cdot \text{sec}^{-1} \times B \quad (3)$$

etc.

Normalized Response. The value of 32.7876 is the total activation from the  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction in this spectrum. In every spectrum in this compilation, the group fluxes listed under Normalized Flux Per Lethargy Interval are similarly normalized as shown above such that multiplication of the Normalized Flux Per Lethargy Interval values times the activation cross sections of Helm will result in the normalized response value of  $32.812 \pm 0.050$ .

The fluxes shown under Normalized Flux Per Lethargy Interval are integral values through lethargy 4.0 and are the average value for quarter-lethargy intervals for the subsequent groups. Thus, in the group having lower lethargy limit 6.75 u of Fig. 1, a total of 11 quarter-lethargy intervals exist. This follows from

$$6.75 \text{ u} - 4.00 \text{ u} = 2.75 \text{ u / group} \quad (4)$$

and

$$\frac{2.75 \text{ u/group}}{0.25 \text{ u/interval}} = 11 \text{ interval/group} \quad (5)$$

Accordingly, the flux in the group having lower lethargy 6.75 is

$$8.58741 \times 11 = 94.46151 . \quad (6)$$

Spectrum-Averaged Cross Sections. Spectrum-averaged cross-sections can now be calculated for the various threshold energies of interest using the formula shown in the table. The spectrum-averaged cross-section is calculated by dividing the Normalized Response value (in this case 32.7876) by the sum of the fluxes greater than the desired threshold energy. For threshold >1 MeV, the Normalized Flux Per Lethargy Interval values are summed from lethargy 0.25 through 2.30, since  $2.30 \text{ u} = \ln(10 \text{ MeV}/1\text{MeV})$ . Because the group structure does not correspond to 2.30, it is necessary to add 20% of the group having lower lethargy 2.50 to the total, e.g.

$$20.7239 \times 0.20 = 4.14478 \quad (7)$$

The total sum of fluxes between 0.25 u and 2.30 u is then 214.83685, and when divided into the normalized response value, yields the cross section of 152.6 mb. Calculation of the cross section for threshold >0.5 MeV requires the sum of fluxes from 0.25 u through 3.00 u, and this sum again divided into the response value. Calculation of the cross section for threshold 0.1 MeV requires the sum of fluxes from 0.25 u through 4.60 u. Again, interpolation between lethargy groups is required for this total sum, e.g. in spectrum 24 of Fig. 1, recall that the flux for group 6.75 u is the average value for all 11 lethargy intervals, and from equation (6) that the integral flux in this group is 95.46151. To obtain the fraction representing lethargy 4.60 u the following procedure is used:

$$\frac{(4.60 \text{ u} - 4.00 \text{ u})}{(6.75 \text{ u} - 4.00 \text{ u})} \times 94.46151 = 20.60978 \quad (8)$$

This value of 20.60978 is then added to the sum of fluxes from groups 0.25 u through 4.00 u to yield the total value of 357.22725. Thermal Neutron Flux (at Maxwellian Temperature). Thermal neutron flux derived from the  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction using both bare and cadmium-covered foils, is commonly reported as  $2200\text{m.sec}^{-1}$  flux at  $20^\circ\text{C}$  represented herein as  $\phi_{th}^{20^\circ\text{C}}$ . When the actual irradiation temperature exceeds  $20^\circ\text{C}$ , this flux value no longer correctly represents the true thermal neutron flux. To correct existing  $\phi_{th}^{20^\circ\text{C}}$  flux values, for some different temperature,  $x^\circ\text{C}$ , the following relation is used:

$$\phi_{th}^{x^\circ\text{C}} = \frac{\phi_{th}^{20^\circ\text{C}}}{0.8862 \left(\frac{T_0}{T}\right)^{1/2}} \quad (9)$$

where  $T_0$  and  $T$  are both expressed in degrees absolute, ( $^\circ\text{K}$ ) so that

$$T_0 \text{ is } 293^\circ\text{K} = (273 + 20^\circ\text{C}) \quad \text{and} \\ T \text{ represents } x^\circ\text{C} \text{ (expressed as } (273 + X^\circ\text{C}) = ^\circ\text{K}.$$

The  $2200 \text{ m}\cdot\text{sec}^{-1}$  flux at  $20^\circ\text{C}$  for spectrum 24 is  $9.52 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1}$ , and from the main data compilation for spectrum 24, the actual operating temperature was  $302^\circ\text{C}$  (equal to  $575^\circ\text{K}$ ). Thus,

$$\phi_{\text{th}}^{302^\circ\text{C}} = \frac{9.52 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1}}{0.8862 \left( \frac{293}{575} \right)^{1/2}} \quad (10)$$

$$= 15.05 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1} \quad (11)$$

This technique can also be used for  $2200 \text{ m}\cdot\text{sec}^{-1}$  flux at  $20^\circ\text{C}$  calculated by the Ag-Co technique.<sup>11</sup>

Calculation of Fluxes from Cross Sections. It is a very simple matter to calculate flux values for different threshold energies if the spectral-averaged cross-sections ( $\bar{\sigma}$ ) are known for those threshold energies. For thresholds 1 and 2, for example, the relation is

$$\phi_1 \times \bar{\sigma}_1 = \phi_2 \times \bar{\sigma}_2 . \quad (12)$$

Using the values for spectrum 24 again as an example,

$$\begin{aligned} 1.37 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1} > 1 \text{ MeV} \times 152.6 \text{ mb} &= \\ 1.75 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1} > 0.5 \text{ MeV} \times 119.4 \text{ mb} &\quad (13) \end{aligned}$$

Care must be taken to be sure that the correct cross section is being used. If one desires flux greater than some threshold energy, the cross section must also be calculated based on the flux greater than that same energy.

Frequently, the fission-spectrum-averaged cross sections are used for flux calculations. In this case, all the neutrons in the fission spectrum are being considered, not just those greater than some threshold, such as  $>1 \text{ MeV}$ . For example, the fission-spectrum-averaged cross section may be given as  $68 \text{ mb}$  for the  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction, but the corresponding flux values are quoted as  $>1 \text{ MeV}$ . In this case, the cross section corresponding to these fluxes is not  $68 \text{ mb}$ , but rather is

$$\frac{68 \text{ mb}}{0.692} = 98.26 \text{ mb} . \quad (14)$$

This results because flux  $>1$  MeV represents 69.2% of the flux in the fission spectrum but the cross section of 68mb represents flux averaged over the entire fission spectrum. In order to determine the flux value corresponding to these conditions of a fission-spectrum-averaged cross section of 68mb, and fluxes  $>1$  MeV, the cross section of 98.26 is used for  $\bar{\sigma}_2$  in equation (12), and the values on the left side of equation (13) representing calculated-spectrum flux  $>1$  MeV for threshold 1. Thus, the fission-spectrum flux  $>1$  MeV of  $2.12 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1}$   $>1$  MeV is calculated:

$$\begin{aligned} 1.37 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1} &>1 \text{ MeV} \times 152.6 \text{ mb} = \\ 2.12 \times 10^{12} \text{ n/cm}^2 \cdot \text{sec}^{-1} &>1 \text{ MeV} \times 98.26 \text{ mb} \end{aligned} \quad (14)$$

Flux Fraction Per Group. As was stated earlier, this is the tabulated integral spectrum. It is normalized to one neutron for consistency throughout this report. This has an advantage, because it is thus possible to easily determine the population fraction of any flux group or groups. For example, it can be seen that the value for the thermal group, (at lower energy  $1 \times 10^{-10}$  MeV) is 7.636-001, meaning that thermal neutrons occupy 76.36% of the entire spectrum. By contrast, the highest energy group (7.79 MeV, lower lethargy 0.25 u) has only 0.115% of the neutrons in the entire spectrum. The group flux values listed in this column are plotted as percentages directly in the accompanying figures in the main compilation for groups through lethargy 4.0. For group-fluxes at higher lethargies, the values plotted are those derived from division of the tabulated group fluxes by the number of quarter-lethargy intervals in the group as has been described above in the section titled "Flux Fraction Per Group", page 6.

## REFERENCES

1. Bengston, J., et al, "2DXY Two Dimensional, Cartesian Coordinate Sn Transport Calculation," U. S. AEC Research and Development Report, AGNTM-392, June 1961.
2. Duane, B. H., "Neutron and Photon Transport Plane-Cylinder-Sphere (GE-ANPD) Program S Variational Optimum Formulation," General Electric Company XOC-9-118, 1959.
3. Lathrop, K. D., "DTF-IV, A Fortran-IV Program for Solving the Multigroup Transport Equation with Anisotropic Scattering," LA-3373, Los Alamos Scientific Laboratory, 1965 .
4. Little, W. W., Jr. and Hardie, R. W., "2DB, A Two-Dimensional Diffusion-Burnup Code for Fast Reactor Analysis," BNWL-640, Pacific Northwest Laboratory, 1968 .
5. McElroy, W. N., Berg, S., Crockett, T. B., and Hawkins, R. G., "A Computer-Automated Iterative Method for Neutron Flux Spectra Determination by Foil Activation," AFWL-TR-67-41, Vol. I-IV, Air Force Weapons Laboratory, 1967 .
6. Bohl, H., et al, "P1MG - A One-Dimensional Multigroup P-1 Code for the IBM 704," WAPD-TM-135, Bettis Atomic Power Laboratory, Pittsburgh, Pa., July 1969.
7. Bohl, H., et al, "P3MG - A One-Dimensional Multigroup P-3 Program for the Philco-2000 Computer," WAPD-TM-272, Bettis Atomic Power Laboratory, Pittsburgh, Pa., 1963.
8. Helm, J. W., "High-Temperature Graphite Irradiations: 800 to 1200 Degrees C: Interim Report No. 1," BNWL-112, Battelle Northwest Laboratory, September 1965 .
9. Simons, R. L. and McElroy, W. N., "Evaluated Reference Cross Section Library," BNWL-1312, Battelle Northwest Laboratory, May 1970 .
10. Shure, K., "Radiation Damage Exposure and Embrittlement of Reactor Pressure Vessels," WAPD-TM-471, Bettis Atomic Power Laboratory, Pittsburgh, Pa., November 1964 .
11. Book of ASTM Standards, Part 30, 1974, Standard Method E481, "Measuring Neutron-Flux Density by Radiochemistry of Cobalt and Silver".
12. Serpan, C. Z., Jr. and Steele, L. E., "Damaging Neutron Exposure Criteria for Evaluating the Embrittlement of Reactor Pressure Vessel Steels in Different Neutron Spectra," NRL Report 6415, Naval Research Laboratory, July 28, 1966; ASTM STP 426, 594-624, 1967.
13. Dahl, R. E., Battelle-Northwest, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication 1965 .

14. Ulseth, J. A., Battelle Northwest, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1967, 1968 .
15. Ulseth, J. A., Battelle Northwest, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1969 .
16. Carter, N. E., Westinghouse Hanford, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1970 .
17. Busselman, G. J. and Ulseth, J. A., Battelle Northwest to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1969.
18. Serpan, C. Z., Jr. and Watson, H. E., "Mechanical Property and Neutron Spectral Analyses of the Big Rock Point Reactor Pressure Vessel," Nucl. Eng. and Design, Vol. 11, No. 3, April 1970, 393-415.
19. Ulseth, J. A. and Dahl, R. E., Battelle-Northwest Laboratory, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1966 .
20. Serpan, C. Z., Jr. and Hawthorne, J. R., "Yankee Reactor Pressure Vessel Surveillance: Notch Ductility Performance of Vessel Steel and Maximum Service Fluence Determined from Exposure During Cores II, III, and IV," NRL Report 6616, Naval Research Laboratory, Sep. 29, 1967; Trans. ASME, J. Basic Eng., Vol. 89, Series D, No. 4, December 1967, 897-910.
21. Unpublished data, unfolded at Naval Research Laboratory, C. Z. Serpan, Jr., from Battelle Northwest Laboratory activation data, 1971.
22. Serpan, C. Z., Jr. and Steele, L. E., "Neutron Spectral Considerations Affecting Projected Estimates of Radiation Embrittlement of the Army SM-1A Reactor Pressure Vessel," NRL Report 6474, Naval Research Laboratory, Sep. 30, 1966.
23. Serpan, C. Z., Jr., "Implications of the Differences in Neutron Spectra Predicted for Reactor Pressure Vessel Walls by Transport and the P1MG Codes," Nucl. Eng. and Design, Vol. 16, No. 1, May 1971, 24-34.
24. Barry, K. M., Westinghouse Power Systems, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1970.
25. Barry, K. M., Westinghouse Power Systems, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1968.
26. Shure, K. and Oberg, C. T., "Neutron Exposure of the PM-2A Reactor Vessel," Nucl. Sci. and Engr. Vol. 29, 1967, 348.
27. Serpan, C. Z., Jr., "Notch Ductility and Tensile Property Evaluation of the PM-2A Reactor Pressure Vessel," NRL Report 6739, Naval Research Laboratory, June 19, 1968; ASTM STP 457, 1969, 135-155.

28. Carter, N. E., Battelle-Northwest Laboratory, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1969.
29. Jenquin, U., Battelle Northwest Laboratory, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1970.
30. Serpan, C. Z., Jr., "Reliability of Fluence-Embrittlement Projection of Pressure Vessel Surveillance Analysis," Nucl. Tech. Vol. 12, No. 1, Sep. 1971, 108-118.
31. Simons, R. L., Kellog, L. S., Barry, K. M., and Serpan, C. Z., Jr., "A Comparison of Measured and Calculated Integral Fluxes and Spectra in a Pressure Vessel Mock-Up," ANS Trans., Vol. 13, No. 2, Nov. 1970, 884.
32. Busselman, G. J., Battelle Northwest Laboratory, to C. Z. Serpan, Jr., Private Communication, 1969.
33. Schoen, G. F., Westinghouse Power Systems, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1970.
34. Busselman, G. J., Battelle Northwest Laboratory, to C. Z. Serpan, Jr., Naval Research Laboratory, Private Communication, 1968.
35. McElroy, W. N., Jackson, J. L., Ulseth, J. A., and Simons, R. L., "EBR-II Dosimetry Test Data Analysis (Reactor Runs 31E and 31F)", BNWL-1402, Battelle-Northwest, 1970.




MAIN COMPILATION


LIGHT WATER MODERATED REACTORS

RESEARCH AND TEST REACTORS

SP3 LITR C-53



	FUEL
E	EXPERIMENT
Be	BERYLLIUM
ISO	ISOTOPE STRINGER
CR	CONTROL ROD



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Core lattice facility C-53; unfueled location; steel and water.

Spectrum Code

Code: 2 DXY Calculation: BNW12-14

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$2.78 \times 10^{12}$	87.5
>0.5 MeV	4.05	60.1
>0.1 MeV	5.46	44.6
Thermal, 49 °C	4.00	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP3 LITR C-53

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	3.231-004	2.33958+000
0.50	6.07000+000	9.827-004	7.12354+000
0.75	4.72000+000	2.236-003	1.60733+001
1.00	3.68000+000	3.113-003	2.26180+001
1.25	2.87000+000	4.663-003	3.39235+001
1.50	2.23000+000	8.400-003	6.02092+001
1.75	1.74000+000	9.755-003	7.11011+001
2.00	1.35000+000	1.072-002	7.64117+001
2.25	1.05000+000	9.875-003	7.10618+001
2.50	8.21000-001	8.644-003	6.35374+001
2.75	6.39000-001	9.592-003	6.92132+001
3.00	4.98000-001	7.200-003	5.22278+001
3.25	3.88000-001	7.499-003	5.43377+001
3.50	3.02000-001	7.307-003	5.27380+001
3.75	2.35000-001	5.209-003	3.75568+001
4.00	1.83000-001	5.235-003	3.78509+001
17.00	4.14000-007	1.647-001	2.29090+001
25.33	1.00000-010	7.346-001	1.59509+002
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP4 LITR C-49



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Core lattice facility C-49; unfueled location: steel and water.

Spectrum Code

Code: 2\_DXY Calculation: BNW13-14

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$2.08 \times 10^{12}$	74.5
>0.5 MeV	3.04	51.0
>0.1 MeV	4.41	35.2
Thermal, 49°C	4.59	


\*Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP4 LITR C-49

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	6.502-004	2.68646+000
0.50	6.07000+000	1.688-003	6.98228+000
0.75	4.72000+000	3.848-003	1.57864+001
1.00	3.68000+000	5.220-003	2.16401+001
1.25	2.87000+000	7.113-003	2.95239+001
1.50	2.23000+000	1.652-002	6.75815+001
1.75	1.74000+000	2.300-002	9.56603+001
2.00	1.35000+000	2.353-002	9.56653+001
2.25	1.05000+000	2.148-002	8.81792+001
2.50	8.21000-001	1.810-002	7.59152+001
2.75	6.39000-001	1.962-002	8.07643+001
3.00	4.98000-001	1.508-002	6.24120+001
3.25	3.88000-001	2.041-002	8.43640+001
3.50	3.02000-001	1.883-002	7.75316+001
3.75	2.35000-001	1.352-002	5.56100+001
4.00	1.83000-001	1.475-002	6.08561+001
17.00	4.14000-007	5.421-001	4.30330+001
25.33	1.00000-010	2.346-001	2.90633+001
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP5 LITR C-28



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Partial fuel element, core lattice facility C-28; steel, water,  
aluminum and uranium.

Spectrum Code

Code: 2 DXY Calculation: BNW 12-14

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$6.70 \times 10^{12}$	95.2
>0.5 MeV	9.46	67.4
>0.1 MeV	12.8	49.7
Thermal, 49°C	10.6	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SPS LITR C-28

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.244-003	2.31943+000
0.50	6.07000+000	3.592-003	6.70619+000
0.75	4.72000+000	8.342-003	1.54457+001
1.00	3.68000+000	1.228-002	2.29765+001
1.25	2.87000+000	2.068-002	3.87485+001
1.50	2.23000+000	3.052-002	5.63309+001
1.75	1.74000+000	3.391-002	6.36472+001
2.00	1.35000+000	3.562-002	6.53645+001
2.25	1.05000+000	3.307-002	6.12822+001
2.50	8.21000-001	2.839-002	5.37516+001
2.75	6.39000-001	3.089-002	5.74061+001
3.00	4.98000-001	2.257-002	4.21699+001
3.25	3.88000-001	2.247-002	4.19345+001
3.50	3.02000-001	2.187-002	4.06451+001
3.75	2.35000-001	1.577-002	2.92766+001
4.00	1.83000-001	1.580-002	2.94212+001
17.00	4.14000-007	3.699-001	1.32534+001
25.33	1.00000-010	2.931-001	1.63911+001
-----			1.000+000

ONE LETHARGY INTERVAL = 0.25U

SP6 LITR C-18



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Core lattice facility C-18; unfueled location; steel and water.

Spectrum Code

Code: 2 DXY Calculation: BNW 12-14

Lower Energy Limit	Neutron Flux* $\text{cm}^{-2} \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$4.54 \times 10^{12}$	99.6
>0.5 MeV	6.64	68.1
>0.1 MeV	9.19	49.2
Thermal, 49 °C	4.63	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP6 LITR C-18

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	1.221e-003	2.37560e+000
0.50	6.07000e+000	3.458e-003	6.73659e+000
0.75	4.72000e+000	8.029e-003	1.55128e+001
1.00	3.68000e+000	1.185e-002	2.31329e+001
1.25	2.87000e+000	1.942e-002	3.83571e+001
1.50	2.23000e+000	2.949e-002	5.67997e+001
1.75	1.74000e+000	2.931e-002	5.74197e+001
2.00	1.35000e+000	3.315e-002	6.34845e+001
2.25	1.05000e+000	3.186e-002	6.16158e+001
2.50	8.21000e-001	2.786e-002	5.50412e+001
2.75	6.39000e-001	3.131e-002	6.07233e+001
3.00	4.98000e-001	2.290e-002	4.46479e+001
3.25	3.88000e-001	2.294e-002	4.46774e+001
3.50	3.02000e-001	2.313e-002	4.48714e+001
3.75	2.35000e-001	1.658e-002	3.21183e+001
4.00	1.83000e-001	1.724e-002	3.34956e+001
17.00	4.14000e-007	4.964e-001	1.85597e+001
25.33	1.00000e-010	1.737e-001	1.01365e+001
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP7 LITR C-55



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Core lattice facility C-55; unfueled location; steel and water.

Spectrum Code

Code: 2 DXY Calculation: BNW 12-14

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$3.58 \times 10^{12}$	89.0
>0.5 MeV	5.24	60.8
>0.1 MeV	7.39	43.1
Thermal, 49°C	3.95	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP7 LITR C-55

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.043+003	2.40347+000
0.50	6.07000+000	3.220+003	7.42859+000
0.75	4.72000+000	7.262+003	1.66168+001
1.00	3.68000+000	9.776+003	2.26083+001
1.25	2.87000+000	1.354+002	3.13588+001
1.50	2.23000+000	2.644+002	6.03059+001
1.75	1.74000+000	3.250+002	7.53957+001
2.00	1.35000+000	3.501+002	7.93961+001
2.25	1.05000+000	3.133+002	7.17653+001
2.50	8.21000+001	2.693+002	6.29933+001
2.75	6.39000+001	2.930+002	6.72811+001
3.00	4.98000+001	2.185+002	5.04519+001
3.25	3.88000+001	2.369+002	5.46227+001
3.50	3.02000+001	2.264+002	5.19989+001
3.75	2.35000+001	1.620+002	3.71632+001
4.00	1.83000+001	1.696+002	3.90261+001
17.00	4.14000+007	5.039+001	2.23123+001
25.33	1.00000+010	1.784+001	1.23301+001
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP21 LITR C-43



Reactor Description

Name: Low Intensity Test Reactor  
 Type: Test, tank Power Level: 3 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Oak Ridge National Laboratory, Oak Ridge, Tennessee

Spectrum Facility Description

Core lattice facility C-43; unfueled location; steel and water.

Spectrum Code

Code: 2 DXY Calculation: BNW 12-14

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$6.91 \times 10^{13}$	101.
>0.5 MeV	9.68	72.1
>0.1 MeV	13.4	52.2
Thermal, 49 °C	6.40	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP21 LITR C-43

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.559+003	2.70026+000
0.50	6.07000+000	4.435+003	7.69081+000
0.75	4.72000+000	9.414+003	1.61916+001
1.00	3.68000+000	1.290+002	2.24300+001
1.25	2.87000+000	1.996+002	3.47406+001
1.50	2.23000+000	3.289+002	5.63959+001
1.75	1.74000+000	3.400+002	5.92890+001
2.00	1.35000+000	3.562+002	6.07280+001
2.25	1.05000+000	3.125+002	5.38050+001
2.50	8.21000+001	2.777+002	4.88437+001
2.75	6.39000+001	3.032+002	5.23425+001
3.00	4.98000+001	2.278+002	3.95271+001
3.25	3.88000+001	2.272+002	3.93817+001
3.50	3.02000+001	2.242+002	3.87101+001
3.75	2.35000+001	1.620+002	2.79411+001
4.00	1.83000+001	1.651+002	2.85637+001
17.00	4.14000+007	4.863+001	1.61869+001
25.33	1.00000+010	1.729+001	8.98497+000
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP82 UCRR T-C3



Reactor Description

Name: Union Carbide Research Reactor  
 Type: Pool, test Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Tuxedo, New York

Spectrum Facility Description

Core facility C3; unfueled position; steel and water.

Spectrum Code

Code: 2 DB Calculation: BNW 16

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$7.98 \times 10^{12}$	111.
>0.5 MeV	11.5	77.1
>0.1 MeV	16.1	55.0
Thermal, 49°C	9.43	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP82 UCRR T-C3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.646-003	2.39965+000
0.50	6.07000+000	5.070-003	7.39870+000
0.75	4.72000+000	1.132-002	1.63889+001
1.00	3.68000+000	1.653-002	2.41844+001
1.25	2.87000+000	2.505-002	3.66850+001
1.50	2.23000+000	3.566-002	5.14472+001
1.75	1.74000+000	3.341-002	4.90264+001
2.00	1.35000+000	3.472-002	4.98045+001
2.25	1.05000+000	3.256-002	4.71690+001
2.50	8.21000-001	2.972-002	4.39861+001
2.75	6.39000-001	3.332-002	4.83994+001
3.00	4.98000-001	2.559-002	3.73625+001
3.25	3.88000-001	2.306-002	3.36398+001
3.50	3.02000-001	2.469-002	3.58684+001
3.75	2.35000-001	1.775-002	2.57613+001
4.00	1.83000-001	1.764-002	2.56843+001
5.00	6.74000-002	5.196-002	1.89383+001
6.75	1.17000-002	6.229-002	1.29499+001
8.00	3.36000-003	3.783-002	1.10390+001
9.00	1.23000-003	3.265-002	1.18285+001
9.75	5.83000-004	2.150-002	1.04835+001
11.50	1.01000-004	5.259-002	1.09210+001
14.00	8.32000-006	7.287-002	1.06260+001
16.50	6.83000-007	6.779-002	9.87169+000
25.33	1.00000-010	2.328-001	9.59866+000
-----			
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP83 UCRR T-D3



Reactor Description

Name: Union Carbide Research Reactor  
 Type: Pool, research Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Tuxedo, New York

Spectrum Facility Description

Core facility D3; unfueled position; steel and water.

Spectrum Code

Code: 2 DB Calculation: BNW 15

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	8.26 x 10 <sup>-2</sup>	113.
>0.5 MeV	11.9	78.7
>0.1 MeV	16.6	56.3
Thermal, 49°C	9.76	-


\*Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

SP83 UCRR T-D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.650+003	2,54836+000
0.50	6.07000+000	5.080+003	7,85518+000
0.75	4.72000+000	1.108+002	1,69903+001
1.00	3.68000+000	1.384+002	2,14529+001
1.25	2.87000+000	2.383+002	3,69763+001
1.50	2.23000+000	3.468+002	5,30266+001
1.75	1.74000+000	3.178+002	4,94141+001
2.00	1.35000+000	3.291+002	5,00367+001
2.25	1.05000+000	3.047+002	4,67737+001
2.50	8.21000+001	2.786+002	4,36940+001
2.75	6.39000+001	3.160+002	4,86428+001
3.00	4.98000+001	2.435+002	3,76770+001
3.25	3.88000+001	2.171+002	3,35620+001
3.50	3.02000+001	2.341+002	3,60487+001
3.75	2.35000+001	1.688+002	2,59606+001
4.00	1.83000+001	1.672+002	2,57966+001
5.00	6.74000+002	4.970+002	1,91978+001
6.75	1.17000+002	5.945+002	1,30993+001
8.00	3.36000+003	3.599+002	1,11286+001
9.00	1.23000+003	3.140+002	1,20547+001
9.75	5.83000+004	2.054+002	1,06120+001
11.50	1.01000+004	5.020+002	1,10482+001
14.00	8.32000+006	6.950+002	1,07401+001
16.50	6.83000+007	6.463+002	9,97390+000
25.33	1.00000+010	2.708+001	1,18313+001
		----- 1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP84 UCRR T-B3



Reactor Description

Name: Union Carbide Research Reactor  
 Type: Pool, research Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Tuxedo, New York

Spectrum Facility Description

Core lattice facility D3; unfueled position; steel and water.

Spectrum Code

Code: 2 DB Calculation: BNW 15

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	7.52 x 10 <sup>-2</sup>	111.
>0.5 MeV	10.9	76.3
>0.1 MeV	15.2	55.1
Thermal, 49 °C	9.81	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP84 UCRR T-B3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.585-003	2.36705+000
0.50	6.07000+000	4.873-003	7.28733+000
0.75	4.72000+000	1.101-002	1.63221+001
1.00	3.68000+000	1.605-002	2.40585+001
1.25	2.87000+000	2.432-002	3.65039+001
1.50	2.23000+000	3.582-002	5.29618+001
1.75	1.74000+000	3.278-002	4.92848+001
2.00	1.35000+000	3.412-002	5.01613+001
2.25	1.05000+000	3.169-002	4.70434+001
2.50	8.21000-001	2.905-002	4.40447+001
2.75	6.39000-001	3.292-002	4.90107+001
3.00	4.98000-001	2.549-002	3.81480+001
3.25	3.88000-001	2.263-002	3.38196+001
3.50	3.02000-001	2.437-002	3.62780+001
3.75	2.35000-001	1.756-002	2.61210+001
4.00	1.83000-001	1.737-002	2.59073+001
5.00	6.74000-002	5.155-002	1.92525+001
6.75	1.17000-002	6.117-002	1.30327+001
8.00	3.36000-003	3.665-002	1.09595+001
9.00	1.23000-003	3.180-002	1.18059+001
9.75	5.83000-004	2.068-002	1.03327+001
11.50	1.01000-004	5.038-002	1.07221+001
14.00	8.32000-006	6.964-002	1.04066+001
16.50	6.83000-007	6.460-002	9.64091+000
25.33	1.00000-010	2.519-001	1.06437+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP85 UCRR T-A4



Reactor Description

Name: Union Carbide Research Reactor  
 Type: Pool, research Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Tuxedo, New York

Spectrum Facility Description

Core lattice facility A4; unfueled position; steel and water.

Spectrum Code

Code: 2 DB Calculation: BNW 15

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	8.41 x 10 <sup>-2</sup>	111.
>0.5 MeV	12.2	76.7
>0.1 MeV	17.0	54.9
Thermal, 49 °C	11.6	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP85 UCRR T-A4

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.545-003	2.33916+000
0.50	6.07000+000	4.728-003	7.16434+000
0.75	4.72000+000	1.080-002	1.62352+001
1.00	3.68000+000	1.599-002	2.42828+001
1.25	2.87000+000	2.433-002	3.69942+001
1.50	2.23000+000	3.505-002	5.25126+001
1.75	1.74000+000	3.242-002	4.93897+001
2.00	1.35000+000	3.368-002	5.01736+001
2.25	1.05000+000	3.122-002	4.69538+001
2.50	8.21000-001	2.856-002	4.38774+001
2.75	6.39000-001	3.225-002	4.86477+001
3.00	4.98000-001	2.486-002	3.76907+001
3.25	3.88000-001	2.218-002	3.35966+001
3.50	3.02000-001	2.389-002	3.60416+001
3.75	2.35000-001	1.723-002	2.59664+001
4.00	1.83000-001	1.707-002	2.58028+001
5.00	6.74000-002	5.048-002	1.91040+001
6.75	1.17000-002	6.007-002	1.29670+001
8.00	3.36000-003	3.618-002	1.09623+001
9.00	1.23000-003	3.148-002	1.18407+001
9.75	5.83000-004	2.053-002	1.03934+001
11.50	1.01000-004	5.017-002	1.08186+001
14.00	8.32000-006	6.974-002	1.05607+001
16.50	6.83000-007	6.508-002	9.84107+000
25.33	1.00000-010	2.605-001	1.11512+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP86 UCRR T-F5



Reactor Description

Name: Union Carbide Research Reactor  
 Type: Pool, research Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Tuxedo, New York

Spectrum Facility Description

Core lattice facility F5; unfueled position; steel and water.

Spectrum Code

Code: 2 DB Calculation: BNW<sup>15</sup>

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	9.91 × 10 <sup>-2</sup>	114.
>0.5 MeV	14.2	79.3
>0.1 MeV	19.9	56.8
Thermal, 49 °C	14.2	-


\*Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP86 UCRR T-F5

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.679-003	2.51558+000
0.50	6.07000+000	5.164-003	7.74697+000
0.75	4.72000+000	1.124-002	1.67190+001
1.00	3.68000+000	1.584-002	2.38216+001
1.25	2.87000+000	2.367-002	3.56291+001
1.50	2.23000+000	3.445-002	5.10938+001
1.75	1.74000+000	3.147-002	4.74731+001
2.00	1.35000+000	3.263-002	4.81182+001
2.25	1.05000+000	3.022-002	4.50019+001
2.50	8.21000-001	2.769-002	4.21189+001
2.75	6.39000-001	3.132-002	4.67664+001
3.00	4.98000-001	2.423-002	3.63733+001
3.25	3.88000-001	2.158-002	3.23623+001
3.50	3.02000-001	2.323-002	3.46929+001
3.75	2.35000-001	1.676-002	2.50135+001
4.00	1.83000-001	1.660-002	2.48395+001
5.00	6.74000-002	4.934-002	1.84879+001
6.75	1.17000-002	5.924-002	1.26609+001
8.00	3.36000-003	3.594-002	1.07810+001
9.00	1.23000-003	3.148-002	1.17235+001
9.75	5.83000-004	2.060-002	1.03283+001
11.50	1.01000-004	5.048-002	1.07762+001
14.00	8.32000-006	7.040-002	1.05546+001
16.50	6.83000-007	6.577-002	9.84624+000
25.33	1.00000-010	2.690-001	1.14025+001
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP60 ETR P-12



Reactor Description

Name: Engineering Test Reactor  
 Type: Test, tank Power Level: 175 MWT  
 Coolant: Light water Moderator: Light water  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Reflector position P-12; steel and water

Spectrum Code

Code: DTF-IV Calculation: BNW 1<sup>8</sup>

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	88.7
>0.5 MeV	-	53.2
>0.1 MeV	-	35.2
Thermal, 20°C	-	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

SP60 ETR P-12

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	6.383-004	2.47108+000
0.50	6.07000+000	2.334-003	9.04388+000
0.75	4.72000+000	4.731-003	1.81838+001
1.00	3.68000+000	6.495-003	2.52297+001
1.25	2.87000+000	7.439-003	2.89319+001
1.50	2.23000+000	1.129-002	4.32769+001
1.75	1.74000+000	2.027-002	7.89811+001
2.00	1.35000+000	2.045-002	7.79105+001
2.25	1.05000+000	1.767-002	6.79607+001
2.50	8.21000-001	1.663-002	6.53591+001
2.75	6.39000-001	2.216-002	8.54979+001
3.00	4.98000-001	2.331-002	9.04097+001
3.25	3.88000-001	1.691-002	6.54958+001
3.50	3.02000-001	1.731-002	6.67696+001
3.75	2.35000-001	1.253-002	4.82822+001
4.00	1.83000-001	1.246-002	4.81795+001
5.00	6.74000-002	4.097-002	3.96537+001
6.75	1.17000-002	5.318-002	2.93610+001
8.00	3.36000-003	3.516-002	2.72460+001
9.00	1.23000-003	3.069-002	2.95226+001
9.75	5.83000-004	2.045-002	2.64875+001
11.50	1.01000-004	5.185-002	2.85970+001
14.00	8.32000-006	7.667-002	2.97677+001
16.50	6.83000-007	8.214-002	3.17661+001
25.33	1.00000-010	3.961-001	4.33694+001
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP61 ATR 1-D NORTH LOOP



Reactor Description

Name: Advanced Test Reactor  
 Type: Test, tank Power Level: 250 MWT  
 Coolant: Light water Moderator: Light water  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Mid plane of 1-D North loop.

Spectrum Code

Code: DTF-IV Calculation: BNW 16

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.50 x 10 <sup>-4</sup>	103.6
>0.5 MeV	2.24	69.4
>0.1 MeV	3.23	48.1
Thermal, 260 °C	3.88	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP61 ATR 1-D NORTH LOOP

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.113-003	2.25529+000
0.50	6.07000+000	3.456-003	7.00663+000
0.75	4.72000+000	7.862-003	1.58089+001
1.00	3.68000+000	1.190-002	2.41688+001
1.25	2.87000+000	1.846-002	3.75536+001
1.50	2.23000+000	2.694-002	5.40116+001
1.75	1.74000+000	2.625-002	5.35125+001
2.00	1.35000+000	2.774-002	5.52923+001
2.25	1.05000+000	2.655-002	5.34380+001
2.50	8.21000-001	2.468-002	5.07430+001
2.75	6.39000-001	2.837-002	5.72612+001
3.00	4.98000-001	2.223-002	4.51062+001
3.25	3.88000-001	1.996-002	4.04518+001
3.50	3.02000-001	2.171-002	4.38317+001
3.75	2.35000-001	1.565-002	3.15585+001
4.00	1.83000-001	1.567-002	3.16925+001
5.00	6.74000-002	4.663-002	2.36130+001
6.75	1.17000-002	5.628-002	1.82589+001
8.00	3.36000-003	3.444-002	1.39633+001
9.00	1.23000-003	2.749-002	1.38361+001
9.75	5.83000-004	1.809-002	1.22593+001
11.50	1.01000-004	4.226-002	1.21951+001
14.00	8.32000-006	4.982-002	1.00941+001
16.50	6.83000-007	3.700-002	7.48704+000
25.33	1.00000-010	3.894-001	2.23120+001
-----			
1.000+000			


ONE LETHARGY INTERVAL = 0.25U



**LIGHT WATER MODERATED REACTORS**

**POWER REACTORS**

SP23 BIG ROCK POINT -1 INCH



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power, BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Spatial location: 1-in. closer to fuel than accelerated  
surveillance location: water.

Spectrum Code

Code: Program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	147.6
>0.5 MeV	(13.83†)	119.8
>0.1 MeV	-	81.1
Thermal, 20 °C	-	-

\*Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


†In series of spectra 23 through 32

## SP23 BIG ROCK POINT -1 INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	6.489-004	3.31755+000
0.50	6.07000+000	2.089-003	1.06918+001
0.75	4.72000+000	3.795-003	1.92644+001
1.00	3.68000+000	4.247-003	2.17888+001
1.25	2.87000+000	5.496-003	2.82303+001
1.50	2.23000+000	8.813-003	4.45996+001
1.75	1.74000+000	6.418-003	3.30310+001
2.00	1.35000+000	6.196-003	3.11729+001
2.25	1.05000+000	5.061-003	2.57156+001
2.50	8.21000-001	4.314-003	2.23915+001
2.75	6.39000-001	5.308-003	2.70453+001
3.00	4.98000-001	3.913-003	2.00391+001
3.25	3.88000-001	3.483-003	1.78193+001
3.50	3.02000-001	3.923-003	1.99908+001
3.75	2.35000-001	2.869-003	1.46038+001
4.00	1.83000-001	3.045-003	1.55456+001
6.75	1.17000-002	2.046-002	9.50154+000
9.00	1.23000-003	1.380-002	7.82455+000
11.50	1.01000-004	1.602-002	8.18335+000
16.50	6.83000-007	3.596-002	9.19047+000
25.33	1.00000-010	8.441-001	1.22060+002
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP24 BIG ROCK POINT ACCEL SURV



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Accelerated-irradiation rate surveillance location; position 124; steel and water.

Spectrum Code

Code: program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$1.37 \times 10^{12}$	152.6
>0.5 MeV	1.75 (9.924+)	119.4
>0.1 MeV	2.28	91.8
Thermal, 302°C	15.05	

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


+In series of spectra 23 through 32

## SP24 BIG ROCK POINT ACCEL SUHV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.115-003	3.45167+000
0.50	6.07000+000	3.603-003	1.11691+001
0.75	4.72000+000	6.390-003	1.96446+001
1.00	3.68000+000	6.910-003	2.14700+001
1.25	2.87000+000	8.762-003	2.72567+001
1.50	2.23000+000	1.408-002	4.31516+001
1.75	1.74000+000	1.008-002	3.13472+001
2.00	1.35000+000	9.603-003	2.92623+001
2.25	1.05000+000	7.780-003	2.39398+001
2.50	8.21000-001	6.593-003	2.07239+001
2.75	6.39000-001	8.045-003	2.48240+001
3.00	4.98000-001	5.909-003	1.83312+001
3.25	3.88000-001	5.275-003	1.63456+001
3.50	3.02000-001	5.915-003	1.82545+001
3.75	2.35000-001	4.316-003	1.33060+001
4.00	1.83000-001	4.573-003	1.41393+001
6.75	1.17000-002	3.054-002	8.58741+000
9.00	1.23000-003	2.047-002	7.02896+000
11.50	1.01000-004	2.365-002	7.31666+000
16.50	6.83000-007	5.277-002	8.16788+000
25.33	1.00000-010	7.636-001	6.68885+001
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP25 BIG ROCK POINT +1 INCH



Reactor DescriptionName: Big Rock Point ReactorType: Power BWR Power Level: 240 MWTCoolant: Light water Moderator: Light waterLocation: Charlevoix, MichiganSpectrum Facility DescriptionOne inch farther away from accelerated surveillance; water.Spectrum CodeCode: Program S Calculation: BNW 17,18

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	157.5
>0.5 MeV	(7.233†)	124.7
>0.1 MeV	-	88.1
Thermal, 20 °C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 23 through 32

## SP25 BIG ROCK POINT +1 INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	7.632-004	3.58913+000
0.50	6.07000+000	2.473-003	1.16441+001
0.75	4.72000+000	4.283-003	1.99966+001
1.00	3.68000+000	4.506-003	2.12616+001
1.25	2.87000+000	5.557-003	2.62567+001
1.50	2.23000+000	8.924-003	4.15451+001
1.75	1.74000+000	6.305-003	2.98470+001
2.00	1.35000+000	5.933-003	2.74595+001
2.25	1.05000+000	4.777-003	2.23244+001
2.50	8.21000-001	4.031-003	1.92431+001
2.75	6.39000-001	4.882-003	2.28776+001
3.00	4.98000-001	3.576-003	1.68484+001
3.25	3.88000-001	3.201-003	1.50649+001
3.50	3.02000-001	3.576-003	1.67596+001
3.75	2.35000-001	2.604-003	1.21929+001
4.00	1.83000-001	2.755-003	1.29387+001
6.75	1.17000-002	1.830-002	7.81714+000
9.00	1.23000-003	1.221-002	6.36542+000
11.50	1.01000-004	1.400-002	6.58031+000
16.50	6.83000-007	3.106-002	7.30087+000
25.63	1.00000-010	8.563-001	1.13913+002
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

# SP26 BIG ROCK POINT V WALL SURV



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Vessel wall surveillance location: steel and water

Spectrum Code

Code: program S Calculation: BNW 17,18

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	6.95 x 10 <sup>10</sup>	170.9
>0.5 MeV	9.30 (1.017†)	127.7
>0.1 MeV	16.5	72.9
Thermal, 20°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)



† In series of spectra 23 through 32

## SP26 BIG ROCK POINT V WALL SURV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.758-003	4.36554+000
0.50	6.07000+000	5.725-003	1.42308+001
0.75	4.72000+000	8.732-003	2.15265+001
1.00	3.68000+000	7.890-003	1.96572+001
1.25	2.87000+000	8.903-003	2.22078+001
1.50	2.23000+000	1.323-002	3.25156+001
1.75	1.74000+000	1.031-002	2.57616+001
2.00	1.35000+000	1.044-002	2.55065+001
2.25	1.05000+000	9.483-003	2.34001+001
2.50	8.21000-001	8.807-003	2.21994+001
2.75	6.39000-001	1.060-002	2.62328+001
3.00	4.98000-001	8.522-003	2.11966+001
3.25	3.88000-001	6.953-003	1.72739+001
3.50	3.02000-001	7.526-003	1.86255+001
3.75	2.35000-001	5.435-003	1.34372+001
4.00	1.83000-001	5.498-003	1.36334+001
6.75	1.17000-002	3.706-002	8.35682+000
9.00	1.23000-003	2.402-002	6.61244+000
11.50	1.01000-004	2.579-002	6.39744+000
16.50	6.83000-007	5.070-002	6.29317+000
25.33	1.00000-010	7.326-001	5.14563+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP27 BIG ROCK POINT V WALL CLADDING



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel  
cladding; steel.

Spectrum Code

Code: program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	157.6
>0.5 MeV	(0.8963†)	109.5
>0.1 MeV	-	74.5
Thermal, 20 °C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n, p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n, \gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

† In series of spectra 23 through 32

## SP27 BIG ROCK POINT V WALL CLADDING

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	2.091-003	4.27134+000
0.50	6.07000+000	6.868-003	1.40427+001
0.75	4.72000+000	1.055-002	2.14045+001
1.00	3.68000+000	9.714-003	1.99092+001
1.25	2.87000+000	1.102-002	2.26101+001
1.50	2.23000+000	1.610-002	3.25532+001
1.75	1.74000+000	1.365-002	2.80679+001
2.00	1.35000+000	1.449-002	2.91323+001
2.25	1.05000+000	1.461-002	2.96558+001
2.50	8.21000-001	1.454-002	3.01567+001
2.75	6.39000-001	1.753-002	3.56857+001
3.00	4.98000-001	1.570-002	3.21291+001
3.25	3.88000-001	1.111-002	2.27087+001
3.50	3.02000-001	1.101-002	2.24157+001
3.75	2.35000-001	7.927-003	1.61211+001
4.00	1.83000-001	7.184-003	1.46335+001
6.75	1.17000-002	5.216-002	9.67681+000
9.00	1.23000-003	3.108-002	7.03755+000
11.50	1.01000-004	2.976-002	6.07305+000
16.50	6.83000-007	6.188-002	6.31760+000
25.33	1.00000-010	6.410-001	3.70359+001
-----			
1,000+000			

ONE LETHARGY INTERVAL = 0.25U

SP28 BIG ROCK POINT 1 INCH IN VESSEL

ACTIVE REACTOR CORE

THERMAL CONTROL CAPSULE POSITION

I21

ALL POSITIONS ARE SURVEILLANCE CAPSULES

I22

I24

I27  
I19

6<sub>n</sub>0

5<sub>n</sub>5

5<sub>n</sub>0

4<sub>n</sub>5

4<sub>n</sub>0

3<sub>n</sub>5

3<sub>n</sub>0

2<sub>n</sub>5

2<sub>n</sub>0


1<sub>n</sub>5

1<sub>n</sub>0


0<sub>n</sub>5

0<sub>n</sub>0

NEUTRON FLUX  $\Phi$  (U) DU  
(PERCENT)



LETHARGY (U)



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Location one inch into vessel wall; steel

Spectrum Code

Code: program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	143.5
>0.5 MeV	(0.7645†)	92.3
>0.1 MeV	-	61.3
Thermal, 20°C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n, p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n, \gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

† In series of spectra 23 through 32

## SP28 BIG ROCK POINT 1 INCH IN VESSEL

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	2.039-003	4,13603+000
0.50	6.07000+000	6.695-003	1,35941+001
0.75	4.72000+000	1.047-002	2,10828+001
1.00	3.68000+000	9.956-003	2,02631+001
1.25	2.87000+000	1.155-002	2,35322+001
1.50	2.23000+000	1.665-002	3,34279+001
1.75	1.74000+000	1.534-002	3,13092+001
2.00	1.35000+000	1.729-002	3,45075+001
2.25	1.05000+000	1.888-002	3,80595+001
2.50	8.21000-001	1.989-002	4,09559+001
2.75	6.39000-001	2.410-002	4,87085+001
3.00	4.98000-001	2.289-002	4,65201+001
3.25	3.88000-001	1.533-002	3,11080+001
3.50	3.02400-001	1.445-002	2,92142+001
3.75	2.35000-001	1.033-002	2,08635+001
4.00	1.83000-001	8.442-003	1,70988+001
4.75	1.17000-002	6.610-002	1,21765+001
9.00	1.23000-003	3.707-002	8,33609+000
11.50	1.01000-004	2.982-002	6,04418+000
16.50	6.83000-007	6.310-002	6,39767+000
25.33	1.00000-010	5.796-001	3,32555+001
-----			
1.000+000			


ONE LETHARGY INTERVAL = 0.25U

SP29 BIG ROCK POINT 2 INCH IN VESSEL

ACTIVE REACTOR CORE

THERMAL CONTROL CAPSULE POSITION

ALL POSITIONS ARE SURVEILLANCE CAPSULES



LETHARGY (U)

NEUTRON FLUX  $\Phi$  (U) DU  
(PERCENT)

25

20

15

10

5

0

$10^{-10}$

$6.83 \times 10^{-7}$

$1.23 \times 10^{-3}$

$0.18$

$1.35$

$10$

ENERGY (MeV)

Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Location two inches into vessel wall; steel.

Spectrum Code

Code: Program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	130.8
>0.5 MeV	(0.6111†)	77.8
>0.1 MeV	-	49.9
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 23 through 32

## SP29 BIG ROCK POINT 2 INCH IN VESSEL

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.853-003	3.99691+000
0.50	6.07000+000	6.092-003	1.31542+001
0.75	4.72000+000	9.661-003	2.06892+001
1.00	3.68000+000	9.492-003	2.05441+001
1.25	2.87000+000	1.131-002	2.44990+001
1.50	2.23000+000	1.624-002	3.46837+001
1.75	1.74000+000	1.593-002	3.45798+001
2.00	1.35000+000	1.896-002	4.02376+001
2.25	1.05000+000	2.204-002	4.72523+001
2.50	8.21000-001	2.442-002	5.34758+001
2.75	6.39000-001	2.991-002	6.42982+001
3.00	4.98000-001	2.981-002	6.44157+001
3.25	3.88000-001	1.972-002	4.25611+001
3.50	3.02000-001	1.816-002	3.90399+001
3.75	2.35000-001	1.290-002	2.77013+001
4.00	1.83000-001	9.992-003	2.15227+001
6.75	1.17000-002	8.068-002	1.58058+001
9.00	1.23000-003	4.345-002	1.03900+001
11.50	1.01000-004	3.053-002	6.58056+000
16.50	6.83000-007	6.411-002	6.91224+000
25.33	1.00000-010	5.247-001	3.20176+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP30 BIG ROCK POINT 3 INCH IN VESSEL



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Location three inches into vessel wall; steel.

Spectrum Code

Code: Program S Calculation: BNW 17,18

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	120.2
>0.5 MeV	(0.4729†)	66.7
>0.1 MeV	-	41.1
Thermal, 20°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 23 through 32

## SP30 BIG ROCK POINT 3 INCH IN VESSEL

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.652-003	3.86167+000
0.50	6.07000+000	5.457-003	1.27668+001
0.75	4.72000+000	8.765-003	2.03389+001
1.00	3.68000+000	8.851-003	2.07575+001
1.25	2.87000+000	1.080-002	2.53478+001
1.50	2.23000+000	1.553-002	3.59318+001
1.75	1.74000+000	1.598-002	3.75979+001
2.00	1.35000+000	1.992-002	4.58168+001
2.25	1.05000+000	2.434-002	5.65382+001
2.50	8.21000-001	2.818-002	6.68645+001
2.75	6.39000-001	3.498-002	8.14650+001
3.00	4.98000-001	3.615-002	8.46484+001
3.25	3.88000-001	2.396-002	5.60348+001
3.50	3.02000-001	2.194-002	5.11130+001
3.75	2.35000-001	1.556-002	3.62185+001
4.00	1.83000-001	1.169-002	2.72910+001
6.75	1.17000-002	9.548-002	2.02670+001
9.00	1.23000-003	5.000-002	1.29574+001
11.50	1.01000-004	3.176-002	7.41645+000
16.50	6.83000-007	6.497-002	7.59037+000
25.33	1.00000-010	4.740-001	3.13365+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP31 BIG ROCK POINT 4 INCH IN VESSEL



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Location four inches into vessel wall; steel.

Spectrum Code

Code: Program S Calculation: BNW 17, 18

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	111.8
>0.5 MeV	(0.3525†)	58.5
>0.1 MeV	-	34.8
Thermal, 20°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 23 through 32

## SP31 BIG ROCK POINT 4 INCH IN VESSEL

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79400+000	1.452-003	3.73855+000
0.50	6.07000+000	4.824-003	1.24336+001
0.75	4.72000+000	7.837-003	2.00317+001
1.00	3.68000+000	8.088-003	2.08937+001
1.25	2.87000+000	1.008-002	2.60672+001
1.50	2.23000+000	1.459-002	3.71929+001
1.75	1.74000+000	1.553-002	4.02528+001
2.00	1.35000+000	2.011-002	5.09602+001
2.25	1.05000+000	2.548-002	6.51776+001
2.50	8.21000-001	3.060-002	7.99798+001
2.75	6.39000-001	3.847-002	9.86981+001
3.00	4.98000-001	4.085-002	1.05366+002
3.25	3.88000-001	2.712-002	6.98614+001
3.50	3.02000-001	2.518-002	6.46209+001
3.75	2.35000-001	1.797-002	4.60695+001
4.00	1.83000-001	1.332-002	3.42487+001
6.75	1.17000-002	1.083-001	2.53304+001
9.00	1.23000-003	5.588-002	1.59501+001
11.50	1.01000-004	3.391-002	8.72317+000
16.50	6.83000-007	6.596-002	8.46781+000
25.33	1.00000-010	4.344-001	3.16348+001
-----			
1,000+000			

ONE LETHARGY INTERVAL = 0.25U

SP32 BIG ROCK POINT 5 INCH IN VESSEL



Reactor Description

Name: Big Rock Point Reactor  
 Type: Power BWR Power Level: 240 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Charlevoix, Michigan

Spectrum Facility Description

Location five inches into vessel wall: steel.

Spectrum Code

Code: program S Calculation: BNW 17,18

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	105.6
>0.5 MeV	(0.2416±)	53.0
>0.1 MeV	-	30.3
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

+In series of spectra 23 through 32

## SPS2 BIG ROCK POINT 5 INCH IN VESSEL

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.245-003	3,63297+000
0.50	6.07000+000	4.155-003	1,21390+001
0./5	4.72000+000	6.801-003	1,97069+001
1.00	3.68000+000	7.123-003	2,08598+001
1.25	2.87000+000	9.099-003	2,66783+001
1.50	2.23000+000	1.350-002	3,89994+001
1./5	1.74000+000	1.441-002	4,23328+001
2.00	1.35000+000	1.928-002	5,53900+001
2.25	1.05000+000	2.476-002	7,18206+001
2.50	8.21000-001	3.068-002	9,09009+001
2./5	6.39000-001	3.894-002	1,13253+002
3.00	4.98000-001	4.220-002	1,23377+002
3.25	3.88000-001	2.767-002	8,08207+001
3.50	3.02000-001	2.722-002	7,91715+001
3.75	2.35000-001	1.969-002	5,72102+001
4.00	1.83000-001	1.473-002	4,29344+001
6./5	1.17000-002	1.162-001	3,08013+001
9.00	1.23000-003	6.029-002	1,95083+001
11.50	1.01000-004	3.812-002	1,11158+001
16.50	6.83000-007	6.723-002	9,80739+000
25.33	1.00000-010	4.167-001	3,43981+001
-----			
1,000+000			



ONE LETHARGY INTERVAL = 0.25U

SP14 YANKEE INNER MONITOR (ACCEL)

ACTIVE REACTOR CORE

ACCELERATED POSITION CAPSULES

VESSEL WALL CAPSULES



Reactor Description

Name: Yankee Atomic Power Plant  
 Type: Power PWR Power Level: 600 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Rowe, Massachusetts

Spectrum Facility Description

Accelerated-irradiation rate surveillance location; steel and water.

Spectrum Code

Code: Program S Calculation: BNW 19,20

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	2.26 x 10 <sup>3</sup>	154.2
>0.5 MeV	2.91 (42.7†)	119.7
>0.1 MeV	3.87	90.1
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

† In series of spectra 14, 15, 33

## SP14 YANKEE INNER MONITOR (ACCEL)

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION FOR GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.437+003	3.50759+000
0.50	6.07000+000	4.538+003	1.10906+001
0.75	4.72000+000	8.067+003	1.95518+001
1.00	3.68000+000	8.588+003	2.10368+001
1.25	2.87000+000	1.148+002	2.81538+001
1.50	2.23000+000	1.726+002	4.31585+001
1.75	1.74000+000	1.298+002	3.18966+001
2.00	1.35000+000	1.214+002	2.91686+001
2.25	1.05000+000	8.418+003	2.04236+001
2.50	8.21000+001	8.598+003	2.13078+001
2.75	6.39000+001	1.050+002	2.55492+001
3.00	4.98000+001	7.830+003	1.91496+001
3.25	3.88000+001	6.934+003	1.69390+001
3.50	3.02000+001	7.774+003	1.89159+001
3.75	2.35000+001	5.682+003	1.38099+001
4.00	1.83000+001	5.978+003	1.45738+001
5.00	6.74000+002	1.751+002	1.06913+001
9.00	1.23000+003	5.190+002	7.90390+000
13.00	2.26000+005	5.707+002	8.70526+000
17.00	4.14000+007	6.145+002	9.36732+000
25.33	1.00000+010	6.733+001	4.92876+001
-----			
1.000+000			


ONE LETHARGY INTERVAL = 0.25U

## SP15 YANKEE OUTER MONITOR (V WALL)


ACTIVE REACTOR CORE

ACCELERATED POSITION CAPSULES

VESSEL WALL CAPSULES



NEUTRON FLUX  $\Phi$  (U) DU  
(PERCENT)



Reactor Description

Name: Yankee Atomic Power Plant  
 Type: Power PWR Power Level: 600 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Rowe, Massachusetts

Spectrum Facility Description

Vessel-wall-irradiation surveillance location: steel and water.

Spectrum Code

Code: Program S Calculation: BNW 19,20

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	1.45 × 10 <sup>11</sup>	172.5
>0.5 Mev	1.94 (0.542+)	128.9
>0.1 Mev	2.72	92.1
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

+In series of spectra 14, 15, 33



## SP15 YANKEE OUTER MONITOR (V WALL)

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000×000	2.885×003	4.76850×000
0.50	6.07000×000	9.059×003	1.49869×001
0.75	4.72000×000	1.289×002	2.11458×001
1.00	3.68000×000	1.145×002	1.89861×001
1.25	2.87000×000	1.327×002	2.20295×001
1.50	2.23000×000	1.907×002	3.11984×001
1.75	1.74000×000	1.531×002	2.54704×001
2.00	1.35000×000	1.518×002	2.46901×001
2.25	1.05000×000	1.350×002	2.21716×001
2.50	8.21000×001	1.287×002	2.15856×001
2.75	6.39000×001	1.585×002	2.61076×001
3.00	4.98000×001	1.280×002	2.11988×001
3.25	3.88000×001	1.129×002	1.86738×001
3.50	3.02000×001	1.297×002	2.13679×001
3.75	2.35000×001	9.567×003	1.57426×001
4.00	1.83000×001	1.038×002	1.71230×001
5.00	6.74000×002	2.914×002	1.20413×001
9.00	1.23000×003	8.250×002	8.50557×000
13.00	2.26000×005	8.266×002	8.53584×000
17.00	4.14000×007	7.707×002	7.95299×000
25.33	1.00000×010	5.303×001	2.62801×001
		----- 1.000×000	

ONE LETHARGY INTERVAL = 0.25U

# SP33 YANKEE V WALL CLADDING

ACTIVE REACTOR CORE  
 ACCELERATED POSITION CAPSULES  
 VESSEL WALL CAPSULES



Reactor Description

Name: Yankee Atomic Power Plant  
 Type: Power PWR Power Level: 600 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Rowe, Massachusetts

Spectrum Facility Description

Interface of water and stainless steel cladding; steel and water.

Spectrum Code

Code: Program S Calculation: BNW 19, 20

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	168.3
>0.5 MeV	(0.418†)	125.6
>0.1 MeV	-	74.4
Thermal, 20 °C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 14, 15, 33

## SP33 YANKEE V WALL CLADDING

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	3.933-003	4.75728+000
0.50	6.07000+000	1.252-002	1.51634+001
0.75	4.72000+000	1.773-002	2.12943+001
1.00	3.68000+000	1.565-002	1.89912+001
1.25	2.87000+000	1.783-002	2.16627+001
1.50	2.23000+000	2.540-002	3.04116+001
1.75	1.74000+000	2.134-002	2.59847+001
2.00	1.35000+000	2.086-002	2.48313+001
2.25	1.05000+000	1.925-002	2.31323+001
2.50	8.21000-001	1.866-002	2.29150+001
2.75	6.39000-001	2.269-002	2.73412+001
3.00	4.98000-001	2.024-002	2.49248+001
3.25	3.88000-001	1.672-002	2.02329+001
3.50	3.02000-001	1.777-002	2.14189+001
3.75	2.35000-001	1.300-002	1.56554+001
4.00	1.83000-001	1.238-002	1.49527+001
5.00	6.74000-002	3.894-002	1.17760+001
9.00	1.23000-003	1.082-001	8.15979+000
13.00	2.26000-005	1.095-001	8.27732+000
17.00	4.14000-007	9.933-002	7.50149+000
25.33	1.00000-010	3.681-001	1.33487+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP45U SAN ONOFRE ACCEL SURV



Reactor Description

Name: San Onofre Nuclear Generating Station, Unit 1  
 Type: Power PWR Power Level: 1347 MWt  
 Coolant: Light water Moderator: Light water  
 Location: San Onofre, California

Spectrum Facility Description

Accelerated irradiation rate surveillance location; steel and water; unfolded from activation foil data.

Spectrum Code

Code: SAND-II Calculation: NRL 21

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$2.07 \times 10^{11}$	98.9
>0.5 MeV	$3.58 \times 10^{11}$	57.4
>0.1 MeV	$5.61 \times 10^{11}$	36.6
Thermal, 288°C	$3.83 \times 10^{11}$	-



\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP45U SAN ONOFRE ACCEL SURV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	9.799+004	3,34818+000
0.50	6.07000+000	2.893+003	9,89474+000
0.75	4.72000+000	4.706+003	1,59660+001
1.00	3.68000+000	5.025+003	1,72299+001
1.25	2.87000+000	9.235+003	3,16986+001
1.50	2.23000+000	1.900+002	6,42456+001
1.75	1.74000+000	1.661+002	5,71328+001
2.00	1.35000+000	1.846+002	6,20802+001
2.25	1.05000+000	1.608+002	5,46124+001
2.50	8.21000+001	1.937+002	6,71781+001
2.75	6.39000+001	2.948+002	1,00372+002
3.00	4.98000+001	1.992+002	6,81903+001
3.25	3.88000+001	2.309+002	7,89473+001
3.50	3.02000+001	2.412+002	8,21384+001
3.75	2.35000+001	1.519+002	5,16800+001
4.00	1.83000+001	1.716+002	5,85353+001
5.00	6.74000+002	6.128+002	5,23511+001
9.00	1.23000+003	1.911+001	4,07224+001
13.00	2.26000+005	1.458+001	3,11341+001
17.00	4.14000+007	1.887+001	4,02510+001
25.33	1.00000+010	1.719+001	1,76084+001
		----- 1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP38 SM-1A V WALL CLADDING PROG S



Reactor Description

Name: SM-1A  
 Type: Power PWR Power Level: 20.2 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Fort Greely, Alaska (decommissioned)

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel  
cladding; steel

Spectrum Code

Code: Program S Calculation: BNW 19, 22

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.85 x 10 <sup>-1</sup>	137.4
>0.5 MeV	2.88	88.3
>0.1 MeV	4.64	54.8
Thermal, 20°C	-	-



\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP38 SM-1A V WALL CLADDING PROG S

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.955-003	4.11423+000
0.50	6.07000+000	6.046-003	1.27354+001
0.75	4.72000+000	9.480-003	1.98055+001
1.00	3.68000+000	9.685-003	2.04491+001
1.25	2.87000+000	1.208-002	2.55389+001
1.50	2.23000+000	1.822-002	3.79540+001
1.75	1.74000+000	1.688-002	3.57531+001
2.00	1.35000+000	1.738-002	3.59807+001
2.25	1.05000+000	1.812-002	3.78852+001
2.50	8.21000-001	1.884-002	4.02511+001
2.75	6.39000-001	2.585-002	5.41962+001
3.00	4.98000-001	2.224-002	4.68766+001
3.25	3.88000-001	2.102-002	4.42665+001
3.50	3.02000-001	2.168-002	4.54726+001
3.75	2.35000-001	1.683-002	3.52594+001
4.00	1.83000-001	1.786-002	3.75220+001
5.00	6.74000-002	5.109-002	2.68830+001
9.00	1.23000-003	1.339-001	1.75721+001
13.00	2.26000-005	1.937-001	2.54745+001
17.00	4.14000-007	2.186-001	2.87227+001
25.33	1.00000-010	1.485-001	9.37188+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP81 SM-1A ABOVE CORE SURV PROG S



Reactor Description

Name: SM-1A  
 Type: Power PWR Power Level: 20.2 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Fort Greely, Alaska (decommissioned)

Spectrum Facility Description

Surveillance location above fuel core; steel and water

Spectrum Code

Code: program S Calculation: BNW 19,22

Lower Energy Limit	Neutron Flux* $n/cm^2 \cdot sec^{-1}$	Spectrum-Averaged Cross-Section $\sigma, mb$
>1 MeV	$6.96 \times 10^0$	168
>0.5 MeV	8.10	144
>0.1 MeV	9.03	129.5
Thermal, 20 °C	-	-



\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)  
 Compare with fluxes, spectrum 59

## SP81 SM-1A ABOVE CORE SURV PROG S

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	6.07 00+000	3.246-002	3.22252+000
0.75	3.68000+000	7.553-002	7.48000+000
1.25	2.23000+000	1.259-001	1.24529+001
2.00	1.05000+000	1.357-001	8.92701+000
2.75	4.98000-001	6.264-002	4.16147+000
3.75	1.83000-001	4.025-002	1.99243+000
4.75	6.74000-002	1.453-002	7.20848-001
8.75	1.23000-003	2.644-002	3.27227-001
13.75	8.32000-006	4.263-002	4.22815-001
16.75	4.14000-007	1.223-002	2.02000-001
25.08	1.00000-010	4.318-001	2.56915+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP58 SM-1A V WALL CLADDING P1MG



Reactor Description

Name: SM-1A  
 Type: Power PWR Power Level: 20.2 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Fort Greely, Alaska, (decommissioned)

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel  
cladding.

Spectrum Code

Code: P1MG Calculation: Westinghouse 23, 24

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	85.9
>0.5 MeV	-	48.1
>0.1 MeV	-	28.1
Thermal, 20 °C	-	-



\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP58 SM-1A V WALL CLADDING P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.161-003	3.14130+000
0.50	6.07000+000	3.120-003	8.44825+000
0.75	4.72000+000	7.087-003	1.90306+001
1.00	3.68000+000	7.692-003	2.08755+001
1.25	2.87000+000	1.066-002	2.89533+001
1.50	2.23000+000	1.856-002	4.96779+001
1.75	1.74000+000	3.329-002	9.06370+001
2.00	1.35000+000	2.897-002	7.71217+001
2.25	1.05000+000	2.340-002	6.28894+001
2.50	8.21000-001	3.048-002	8.36734+001
2.75	6.39000-001	3.844-002	1.03620+002
3.00	4.98000-001	3.898-002	1.05628+002
3.25	3.88000-001	3.693-002	9.99522+001
3.50	3.02000-001	3.468-002	9.34890+001
3.75	2.35000-001	2.683-002	7.22509+001
4.00	1.83000-001	2.529-002	6.82935+001
5.00	6.74000-002	8.366-002	5.65787+001
9.00	1.23000-003	2.042-001	3.44485+001
13.00	2.26000-005	1.757-001	2.96864+001
16.59	6.25000-007	1.152-001	2.16976+001
25.33	1.00000-010	5.569-002	4.30407+000
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP59 SM-1A ABOVE CORE SURV P1MG



Reactor Description

Name: SM-1A  
 Type: Power PWR Power Level: 20.2 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Fort Greely, Alaska (decommissioned)

Spectrum Facility Description

Surveillance location above fuel core; steel and water.

Spectrum Code

Code: P1MG Calculation: Westinghouse 23, 24

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$1.33 \times 10^{11}$	87.9
>0.5 MeV	2.32	50.4
>0.1 MeV	3.90	30.0
Thermal, 20°C	-	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)  
 Compare with fluxes spectrum 81

## SP59 SM-1A ABOVE CORE SURV P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79400+000	1.204-003	3.16683+000
0.50	6.07000+000	3.237-003	8.52171+000
0.75	4.72000+000	7.324-003	1.91210+001
1.00	3.68000+000	7.892-003	2.08253+001
1.25	2.87000+000	1.096-002	2.89630+001
1.50	2.23000+000	1.893-002	4.92869+001
1.75	1.74000+000	3.342-002	8.84609+001
2.00	1.35000+000	2.852-002	7.37949+001
2.25	1.05000+000	2.346-002	6.13124+001
2.50	8.21000-001	3.001-002	8.01105+001
2.75	6.39000-001	3.660-002	9.59200+001
3.00	4.98000-001	3.617-002	9.52856+001
3.25	3.88000-001	3.428-002	9.02123+001
3.50	3.02000-001	3.258-002	8.53790+001
3.75	2.35000-001	2.513-002	6.57965+001
4.00	1.83000-001	2.385-002	6.26332+001
5.00	6.74000-002	7.715-002	5.07274+001
9.00	1.23000-003	1.945-001	3.19102+001
13.00	2.26000-005	1.703-001	2.79795+001
16.59	6.25000-007	1.209-001	2.21242+001
25.33	1.00000-010	8.361-002	6.28253+000
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP34 PM-2A V WALL CLADDING PROG S



Reactor Description

Name: PM-2A  
 Type: Power PWR Power Level: 10 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Camp Century, Greenland (decommissioned)

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel  
cladding; steel.

Spectrum Code

Code: Program S Calculation: BNW 14, 27

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	157.7
>0.5 MeV	(5.032†)	120.4
>0.1 MeV	-	89.0
Thermal, 20°C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(\gamma, n)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 34, 17U, 16U

## SP34 PM-2A V WALL CLADDING PROG S

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.693-003	3.80354+000
0.50	6.07000+000	5.527-003	1.24267+001
0.75	4.72000+000	9.338-003	2.08266+001
1.00	3.68000+000	9.321-003	2.10112+001
1.25	2.87000+000	1.100-002	2.48187+001
1.50	2.23000+000	1.664-002	3.70120+001
1.75	1.74000+000	1.308-002	2.95688+001
2.00	1.35000+000	1.270-002	2.80846+001
2.25	1.05000+000	1.136-002	2.53684+001
2.50	8.21000-001	1.003-002	2.28725+001
2.75	6.39000-001	1.163-002	2.60472+001
3.00	4.98000-001	9.112-003	2.05076+001
3.25	3.88000-001	6.663-003	1.49774+001
3.50	3.02000-001	6.731-003	1.50705+001
3.75	2.35000-001	4.864-003	1.08787+001
4.00	1.83000-001	5.337-003	1.19736+001
5.00	6.74000-002	3.198-002	1.79614+001
9.00	1.23000-003	1.954-002	2.73893+000
13.00	2.26000-005	2.160-002	3.03212+000
17.00	4.14000-007	4.939-002	6.92805+000
25.33	1.00000-010	7.325-001	4.93428+001
-----			1.000+000

ONE LETHARGY INTERVAL = 0.25U

SP17U PM-2A VESSEL 1/4T PROGRAM S



Reactor Description

Name: PM-2A  
 Type: power PWR Power Level: 10MWt  
 Coolant: Light water Moderator: Light water  
 Location: Camp Century, Greenland (decommissioned)

Spectrum Facility Description

pressure vessel wall; 1/4 thickness from inside: steel.

Spectrum Code

Code: Program S Calculation: BNW 14,27

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	0.78 x 10 <sup>-1</sup>	154
>0.5 Mev	1.07 (4.454†)	112
>0.1 Mev	1.29	93.2
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)



†In series of spectra 34, 17U, 16U

## SP17U PM-2A VESSEL 1/4T PROGRAM S

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.806-003	3.60760+000
0.50	6.07000+000	6.253-003	1.25043+001
0.75	4.72000+000	1.053-002	2.08886+001
1.00	3.68000+000	1.049-002	2.10284+001
1.25	2.87000+000	1.242-002	2.49332+001
1.50	2.23000+000	1.861-002	3.68021+001
1.75	1.74000+000	1.533-002	3.08243+001
2.00	1.35000+000	1.538-002	3.02316+001
2.25	1.05000+000	1.439-002	2.85565+001
2.50	8.21000-001	1.305-002	2.64602+001
2.75	6.39000-001	1.487-002	2.96061+001
3.00	4.98000-001	1.204-002	2.40866+001
3.25	3.88000-001	7.937-003	1.58638+001
3.50	3.02000-001	7.730-003	1.53891+001
3.75	2.35000-001	5.571-003	1.10806+001
4.00	1.83000-001	5.251-003	1.04752+001
6.75	1.17000-002	3.641-002	6.60477+000
9.00	1.23000-003	2.132-002	4.76528+000
11.50	1.01000-004	2.156-002	4.30303+000
16.50	6.83000-007	4.907-002	4.89979+000
25.33	1.00000-010	6.998-001	3.95408+001
*****			
1,000+000			

ONE LETHARGY INTERVAL = 0.25U

SP16U PM-2A VESSEL 3/4T PROGRAM S



Reactor Description

Name: PM-2A  
 Type: Power PWR Power Level: 10 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Camp Century, Greenland (decommissioned)

Spectrum Facility Description

Pressure vessel wall: 3/4 thickness from inside; steel

Spectrum Code

Code: Program S Calculation: BNW 14, 27

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section a, mb
>1 MeV	0.44 x 10 <sup>11</sup>	146
>0.5 MeV	0.64 (2.821+)	102
>0.1 MeV	0.76	85.2
Thermal, 20 °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


+ In series of spectra 34, 17U, 16U

## SP16U PM-2A VESSEL 3/4T PROGRAM S

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	2.428-003	3.95024+000
0.50	6.07000+000	7.813-003	1.27255+001
0.75	4.72000+000	1.183-002	1.91067+001
1.00	3.68000+000	1.323-002	2.15920+001
1.25	2.87000+000	1.588-002	2.59629+001
1.50	2.23000+000	2.360-002	3.80151+001
1.75	1.74000+000	2.061-002	3.37588+001
2.00	1.35000+000	2.179-002	3.48889+001
2.25	1.05000+000	2.143-002	3.46553+001
2.50	8.21000-001	2.023-002	3.34147+001
2.75	6.39000-001	2.232-002	3.61842+001
3.00	4.98000-001	1.910-002	3.11391+001
3.25	3.88000-001	1.134-002	1.84689+001
3.50	3.02000-001	1.065-002	1.72633+001
3.75	2.35000-001	7.582-003	1.22834+001
4.00	1.83000-001	6.297-003	1.02319+001
6.75	1.17000-002	4.737-002	6.99967+000
9.00	1.23000-003	2.658-002	4.79558+000
11.50	1.01000-004	2.221-002	3.61123+000
16.50	6.83000-007	4.799-002	3.90306+000
25.33	1.00000-010	6.197-001	2.85225+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP49 PM-2A V WALL CLADDING P1MG



Reactor Description

Name: PM-2A  
 Type: Power PWR Power Level: 10 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Camp Century, Greenland (decommissioned)

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel cladding; steel.

Spectrum Code

Code: P1MG-4 Calculation: Westinghouse 23, 25

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	129.9
>0.5 MeV	-	92.1
>0.1 MeV	-	66.6
Thermal, 20 °C	-	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP49 PM-2A V WALL CLADDING P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.869-003	3.41464+000
0.50	6.07000+000	5.162-003	9.44149+000
0.75	4.72000+000	1.116-002	2.02486+001
1.00	3.68000+000	1.241-002	2.27518+001
1.25	2.87000+000	1.568-002	2.87807+001
1.50	2.23000+000	2.232-002	4.03598+001
1.75	1.74000+000	2.561-002	4.71016+001
2.00	1.35000+000	2.173-002	3.90709+001
2.25	1.05000+000	1.760-002	3.19610+001
2.50	8.21000-001	1.802-002	3.34310+001
2.75	6.39000-001	2.058-002	3.74642+001
3.00	4.98000-001	1.711-002	3.13175+001
3.25	3.88000-001	1.592-002	2.91002+001
3.50	3.02000-001	1.654-002	3.01163+001
3.75	2.35000-001	1.157-002	2.10491+001
4.00	1.83000-001	1.143-002	2.08468+001
5.00	6.74000-002	3.629-002	1.65813+001
8.00	3.35000-003	9.133-002	1.38838+001
9.00	1.23000-003	1.172-002	5.33581+000
9.50	7.50000-004	1.071-002	9.87533+000
16.59	6.25000-007	1.630-001	1.04888+001
25.33	1.00000-010	4.423-001	2.30911+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP50 PM-2A V WALL CLADDING P3MG



Reactor Description

Name: PM-2A  
 Type: Power PWR Power Level: 10 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Camp Century, Greenland (decommissioned)

Spectrum Facility Description

Interface of carbon steel vessel wall and stainless steel  
 cladding ; steel

Spectrum Code

Code: P3MG Calculation: Westinghouse, BAPL 23, 26

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	118.9
>0.5 MeV	-	-
>0.1 MeV	-	-
Thermal, 20 °C	-	-



\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP50 PM-2A V WALL CLADDING P3MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	3.291-003	4.24091+000
0.50	6.07000+000	8.046-003	1.03786+001
0.75	4.72000+000	1.463-002	1.87226+001
1.00	3.68000+000	1.672-002	2.16232+001
1.25	2.87000+000	2.006-002	2.59719+001
1.50	2.23000+000	3.718-002	4.74200+001
1.75	1.74000+000	3.367-002	4.36699+001
2.00	1.35000+000	3.944-002	5.00101+001
2.25	1.05000+000	3.396-002	4.34846+001
2.50	8.21000-001	2.930-002	3.83219+001
16.59	6.25000-007	6.800-001	1.55331+001
25.33	1.00000-010	8.374-002	3.08329+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP62 SM-1 DFE POS 72



Reactor Description

Name: SM-1  
 Type: power PWR Power Level: 10.66 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Fort Belvoir, Virginia (decommissioned)

Spectrum Facility Description

Unfueled core lattice position No. 72; steel and water.

Spectrum Code

Code: DTF-IV Calculation: BNW 28

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.94 x 10 <sup>-3</sup>	129.6
>0.5 MeV	2.66 (109.4†)	94.5
>0.1 MeV	3.66	68.7
Thermal, 227°C	9.88	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)



†In series of spectra 62, 63

SP62 SM-1 DFE POS 72

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.280-003	2.87266+000
0.50	6.07000+000	3.973-003	8.92745+000
0.75	4.72000+000	8.024-003	1.78816+001
1.00	3.68000+000	1.037-002	2.33490+001
1.25	2.87000+000	1.441-002	3.25015+001
1.50	2.23000+000	2.138-002	4.74975+001
1.75	1.74000+000	1.728-002	3.90417+001
2.00	1.35000+000	1.735-002	3.83173+001
2.25	1.05000+000	1.503-002	3.35202+001
2.50	8.21000-001	1.320-002	3.00822+001
2.75	6.39000-001	1.599-002	3.57670+001
3.00	4.98000-001	1.189-002	2.67363+001
3.25	3.88000-001	1.069-002	2.40025+001
3.50	3.02000-001	1.205-002	2.69549+001
3.75	2.35000-001	8.810-003	1.96895+001
4.00	1.83000-001	9.332-003	2.09185+001
5.00	6.74000-002	2.720-002	1.52672+001
6.75	1.17000-002	3.460-002	1.10766+001
8.00	3.36000-003	2.277-002	1.02332+001
9.00	1.23000-003	1.904-002	1.06229+001
9.75	5.83000-004	1.394-002	1.04663+001
11.50	1.01000-004	3.382-002	1.08163+001
14.00	8.32000-006	4.837-002	1.08617+001
16.50	6.83000-007	5.261-002	1.17969+001
25.33	1.00000-010	5.566-001	3.53430+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP63 SM-1 V WALL CLADDING



Reactor Description

Name: SM-1  
 Type: Power PWR Power Level: 10.66 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Fort Belvoir, Virginia (decommissioned)

Spectrum Facility Description

Interfaced of carbon steel vessel wall and stainless steel cladding.

Spectrum Code

Code: DTF-IV Calculation: BNW 2e

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	166.0
>0.5 MeV	(60.82†)	124.6
>0.1 MeV	-	96.3
Thermal, 227 °C	-	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

† In series of spectra 62, 63

## SP63 SM-1 V WALL CLADDING

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	4.532-003	4.29996+000
0.50	6.07000+000	1.458-002	1.38527+001
0.75	4.72000+000	2.253-002	2.12192+001
1.00	3.68000+000	2.078-002	1.97879+001
1.25	2.87000+000	2.402-002	2.28994+001
1.50	2.23000+000	3.613-002	3.39333+001
1.75	1.74000+000	2.877-002	2.74774+001
2.00	1.35000+000	2.761-002	2.57755+001
2.25	1.05000+000	2.415-002	2.27669+001
2.50	8.21000-001	2.174-002	2.09360+001
2.75	6.39000-001	2.567-002	2.42747+001
3.00	4.98000-001	2.100-002	1.99639+001
3.25	3.88000-001	1.799-002	1.70732+001
3.50	3.02000-001	1.717-002	1.62364+001
3.75	2.35000-001	1.213-002	1.14622+001
4.00	1.83000-001	1.201-002	1.13837+001
5.00	6.74000-002	3.503-002	8.30916+000
6.75	1.17000-002	3.866-002	5.23193+000
8.00	3.36000-003	2.383-002	4.52561+000
9.00	1.23000-003	1.749-002	4.12360+000
9.75	5.83000-004	1.220-002	3.87159+000
11.50	1.01000-004	3.409-002	4.60748+000
14.00	8.32000-006	5.274-002	5.00554+000
16.50	6.83000-007	5.599-002	5.30729+000
25.33	1.00000-010	3.992-001	1.07127+001
-----			
1.000+000			


ONE LETHARGY INTERVAL = 0.25U



**LIGHT WATER MODERATED REACTORS**

**SPECIAL EXPERIMENTAL FACILITIES**

SP9 IRL-3 4 5/8-INCH



Reactor Description

Name: Industrial Reactor Laboratories, Inc.

Type: Research pool Power Level: 5 MWT

Coolant: Light water Moderator: Light water

Location: Plainsboro, New Jersey

Spectrum Facility DescriptionSimulated vessel wall experiment; 4 5/8-inch from fuel core  
(one inch inside exp.); steel.Spectrum Code

Code: 2 DXY Calculation: BNW 12,13

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.70 x 10 <sup>-2</sup>	116.5
>0.5 MeV	2.26	87.2
>0.1 MeV	3.03	65.1
Thermal, 49°C	0.82	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(\gamma, n)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP9 IRL=3 4 5/8-INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	3.224+003	4.03817+000
0.50	6.07000+000	7.470+003	9.36726+000
0.75	4.72000+000	1.477+002	1.83735+001
1.00	3.68000+000	1.512+002	1.90006+001
1.25	2.87000+000	2.428+002	3.05578+001
1.50	2.23000+000	4.228+002	5.24252+001
1.75	1.74000+000	3.858+002	4.86500+001
2.00	1.35000+000	3.862+002	4.76104+001
2.25	1.05000+000	3.453+002	4.29834+001
2.50	8.21000+001	3.059+002	3.88953+001
2.75	6.39000+001	3.036+002	3.78962+001
3.00	4.98000+001	2.078+002	2.60766+001
3.25	3.88000+001	1.839+002	2.30506+001
3.50	3.02000+001	2.190+002	2.73422+001
3.75	2.35000+001	1.454+002	1.81284+001
4.00	1.83000+001	1.599+002	1.99963+001
17.00	4.14000+007	3.919+001	9.43142+000
25.33	1.00000+010	2.367+001	8.89173+000
		-----	
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP10 IRL-3 5 5/8-INCH



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Research, pool Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; 5 3/8-inch from fuel core  
(two inches inside exp.); steel

Spectrum Code

Code: 2 DXY Calculation: BNW 12, 13

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.30 x 10 <sup>12</sup>	94.5
>0.5 Mev	1.86	65.9
>0.1 Mev	2.50	49.2
Thermal, 49 °C	0.18	-


\* Fast flux based on <sup>54</sup>Fe(n,p) <sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ ) <sup>60</sup>Co reaction or Ag-Co technique (11)

SP10 IRL=3 5 5/8-INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7,79000+000	2,875+003	4,22354+000
0.50	6,07000+000	6,274+003	9,22779+000
0.75	4,72000+000	1,138+002	1,66076+001
1.00	3,68000+000	1,239+002	1,82678+001
1.25	2,87000+000	2,091+002	3,08708+001
1.50	2,23000+000	4,066+002	5,91356+001
1.75	1,74000+000	4,174+002	6,17290+001
2.00	1,35000+000	4,763+002	6,88734+001
2.25	1,05000+000	4,456+002	6,50652+001
2.50	8,21000+001	4,076+002	6,07971+001
2.75	6,39000+001	4,200+002	6,15008+001
3.00	4,98000+001	2,774+002	4,08290+001
3.25	3,88000+001	2,332+002	3,42845+001
3.50	3,02000+001	2,908+002	4,25889+001
3.75	2,35000+001	1,928+002	2,82000+001
4.00	1,83000+001	2,337+002	3,42898+001
17.00	4,14000+007	4,447+001	1,25532+001
25.33	1,00000+010	1,213+001	5,34453+000
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP11 IRL-3 6 5/8-INCH



Reactor Description

Name: Industrial Reactor Laboratories, Inc.

Type: Research, pool Power Level: 5 MWT

Coolant: Light water Moderator: Light water

Location: Plainsboro, New Jersey

Spectrum Facility DescriptionSimulated vessel wall experiment; 6 5/8-inch from fuel core  
(three inches inside exp.); steelSpectrum Code

Code: 2 DXY Calculation: BNW 12,13

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$9.05 \times 10^{11}$	81.1
>0.5 Mev	13.9	52.8
>0.1 Mev	19.5	37.6
Thermal, 49°C	0.657	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP11 IRL=3 6 5/8=INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000e+000	2.307e-003	4.33308e+000
0.50	6.07000e+000	4.641e-003	8.72813e+000
0.75	4.72000e+000	8.828e-003	1.64650e+001
1.00	3.68000e+000	9.126e-003	1.72026e+001
1.25	2.87000e+000	1.577e-002	2.97584e+001
1.50	2.23000e+000	3.497e-002	6.50316e+001
1.75	1.74000e+000	3.748e-002	7.08734e+001
2.00	1.35000e+000	4.578e-002	8.46228e+001
2.25	1.05000e+000	4.749e-002	8.86488e+001
2.50	8.21000e-001	4.652e-002	8.87158e+001
2.75	6.39000e-001	4.701e-002	8.79930e+001
3.00	4.98000e-001	3.146e-002	5.91986e+001
3.25	3.88000e-001	2.645e-002	4.97075e+001
3.50	3.02000e-001	3.407e-002	6.37874e+001
3.75	2.35000e-001	2.263e-002	4.23236e+001
4.00	1.83000e-001	2.834e-002	5.31706e+001
17.00	4.14000e-007	4.747e-001	1.71341e+001
25.33	1.00000e-010	8.239e-002	4.64099e+000
		----- 1,000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP12 IRL-3 7 7/8-INCH



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Research, pool Power Level: 5 MWT  
 Coolant: Light water Moderator: Light water  
 Location: plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; 12 5/8-inches inside experiment  
(four inches inside exp.); steel

Spectrum Code

Code: 2 DXY Calculation: BNW 12,13

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section g, mb
>1 MeV	$6.50 \times 10^{11}$	69.2
>0.5 MeV	10.8	41.5
>0.1 MeV	16.1	28.0
Thermal, 49°C	0.41	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP12 IRL=3 7 7/8-INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.624+003	4.18636+000
0.50	6.07000+000	3.043+003	7.85340+000
0.75	4.72000+000	6.133+003	1.56970+001
1.00	3.68000+000	6.429+003	1.66297+001
1.25	2.87000+000	1.307+002	3.38473+001
1.50	2.23000+000	2.604+002	6.64567+001
1.75	1.74000+000	2.894+002	7.51030+001
2.00	1.35000+000	4.172+002	1.05838+002
2.25	1.05000+000	4.786+002	1.22608+002
2.50	8.21000+001	4.585+002	1.19975+002
2.75	6.39000+001	5.113+002	1.31348+002
3.00	4.98000+001	3.483+002	8.99447+001
3.25	3.88000+001	2.874+002	7.41240+001
3.50	3.02000+001	3.826+002	9.83095+001
3.75	2.35000+001	2.546+002	6.53492+001
4.00	1.83000+001	3.272+002	8.42176+001
17.00	4.14000+007	4.951+001	2.45184+001
25.33	1.00000+010	7.309+002	5.65024+000
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP13 IRL-3 8 5/8-INCH



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Research, pool Power Level: 5 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; 8 5/8-inches inside experiment  
 (five inches inside exp.); steel.

Spectrum Code

Code: 2 DXY Calculation: BNW 12,13

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	$4.75 \times 10^{11}$	57.1
>0.5 MeV	8.40	32.3
>0.1 MeV	12.9	21.1
Thermal, 49 °C	0.54	-



\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP13 IRL=3 8 5/8-INCH

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.195+003	4.27176+000
0.50	6.07000+000	2.383+003	8.52775+000
0.75	4.72000+000	3.814+003	1.35346+001
1.00	3.68000+000	4.346+003	1.55866+001
1.25	2.87000+000	8.498+003	3.05145+001
1.50	2.23000+000	2.190+002	7.74735+001
1.75	1.74000+000	2.717+002	9.77509+001
2.00	1.35000+000	3.758+002	1.32189+002
2.25	1.05000+000	4.491+002	1.59536+002
2.50	8.21000+001	4.525+002	1.64180+002
2.75	6.39000+001	5.139+002	1.83041+002
3.00	4.98000+001	3.626+002	1.29827+002
3.25	3.88000+001	2.894+002	1.03511+002
3.50	3.02000+001	3.796+002	1.35242+002
3.75	2.35000+001	2.636+002	9.37984+001
4.00	1.83000+001	3.395+002	1.21173+002
17.00	4.14000+007	5.118+001	3.51478+001
25.33	1.00000+010	7.629+002	8.17672+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP51D IRL-5 ACCEL SURV DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; accelerated irradiation-rate  
location; steel and water

Spectrum Code

Code: DTF-IV Calculation: BNW 28,30

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	$2.45 \times 10^{-1}$	160.0
>0.5 MeV	3.23 (79.95+)	121.3
>0.1 MeV	4.16	94.2
Thermal, 49°C	10.03	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


+In series of spectra 51D through 57D

## SP51D IRL-5 ACCEL SURV DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000e+000	2.793e-003	3.99083e+000
0.50	6.07000e+000	9.101e-003	1.30191e+001
0.75	4.72000e+000	1.487e-002	2.10914e+001
1.00	3.68000e+000	1.432e-002	2.05387e+001
1.25	2.87000e+000	1.663e-002	2.38761e+001
1.50	2.23000e+000	2.920e-002	3.56440e+001
1.75	1.74000e+000	1.952e-002	2.80703e+001
2.00	1.35000e+000	1.888e-002	2.65567e+001
2.25	1.05000e+000	1.681e-002	2.38787e+001
2.50	8.21000e-001	1.508e-002	2.18702e+001
2.75	6.39000e-001	1.741e-002	2.50735e+001
3.00	4.98000e-001	1.417e-002	2.02840e+001
3.25	3.88000e-001	1.077e-002	1.53991e+001
3.50	3.02000e-001	1.137e-002	1.61934e+001
3.75	2.35000e-001	8.295e-003	1.18016e+001
4.00	1.83000e-001	8.183e-003	1.16772e+001
5.00	6.74000e-002	2.530e-002	9.04085e+000
6.75	1.17000e-002	3.042e-002	6.20052e+000
8.00	3.36000e-003	1.845e-002	5.27843e+000
9.00	1.23000e-003	1.599e-002	5.67764e+000
9.75	5.83000e-004	1.019e-002	4.87087e+000
11.50	1.01000e-004	2.600e-002	5.29248e+000
14.00	8.32000e-006	3.819e-002	5.45931e+000
16.50	6.83000e-007	3.921e-002	5.59691e+000
25.33	1.00000e-010	5.727e-001	2.31479e+001
		1.000e+000	


ONE LETHARGY INTERVAL = 0.25U

SP52D IRL-5 V WALL SURV. DTF-IV



LETHARGY (U)

$10^{-10}$        $6.85 \times 10^{-7}$        $1.23 \times 10^{-3}$        $0.18$        $1.35$        $10$   
 ENERGY (MeV)



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; vessel wall surveillance  
location; steel and water.

Spectrum Code

Code: DTF-IV Calculation: BNW 22,30

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	1.07 x 10 <sup>-1</sup>	147.8
>0.5 Mev	1.56 (47.24†)	101.4
>0.1 Mev	2.20	71.9
Thermal, 49 °C	1.25	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 51D through 57D

## SP52C IRL=5 V WALL SURV; DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	3.876+003	4,04329+000
0.50	6.07000+000	1.244+002	1,29863+001
0.75	4.72000+000	2.005+002	2,07646+001
1.00	3.68000+000	1.941+002	2,03149+001
1.25	2.87000+000	2.326+002	2,43691+001
1.50	2.23000+000	3.505+002	3,61871+001
1.75	1.74000+000	2.996+002	3,14574+001
2.00	1.35000+000	3.033+002	3,11380+001
2.25	1.05000+000	2.920+002	3,02667+001
2.50	8.21000+001	2.950+002	3,12403+001
2.75	6.39000+001	3.573+002	3,71415+001
3.00	4.98000+001	3.438+002	3,59193+001
3.25	3.88000+001	2.821+002	2,94455+001
3.50	3.02000+001	2.686+002	2,79198+001
3.75	2.35000+001	1.901+002	1,97409+001
4.00	1.83000+001	1.654+002	1,72242+001
5.00	6.74000+002	9.763+002	1,50303+001
6.75	1.17000+002	6.137+002	9,12987+000
8.00	3.36000+003	3.595+002	7,50680+000
9.00	1.23000+003	2.577+002	6,68038+000
9.75	5.83000+004	1.542+002	5,38097+000
11.50	1.01000+004	4.237+002	6,29593+000
14.00	8.32000+006	6.314+002	6,58879+000
16.50	6.83000+007	6.055+002	6,30951+000
25.33	1.00000+010	2.440+001	7,19880+000
		-----	
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP53D IRL-5 1-INCH INSIDE DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location one inch inside  
vessel; steel

Spectrum Code

Code: DTF-IV Calculation: BNW 29,30

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.66 \times 10^{11}$	132.2
>0.5 MeV	1.08 (38.78†)	81.5
>0.1 MeV	1.62	54.2
Thermal, 49 °C	0.202	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51D through 57D

## SP53D IRL=5 1-INCH INSIDE DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	3.716e-003	3.90412e+000
0.50	6.07000e+000	1.164e-002	1.24559e+001
0.75	4.72000e+000	1.936e-002	2.01888e+001
1.00	3.68000e+000	1.937e-002	2.04137e+001
1.25	2.87000e+000	2.428e-002	2.56188e+001
1.50	2.23000e+000	3.687e-002	3.83404e+001
1.75	1.74000e+000	3.451e-002	3.64889e+001
2.00	1.35000e+000	3.613e-002	3.73502e+001
2.25	1.05000e+000	3.800e-002	3.96722e+001
2.50	8.21000e-001	4.234e-002	4.51478e+001
2.75	6.39000e-001	5.159e-002	5.40049e+001
3.00	4.98000e-001	5.584e-002	5.87667e+001
3.25	3.88000e-001	4.638e-002	4.87536e+001
3.50	3.02000e-001	4.116e-002	4.30937e+001
3.75	2.35000e-001	2.857e-002	2.98782e+001
4.00	1.83000e-001	2.114e-002	2.21756e+001
5.00	6.74000e-002	8.628e-002	2.26619e+001
6.75	1.17000e-002	8.543e-002	1.28005e+001
8.00	3.36000e-003	4.660e-002	9.79950e+000
9.00	1.23000e-003	3.713e-002	9.69489e+000
9.75	5.83000e-004	1.456e-002	5.11719e+000
11.50	1.01000e-004	3.406e-002	5.09713e+000
14.00	8.32000e-006	6.276e-002	6.59579e+000
16.50	6.83000e-007	5.198e-002	5.45546e+000
25.33	1.00000e-010	7.011e-002	2.08328e+000
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP54D IRL-5 2-INCH INSIDE DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location two inches inside vessel; steel

Spectrum Code

Code: DTF-IV Calculation: BNW 29, 30

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.46 \times 10^{11}$	120.8
>0.5 Mev	0.79 (29.78†)	71.4
>0.1 Mev	1.28	43.9
Thermal, 49°C	0.077	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


†In series of spectra 51D through 57D

## SP54C IRL=5 2-INCH INSIDE DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	3.054e-003	3.78609e+000
0.50	6.07000e+000	9.715e-003	1.20576e+001
0.75	4.72000e+000	1.601e-002	1.97104e+001
1.00	3.68000e+000	1.644e-002	2.04578e+001
1.25	2.87000e+000	2.131e-002	2.65436e+001
1.50	2.23000e+000	3.280e-002	4.02576e+001
1.75	1.74000e+000	3.254e-002	4.06060e+001
2.00	1.35000e+000	3.513e-002	4.28672e+001
2.25	1.05000e+000	3.934e-002	4.84694e+001
2.50	8.21000e-001	4.702e-002	5.91787e+001
2.75	6.39000e-001	5.608e-002	6.92859e+001
3.00	4.98000e-001	5.204e-002	6.46317e+001
3.25	3.88000e-001	5.668e-002	7.03156e+001
3.50	3.02000e-001	5.007e-002	6.18692e+001
3.75	2.35000e-001	3.452e-002	4.26128e+001
4.00	1.83000e-001	2.412e-002	2.98592e+001
5.00	6.74000e-002	1.043e-001	3.23257e+001
6.75	1.17000e-002	9.987e-002	1.76597e+001
8.00	3.36000e-003	5.200e-002	1.29048e+001
9.00	1.23000e-003	4.514e-002	1.39072e+001
9.75	5.83000e-004	1.315e-002	5.45548e+000
11.50	1.01000e-004	2.607e-002	4.60402e+000
14.00	8.32000e-006	5.506e-002	6.82874e+000
16.50	6.83000e-007	4.239e-002	5.25078e+000
25.33	1.00000e-010	3.517e-002	1.23341e+000
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP55D IRL-5 4-INCH INSIDE DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location four inches inside vessel; steel

Spectrum Code

Code: DTF-IV Calculation: BNW 29, 30

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	0.22 × 10 <sup>11</sup>	102.6
>0.5 MeV	0.45 (18.95†)	49.0
>0.1 MeV	0.82	27.1
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


†In series of spectra 51D through 57D

## SP55C IRL=5 4-INCH INSIDE DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.791+003	3.57226+000
0.50	6.07000+000	5.703+003	1.13859+001
0.75	4.72000+000	9.554+003	1.89175+001
1.00	3.68000+000	1.022+002	2.04418+001
1.25	2.87000+000	1.398+002	2.80142+001
1.50	2.23000+000	2.219+002	4.38009+001
1.75	1.74000+000	2.401+002	4.82036+001
2.00	1.35000+000	2.740+002	5.37841+001
2.25	1.05000+000	3.398+002	6.73348+001
2.50	8.21000+001	4.548+002	9.20739+001
2.75	6.39000+001	5.755+002	1.14369+002
3.00	4.98000+001	7.483+002	1.49504+002
3.25	3.88000+001	6.446+002	1.28636+002
3.50	3.02000+001	5.860+002	1.16479+002
3.75	2.35000+001	4.063+002	8.06664+001
4.00	1.83000+001	2.720+002	5.41601+001
5.00	6.74000+002	1.249+001	6.22931+001
6.75	1.17000+002	1.173+001	3.33693+001
8.00	3.36000+003	5.742+002	2.29244+001
9.00	1.23000+003	5.943+002	2.94553+001
9.75	5.83000+004	1.118+002	7.46002+000
11.50	1.01000+004	1.674+002	4.75648+000
14.00	8.32000+006	4.098+002	8.17632+000
16.50	6.83000+007	2.939+002	5.85647+000
25.33	1.00000+010	2.504+002	1.41282+000
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP56D IRL-5 6-INCH INSIDE DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location six inches inside  
vessel: steel

Spectrum Code

Code: DTF-IV Calculation: BNW 29,30

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.096 \times 10^{11}$	89.9
>0.5 MeV	0.23 (10.52+)	37.3
>0.1 MeV	0.46	18.6
Thermal, 49°C	0.016	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


+ In series of spectra 51D through 57D

## SP56C IRL-5 6-INCH INSIDE DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e000	1.071e-003	3.42299e000
0.50	6.07000e000	3.409e-003	1.09110e001
0.75	4.72000e000	5.772e-003	1.83205e001
1.00	3.68000e000	6.335e-003	2.03222e001
1.25	2.87000e000	9.033e-003	2.90114e001
1.50	2.23000e000	1.475e-002	4.66812e001
1.75	1.74000e000	1.694e-002	5.45201e001
2.00	1.35000e000	2.021e-002	6.35811e001
2.25	1.05000e000	2.704e-002	8.59115e001
2.50	8.21000e-001	3.977e-002	1.29081e002
2.75	6.39000e-001	5.084e-002	1.61968e002
3.00	4.98000e-001	7.195e-002	2.30421e002
3.25	3.88000e-001	6.186e-002	1.97886e002
3.50	3.02000e-001	5.841e-002	1.86117e002
3.75	2.35000e-001	4.111e-002	1.30845e002
4.00	1.83000e-001	2.707e-002	8.64086e001
5.00	6.74000e-002	1.346e-001	1.07590e002
6.75	1.17000e-002	1.320e-001	6.02099e001
8.00	3.36000e-003	6.358e-002	4.06880e001
9.00	1.23000e-003	8.058e-002	6.40190e001
9.75	5.83000e-004	1.336e-002	1.42907e001
11.50	1.01000e-004	2.188e-002	9.96336e000
14.00	8.32000e-006	4.655e-002	1.48872e001
16.50	6.83000e-007	3.395e-002	1.08429e001
25.33	1.00000e-010	1.790e-002	1.61919e000
		1.000e000	

ONE LETHARGY INTERVAL = 0.25U

SP57D IRL-5 7-INCH INSIDE DTF-IV



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: pool, research Power Level: 4.84 MWt  
 Coolant: light water Moderator: light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment: location seven inches inside vessel; steel

Spectrum Code

Code: DTF-IV Calculation: BNW 29, 30

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	0.063	86.1
>0.5 MeV	0.16 (7.19+)	34.1
>0.1 MeV	0.33	16.4
Thermal, 49°C	0.035	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


+ In series of spectra 51D through 57D

## SP57D IRL=5 7-INCH INSIDE DTF-IV

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	7.932e-004	3.40083e+000
0.50	6.07000e+000	2.519e-003	1.08136e+001
0.75	4.72000e+000	4.259e-003	1.81301e+001
1.00	3.68000e+000	4.698e-003	2.02105e+001
1.25	2.87000e+000	6.798e-003	2.92807e+001
1.50	2.23000e+000	1.121e-002	4.75638e+001
1.75	1.74000e+000	1.305e-002	5.63250e+001
2.00	1.35000e+000	1.585e-002	6.68885e+001
2.25	1.05000e+000	2.175e-002	9.26556e+001
2.50	8.21000e-001	3.332e-002	1.45027e+002
2.75	6.39000e-001	4.194e-002	1.79178e+002
3.00	4.98000e-001	6.179e-002	2.65397e+002
3.25	3.88000e-001	5.187e-002	2.22537e+002
3.50	3.02000e-001	5.032e-002	2.15041e+002
3.75	2.35000e-001	3.574e-002	1.52576e+002
4.00	1.83000e-001	2.323e-002	9.94827e+001
5.00	6.74000e-002	1.260e-001	1.35048e+002
6.75	1.17000e-002	1.315e-001	8.04312e+001
8.00	3.36000e-003	6.457e-002	5.54178e+001
9.00	1.23000e-003	9.213e-002	9.81704e+001
9.75	5.83000e-004	1.753e-002	2.51381e+001
11.50	1.01000e-004	3.435e-002	2.09795e+001
14.00	8.32000e-006	6.011e-002	2.57845e+001
16.50	6.83000e-007	4.725e-002	2.02406e+001
25.33	1.00000e-010	4.743e-002	5.75300e+000
-----			
1,000e+000			

ONE LETHARGY INTERVAL = 0.25U

SP51SA IRL-5 ACCEL SURV SAND-II



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; accelerated-irradiation rate surveillance location; steel and water.

Spectrum Code

Code: SAND-II Calculation: BNW 30, 31

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	2.78 x 10 <sup>-1</sup>	140.8
>0.5 MeV	3.61 (48.85†)	108.6
>0.1 MeV	4.77	82.2
Thermal, 49°C	10.03	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 51SA through 57SA

## SP51SA IRL-5 ACCEL SURV SAND-II

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.662-003	4.07292+000
0.50	6.07000+000	7.223-003	1.10620+001
0.75	4.72000+000	1.288-002	1.95684+001
1.00	3.68000+000	1.217-002	1.86862+001
1.25	2.87000+000	1.823-002	2.80108+001
1.50	2.23000+000	3.102-002	4.69799+001
1.75	1.74000+000	2.274-002	3.50092+001
2.00	1.35000+000	2.129-002	3.20554+001
2.25	1.05000+000	1.812-002	2.75424+001
2.50	8.21000-001	1.421-002	2.20722+001
2.75	6.39000-001	1.773-002	2.70282+001
3.00	4.98000-001	1.404-002	2.15128+001
3.25	3.88000-001	1.287-002	1.96993+001
3.50	3.02000-001	1.363-002	2.07891+001
3.75	2.35000-001	8.598-003	1.30959+001
4.00	1.83000-001	1.031-002	1.57435+001
5.00	6.74000-002	2.851-002	1.09054+001
6.75	1.17000-002	3.224-002	7.03532+000
8.00	3.36000-003	1.883-002	5.76479+000
9.00	1.23000-003	2.018-002	7.67113+000
9.75	5.83000-004	1.280-002	6.55009+000
11.50	1.01000-004	2.550-002	5.55648+000
14.00	8.32000-006	5.239-002	8.01749+000
16.50	6.83000-007	3.876-002	5.92298+000
25.33	1.00000-010	5.331-001	2.30684+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP52SA IRL-5 V WALL SURV SAND-II



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; vessel wall surveillance  
Location: steel and water.

Spectrum Code

Code: SAND-II Calculation: BNW 30, 31

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section a, mb
>1 MeV	1.42 x 10 <sup>-1</sup>	111.3
>0.5 MeV	1.97 (30.69+)	80.2
>0.1 MeV	2.98	53.0
Thermal, 49°C	1.25	-

\* Fast flux based on <sup>54</sup>Fe(n,p) <sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ ) <sup>60</sup>Co reaction or Ag-Co technique (11)


+ In series of spectra 51SA through 57 SA

## SP52SA IRL-5 V WALL SURV SAND-II

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.897-003	3.96756+000
0.50	6.07000+000	7.790-003	1.06784+001
0.75	4.72000+000	1.250-002	1.69967+001
1.00	3.68000+000	1.203-002	1.65262+001
1.25	2.87000+000	2.122-002	2.91871+001
1.50	2.23000+000	4.547-002	6.16343+001
1.75	1.74000+000	3.420-002	4.71454+001
2.00	1.35000+000	3.685-002	4.96646+001
2.25	1.05000+000	3.207-002	4.36430+001
2.50	8.21000-001	2.414-002	3.35635+001
2.75	6.39000-001	3.015-002	4.11412+001
3.00	4.98000-001	3.013-002	4.13353+001
3.25	3.88000-001	3.114-002	4.26643+001
3.50	3.02000-001	3.246-002	4.43003+001
3.75	2.35000-001	2.121-002	2.89130+001
4.00	1.83000-001	2.335-002	3.19227+001
5.00	6.74000-002	6.978-002	2.38903+001
6.75	1.17000-002	5.892-002	1.15075+001
8.00	3.36000-003	3.113-002	8.53217+000
9.00	1.23000-003	3.317-002	1.12872+001
9.75	5.83000-004	2.663-002	1.21994+001
11.50	1.01000-004	3.849-002	7.50928+000
14.00	8.32000-006	1.174-001	1.60761+001
16.50	6.83000-007	4.274-002	5.84667+000
25.33	1.00000-010	1.842-001	7.13448+000
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP53SA IRL-5 1 INCH INSIDE SAND-II



Reactor DescriptionName: Industrial Reactor Laboratories, Inc.Type: Pool, research Power Level: 4.84 MWTCoolant: Light water Moderator: Light waterLocation: Plainsboro, New JerseySpectrum Facility DescriptionSimulated vessel wall experiment; location one inch inside vessel; steel.Spectrum CodeCode: SAND-II Calculation: BNW 30, 31

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$1.13 \times 10^{11}$	77.5
>0.5 MeV	1.61 (23.07†)	54.4
>0.1 MeV	2.36	37.1
Thermal, 49°C	0.202	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51SA through 57SA

## SP53SA IRL-5 1 INCH INSIDE SAND-II

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.733-003	3.99306+000
0.50	6.07000+000	6.719-003	9.82805+000
0.75	4.72000+000	1.036-002	1.50283+001
1.00	3.68000+000	1.063-002	1.55843+001
1.25	2.87000+000	2.147-002	3.15146+001
1.50	2.23000+000	4.731-002	6.84319+001
1.75	1.74000+000	4.898-002	7.20343+001
2.00	1.35000+000	5.245-002	7.54145+001
2.25	1.05000+000	5.229-002	7.59295+001
2.50	8.21000-001	4.295-002	6.37046+001
2.75	6.39000-001	4.257-002	6.19891+001
3.00	4.98000-001	3.866-002	5.65935+001
3.25	3.88000-001	3.814-002	5.57589+001
3.50	3.02000-001	3.852-002	5.60944+001
3.75	2.35000-001	2.569-002	3.73763+001
4.00	1.83000-001	2.561-002	3.73663+001
5.00	6.74000-002	9.883-002	3.61064+001
6.75	1.17000-002	8.936-002	1.86646+001
8.00	3.36000-003	3.996-002	1.16877+001
9.00	1.23000-003	3.531-002	1.28224+001
9.75	5.83000-004	2.048-002	1.00114+001
11.50	1.01000-004	3.740-002	7.78596+000
14.00	8.32000-006	1.064-001	1.55560+001
16.50	6.83000-007	4.815-002	7.02897+000
25.33	1.00000-010	1.879-002	7.76803-001
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP55SA IRL-5 4 INCH INSIDE SAND-II



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location four inches inside vessel; steel

Spectrum Code

Code: SAND-II Calculation: BNW 30, 31

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	0.41 x 10 <sup>-1</sup>	53.6
>0.5 MeV	0.61 (8.72†)	36.4
>0.1 MeV	1.20	18.4
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


†In series of spectra 51SA through 57SA

## SP55SA IRL-5 4 INCH INSIDE SAND-II

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.7900+000	1.024-003	3.23286+000
0.50	6.07000+000	3.003-003	9.49197+000
0.75	4.72000+000	6.326-003	1.98300+001
1.00	3.68000+000	6.270-003	1.98643+001
1.25	2.87000+000	9.087-003	2.88254+001
1.50	2.23000+000	1.585-002	4.95270+001
1.75	1.74000+000	1.626-002	5.16674+001
2.00	1.35000+000	1.765-002	5.48513+001
2.25	1.05000+000	2.020-002	6.33894+001
2.50	8.21000-001	2.019-002	6.47245+001
2.75	6.39000-001	2.980-002	9.37561+001
3.00	4.98000-001	4.257-002	1.34661+002
3.25	3.88000-001	4.818-002	1.52213+002
3.50	3.02000-001	5.170-002	1.62708+002
3.75	2.35000-001	3.485-002	1.09573+002
4.00	1.83000-001	3.315-002	1.04512+002
5.00	6.74000-002	1.767-001	1.39506+002
6.75	1.17000-002	1.993-001	8.97479+001
8.00	3.36000-003	8.001-002	5.05715+001
9.00	1.23000-003	2.366-002	1.85651+001
9.75	5.83000-004	1.099-002	1.16064+001
11.50	1.01000-004	3.468-002	1.55997+001
14.00	8.32000-006	6.141-002	1.93990+001
16.50	6.83000-007	4.139-002	1.30546+001
25.33	1.00000-010	1.576-002	1.40763+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP57SA IRL-5 7 INCH INSIDE SAND-II



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location seven inches inside vessel; steel

Spectrum Code

Code: SAND-II Calculation: BNW 30, 31

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	0.095 x 10 <sup>-1</sup>	56.6
>0.5 MeV	0.16 (2.19†)	33.4
>0.1 MeV	0.28	19.5
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p) <sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ ) <sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 51SA through 57SA

## SP57SA IRL-5 7 INCH INSIDE SAND-II

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.166-003	5.16687+000
0.50	6.07000+000	2.176-003	9.65361+000
0.75	4.72000+000	3.868-003	1.70213+001
1.00	3.68000+000	3.839-003	1.70736+001
1.25	2.87000+000	3.014-003	1.34219+001
1.50	2.23000+000	1.849-002	8.11033+001
1.75	1.74000+000	2.097-002	9.35494+001
2.00	1.35000+000	2.813-002	1.22680+002
2.25	1.05000+000	3.756-002	1.65424+002
2.50	8.21000-001	3.653-002	1.64343+002
2.75	6.39000-001	2.847-002	1.25753+002
3.00	4.98000-001	2.695-002	1.19655+002
3.25	3.88000-001	2.251-002	9.98326+001
3.50	3.02000-001	2.261-002	9.98993+001
3.75	2.35000-001	1.524-002	6.72632+001
4.00	1.83000-001	1.561-002	6.90896+001
5.00	6.74000-002	1.285-001	1.42371+002
6.75	1.17000-002	2.113-001	1.33548+002
8.00	3.36000-003	8.280-002	7.34631+001
9.00	1.23000-003	2.377-002	2.61777+001
9.75	5.83000-004	1.434-002	2.12560+001
11.50	1.01000-004	5.138-002	3.24418+001
14.00	8.32000-006	8.735-002	3.87294+001
16.50	6.83000-007	6.849-002	3.03273+001
25.33	1.00000-010	4.501-002	5.64330+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP51DB IRL-5 ACCEL SURV 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; accelerated irradiation-rate  
surveillance location: steel and water.

Spectrum Code

Code: 2DB Calculation: BNW 30, 32

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$2.73 \times 10^{11}$	143.8
>0.5 Mev	3.74 (17.24†)	104.7
>0.1 Mev	5.18	75.7
Thermal, 49°C	10.03	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51DB through 57DB

## SP51DB IRL-5 ACCEL SURV 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79 00+000	2.401-003	3.86344+000
0.50	6.07000+000	7.546-003	1.21550+001
0.75	4.72000+000	1.260-002	2.01251+001
1.00	3.68000+000	1.248-002	2.01518+001
1.25	2.87000+000	1.557-002	2.51655+001
1.50	2.23000+000	2.651-002	4.22157+001
1.75	1.74000+000	1.964-002	3.18097+001
2.00	1.35000+000	2.030-002	3.21518+001
2.25	1.05000+000	1.880-002	3.00599+001
2.50	8.21000-001	1.778-002	2.90490+001
2.75	6.39000-001	1.989-002	3.18857+001
3.00	4.98000-001	1.655-002	2.66708+001
3.25	3.88000-001	1.491-002	2.40048+001
3.50	3.02000-001	1.578-002	2.53107+001
3.75	2.35000-001	1.144-002	1.83266+001
4.00	1.83000-001	1.065-002	1.71061+001
5.00	6.74000-002	3.455-002	1.39002+001
6.75	1.17000-002	4.162-002	9.55206+000
8.00	3.36000-003	2.310-002	7.44101+000
9.00	1.23000-003	2.289-002	9.15503+000
9.75	5.83000-004	1.358-002	7.31064+000
11.50	1.01000-004	3.121-002	7.15337+000
14.00	8.32000-006	4.292-002	6.90905+000
16.50	6.83000-007	3.955-002	6.35732+000
25.33	1.00000-010	5.077-001	2.31107+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP52DB IRL-5 V WALL SURV 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; vessel wall surveillance  
location; steel and water.

Spectrum Code

Code: 2DB Calculation: BNW 30 32

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section g, mb
>1 MeV	1.26 x 10 <sup>-1</sup>	125.9
>0.5 MeV	1.84 (14.39†)	86.1
>0.1 MeV	2.67	59.2
Thermal, 49°C	1.25	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 51DB through 57DB

SP52DB IRL-5 V WALL SURV 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.768-003	3.37476+000
0.50	6.07000+000	8.589-003	1.04829+001
0.75	4.72000+000	1.560-002	1.88837+001
1.00	3.68000+000	1.734-002	2.12194+001
1.25	2.87000+000	2.337-002	2.86209+001
1.50	2.23000+000	3.877-002	4.67903+001
1.75	1.74000+000	3.229-002	3.96219+001
2.00	1.35000+000	3.361-002	4.03294+001
2.25	1.05000+000	3.111-002	3.76962+001
2.50	8.21000-001	3.049-002	3.77343+001
2.75	6.39000-001	3.730-002	4.53241+001
3.00	4.98000-001	3.266-002	3.98882+001
3.25	3.88000-001	2.765-002	3.37371+001
3.50	3.02000-001	2.990-002	3.63387+001
3.75	2.35000-001	2.212-002	2.68466+001
4.00	1.83000-001	2.036-002	2.47933+001
5.00	6.74000-002	6.496-002	1.98044+001
6.75	1.17000-002	6.636-002	1.15391+001
8.00	3.36000-003	4.007-002	9.78017+000
9.00	1.23000-003	2.184-002	6.61759+000
9.75	5.83000-004	1.752-002	7.14616+000
11.50	1.01000-004	4.590-002	7.97346+000
14.00	8.32000-006	6.896-002	8.41146+000
16.50	6.83000-007	6.279-002	7.64854+000
25.33	1.00000-010	2.077-001	7.16150+000
-----			
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP53DB IRL-5 1 INCH INSIDE 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location one inch inside  
vessel; steel.

Spectrum Code

Code: 2DB Calculation: BNW 30,32

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.82 \times 10^{11}$	107.2
>0.5 MeV	1.35 (9.853†)	64.7
>0.1 MeV	2.17	40.3
Thermal, 49°C	0.202	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)



† In series of spectra 51DB through 57DB

## SP53DB IRL-5 1 INCH INSIDE 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79 00+000	2.256-003	3.21946+000
0.50	6.07000+000	7.018-003	1.00284+001
0.75	4.72000+000	1.279-002	1.81297+001
1.00	3.68000+000	1.465-002	2.09887+001
1.25	2.87000+000	2.090-002	2.99627+001
1.50	2.23000+000	3.510-002	4.95936+001
1.75	1.74000+000	3.375-002	4.84996+001
2.00	1.35000+000	3.690-002	5.18332+001
2.25	1.05000+000	3.833-002	5.43715+001
2.50	8.21000-001	4.138-002	5.99627+001
2.75	6.39000-001	5.093-002	7.24396+001
3.00	4.98000-001	5.060-002	7.23597+001
3.25	3.88000-001	4.317-002	6.16568+001
3.50	3.02000-001	4.525-002	6.43805+001
3.75	2.35000-001	3.389-002	4.81592+001
4.00	1.83000-001	2.733-002	3.89511+001
5.00	6.74000-002	1.016-001	3.62671+001
6.75	1.17000-002	9.229-002	1.87891+001
8.00	3.36000-003	5.264-002	1.50397+001
9.00	1.23000-003	3.233-002	1.14676+001
9.75	5.83000-004	1.728-002	8.24934+000
11.50	1.01000-004	3.596-002	7.31272+000
14.00	8.32000-006	6.836-002	9.76142+000
16.50	6.83000-007	5.397-002	7.69623+000
25.33	1.00000-010	5.129-002	2.07085+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP54DB IRL-5 2 INCH INSIDE 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location two inches inside  
vessel; steel

Spectrum Code

Code: 2DB Calculation: BNW 30, 32

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.58 \times 10^{11}$	97.3
>0.5 MeV	1.04 (7.391†)	53.9
>0.1 MeV	1.79	31.3
Thermal, 49°C	0.077	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)



† In series of spectra 51DB through 57DB

## SP54DB IRL-5 2 INCH INSIDE 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.7900+000	1.780-003	3.13386+000
0.50	6.07000+000	5.566-003	9.80676+000
0.75	4.72000+000	1.013-002	1.76965+001
1.00	3.68000+000	1.174-002	2.07262+001
1.25	2.87000+000	1.734-002	3.06569+001
1.50	2.23000+000	2.952-002	5.14312+001
1.75	1.74000+000	3.051-002	5.40449+001
2.00	1.35000+000	3.431-002	5.94298+001
2.25	1.05000+000	3.797-002	6.64072+001
2.50	8.21000-001	4.393-002	7.84884+001
2.75	6.39000-001	5.417-002	9.50003+001
3.00	4.98000-001	5.806-002	1.02366+002
3.25	3.88000-001	5.010-002	8.82401+001
3.50	3.02000-001	5.241-002	9.19370+001
3.75	2.35000-001	3.915-002	6.86080+001
4.00	1.83000-001	3.022-002	5.31135+001
5.00	6.74000-002	1.158-001	5.09666+001
6.75	1.17000-002	1.047-001	2.62761+001
8.00	3.36000-003	5.799-002	2.04298+001
9.00	1.23000-003	3.870-002	1.69264+001
9.75	5.83000-004	1.587-002	9.34267+000
11.50	1.01000-004	2.867-002	7.18769+000
14.00	8.32000-006	6.131-002	1.07948+001
16.50	6.83000-007	4.553-002	8.00499+000
25.33	1.00000-010	2.459-002	1.22417+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP 55DB IRL-5 4 INCH INSIDE 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location four inches inside vessel; steel.

Spectrum Code

Code: 2DB Calculation: BNW 30, 32

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	0.27 × 10 <sup>11</sup>	82.9
>0.5 MeV	0.57 (3.991+)	38.5
>0.1 MeV	1.14	19.4
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)



+ In series of spectra 51DB through 57DB

## SP 55DB IRL-5 4 INCH INSIDE 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.025-003	2.98680+000
0.50	6.07000+000	3.224-003	9.40757+000
0.75	4.72000+000	5.878-003	1.70119+001
1.00	3.68000+000	6.972-003	2.03921+001
1.25	2.87000+000	1.076-002	3.15032+001
1.50	2.23000+000	1.895-002	5.46734+001
1.75	1.74000+000	2.179-002	6.39412+001
2.00	1.35000+000	2.598-002	7.45218+001
2.25	1.05000+000	3.218-002	9.32093+001
2.50	8.21000-001	4.181-002	1.23723+002
2.75	6.39000-001	5.254-002	1.52626+002
3.00	4.98000-001	6.308-002	1.84193+002
3.25	3.88000-001	5.541-002	1.61622+002
3.50	3.02000-001	5.851-002	1.69991+002
3.75	2.35000-001	4.477-002	1.29934+002
4.00	1.83000-001	3.542-002	1.03115+002
5.00	6.74000-002	1.434-001	1.04521+002
6.75	1.17000-002	1.238-001	5.14591+001
8.00	3.36000-003	6.521-002	3.80506+001
9.00	1.23000-003	5.307-002	3.84452+001
9.75	5.83000-004	1.419-002	1.38388+001
11.50	1.01000-004	2.060-002	8.55391+000
14.00	8.32000-006	4.954-002	1.44472+001
16.50	6.83000-007	3.491-002	1.01654+001
25.33	1.00000-010	1.698-002	1.40012+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP56DB IRL-5 6 INCH INSIDE 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment: location six inches inside vessel wall; steel.

Spectrum Code

Code: 2DB Calculation: BNW 30,32

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.12 \times 10^{11}$	69.7
>0.5 MeV	0.31 (1.912†)	28.1
>0.1 MeV	0.68	12.6
Thermal, 49°C	0.016	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51DB through 57DB

## SP56DB IRL-5 6 INCH INSIDE 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	5.612-004	2.90034+000
0.50	6.07000+000	1.746-003	9.03112+000
0.75	4.72000+000	3.214-003	1.64945+001
1.00	3.68000+000	3.856-003	1.99954+001
1.25	2.87000+000	6.207-003	3.22266+001
1.50	2.23000+000	1.122-002	5.74088+001
1.75	1.74000+000	1.399-002	7.27857+001
2.00	1.35000+000	1.752-002	8.91008+001
2.25	1.05000+000	2.392-002	1.22879+002
2.50	8.21000-001	3.468-002	1.81976+002
2.75	6.39000-001	4.330-002	2.23017+002
3.00	4.98000-001	5.745-002	2.97432+002
3.25	3.88000-001	5.106-002	2.64083+002
3.50	3.02000-001	5.505-002	2.83591+002
3.75	2.35000-001	4.246-002	2.18484+002
4.00	1.83000-001	3.095-002	1.59721+002
5.00	6.74000-002	1.528-001	1.97480+002
6.75	1.17000-002	1.418-001	1.04561+002
8.00	3.36000-003	7.399-002	7.65516+001
9.00	1.23000-003	7.581-002	9.73734+001
9.75	5.83000-004	1.849-002	3.19607+001
11.50	1.01000-004	2.917-002	2.14812+001
14.00	8.32000-006	5.835-002	3.01673+001
16.50	6.83000-007	4.135-002	2.13526+001
25.33	1.00000-010	1.099-002	1.60612+000
		-----	
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP57DB IRL-5 7 INCH INSIDE 2DB



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location seven inches inside vessel: steel.

Spectrum Code

Code: 2DB Calculation: BNW so,32

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> /sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	0.084 x 10 <sup>-1</sup>	63.9
>0.5 MeV	0.22 (1.174†)	24.1
>0.1 MeV	0.53	10.1
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)



† In series of spectra 51DB through 57DB

## SP57DB IRL-5 7 INCH INSIDE 2DB

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79 00+000	3.543-004	2.80301+000
0.50	6.07000+000	1.095-003	8.66998+000
0.75	4.72000+000	2.051-003	1.61068+001
1.00	3.68000+000	2.526-003	2.00492+001
1.25	2.87000+000	4.182-003	3.32350+001
1.50	2.23000+000	7.467-003	5.84666+001
1.75	1.74000+000	9.722-003	7.74126+001
2.00	1.35000+000	1.261-002	9.81750+001
2.25	1.05000+000	1.810-002	1.42263+002
2.50	8.21000-001	2.767-002	2.22232+002
2.75	6.39000-001	3.309-002	2.60875+002
3.00	4.98000-001	4.666-002	3.69742+002
3.25	3.88000-001	4.155-002	3.28681+002
3.50	3.02000-001	4.532-002	3.57336+002
3.75	2.35000-001	3.505-002	2.76097+002
4.00	1.83000-001	2.550-002	2.01481+002
5.00	6.74000-002	1.427-001	2.82262+002
6.75	1.17000-002	1.450-001	1.63598+002
8.00	3.36000-003	7.681-002	1.21629+002
9.00	1.23000-003	8.993-002	1.76805+002
9.75	5.83000-004	2.509-002	6.63934+001
11.50	1.01000-004	4.803-002	5.41313+001
14.00	8.32000-006	7.628-002	6.03661+001
16.50	6.83000-007	5.779-002	4.56699+001
25.33	1.00000-010	2.543-002	5.69009+000
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP51PM IRL-5 ACCEL SURV P1MG



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; accelerated irradiation-rate surveillance location; steel and water.

Spectrum Code

Code: P1MG Calculation: Westinghouse 30,33

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$2.45 \times 10^{11}$	159.7
>0.5 Mev	3.17 (43.439†)	123.7
>0.1 Mev	4.19	93.6
Thermal, 49°C	$10.03 \times 10^{11}$	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(\gamma, n)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51PM through 57PM

## SP51PM IRL-5 ACCEL SURV P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	3.001-003	4.35611+000
0.50	6.07000+000	7.675-003	1.11520+001
0.75	4.72000+000	1.491-002	2.14920+001
1.00	3.68000+000	1.535-002	2.23531+001
1.25	2.87000+000	1.767-002	2.57661+001
1.50	2.23000+000	2.241-002	3.21980+001
1.75	1.74000+000	2.197-002	3.20932+001
2.00	1.35000+000	1.819-002	2.59896+001
2.25	1.05000+000	1.491-002	2.15045+001
2.50	8.21000-001	1.444-002	2.12711+001
2.75	6.39000-001	1.557-002	2.25256+001
3.00	4.98000-001	1.237-002	1.79941+001
3.25	3.88000-001	1.200-002	1.74346+001
3.50	3.02000-001	1.246-002	1.80320+001
3.75	2.35000-001	8.555-003	1.23637+001
4.00	1.83000-001	8.718-003	1.26363+001
5.00	6.74000-002	2.677-002	9.71508+000
6.75	1.17000-002	3.240-002	6.70837+000
8.00	3.36400-003	2.033-002	5.90602+000
9.00	1.23000-003	1.660-002	5.98979+000
9.75	5.83000-004	1.204-002	5.84607+000
11.50	1.01400-004	2.915-002	6.02863+000
14.00	8.32000-006	4.093-002	5.94362+000
16.50	6.83000-007	3.825-002	5.54680+000
25.33	1.00000-010	5.633-001	2.31292+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP52PM IRL-5 V WALL SURV P1MG



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84MWt  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; vessel wall surveillance  
location; steel and water.

Spectrum Code

Code: P1MG Calculation: Westinghouse 30, 33

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	1.23 x 10 <sup>-1</sup>	128.8
>0.5 MeV	1.79 (23.262†)	88.4
>0.1 MeV	2.69	58.9
Thermal, 49°C	1.25	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 51PM through 57PM

## SP52PM IRL-5 V WALL SURV P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79 00+000	3.106-003	4.111140+000
0.50	6.07000+000	7.876-003	1.04357+001
0.75	4.72000+000	1.591-002	2.09044+001
1.00	3.68000+000	1.634-002	2.17000+001
1.25	2.87000+000	1.984-002	2.63879+001
1.50	2.23000+000	2.849-002	3.73298+001
1.75	1.74000+000	3.576-002	4.76371+001
2.00	1.35000+000	3.054-002	3.97808+001
2.25	1.05000+000	2.442-002	3.21253+001
2.50	8.21000-001	2.725-002	3.66190+001
2.75	6.39000-001	3.240-002	4.27356+001
3.00	4.98000-001	3.077-002	4.08019+001
3.25	3.88000-001	2.704-002	3.58155+001
3.50	3.02000-001	2.977-002	3.92781+001
3.75	2.35000-001	2.203-002	2.90306+001
4.00	1.83000-001	2.000-002	2.64396+001
5.00	6.74000-002	6.502-002	2.15169+001
6.75	1.17000-002	7.566-002	1.42828+001
8.00	3.36000-003	4.269-002	1.13116+001
9.00	1.23000-003	3.487-002	1.14693+001
9.75	5.83000-004	2.424-002	1.07307+001
11.50	1.01000-004	5.722-002	1.07905+001
14.00	8.32000-006	7.569-002	1.00229+001
16.50	6.83000-007	6.166-002	8.15341+000
25.33	1.00000-010	1.914-001	7.16589+000
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP53PM IRL-5 1 INCH INSIDE P1MG



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location one inch inside  
vessel; steel.

Spectrum Code

Code: P1MG Calculation: Westinghouse 30, 33

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.84 \times 10^{11}$	104.2
>0.5 MeV	1.45 (17.62†)	60.6
>0.1 MeV	2.44	35.9
Thermal, 49°C	0.202	-

\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


† In series of spectra 51PM through 57PM

## SP53PM IRL=5 1 INCH INSIDE P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.197-003	3.70351+000
0.50	6.07000+000	5.625-003	9.49236+000
0.75	4.72000+000	1.201-002	2.00983+001
1.00	3.68000+000	1.246-002	2.10768+001
1.25	2.87000+000	1.619-002	2.74131+001
1.50	2.23000+000	2.608-002	4.35089+001
1.75	1.74000+000	4.045-002	6.86379+001
2.00	1.35000+000	3.559-002	5.90354+001
2.25	1.05000+000	2.803-002	4.69603+001
2.50	8.21000-001	3.556-002	6.08420+001
2.75	6.39000-001	4.624-002	7.76709+001
3.00	4.98000-001	4.947-002	8.35415+001
3.25	3.88000-001	4.094-002	6.90477+001
3.50	3.02000-001	4.711-002	7.91515+001
3.75	2.35000-001	3.608-002	6.05470+001
4.00	1.83000-001	2.990-002	5.03362+001
5.00	6.74000-002	1.029-001	4.33855+001
6.75	1.17000-002	1.106-001	2.65790+001
8.00	3.36000-003	4.958-002	1.67295+001
9.00	1.23000-003	4.106-002	1.71989+001
9.75	5.83000-004	2.569-002	1.44875+001
11.50	1.01000-004	5.807-002	1.39458+001
14.00	8.32000-006	6.953-002	1.17249+001
16.50	6.83000-007	3.539-002	5.95943+000
25.33	1.00000-010	4.324-002	2.06195+000
---			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP55PM IRL-5 4 INCH INSIDE P1MG



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location four inches inside  
vessel: steel

Spectrum Code

Code: P1MG Calculation: Westinghouse 30,33

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	$0.36 \times 10^{-1}$	61.1
>0.5 MeV	0.82 (9.31+)	27.0
>0.1 MeV	1.77	12.5
Thermal, 49 °C	0.035	-

\*Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)


+In series of spectra 51PM through 57PM

## SP55PM IRL-5 4 INCH INSIDE P1MG

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	6.509+004	2.94023+000
0.50	6.07000+000	1.680+003	7.59561+000
0.75	4.72000+000	4.037+003	1.81049+001
1.00	3.68000+000	4.308+003	1.95285+001
1.25	2.87000+000	6.272+003	2.84620+001
1.50	2.23000+000	1.269+002	5.67459+001
1.75	1.74000+000	2.934+002	1.33425+002
2.00	1.35000+000	2.664+002	1.18449+002
2.25	1.05000+000	2.186+002	9.81169+001
2.50	8.21000+001	3.403+002	1.56033+002
2.75	6.39000+001	5.011+002	2.25564+002
3.00	4.98000+001	6.400+002	2.89624+002
3.25	3.88000+001	5.364+002	2.42472+002
3.50	3.02000+001	6.278+002	2.82647+002
3.75	2.35000+001	5.190+002	2.33430+002
4.00	1.83000+001	4.142+002	1.86849+002
5.00	6.74000+002	1.456+001	1.64484+002
6.75	1.17000+002	1.513+001	9.75080+001
8.00	3.36000+003	5.170+002	4.67543+001
9.00	1.23000+003	4.148+002	4.65722+001
9.75	5.83000+004	2.340+002	3.53590+001
11.50	1.01000+004	4.717+002	3.03539+001
14.00	8.32000+006	4.886+002	2.20810+001
16.50	6.83000+007	1.429+002	6.45079+000
25.33	1.00000+010	1.079+002	1.37820+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP57PM IRL-5 7 INCH INSIDE P1MG



Reactor Description

Name: Industrial Reactor Laboratories, Inc.  
 Type: Pool, research Power Level: 4.84 MWT  
 Coolant: Light water Moderator: Light water  
 Location: Plainsboro, New Jersey

Spectrum Facility Description

Simulated vessel wall experiment; location seven inches inside vessel; steel

Spectrum Code

Code: P1MG Calculation: Westinghouse 30,33

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\bar{\sigma}$ , mb
>1 MeV	0.098 x 10 <sup>11</sup>	54.9
>0.5 MeV	0.35 (3.91+)	15.3
>0.1 MeV	0.87	6.2
Thermal, 49°C	0.035	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

+ In series of spectra 51PM through 57PM

## SP57PM IRL-5 7 INCH INSIDE P1MG


LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79 00+000	2.348-004	2.41766+000
0.50	6.07000+000	6.153-004	6.34094+000
0.75	4.72000+000	1.634-003	1.67019+001
1.00	3.68000+000	1.721-003	1.77806+001
1.25	2.87000+000	2.700-003	2.79263+001
1.50	2.23000+000	6.460-003	6.58259+001
1.75	1.74000+000	2.000-002	2.07257+002
2.00	1.35000+000	1.784-002	1.80686+002
2.25	1.05000+000	1.602-002	1.63863+002
2.50	8.21000-001	2.836-002	2.96364+002
2.75	6.39000-001	4.190-002	4.29821+002
3.00	4.98000-001	5.935-002	6.12054+002
3.25	3.88000-001	5.019-002	5.17004+002
3.50	3.02000-001	5.945-002	6.09942+002
3.75	2.35000-001	5.119-002	5.24689+002
4.00	1.83000-001	4.036-002	4.14922+002
5.00	6.74000-002	1.422-001	3.65989+002
6.75	1.17000-002	1.557-001	2.28678+002
8.00	3.36000-003	6.052-002	1.24713+002
9.00	1.23000-003	4.581-002	1.17197+002
9.75	5.83000-004	2.746-002	9.45732+001
11.50	1.01000-004	5.765-002	8.45499+001
14.00	8.32000-006	6.337-002	6.32600+001
16.50	6.83000-007	3.027-002	3.11267+001
25.33	1.00000-010	1.898-002	5.32568+000
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U



**HEAVY WATER MODERATED REACTORS**

SP1 CVTR 10-L



Reactor Description

Name: Carolinias-Virginia Tube Reactor  
 Type: Power, pressure tube Power Level: 56 MWT  
 Coolant: Heavy water Moderator: Heavy water  
 Location: Parr, South Carolina

Spectrum Facility Description

Position 10-L; unfueled pressure tube location in heavy water  
coolant; steel and heavy water.

Spectrum Code

Code: 2DXY Calculation: BNW 11, 12

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	$3.11 \times 10^{11}$	116.7
>0.5 MeV	4.43	81.8
>0.1 MeV	7.48	48.5
Thermal, 49 °C	$6.82 \times 10^{13}$	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)  
 Fluxes calculated @ 53.2 MWT

SP1 CVTR 10-L

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	7.576+005	2.89123+000
0.50	6.07000+000	2.198+004	8.39763+000
0.75	4.72000+000	3.997+004	1.51451+001
1.00	3.68000+000	5.663+004	2.16863+001
1.25	2.87000+000	1.001+003	3.83966+001
1.50	2.23000+000	1.420+003	5.36363+001
1.75	1.74000+000	1.289+003	4.95300+001
2.00	1.35000+000	1.103+003	4.14297+001
2.25	1.05000+000	1.010+003	3.82900+001
2.50	8.21000+001	8.675+004	3.36069+001
2.75	6.39000+001	1.245+003	4.73559+001
3.00	4.98000+001	9.594+004	3.66777+001
3.25	3.88000+001	8.499+004	3.24567+001
3.50	3.02000+001	1.090+003	4.14755+001
3.75	2.35000+001	9.067+004	3.44514+001
4.00	1.83000+001	1.287+003	4.90457+001
5.00	6.74000+002	4.985+003	4.75725+001
9.00	1.23000+003	3.752+002	8.93241+001
13.00	2.26000+005	4.689+002	1.11813+002
17.00	4.14000+007	5.913+002	1.40893+002
25.33	1.00000+010	8.372+001	9.58097+002
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U

SP22 HWCTR GRAY ROD



Reactor Description

Name: Heavy Water Components Test Reactor  
 Type: Test Power Level: 45 MWT  
 Coolant: Heavy water Moderator: Heavy water  
 Location: Savannah River Laboratories, Aiken, S. Carolina

Spectrum Facility Description

Gray control rod location: above mid-plane; steel and heavy water

Spectrum Code

Code: Program S Calculation: BNW 12,13

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	3.34 x 10 <sup>-2</sup>	124.8
>0.5 MeV	4.73	88.1
>0.1 MeV	7.35	56.7
Thermal, 232°C	1.90 x 10 <sup>-4</sup>	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

Flux calculated at 43 MWT

## SP22 HWCTR GRAY ROD


LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.714-004	3.37899+000
0.50	6.07000+000	4.690-004	9.25758+000
0.75	4.72000+000	8.216-004	1.60858+001
1.00	3.68000+000	1.063-003	2.10279+001
1.25	2.87000+000	1.777-003	3.51934+001
1.50	2.23000+000	2.696-003	5.26287+001
1.75	1.74000+000	2.009-003	3.98825+001
2.00	1.35000+000	2.041-003	3.96127+001
2.25	1.05000+000	1.934-003	3.79007+001
2.50	8.21000-001	1.848-003	3.69852+001
2.75	6.39000-001	2.356-003	4.62968+001
3.00	4.98000-001	1.729-003	3.41645+001
3.25	3.88000-001	1.628-003	3.21131+001
3.50	3.02000-001	2.440-003	4.79631+001
3.75	2.35000-001	2.300-003	4.51538+001
4.00	1.83000-001	2.587-003	5.09519+001
5.00	6.74000-002	2.493-003	1.22935+001
9.00	1.23000-003	1.283-002	1.57796+001
13.00	2.26000-005	6.650-002	8.19417+001
17.00	4.14000-007	1.322-001	1.62789+002
25.33	1.00000-010	7.581-001	4.48286+002
		1,000+000	

ONE LETHARGY INTERVAL = 0.25U



## **GRAPHITE MODERATED REACTORS**

SP8 BGR W-44



Reactor Description

Name: Brookhaven Graphite Reactor  
 Type: Research, pile Power Level: 20 MWt  
 Coolant: Air Moderator: Graphite  
 Location: Brookhaven National Laboratory, Upton, L. I., New York

Spectrum Facility Description

Horizontal experiment hole, W-44; unfueled; steel, air and aluminum.

Spectrum Code

Code: 2 DXY Calculation: BNW 12, 13

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	$3.10 \times 10^{11}$	69.7
>0.5 MeV	5.22	41.4
>0.1 MeV	9.74	22.2
Thermal, 49°C	$5.85 \times 10^{12}$	-


\* Fast flux based on  $^{54}\text{Fe}(n, p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n, \gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP8 BGR W-44

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	9.811+003	1.49186+000
0.50	6.07000+000	3.780+004	5.75386+000
0.75	4.72000+000	1.077+003	1.62595+001
1.00	3.68000+000	1.475+003	2.25024+001
1.25	2.87000+000	2.244+003	3.42792+001
1.50	2.23000+000	4.417+003	6.64770+001
1.75	1.74000+000	5.710+003	8.73904+001
2.00	1.35000+000	6.806+003	1.01845+002
2.25	1.05000+000	7.124+003	1.07647+002
2.50	8.21000+001	6.525+003	1.00715+002
2.75	6.39000+001	7.503+003	1.13689+002
3.00	4.98000+001	6.454+003	9.83066+001
3.25	3.88000+001	7.547+003	1.14819+002
3.50	3.02000+001	7.075+003	1.07226+002
3.75	2.35000+001	5.611+003	8.49438+001
4.00	1.83000+001	6.465+003	9.81599+001
17.00	4.14000+007	3.649+001	1.06610+002
25.33	1.00000+010	5.586+001	2.54683+002
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

SP39 GMWC, KE COLD NO SHIELD



Reactor Description

Name: K-East  
 Type: Production Power Level: Not available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility; no thermal neutron shield; flux  
 ratio Thermal (49°C): Fast >0.5 MeV = 9:1

Spectrum Code

Code: DTF-IV Calculation: BNW 28, 34

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section a, mb
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 49°C	-	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP39 GMWC, KE COLD NG SHIELD

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	1.524e+004	1.59899e+000
0.50	6.07000e+000	5.743e+004	6.03269e+000
0.75	4.72000e+000	1.864e+003	1.97310e+001
1.00	3.68000e+000	1.893e+003	1.99329e+001
1.25	2.87000e+000	2.657e+003	3.01214e+001
1.50	2.23000e+000	6.357e+003	6.60285e+001
1.75	1.74000e+000	7.339e+003	7.75118e+001
2.00	1.35000e+000	8.608e+003	8.88852e+001
2.25	1.05000e+000	8.812e+003	9.18833e+001
2.50	8.21000e+001	8.387e+003	8.93342e+001
2.75	6.39000e+001	9.577e+003	1.00144e+002
3.00	4.98000e+001	8.244e+003	8.66563e+001
3.25	3.88000e+001	8.212e+003	8.62165e+001
3.50	3.02000e+001	8.595e+003	8.98871e+001
3.75	2.35000e+001	6.636e+003	6.93277e+001
4.00	1.83000e+001	7.010e+003	7.34545e+001
5.00	6.74000e+002	2.481e+002	6.50956e+001
6.75	1.17000e+002	3.872e+002	5.79479e+001
8.00	3.36000e+003	2.726e+002	5.72633e+001
9.00	1.23000e+003	2.521e+002	6.57282e+001
9.75	5.83000e+004	1.735e+002	6.09172e+001
11.50	1.01000e+004	4.710e+002	7.04035e+001
14.00	8.32000e+006	7.031e+002	7.38025e+001
16.50	6.63000e+007	7.340e+002	7.69399e+001
25.33	1.00000e+010	5.807e+001	1.72358e+002
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP40 GMWC COLD INTER. SHIELD



Reactor Description

Name: K-East  
 Type: production Power Level: Not available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility; "intermediate" thermal neutron shield; flux ratio Thermal (49°C): Fast >0.5 MeV = 5:1

Spectrum Code

Code: DTF-IV Calculation: BNW 34

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 49°C	-	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

## SP40 GMWC COLD INTER, SHIELD

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e+000	2.054e+004	1.59899e+000
0.50	6.07000e+000	7.742e+004	6.03269e+000
0.75	4.72000e+000	2.553e+003	1.97310e+001
1.00	3.68000e+000	2.552e+003	1.99329e+001
1.25	2.87000e+000	3.852e+003	3.01214e+001
1.50	2.23000e+000	8.570e+003	6.60285e+001
1.75	1.74000e+000	9.893e+003	7.75118e+001
2.00	1.35000e+000	1.160e+002	8.88852e+001
2.25	1.05000e+000	1.188e+002	9.18833e+001
2.50	8.21000e-001	1.131e+002	8.93342e+001
2.75	6.39000e-001	1.291e+002	1.00144e+002
3.00	4.98000e-001	1.111e+002	8.66563e+001
3.25	3.88000e-001	1.107e+002	8.62165e+001
3.50	3.02000e-001	1.159e+002	8.98871e+001
3.75	2.35000e-001	8.946e+003	6.93277e+001
4.00	1.83000e-001	9.450e+003	7.34545e+001
5.00	6.74000e-002	3.345e+002	6.50956e+001
6.75	1.17000e-002	5.220e+002	5.79479e+001
8.00	3.36000e-003	3.675e+002	5.72633e+001
9.00	1.23000e-003	3.398e+002	6.57282e+001
9.75	5.83000e-004	2.340e+002	6.09172e+001
11.50	1.01000e-004	6.349e+002	7.04035e+001
14.00	8.32000e-006	9.479e+002	7.38118e+001
16.50	6.83000e-007	9.888e+002	7.68884e+001
25.33	1.00000e-010	4.348e+001	9.57331e+001
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP41 GMWC COLD FULL SHIELD



Reactor Description

Name: K-East  
 Type: Production Power Level: Not Available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility, "full" thermal neutron shield; flux ratio Thermal (49°C): Fast >0.5 MeV = 1.8:1

Spectrum Code

Code: DTF-IV Calculation: BNW 34

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section g, mb
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 49°C	-	-


\*Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP41 GMWC COLD FULL SHIELD

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000e+000	2.847e+004	1.59899e+000
0.50	6.07000e+000	1.073e+003	6.03269e+000
0.75	4.72000e+000	3.539e+003	1.97310e+001
1.00	3.68000e+000	3.537e+003	1.99329e+001
1.25	2.87000e+000	5.339e+003	3.01214e+001
1.50	2.23000e+000	1.188e+002	6.60285e+001
1.75	1.74000e+000	1.371e+002	7.75118e+001
2.00	1.35000e+000	1.608e+002	8.88852e+001
2.25	1.05000e+000	1.646e+002	9.18833e+001
2.50	8.21000e-001	1.567e+002	8.93342e+001
2.75	6.39000e-001	1.729e+002	1.00144e+002
3.00	4.98000e-001	1.540e+002	8.66563e+001
3.25	3.88000e-001	1.534e+002	8.62165e+001
3.50	3.02000e-001	1.606e+002	8.98871e+001
3.75	2.35000e-001	1.240e+002	6.93277e+001
4.00	1.83000e-001	1.310e+002	7.34545e+001
5.00	6.74000e-002	4.636e+002	6.50956e+001
6.75	1.17000e-002	7.235e+002	5.79479e+001
8.00	3.36000e-003	5.094e+002	5.72633e+001
9.00	1.23000e-003	4.710e+002	6.57282e+001
9.75	5.83000e-004	3.243e+002	6.09172e+001
11.50	1.01000e-004	8.800e+002	7.04035e+001
14.00	8.32000e-006	1.314e+001	7.38274e+001
16.50	6.83000e-007	1.369e+001	7.67989e+001
25.33	1.00000e-010	2.167e+001	3.44305e+001
		----- 1.000e+000	

ONE LETHARGY INTERVAL = 0.250

SP42C KE COLD, CD



Reactor Description

Name: K-East  
 Type: Production Power Level: Not available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility, 0.040-inch Cd shield; flux ratio  
Thermal (49°C): Fast >0.5 MeV = 1.5:1.

Spectrum Code

Code: DTF-IV Calculation: BNW 28

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 49°C	-	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP42C KE COLD: CD

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000e+000	2.954e-004	1.59899e+000
0.50	6.07000e+000	1.113e-003	6.03269e+000
0.75	4.72000e+000	3.672e-003	1.97310e+001
1.00	3.68000e+000	3.670e-003	1.99329e+001
1.25	2.87000e+000	5.540e-003	3.01214e+001
1.50	2.23000e+000	1.232e-002	6.60285e+001
1.75	1.74000e+000	1.423e-002	7.75118e+001
2.00	1.35000e+000	1.669e-002	8.88852e+001
2.25	1.05000e+000	1.708e-002	9.18833e+001
2.50	8.21000e+001	1.626e-002	8.93342e+001
2.75	6.39000e+001	1.857e-002	1.00144e+002
3.00	4.98000e+001	1.598e-002	8.66563e+001
3.25	3.88000e+001	1.592e-002	8.62165e+001
3.50	3.02000e+001	1.666e-002	8.98871e+001
3.75	2.35000e+001	1.286e-002	6.93277e+001
4.00	1.83000e+001	1.359e-002	7.34545e+001
5.00	6.74000e+002	4.810e-002	6.50956e+001
6.75	1.17000e+002	7.507e-002	5.79479e+001
8.00	3.36000e+003	5.285e-002	5.72633e+001
9.00	1.23000e+003	4.886e-002	6.57282e+001
9.75	5.83000e+004	3.364e-002	6.09172e+001
11.50	1.01000e+004	9.130e-002	7.04035e+001
14.00	8.32000e+006	1.364e-001	7.38302e+001
16.50	6.83000e+007	1.420e-001	7.67831e+001
25.33	1.00000e+010	1.874e-001	2.86847e+001
		1,000e+000	

ONE LETHARGY INTERVAL = 0.25U

SP43CB KE COLD, CD+B



Reactor Description

Name: K-East  
 Type: Production Power Level: Not Available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility; 1-1/8 inch <sup>10</sup>B plus 0.040-inch Cd; flux ratio Thermal (49°C): Fast >0.5 MeV = 0.5:1.

Spectrum Code

Code: DTF-IV Calculation: BNW 28

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 49°C	-	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

SP43CB KE COLD, CD+B

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000e000	4.810e-004	1.59498e000
0.50	6.07000e000	1.822e-003	6.04836e000
0.75	4.72000e000	6.027e-003	1.98421e001
1.00	3.68000e000	5.996e-003	1.99502e001
1.25	2.87000e000	9.001e-003	2.99826e001
1.50	2.23000e000	2.003e-002	6.57359e001
1.75	1.74000e000	2.319e-002	7.73811e001
2.00	1.35000e000	2.730e-002	8.90943e001
2.25	1.05000e000	2.802e-002	9.23408e001
2.50	8.21000e-001	2.672e-002	8.99485e001
2.75	6.39000e-001	3.050e-002	1.00778e002
3.00	4.98000e-001	2.624e-002	8.71690e001
3.25	3.88000e-001	2.611e-002	8.66428e001
3.50	3.02000e-001	2.724e-002	9.00303e001
3.75	2.35000e-001	2.104e-002	6.94665e001
4.00	1.83000e-001	2.219e-002	7.34651e001
5.00	6.74000e-002	7.810e-002	6.47468e001
6.75	1.17000e-002	1.183e-001	5.59235e001
8.00	3.36000e-003	7.812e-002	5.18520e001
9.00	1.23000e-003	6.679e-002	5.50355e001
9.75	5.83000e-004	4.157e-002	4.61135e001
11.50	1.01000e-004	9.297e-002	4.39162e001
14.00	8.32000e-006	8.387e-002	2.78217e001
16.50	6.83000e-007	3.607e-002	1.19475e001
25.33	1.00000e-010	1.023e-001	9.59768e000
		----- 1.000e000	

ONE LETHARGY INTERVAL = 0.25U

SP39UH KE 550F O SHIELD



Reactor Description

Name: K-East  
 Type: Production Power Level: Not available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility; no thermal neutron shield; flux ratio Thermal (288°C): Fast >0.5 MeV = 10.9:1.

Spectrum Code

Code: DTF-IV Calculation: BNW 34

Lower Energy Limit	Neutron Flux* $\text{n/cm}^2 \cdot \text{sec}^{-1}$	Spectrum-Averaged Cross-Section $\sigma, \text{mb}$
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 288°C	-	-


\* Fast flux based on  $^{54}\text{Fe}(n,p)^{54}\text{Mn}$  reaction (8); Thermal flux based on  $^{59}\text{Co}(n,\gamma)^{60}\text{Co}$  reaction or Ag-Co technique (11)

SP39UH KE 550F 0 SHIELD

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLLX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.069+004	1.54371+000
0.50	6.07000+000	4.233+004	6.00689+000
0.75	4.72000+000	1.404+003	1.97689+001
1.00	3.68000+000	1.293+003	1.83877+001
1.25	2.87000+000	2.148+003	3.05871+001
1.50	2.23000+000	4.960+003	6.95970+001
1.75	1.74000+000	5.374+003	7.66908+001
2.00	1.35000+000	6.218+003	8.67485+001
2.25	1.05000+000	6.329+003	8.91622+001
2.50	8.21000+001	5.571+003	8.01754+001
2.75	6.39000+001	7.089+003	1.00145+002
3.00	4.98000+001	5.894+003	8.37125+001
3.25	3.88000+001	9.460+003	1.34193+002
3.50	3.02000+001	1.092+002	1.54296+002
3.75	2.35000+001	7.329+003	1.03447+002
4.00	1.83000+001	9.317+003	1.31897+002
5.00	6.74000+002	3.072+002	1.08905+002
6.75	1.17000+002	4.861+002	9.86958+001
8.00	3.36000+003	3.406+002	9.66713+001
9.00	1.23000+003	3.249+002	1.14456+002
9.75	5.83000+004	2.173+002	1.03053+002
11.50	1.01000+004	5.983+002	1.20843+002
14.00	8.32000+006	8.763+002	1.24290+002
16.50	6.83000+007	9.256+002	1.31090+002
25.33	1.00000+010	5.063+001	2.03853+002
		----- 1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP42UH KE 550F CD SHIELD



Reactor Description

Name: K-East  
 Type: Production Power Level: Not available  
 Coolant: Light water Moderator: Graphite  
 Location: Hanford, Washington

Spectrum Facility Description

Tailored spectrum facility; 0.040-inch Cd shield; flux ratio  
 Thermal (288°C): Fast >0.5 MeV = 1.4:1.

Spectrum Code

Code: DTF-IV Calculation: BNW 28

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	77.2
>0.5 MeV	-	46.3
>0.1 MeV	-	30.5
Thermal, 288°C	-	-

\*Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)

## SP426H KE 550F Cd SHIELD


LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000e+000	3.790e-004	2.69517e+000
0.50	6.07000e+000	1.201e-003	8.55308e+000
0.75	4.72000e+000	2.839e-003	2.00482e+001
1.00	3.68000e+000	2.357e-003	1.68198e+001
1.25	2.87000e+000	3.878e-003	2.77061e+001
1.50	2.23000e+000	8.900e-003	6.26554e+001
1.75	1.74000e+000	9.661e-003	6.91605e+001
2.00	1.35000e+000	1.121e-002	7.84876e+001
2.25	1.05000e+000	1.144e-002	8.08460e+001
2.50	8.21000e-001	1.009e-002	7.28695e+001
2.75	6.39000e-001	1.328e-002	9.83876e+001
3.00	4.98000e-001	1.284e-002	9.14740e+001
3.25	3.88000e-001	1.923e-002	1.36839e+002
3.50	3.02000e-001	1.963e-002	1.39164e+002
3.75	2.35000e-001	1.292e-002	9.15122e+001
4.00	1.83000e-001	1.646e-002	1.16867e+002
5.00	6.74000e-002	5.426e-002	9.64978e+001
6.75	1.17000e-002	8.621e-002	8.74501e+001
8.00	3.36000e-003	6.017e-002	8.56584e+001
9.00	1.23000e-003	5.738e-002	1.01417e+002
9.75	5.83000e-004	3.838e-002	9.13128e+001
11.50	1.01000e-004	1.057e-001	1.07079e+002
14.00	8.32000e-006	1.549e-001	1.10227e+002
16.50	6.83000e-007	1.627e-001	1.15611e+002
25.33	1.00000e-010	1.234e-001	2.48174e+001
		1.000e+000	

ONE LETHARGY INTERVAL = 0.25U



**ORGANIC MODERATED REACTORS**

SP35 OMRE CORE CENTER



Reactor Description

Name: Organic Moderated Reactor Experiment  
 Type: power, experimental Power Level: 8 MWT  
 Coolant: organic Moderator: organic  
 Location: National Reactor Testing Station, Idaho Falls, Idaho  
(decommissioned)

Spectrum Facility Description

Location in core center, mid plane: organic, steel, uranium.

Spectrum Code

Code: Program S Calculation: BNW 1<sup>e</sup>

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	110.4
>0.5 Mev	(31.47†)	64.0
>0.1 Mev	-	49.3
Thermal, 20°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 35, 36 and 35, 37

## SP35 OMRE CORE CENTER

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	1.837-003	2.34400+000
0.50	6.07000+000	5.651-003	7.21867+000
0.75	4.72000+000	1.359-002	1.72158+001
1.00	3.68000+000	1.798-002	2.30170+001
1.25	2.87000+000	2.854-002	3.65835+001
1.50	2.23000+000	4.112-002	5.19438+001
1.75	1.74000+000	4.062-002	5.21814+001
2.00	1.35000+000	4.005-002	5.02918+001
2.25	1.05000+000	3.749-002	4.75359+001
2.50	8.21000-001	3.141-002	4.06869+001
2.75	6.39000-001	3.171-002	4.03287+001
3.00	4.98000-001	2.516-002	3.21580+001
3.25	3.88000-001	2.766-002	3.53172+001
3.50	3.02000-001	2.368-002	3.01116+001
3.75	2.35000-001	1.743-002	2.21451+001
4.00	1.83000-001	1.853-002	2.36094+001
5.00	6.74000-002	5.329-002	1.70020+001
9.00	1.23000-003	1.380-001	1.09856+001
13.00	2.26000-005	1.220-001	9.72911+000
17.00	4.14000-007	1.083-001	8.63251+000
25.33	1.00000-010	1.759-001	6.73152+000
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP36 OMRE GRID PLATE



Reactor Description

Name: Organic Moderated Reactor Experiment  
 Type: Power, experimental Power Level: ~8 MWt  
 Coolant: Organic Moderator: Organic  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description (decommissioned)

Location 3/4-inch into the 1-1/2-inch thick grid plate; steel.

Spectrum Code

Code: Program S Calculation: BNW 19

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> .sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	2.30 x 10 <sup>11</sup>	153.2
>0.5 MeV	3.09 (0.1862†)	113.8
>0.1 MeV	4.21	83.6
Thermal, 20°C	-	-


\*Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)  
 Flux calculated @ 2.76 MWt  
 †In series of spectra 35, 36

## SP36 OMRE GRID PLATE

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79 00+000	2.428-003	3.10104+000
0.50	6.07000+000	9.878-003	1.26275+001
0.75	4.72000+000	1.875-002	2.37722+001
1.00	3.68000+000	1.494-002	1.91379+001
1.25	2.87000+000	1.864-002	2.39131+001
1.50	2.23000+000	2.617-002	3.30826+001
1.75	1.74000+000	2.540-002	3.26512+001
2.00	1.35000+000	2.417-002	3.03732+001
2.25	1.05000+000	2.334-002	2.96171+001
2.50	8.21000-001	2.089-002	2.70752+001
2.75	6.39000-001	2.211-002	2.81325+001
3.00	4.98000-001	1.931-002	2.46993+001
3.25	3.88000-001	1.871-002	2.39032+001
3.50	3.02000-001	1.647-002	2.09584+001
3.75	2.35000-001	1.239-002	1.57523+001
4.00	1.83000-001	1.135-002	1.44782+001
5.00	6.74000-002	3.872-002	1.23642+001
9.00	1.23000-003	8.407-002	6.69703+000
13.00	2.26000-005	7.877-002	6.28573+000
17.00	4.14000-007	6.988-002	5.57201+000
25.33	1.00000-010	4.436-001	1.69874+001
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

SP37 OMRE VESSEL WALL



Reactor Description

Name: Organic Moderated Reactor Experiment  
 Type: Power, experiment Power Level: ~8 MWt  
 Coolant: Organic Moderator: Organic  
 Location: National Reactor Testing Station, Idaho Falls, Idaho  
(decommissioned)

Spectrum Facility Description

Location 1/4 inch into pressure vessel wall.

Spectrum Code

Code: Program S Calculation: BNW 19

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	$2.08 \times 10^{11}$	140.2
>0.5 MeV	2.88 (0.0783†)	101.4
>0.1 MeV	4.05	72.0
Thermal, 20°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)

Flux calculated @ 2.76 MWt

†In series of spectra 35, 37

## SP37 OMRE VESSEL WALL


LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.543-003	4.12390+000
0.50	6.07000+000	5.250-003	8.52316+000
0.75	4.72000+000	1.579-002	2.54175+001
1.00	3.68000+000	1.208-002	1.96647+001
1.25	2.87000+000	1.568-002	2.55481+001
1.50	2.23000+000	2.216-002	3.55661+001
1.75	1.74000+000	2.310-002	3.77007+001
2.00	1.35000+000	2.272-002	3.62659+001
2.25	1.05000+000	2.104-002	3.39104+001
2.50	8.21000-001	2.073-002	3.41345+001
2.75	6.39000-001	2.062-002	3.33255+001
3.00	4.98000-001	1.811-002	2.94208+001
3.25	3.88000-001	1.954-002	3.17113+001
3.50	3.02000-001	1.570-002	2.53703+001
3.75	2.35000-001	1.104-002	1.78311+001
4.00	1.83000-001	1.317-002	2.13258+001
5.00	6.74000-002	3.691-002	1.49652+001
9.00	1.23000-003	9.357-002	9.46598+000
13.00	2.26000-005	9.811-002	9.94232+000
17.00	4.14000-007	1.241-001	1.25637+001
25.33	1.00000-010	3.880-001	1.88706+001
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U



**FAST BREEDER REACTOR**

S31F24 EBR-II CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm, Z = + 16.8cm

Spectrum Code

Code: SAND-II Calculation: WADCO 36

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	78.5
>0.5 MeV	(4.08 x 10 <sup>14</sup> +)	43.3
>0.1 MeV	-	19.3
Thermal, - °C	-	-


\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)  
 † In series of spectra 31F24 through 31F26 (above 5D3)

## S31F24 EBR-II CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.128-003	2.33476+000
0.50	6.07000+000	2.190-003	4.53996+000
0.75	4.72000+000	7.052-003	1.44971+001
1.00	3.68000+000	1.165-002	2.41986+001
1.25	2.87000+000	2.045-002	4.25345+001
1.50	2.23000+000	2.881-002	5.90522+001
1.75	1.74000+000	3.368-002	7.01961+001
2.00	1.35000+000	4.167-002	8.49132+001
2.25	1.05000+000	4.696-002	9.66394+001
2.50	8.21000-001	4.199-002	8.82548+001
2.75	6.39000-001	5.123-002	1.05720+002
3.00	4.98000-001	7.954-002	1.64994+002
3.25	3.88000-001	1.038-001	2.15113+002
3.50	3.02000-001	1.035-001	2.13505+002
3.75	2.35000-001	7.551-002	1.55679+002
4.00	1.83000-001	7.569-002	1.56507+002
5.00	6.74000-002	1.605-001	8.31136+001
6.75	1.17000-002	1.068-001	3.15407+001
8.00	3.36000-003	1.770-003	7.33356-001
9.00	1.23000-003	3.825-003	1.96037+000
9.75	5.83000-004	1.506-003	1.04313+000
11.50	1.01000-004	2.911-004	8.58750-002
14.00	8.32000-006	4.465-004	9.24874-002
16.50	6.83000-007	1.127-005	2.33113-003
25.33	1.00000-010	8.561-007	5.01422-005
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F25 CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm Z = +31.7cm

Spectrum Code

Code: SAND-II Calculation: WADCO<sup>35</sup>

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	66.0
>0.5 MeV	(1.41 x 10 <sup>14</sup> †)	24.9
>0.1 MeV	-	10.1
Thermal, - °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F24 through 31F26 (above & 5D3)

## S31F25 CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	5.532-004	1.99206+000
0.50	6.07000+000	1.065-003	3.84011+000
0.75	4.72000+000	3.410-003	1.21919+001
1.00	3.68000+000	6.172-003	2.23025+001
1.25	2.87000+000	1.262-002	4.56643+001
1.50	2.23000+000	1.983-002	7.06926+001
1.75	1.74000+000	2.310-002	8.37177+001
2.00	1.35000+000	2.742-002	9.71849+001
2.25	1.05000+000	3.608-002	1.29126+002
2.50	8.21000-001	3.996-002	1.46084+002
2.75	6.39000-001	8.915-002	3.19894+002
3.00	4.98000-001	1.067-001	3.84998+002
3.25	3.88000-001	1.422-001	5.12300+002
3.50	3.02000-001	1.481-001	5.31402+002
3.75	2.35000-001	1.091-001	3.91173+002
4.00	1.83000-001	1.035-001	3.72171+002
5.00	6.74000-002	6.361-002	5.72736+001
6.75	1.17000-002	4.171-002	2.14193+001
8.00	3.36000-003	6.948-003	5.03723+000
9.00	1.23000-003	9.587-003	8.37927+000
9.75	5.83000-004	4.948-003	5.95983+000
11.50	1.01000-004	2.948-003	1.51224+000
14.00	8.32000-006	1.168-003	4.20840-001
16.50	6.83000-007	8.788-005	3.16157-002
25.33	1.00000-010	6.297-006	6.41381-004
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F26 CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm Z = +44.2cm

Spectrum Code

Code: SAND-II Calculation: WADCO 35

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	57.5
>0.5 MeV	(5.62 x 10 <sup>-3</sup> +)	18.1
>0.1 MeV	-	5.1
Thermal, - °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F24 through 31F26 (above 5D3)

## S31F26 CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.706-004	1.98201+000
0.50	6.07000+000	3.128-004	3.63774+000
0.75	4.72000+000	9.181-004	1.05881+001
1.00	3.68000+000	1.774-003	2.06752+001
1.25	2.87000+000	3.988-003	4.65325+001
1.50	2.23000+000	6.877-003	7.90663+001
1.75	1.74000+000	8.370-003	9.78642+001
2.00	1.35000+000	1.009-002	1.15374+002
2.25	1.05000+000	1.355-002	1.56353+002
2.50	8.21000-001	1.570-002	1.85061+002
2.75	6.39000-001	4.072-002	4.71326+002
3.00	4.98000-001	5.343-002	6.21706+002
3.25	3.88000-001	7.755-002	9.01371+002
3.50	3.02000-001	8.973-002	1.03883+003
3.75	2.35000-001	7.019-002	8.11682+002
4.00	1.83000-001	7.383-002	8.56362+002
5.00	6.74000-002	1.514-001	4.39854+002
6.75	1.17000-002	2.510-001	4.15867+002
8.00	3.36000-003	3.395-002	7.89333+001
9.00	1.23000-003	3.535-002	1.02036+002
9.75	5.83000-004	1.799-002	6.98968+001
11.50	1.01000-004	2.598-002	4.29904+001
14.00	8.32000-006	1.545-002	1.79539+001
16.50	6.83000-007	1.560-003	1.81022+000
25.33	1.00000-010	6.414-005	2.10732-002
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F27 CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWt  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm Z = -4.6cm

Spectrum Code

Code: SAND-II Calculation: WADCO 35

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	79.8
>0.5 MeV	(6.75 x 10 <sup>4</sup> †)	47.8
>0.1 MeV	-	24.7
Thermal, - °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F27 through 31F29 (below 5D3)

## S31F27 CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.613-003	2.41674+000
0.50	6.07000+000	3.493-003	5.23901+000
0.75	4.72000+000	9.957-003	1.48102+001
1.00	3.68000+000	1.572-002	2.36302+001
1.25	2.87000+000	2.663-002	4.00879+001
1.50	2.23000+000	4.018-002	5.95901+001
1.75	1.74000+000	4.912-002	7.40748+001
2.00	1.35000+000	5.540-002	8.16855+001
2.25	1.05000+000	6.249-002	9.30389+001
2.50	8.21000-001	5.060-002	7.69513+001
2.75	6.39000-001	7.053-002	1.05298+002
3.00	4.98000-001	7.251-002	1.08825+002
3.25	3.88000-001	9.728-002	1.45842+002
3.50	3.02000-001	9.897-002	1.47785+002
3.75	2.35000-001	7.458-002	1.11249+002
4.00	1.83000-001	7.613-002	1.13897+002
5.00	6.74000-002	1.344-001	5.03511+001
6.75	1.17000-002	5.805-002	1.24046+001
8.00	3.36000-003	2.086-003	6.25645-001
9.00	1.23000-003	2.147-004	7.99528-002
9.75	5.83000-004	1.019-005	5.10606-003
11.50	1.01000-004	1.089-005	2.32346-003
14.00	8.32000-006	1.081-005	1.62050-003
16.50	6.83000-007	1.095-005	1.63967-003
25.33	1.00000-010	1.626-006	6.89189-005
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F28 CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm Z = -18.3cm

Spectrum Code

Code: SAND-II Calculation: WADCO<sup>35</sup>

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	78.7
>0.5 MeV	(3.86 x 10 <sup>14</sup> †)	40.1
>0.1 MeV	-	18.1
Thermal, °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F27 through 31F29 (below 5D3)

## S31F28 CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.041-003	2.32546+000
0.50	6.07000+000	1.949-003	4.35905+000
0.75	4.72000+000	6.386-003	1.41668+001
1.00	3.68000+000	1.069-002	2.39623+001
1.25	2.87000+000	1.927-002	4.32596+001
1.50	2.23000+000	2.738-002	6.05599+001
1.75	1.74000+000	3.135-002	7.04996+001
2.00	1.35000+000	3.634-002	7.99136+001
2.25	1.05000+000	4.388-002	9.74246+001
2.50	8.21000-001	4.179-002	9.47982+001
2.75	6.39000-001	7.039-002	1.56743+002
3.00	4.98000-001	7.617-002	1.70489+002
3.25	3.88000-001	1.012-001	2.26344+002
3.50	3.02000-001	1.013-001	2.25664+002
3.75	2.35000-001	7.408-002	1.64813+002
4.00	1.83000-001	7.429-002	1.65770+002
5.00	6.74000-002	1.574-001	8.79169+001
6.75	1.17000-002	1.086-001	3.46009+001
8.00	3.36000-003	7.423-003	3.32013+000
9.00	1.23000-003	4.162-003	2.31133+000
9.75	5.83000-004	1.843-003	1.37760+000
11.50	1.01000-004	2.409-003	7.66918-001
14.00	8.32000-006	6.420-004	1.43501-001
16.50	6.83000-007	1.098-005	2.45117-003
25.33	1.00000-010	7.554-007	4.77427-005
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

S31F29 CRS 5D3



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWt  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 18cm Z = -32.6cm

Spectrum Code

Code: SAND-II Calculation: WADCO 35

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	64.4
>0.5 MeV	(1.08 x 10 <sup>14</sup> +)	22.7
>0.1 MeV	-	7.3
Thermal, -°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


+ In series of spectra 31F27 through 31F29 (below & 5D3)

## S31F29 CRS 5D3

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.781-004	1.96104+000
0.50	6.07000+000	5.247-004	3.70340+000
0.75	4.72000+000	1.669-003	1.16821+001
1.00	3.68000+000	3.093-003	2.18833+001
1.25	2.87000+000	6.550-003	4.63948+001
1.50	2.23000+000	1.046-002	7.29937+001
1.75	1.74000+000	1.216-002	8.62891+001
2.00	1.35000+000	1.436-002	9.96168+001
2.25	1.05000+000	1.897-002	1.32915+002
2.50	8.21000-001	2.160-002	1.54608+002
2.75	6.39000-001	5.205-002	3.65736+002
3.00	4.98000-001	6.395-002	4.51738+002
3.25	3.88000-001	8.739-002	6.16543+002
3.50	3.02000-001	9.382-002	6.59311+002
3.75	2.35000-001	7.042-002	4.94360+002
4.00	1.83000-001	7.278-002	5.12473+002
5.00	6.74000-002	1.770-001	3.12048+002
6.75	1.17000-002	2.048-001	2.05912+002
8.00	3.36000-003	2.555-002	3.60679+001
9.00	1.23000-003	2.308-002	4.04368+001
9.75	5.83000-004	1.215-002	2.86692+001
11.50	1.01000-004	1.713-002	1.72076+001
14.00	8.32000-006	9.298-003	6.55874+000
16.50	6.83000-007	9.128-004	6.42987+001
25.33	1.00000-010	4.096-005	8.16840-003
		-----	
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F3Q CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 22.5cm Z = +16.8cm

Spectrum Code

Code: SAND-II Calculation: WADCO 36

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	78.0
>0.5 MeV	(3.38 x 10 <sup>14</sup> ±)	40.3
>0.1 MeV	-	17.8
Thermal, - °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F30 through 31F32 (above & 5A1)

## S31F30 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.023-003	2.35058+000
0.50	6.07000+000	2.058-003	4.73415+000
0.75	4.72000+000	6.318-003	1.44156+001
1.00	3.68000+000	1.030-002	2.37554+001
1.25	2.87000+000	1.818-002	4.19783+001
1.50	2.23000+000	2.652-002	6.03155+001
1.75	1.74000+000	3.127-002	7.23221+001
2.00	1.35000+000	3.638-002	8.22768+001
2.25	1.05000+000	4.333-002	9.89480+001
2.50	8.21000-001	3.971-002	9.26382+001
2.75	6.39000-001	6.657-002	1.52451+002
3.00	4.98000-001	7.341-002	1.68997+002
3.25	3.88000-001	9.919-002	2.28080+002
3.50	3.02000-001	1.011-001	2.31595+002
3.75	2.35000-001	7.483-002	1.71217+002
4.00	1.83000-001	7.618-012	1.74810+002
5.00	6.74000-002	1.637-001	9.40649+001
6.75	1.17000-002	1.147-001	3.75891+001
8.00	3.36000-003	7.444-003	3.42437+000
9.00	1.23000-003	3.830-003	2.18745+000
9.75	5.83000-004	1.525-003	1.17223+000
11.50	1.01000-004	2.081-003	6.81340-001
14.00	8.32000-006	3.204-004	7.36678-002
16.50	6.83000-007	1.105-005	2.53716-003
25.33	1.00000-010	8.979-007	5.83652-005
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

S31F31 CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 22.5cm Z = +31.7cm

Spectrum Code

Code: SAND-II Calculation: WADCO 38

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	69.7
>0.5 MeV	(1.22 x 10 <sup>44</sup> †)	26.2
>0.1 MeV	-	8.9
Thermal, - °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F30 through 31F32 (above & 5A1)

## S31F31 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	3.682-004	2.04815+000
0.50	6.07000+000	6.982-004	3.88838+000
0.75	4.72000+000	2.189-003	1.20872+001
1.00	3.68000+000	4.039-003	2.25448+001
1.25	2.87000+000	8.308-003	4.64313+001
1.50	2.23000+000	1.260-002	6.93978+001
1.75	1.74000+000	1.402-002	7.84903+001
2.00	1.35000+000	1.631-002	8.92955+001
2.25	1.05000+000	2.142-002	1.18425+002
2.50	8.21000+001	2.405-002	1.35792+002
2.75	6.39000+001	3.481-002	3.03828+002
3.00	4.98000+001	6.647-002	3.70443+002
3.25	3.88000+001	9.001-002	5.01047+002
3.50	3.02000+001	9.525-002	5.28133+002
3.75	2.35000+001	7.097-002	3.93082+002
4.00	1.83000+001	7.486-002	4.15832+002
5.00	6.74000+002	1.827-001	2.54169+002
6.75	1.17000+002	1.943-001	1.54172+002
8.00	3.36000+003	2.217-002	2.46890+001
9.00	1.23000+003	1.629-002	2.25209+001
9.75	5.83000+004	9.067-003	1.68729+001
11.50	1.01000+004	1.301-002	1.03096+001
14.00	8.32000+006	5.545-003	3.08572+000
16.50	6.83000+007	4.530-004	2.51756+001
25.33	1.00000+010	2.229-005	3.50729+003
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F32 CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWt  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 22.5cm Z = +44.2cm

Spectrum Code

Code: SAND-II Calculation: WADCO 36

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	60.3
>0.5 MeV	(4.97 x 10 <sup>3</sup> †)	18.9
>0.1 MeV	-	6.2
Thermal, -°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F30 through 31F32 (above 5A1)

## S31F32 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	2.138-004	1.93715+000
0.50	6.07000+000	4.077-004	3.69735+000
0.75	4.72000+000	1.200-003	1.07945+001
1.00	3.68000+000	2.328-003	2.11566+001
1.25	2.87000+000	5.163-003	4.69889+001
1.50	2.23000+000	8.570-003	7.68432+001
1.75	1.74000+000	1.010-002	9.20996+001
2.00	1.35000+000	1.208-002	1.07678+002
2.25	1.05000+000	1.629-002	1.46638+002
2.50	8.21000-001	1.867-002	1.71682+002
2.75	6.39000-001	4.893-002	4.41695+002
3.00	4.98000-001	6.474-002	5.87550+002
3.25	3.88000-001	9.590-002	8.69262+002
3.50	3.02000-001	1.124-001	1.01438+003
3.75	2.35000-001	8.811-002	7.94685+002
4.00	1.83000-001	9.660-002	8.73889+002
5.00	6.74000-002	2.367-001	5.36191+002
6.75	1.17000-002	3.251-002	4.20070+001
8.00	3.36000-003	4.226-002	7.66333+001
9.00	1.23000-003	4.025-002	9.06046+001
9.75	5.83000-004	2.002-002	6.06750+001
11.50	1.01000-004	2.920-002	3.76875+001
14.00	8.32000-006	1.565-002	1.41833+001
16.50	6.83000-007	1.654-003	1.49709+000
25.33	1.00000-010	7.094-005	1.01773-002
-----			
1.000+000			

ONE LETHARGY INTERVAL = 0.25U

S31F33 CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble; R = 22.5cm Z = -4.6cm

Spectrum Code

Code: SAND-II Calculation: WADCO 36

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section $\sigma$ , mb
>1 MeV	-	81.4
>0.5 MeV	(5.59 x 10 <sup>14</sup> †)	46.1
>0.1 MeV	-	22.7
Thermal, -°C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n, $\gamma$ )<sup>60</sup>Co reaction or Ag-Co technique (11)


† In series of spectra 31F33 through 31F35 (below 4.5A1)

## 31F33 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	1.486-003	2.45910+000
0.50	6.07000+000	3.272-003	5.42134+000
0.75	4.72000+000	8.727-003	1.43409+001
1.00	3.68000+000	1.404-002	2.33164+001
1.25	2.87000+000	2.486-002	4.13345+001
1.50	2.23000+000	3.640-002	5.96257+001
1.75	1.74000+000	4.244-002	7.07065+001
2.00	1.35000+000	4.772-002	7.77222+001
2.25	1.05000+000	5.525-002	9.08655+001
2.50	8.21000-001	4.822-002	8.10231+001
2.75	6.39000-001	7.256-002	1.19673+002
3.00	4.98000-001	7.538-002	1.24987+002
3.25	3.88000-001	1.010-001	1.67318+002
3.50	3.02000-001	1.033-001	1.70451+002
3.75	2.35000-001	7.814-002	1.28757+002
4.00	1.83000-001	7.985-002	1.31979+002
5.00	6.74000-002	1.385-001	5.73048+001
6.75	1.17000-002	6.417-002	1.51470+001
8.00	3.36000-003	2.457-003	8.14142+001
9.00	1.23000-003	2.164-003	8.90045+001
9.75	5.83000-004	9.660-006	5.34830-003
11.50	1.01000-004	1.092-005	2.57552-003
14.00	8.32000-006	1.085-005	1.79630-003
16.50	6.83000-007	1.099-005	1.81795-003
25.33	1.00000-010	1.632-006	7.63950-005
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F34 CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWt  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 22.5cm Z = -18.3cm

Spectrum Code

Code: SAND-II Calculation: WADCO 35

Lower Energy Limit	Neutron Flux* $n/cm^2 \cdot sec^{-1}$	Spectrum-Averaged Cross-Section a, mb
>1 MeV	-	77.5
>0.5 MeV	( $3.15 \times 10^{14} t$ )	39.4
>0.1 MeV	-	17.2
Thermal, ${}^\circ C$	-	-

\* Fast flux based on  ${}^{54}\text{Fe}(n,p){}^{54}\text{Mn}$  reaction (8); Thermal flux based on  ${}^{59}\text{Co}(n,\gamma){}^{60}\text{Co}$  reaction or Ag-Co technique (11)


+ In series of spectra 31F33 through 31F35 (below 5A1)

## S31F34 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX INTERVAL
0.25	7.79000+000	9.686-004	2.33213+000
0.50	6.07000+000	1.969-003	4.74462+000
0.75	4.72000+000	5.959-003	1.42433+001
1.00	3.68000+000	9.778-003	2.36237+001
1.25	2.87000+000	1.748-002	4.22798+001
1.50	2.23000+000	2.553-002	6.08335+001
1.75	1.74000+000	2.995-002	7.23795+001
2.00	1.35000+000	3.488-002	8.26513+001
2.25	1.05000+000	4.165-002	9.96605+001
2.50	8.21000-001	3.871-002	9.46083+001
2.75	6.39000-001	6.604-002	1.58453+002
3.00	4.98000-001	7.305-002	1.76201+002
3.25	3.88000-001	9.863-002	2.37613+002
3.50	3.02000-001	1.006-001	2.41451+002
3.75	2.35000-001	7.449-002	1.78561+002
4.00	1.83000-001	7.580-002	1.82253+002
5.00	6.74000-002	1.656-001	9.96844+001
6.75	1.17000-002	1.207-001	4.14409+001
8.00	3.36000-003	8.549-003	4.12017+000
9.00	1.23000-003	4.524-003	2.70681+000
9.75	5.83000-004	1.965-003	1.58270+000
11.50	1.01000-004	2.639-003	9.05180-001
14.00	8.32000-006	5.366-004	1.29241-001
16.50	6.83000-007	1.105-005	2.65883-003
25.33	1.00000-010	7.956-007	5.41854-005
		1.000+000	

ONE LETHARGY INTERVAL = 0.25U

S31F35 CRS 5A1



Reactor Description

Name: Experimental Breeder Reactor-II  
 Type: Fast, test Power Level: 62.5 MWT  
 Coolant: Sodium Moderator: -  
 Location: National Reactor Testing Station, Idaho Falls, Idaho

Spectrum Facility Description

Control rod thimble: R = 22.5cm Z = -32.6cm

Spectrum Code

Code: SAND-II Calculation: WADCO 36

Lower Energy Limit	Neutron Flux* n/cm <sup>2</sup> ·sec <sup>-1</sup>	Spectrum-Averaged Cross-Section σ, mb
>1 MeV	-	67.4
>0.5 MeV	(9.02 × 10 <sup>-3</sup> †)	22.9
>0.1 MeV	-	7.0
Thermal, °C	-	-

\* Fast flux based on <sup>54</sup>Fe(n,p)<sup>54</sup>Mn reaction (8); Thermal flux based on <sup>59</sup>Co(n,γ)<sup>60</sup>Co reaction or Ag-Co technique (11)  
 † In series of spectra 31F33 through 31F35 (below 5A1)

S31F35 CRS 5A1

LETHARGY (U)	LOWER ENERGY LIMIT (MEV)	FLUX FRACTION PER GROUP	NORMALIZED FLUX PER LETHARGY INTERVAL
0.25	7.79000+000	2.673-004	1.99523+000
0.50	6.07000+000	5.019-004	3.74960+000
0.75	4.72000+000	1.551-003	1.14961+001
1.00	3.68000+000	2.968-003	2.22265+001
1.25	2.87000+000	6.309-003	4.73035+001
1.50	2.23000+000	9.700-003	7.16595+001
1.75	1.74000+000	1.075-002	8.07236+001
2.00	1.35000+000	1.252-002	9.19870+001
2.25	1.05000+000	1.681-002	1.24708+002
2.50	8.21000-001	1.976-002	1.49673+002
2.75	6.39000-001	4.911-002	3.65268+002
3.00	4.98000-001	6.191-002	4.62834+002
3.25	3.88000-001	8.585-002	6.41074+002
3.50	3.02000-001	9.372-002	6.97112+002
3.75	2.35000-001	7.068-002	5.25214+002
4.00	1.83000-001	7.351-002	5.47849+002
5.00	6.74000-002	1.845-001	3.44269+002
6.75	1.17000-002	2.159-001	2.29840+002
8.00	3.36000-003	2.571-002	3.84130+001
9.00	1.23000-003	2.161-002	4.00868+001
9.75	5.83000-004	1.141-002	2.84860+001
11.50	1.01000-004	1.636-002	1.73917+001
14.00	6.32000-006	7.743-003	5.78124+000
16.50	6.63000-007	6.013-004	5.97415+001
25.33	1.00000-010	3.730-005	7.87444-003
-----			1.000+000

ONE LETHARGY INTERVAL = 0.25U



