



# Standard Practice for Determining Neutron Exposures for Nuclear Reactor Vessel Support Structures<sup>1</sup>

This standard is issued under the fixed designation E1035; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

## 1. Scope

1.1 This practice covers procedures for monitoring the neutron radiation exposures experienced by ferritic materials in nuclear reactor vessel support structures located in the vicinity of the active core. This practice includes guidelines for:

1.1.1 Selecting appropriate dosimetric sensor sets and their proper installation in reactor cavities.

1.1.2 Making appropriate neutronics calculations to predict neutron radiation exposures.

1.2 This practice is applicable to all pressurized water reactors whose vessel supports will experience a lifetime neutron fluence ( $E > 1$  MeV) that exceeds  $1 \times 10^{17}$  neutrons/cm<sup>2</sup> or  $3.0 \times 10^{-4}$  dpa.<sup>2</sup> (See Terminology E170.)

1.3 Exposure of vessel support structures by gamma radiation is not included in the scope of this practice, but see the brief discussion of this issue in 3.2.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

## 2. Referenced Documents

### 2.1 ASTM Standards:<sup>3</sup>

E170 Terminology Relating to Radiation Measurements and Dosimetry

E482 Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance, E706 (IID)

E693 Practice for Characterizing Neutron Exposures in Iron and Low Alloy Steels in Terms of Displacements Per Atom (DPA), E 706(ID)

E844 Guide for Sensor Set Design and Irradiation for Reactor Surveillance, E 706 (IIC)

E854 Test Method for Application and Analysis of Solid State Track Recorder (SSTR) Monitors for Reactor Surveillance, E706(IIIB)

E910 Test Method for Application and Analysis of Helium Accumulation Fluence Monitors for Reactor Vessel Surveillance, E706 (IIIC)

E944 Guide for Application of Neutron Spectrum Adjustment Methods in Reactor Surveillance, E 706 (IIA)

E1005 Test Method for Application and Analysis of Radiometric Monitors for Reactor Vessel Surveillance, E 706 (IIIA)

E1018 Guide for Application of ASTM Evaluated Cross Section Data File, Matrix E706 (IIB)

### 2.2 ASME Standard:

Boiler and Pressure Vessel Code, Section III<sup>4</sup>

### 2.3 Nuclear Regulatory Documents:

Code of Federal Regulations, “Fracture Toughness Requirements,” Chapter 10, Part 50, Appendix G<sup>5</sup>

Code of Federal Regulations, “Reactor Vessel Materials Surveillance Program Requirements,” Chapter 10, Part 50, Appendix H<sup>5</sup>

Regulatory Guide 1.99, Rev. 1, “Effects of Residual Elements on Predicted Radiation Damage on Reactor Vessel Materials,” U. S. Nuclear Regulatory Commission, April 1977<sup>5</sup>

## 3. Significance and Use

3.1 Prediction of neutron radiation effects to pressure vessel steels has long been a part of the design and operation of light water reactor power plants. Both the federal regulatory agencies (see 2.3) and national standards groups (see 2.1 and 2.2) have promulgated regulations and standards to ensure safe operation of these vessels. The support structures for pressurized water reactor vessels may also be subject to similar

<sup>1</sup> This practice is under the jurisdiction of ASTM Committee E10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.05 on Nuclear Radiation Metrology.

Current edition approved Jan. 1, 2013. Published January 2013. Originally approved in 1985. Last previous edition approved in 2008 as E1035–08. DOI: 10.1520/E1035-13.

<sup>2</sup> Based on data from Table 5 of Master Matrix E706 and Reference 5.

<sup>3</sup> For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard’s Document Summary page on the ASTM website.

<sup>4</sup> Available from American Society of Mechanical Engineers, 345 E. 47th St., New York, NY 10017.

<sup>5</sup> Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

neutron radiation effects (1, 2, 3, 4, 5).<sup>6</sup> The objective of this practice is to provide guidelines for determining the neutron radiation exposures experienced by individual vessel supports.

3.2 It is known that high energy photons can also produce displacement damage effects that may be similar to those produced by neutrons. These effects are known to be much less at the belt line of a light water reactor pressure vessel than those induced by neutrons. The same has not been proven for all locations within vessel support structures. Therefore, it may be prudent to apply coupled neutron-photon transport methods and photon induced displacement cross sections to determine whether gamma-induced dpa exceeds the screening level of  $3.0 \times 10^{-4}$ , used in this practice for neutron exposures. (See 1.2).

#### 4. Irradiation Requirements

4.1 *Location of Neutron Dosimeters*—Neutron dosimeters shall be located along the support structure in the region where the maximum dpa or fluence ( $E > 1$  MeV) is expected to occur, based on neutronics calculations outlined in Section 5. Care must be taken to ensure that reactor cavity structures not modeled in the neutronics calculation offer no additional shielding to the dosimeters. The neutron dosimeters will be analyzed to obtain a map of the neutron fields within the actual location of the support structures.

##### 4.2 *Neutron Dosimeters:*

4.2.1 Information regarding the selection of appropriate sensor sets for support structure application may be found in Guide E844, Test Method E1005, and Test Methods E854 and E910.

4.2.2 In particular, Test Method E910 also provides guidance for the additional possibility that operating plants may use existing copper bearing instruments and cables within the reactor cavity as a priori passive dosimeter candidate.

#### 5. Determination of Neutron Exposure Parameter Values

5.1 *Neutronics Calculations*—All neutronics calculations for (a) the analysis of integral dosimetry data, and (b) the

<sup>6</sup> The boldface numbers in parentheses refer to a list of references at the end of this practice.

prediction of irradiation damage exposure parameter values shall follow Guide E482, subject to these additional considerations that may be encountered in reactor cavities:

5.1.1 If the vessel supports do not lie within the core's active height, then an asymmetric quadrature set must be chosen for discrete ordinates calculations that will accurately reproduce the neutron transport in the direction of the supports. Care must be exercised in constructing the quadrature set to ensure that "ray streaming" effects in the cavity air gap do not distort the calculation of the neutron transport.

5.1.2 If the support system is so large or geometrically complex that it perturbs the general neutron field in the cavity, the analysis method of choice may be that of a Monte Carlo calculation or a combined discrete ordinates/Monte Carlo calculation. The combined calculation involves a two or three dimensional discrete ordinates analysis only within the vessel. The neutron currents or fluences generated by this analysis may be used to create the appropriate source distribution functions in the final Monte Carlo analysis, or to develop bias (weighting) factors for use in a complete Monte Carlo model. For details of analyses in which discrete ordinates and Monte Carlo methods were coupled see Refs (6), (7), and (8). Reference (9) provides a review of the available combined or hybrid discrete ordinates/Monte Carlo calculations. For hybrid calculations, the above caveats still hold for the discrete ordinates calculation, but in addition, the variance of the Monte Carlo results must now be included with the overall assessment of the variance of the dosimetry data.

5.2 *Determination of Damage Exposure Values and Uncertainties*—Adjustment procedures outlined in Guide E944 and Guide E1018 shall be performed to obtain damage exposure values dpa and fluence ( $E > 1$  MeV) using the integral data from the neutron dosimeters and the calculation in 5.1. The cross sections for dpa are found in Practice E693. Dpa shall be determined for this application rather than just fluence ( $E > 1$  MeV) because Ref (5) notes an increase in the ratio of dpa to fluence ( $E > 1$  MeV) by a factor of two in going from the surveillance capsule position inside the reactor vessel to a position out in the reactor cavity.

#### REFERENCES

- (1) Docket 50338-207, North Anna Power Station, Units 1 and 2, *Summary of Meeting Held on September 19, 1975 on Dynamic Effects of LOCAs*, Sept. 22, 1975.
- (2) Sprague, J. A., and Hawthorne, J. R., "Radiation Effects to Reactor Vessel Supports," U. S. Naval Research Laboratory Report NRC-03-79-148 for the U. S. Nuclear Regulatory Commission, Oct. 22, 1979.
- (3) *Unresolved Safety Issues Summary*, NUREG-0606, Vol 4, No. 4, Task A-11: *Reactor Vessel Materials Toughness*, November, 1982.
- (4) *Asymmetric Blowdown Loads on PWR Primary Systems*, NUREG-0609, U.S. Nuclear Regulatory Commission, 1981.
- (5) Hopkins, W. C., "Suggested Approach for Fracture-Safe PRV Support Design in Neutron Environments," *Transactions of the American Nuclear Society*, Vol 30, 1978, pp. 187-188.
- (6) Cain, V. R., "The Use of Monte Carlo with Albedos to Predict Neutron Streaming in PWR Containment Buildings," *Transactions of the American Nuclear Society*, Vol 23, 1976, p. 618.
- (7) Straker, E. A., Stevens, P. N., Irving, D. C. and Cain, V. R., "The MORSE Code—A Multigroup Neutron and Gamma-Ray Monte Carlo Transport Code," ORNL-4585, September 1970.
- (8) Emmett, M. B., Burgart, C. E., and Hoffman, T. J., "DOMINO: A General Purpose Code for Coupling Discrete Ordinates and Monte Carlo Radiation Transport Calculations," ORNL-4853, July 1973.
- (9) Wagner, J. C., Peplow, D. E., Mosher, S. W., and Evans, T. M., "Review of Hybrid (Deterministic/Monte Carlo) Radiation Transport Methods, Codes, and Applications at Oak Ridge National Laboratory," In *Progress in Nuclear Science and Technology*, Vol 2, Toshikazu Takeda, Ed., Atomic Energy Society of Japan, October 2011, pp. 808-814.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)). Permission rights to photocopy the standard may also be secured from the ASTM website ([www.astm.org/COPYRIGHT/](http://www.astm.org/COPYRIGHT/)).*