



Standard Practice for Reporting Data from Structural Tests of Building Constructions, Elements, Connections, and Assemblies¹

This standard is issued under the fixed designation E575; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers general use in reporting structural performance tests of building constructions, elements, connections, and assemblies. A comprehensive report describing the conditions under which the structural data were recorded will enable other workers to reproduce the test methods and, as nearly as possible, the results for each material or assembly, and to reconcile differences that might be found in tests by others.

1.2 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

- 2.1 *ASTM Standards*:²
[E631 Terminology of Building Constructions](#)

3. Terminology

3.1 For definitions of terms used in this practice, see Terminology [E631](#).

4. Significance and Use

4.1 This practice provides a standard procedure for reporting data and results of structural tests used for building constructions, elements, connections, and assemblies. It enumerates and discusses the report sections required to report data from test methods and practices. The written reports will describe the products tested, method of testing, and results.

¹ This practice is under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.11 on Horizontal and Vertical Structures/Structural Performance of Completed Structures. Current edition approved April 1, 2011. Published May 2011. Originally approved in 1976. Last previous edition approved in 1999 as E575 – 99. DOI: 10.1520/E0575-05.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

5. Organization of Report

5.1 Generally, a report shall contain the following parts in the sequence listed:

- 5.1.1 Title page with byline,
- 5.1.2 Object statement,
- 5.1.3 Descriptions of specimen(s) and apparatus,
- 5.1.4 Procedure statement,
- 5.1.5 Discussion of test results,
- 5.1.6 Conclusion,
- 5.1.7 Recommendations,
- 5.1.8 References,
- 5.1.9 Pictures,
- 5.1.10 Tabulations,
- 5.1.11 Calculations, and
- 5.1.12 Supplementary data.

5.2 Use the headings listed that are appropriate. Use other more appropriate headings if they better describe the content.

5.3 When the expected readership includes both experts and laymen, an early insertion in nontechnical language of the necessary background, data summary, and results is useful.

6. Documented Information

6.1 A report shall include the following information, but not necessarily in the order listed:

- 6.1.1 *Title*—A title shall be brief but definitive.
- 6.1.2 *Author*—One first name and surname and any professional registration shall be included in a byline for positive identification.
- 6.1.3 Date of test and date of report.
- 6.1.4 Test agency, sponsor, and their mailing addresses.
- 6.1.5 *Specimen Selection and Identification*—Indicate the number of specimens, method of choosing them, and whether they were specially fabricated for this test, prototypes of planned production, randomly selected production units, and so forth. If specimens were obtained from routine production, include the manufacturer's name, source of supply, specimen dimensions, model, type, materials, and other pertinent information such as quality, conditioning, and treatment, including data on assembly techniques and fastenings.

6.1.6 *Specimen Drawings*—Drawings shall provide a description of the physical characteristics and dimensioned section profiles and any other pertinent construction details. This

requirement may be waived if an existing description is easily available and is included by reference. Any modification made to the specimen to obtain a measurement or reading shall be noted. Any unusual characteristics or conditions existing in the specimen construction prior to test shall be described.

6.1.7 *Specimen Design*—Details shall be provided for an understanding of the principles used in the structural design of the specimen.

6.1.8 *Apparatus Description*—Sufficient details shall be provided to explain the construction, operation, and position of the test apparatus. This description may require a presentation of the structural design of the apparatus, especially if it is original in design or operation. This requirement may be waived if an existing description is easily available and is included by reference.

6.1.9 *Specimen Installation*—Illustrations and a description of details of installation in or attachment to the test apparatus shall be provided for each type of specimen. Details of restraint devices and their location relative to the specimen shall be described as well as the locations of loading and reaction points.

6.1.10 *Instrumentation*—A report shall describe the location, direction of measurement, and technical specifications of any instrumentation used to measure loads, reactions, and deformations generated by the test apparatus and the specimen. A description of the working condition, tolerances, and accuracy of such meters is useful. The relative deformation measured by each gage shall be described.

6.1.11 *Ambient Conditions*—Records of temperature, relative humidity, moisture content, seasoning, and any other conditions that are relevant to structural performance of the specimen shall be included. A history of such conditions from the time of construction until the time of test may be more significant than those present at the time of test, and therefore, if warranted, measurements of ambient conditions and the condition of the specimen from the time of specimen construction shall be made.

6.1.12 *Specimen Weight*—A report shall state the amount of dead load of the apparatus or specimen that has been deducted if the net load or strength is reported or that may be deducted if the gross load or strength is reported.

6.1.13 *Load-Deformation Graphs*—Graphs portraying the specimen's response to loading shall be included for each deformation-measuring device.

6.1.14 *Failure Load and Description*—Specimens can have more than one failure mode, for example, ductile or brittle fracture, yielding, excessive deflection, or harmful distortion. Applicable modes of failure shall be described in general terms with criteria for their measurement. A description of each specimen's failure mode and a value of its ultimate strength or maximum load or both shall be tabulated.

6.1.15 *Time Under Load*—A load-time record is needed to interpret some test results and shall be presented as a graph or tabulation to indicate the time duration for each magnitude of load.

6.1.16 *Photographs*—Photographs of the specimen before and after testing shall be provided to show what cannot be described easily or clearly by writing. However, if the mode of failure is well known, the photographs are optional.

6.1.17 *Video (optional)*—A video may be used as a standard practice for reporting data from structural tests of building constructions, elements, connections, and assemblies. The video may be used in conjunction with a written test report. Generally, a video should contain the following parts:

6.1.17.1 Object statement (title and author),

6.1.17.2 Specimen design and selection,

6.1.17.3 Apparatus description,

6.1.17.4 Specimen installation,

6.1.17.5 Instrumentation,

6.1.17.6 Ambient conditions,

6.1.17.7 Specimen weight (dead and live),

6.1.17.8 Testing,

6.1.17.9 Failure load and description,

6.1.17.10 Time under load,

6.1.17.11 Conformity of specimen,

6.1.17.12 Officials (technicians, professionals, and observers), and

6.1.17.13 Appendixes.

6.1.18 Use the headings listed that are appropriate. Use other more appropriate headings may be used, if they better describe the contents.

7. Conformity

7.1 A report shall contain a statement indicating whether or not the construction of the test specimen represents actual or intended construction. If the construction does not represent typical manufacture, deviations shall be noted.

7.2 When a standard test method is used, a statement shall be included indicating its name and designation. Deviations from it shall be described.

8. Officials

8.1 Signatures of persons responsible for the supervision of a test shall be included as well as a list of any official observers.

9. Appendixes

9.1 All data not specifically required by a testing standard but useful to a better understanding of the test results, conclusions, or recommendations should be appended to a report.

10. Keywords

10.1 building construction; structural tests

 **E575 – 05 (Reapproved 2011)**

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).