



Standard Practice for Safe Walking Surfaces¹

This standard is issued under the fixed designation F1637; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers design and construction guidelines and minimum maintenance criteria for new and existing buildings and structures. This practice is intended to provide reasonably safe walking surfaces for pedestrians wearing ordinary footwear. These guidelines may not be adequate for those with certain mobility impairments.

1.2 Conformance with this practice will not alleviate all hazards; however, conformance will reduce certain pedestrian risks.

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

F1646 Terminology Relating to Safety and Traction for Footwear

3. Terminology

3.1 See Terminology **F1646** for the following terms used in this practice:

- 3.1.1 Bollard,
- 3.1.2 Carpet,
- 3.1.3 Cross slope,
- 3.1.4 Element,
- 3.1.5 Fair,

- 3.1.6 Footwear,
- 3.1.7 Foreseeable pedestrian path,
- 3.1.8 Planar,
- 3.1.9 Ramp,
- 3.1.10 Sidewalk,
- 3.1.11 Slip resistance,
- 3.1.12 Slip resistant,
- 3.1.13 Walkway.
- 3.1.14 Walkway surface hardware, and

4. Significance and Use

4.1 This practice addresses elements along and in walkways including floors and walkway surfaces, sidewalks, short flight stairs, gratings, wheel stops, and speed bumps. Swimming pools, bath tubs, showers, natural walks, and unimproved paths are beyond the scope of this practice.

5. Walkway Surfaces

5.1 General:

5.1.1 Walkways shall be stable, planar, flush, and even to the extent possible. Where walkways cannot be made flush and even, they shall conform to the requirements of **5.2** and **5.3**.

5.1.2 Walkway surfaces for pedestrians shall be capable of safely sustaining intended loads.

5.1.3 Walkway surfaces shall be slip resistant under expected environmental conditions and use. Painted walkways shall contain an abrasive additive, cross cut grooving, texturing or other appropriate means to render the surface slip resistant where wet conditions may be reasonably foreseeable.

5.1.4 Interior walkways that are not slip resistant when wet shall be maintained dry during periods of pedestrian use.

5.2 Walkway Changes in Level:

5.2.1 Adjoining walkway surfaces shall be made flush and fair, whenever possible and for new construction and existing facilities to the extent practicable.

5.2.2 Changes in levels up to ¼ in. (6 mm) may be vertical and without edge treatment. (See **Fig. 1**.)

5.2.3 Changes in levels between ¼ and ½ in. (6 and 12 mm) shall be beveled with a slope no greater than 1:2 (rise:run).

5.2.4 Changes in levels greater than ½ in. (12 mm) shall be transitioned by means of a ramp or stairway that complies with applicable building codes, regulations, standards, or ordinances, or all of these.

¹ This practice is under the jurisdiction of ASTM Committee **F13** on Pedestrian/Walkway Safety and Footwear and is the direct responsibility of Subcommittee **F13.50** on Walkway Surfaces.

Current edition approved Aug. 1, 2013. Published August 2013. Originally approved in 1995. Last previous edition approved in 2010 as F1637 – 10. DOI: 10.1520/F1637-13.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.




FIG. 1 Changes in Levels up to a Maximum of 1/4 in. (6 mm)

5.3 Carpet:

5.3.1 Carpet shall be maintained so as not to create pedestrian hazard. Carpet shall be firmly secured and seams tightly maintained. Carpet shall not have loose or frayed edges, unsecured seams, worn areas, holes, wrinkles or other hazards that may cause trip occurrence.

5.3.2 Carpet on floor surfaces shall be routinely inspected. Periodic restretching may become necessary. Periodic inspection is particularly important at step nosing edges.

5.3.3 Carpet and carpet trim (as measured when compressed) shall meet the transition requirements of 5.2.

5.3.4 Shag-type carpet shall not be used on stair treads. Carpeting should be firmly secured onto the tread and around the nosing.

5.4 Mats and Runners:

5.4.1 Mats, runners, or other means of ensuring that building entrances and interior walkways are kept dry shall be provided, as needed, during inclement weather. Replacement of mats or runners may be necessary when they become saturated.

5.4.2 Building entrances shall be provided with mats or runners, or other means to help remove foreign particles and other contaminants from the bottom of pedestrian footwear. Mats should be provided to minimize foreign particles, that may become dangerous to pedestrians particularly on hard smooth floors, from being tracked on floors.

5.4.3 Mats or runners should be provided at other wet or contaminated locations, particularly at known transitions from dry locations. Mats at building entrances also may be used to control the spread of precipitation onto floor surfaces, reducing the likelihood of the floors becoming slippery.

5.4.4 Mats shall be of sufficient design, area, and placement to control tracking of contaminants into buildings. Safe practice requires that mats be installed and maintained to avoid tracking water off the last mat onto floor surfaces.

5.4.5 Mats, runners, and area rugs shall be provided with safe transition from adjacent surfaces and shall be fixed in place or provided with slip resistant backing.

5.4.6 Mats, runners, and area rugs shall be maintained so as not to create pedestrian hazards. Mats, runners, and area rugs shall not have loose or frayed edges, worn areas, holes, wrinkles, or other hazards that may cause trip occurrences.

5.5 Illumination:

5.5.1 Minimum walkway illumination shall be governed by the requirements of local codes and ordinances or, in their absence, by the recommendations set forth by the Illuminating Engineering Society of North America (IES) (Application and Reference Volumes).

5.5.2 Illumination shall be designed to be glare free.

5.5.3 Illumination shall be designed to avoid casting of obscuring shadows on walkways, including shadows on stairs that may be cast by users.

5.5.4 Interior and exterior pedestrian use areas, including parking lots, shall be properly illuminated during periods when pedestrians may be present.

5.6 *Headroom*—A minimum headroom clearance of 6 ft 8 in. (2.03 m), measured from the walkway surface, shall be provided above all parts of the walkway. Where such clearance is not provided in existing structures, the low clearance portions of the walkway shall be safely padded, marked with safety contrast color coding and posted with appropriate warning signs.

5.7 Exterior Walkways:

5.7.1 Exterior walkways shall be maintained so as to provide safe walking conditions.

5.7.1.1 Exterior walkways shall be slip resistant.

5.7.1.2 Exterior walkway conditions that may be considered substandard and in need of repair include conditions in which the pavement is broken, depressed, raised, undermined, slippery, uneven, or cracked to the extent that pieces may be readily removed.

5.7.2 Exterior walkways shall be repaired or replaced where there is an abrupt variation in elevation between surfaces. Vertical displacements in exterior walkways shall be transitioned in accordance with 5.2.

5.7.3 Edges of sidewalk joints shall be rounded.

6. Walking Surface Hardware

6.1 Walking surface hardware within foreseeable pedestrian paths shall be maintained flush with the surrounding surfaces; variances between levels shall be transitioned in accordance with 5.2.

6.2 Walking surface hardware within foreseeable pedestrian paths shall be maintained slip resistant.

6.3 Walking surface hardware shall be installed and maintained so as to be stable under reasonable foreseeable loading.

7. Stairs

7.1 General:

7.1.1 Stairways with “distracting” forward or side views shall be avoided. A “distracting” view is one which can attract the stair user’s attention, (for example, advertisements, store displays), thus distracting the stair user.

7.1.2 Step nosings shall be readily discernible, slip resistant, and adequately demarcated. Random, pictorial, floral, or geometric designs are examples of design elements that can camouflage a step nosing.

7.1.3 Doors shall not open over stairs.

7.1.4 Structure (reserved).

7.2 Short Flight Stairs (Three or Fewer Risers):

7.2.1 Short flight stairs shall be avoided where possible.

7.2.2 In situations where a short flight stair or single step transition exists or cannot be avoided, obvious visual cues shall be provided to facilitate improved step identification. Handrails, delineated nosing edges, tactile cues, warning signs, contrast in surface colors, and accent lighting are examples of some appropriate warning cues.

8. Speed Bumps

8.1 Design to avoid the use of speed bumps.

8.2 All speed bumps which are in foreseeable pedestrian paths shall comply with 5.2 (walkway changes in level).

8.3 Existing speed bumps, that do not conform to 5.2, shall be clearly marked with safety color coding to contrast with surroundings. Painted speed bumps shall be slip resistant. Pedestrian CAUTION signs are recommended.

9. Wheel Stops

9.1 Parking lots should be designed to avoid the use of wheel stops.

9.2 Wheel stops shall not be placed in pedestrian walkways or foreseeable pedestrian paths.

9.3 Wheel stops shall be in contrast with their surroundings.

9.4 Wheel stops shall be no longer than 6 ft (1.83 m) and shall be placed in the center of parking stalls. The minimum width of pedestrian passage between wheel stops shall be 3 ft (0.91 m).

9.5 The top of wheel stops shall not exceed 6.5 in. (165 mm) in height above the parking lot surface.

9.6 Adequate illumination shall be maintained at wheel stops as governed by the requirements of local codes and ordinances or, in their absence, by the recommendations set forth by the Illuminating Engineering Society of North America (IES-Application and Reference Volumes).

9.7 Bollards, not less than 3 ft 6 in. (1.07 m) height, may be placed in the center of parking stalls as an alternative to wheel stops. Bollards should be appropriately marked to enhance visibility.

10. Gratings

10.1 Gratings used in public areas should be located outside of pedestrian walkways.

10.2 Gratings located in foreseeable pedestrian walkways shall not have openings wider than ½ in. (13 mm) in the direction of predominant travel.

10.2.1 *Exemption*—The requirements of 10.2 do not apply in areas where footwear worn is controlled (for example, industrial areas).

10.3 Gratings with elongated openings shall be placed with the long dimension perpendicular to the direction of predominant travel.

10.4 Gratings shall be maintained slip resistant.

11. Warnings

11.1 The use of visual cues such as warnings, accent lighting, handrails, contrast painting, and other cues to improve the safety of walkway transitions are recognized as effective controls in some applications. However, such cues or warnings do not necessarily negate the need for safe design and construction.

11.2 When relying on applications of color as a warning, provide colors and patterns that provide conspicuous markings for the conditions being delineated, their surroundings, and the environment in which they will be viewed by users. Bright yellow is a commonly used color for alerting users of the presence of certain walkway conditions. When properly applied and maintained, other colors can also provide effective warnings.

12. Keywords

12.1 carpet; floors; gratings; mats; runners; sidewalks; short flight stairs; slip resistance; speed bump; stairs; walkway; wheel stop

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>