



Standard Practice for Reporting Slip Resistance Test Results¹

This standard is issued under the fixed designation F2048; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice provides a framework for reporting the results of slip resistance tests.

1.2 *Application*—This practice is intended for use as a suggested format for recording and reporting data obtained during slip resistance testing. It is recognized that it may not be necessary or possible to record all of the data for all types of tests; however, this practice is considered a basic approach for data collection.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Significance and Use

2.1 This practice provides a basic approach for recording the preparation, parameters, and results of field slip resistance testing. It is intended to assist those performing such tests in documenting information gathered for further analysis, in preparation for writing a final report, or for record keeping purposes.

2.2 Potential users include those performing slip resistance testing in the field, such as industrial and commercial safety professionals, facility management and maintenance

¹ This practice is under the jurisdiction of ASTM Committee F13 on Pedestrian/Walkway Safety and Footwear and is the direct responsibility of Subcommittee F13.10 on Traction.

Current edition approved Aug. 1, 2017. Published August 2017. Originally approved in 2000. Last previous edition approved in 2009 as F2048 – 00 (2009). DOI: 10.1520/F2048-00R17.

personnel, forensic engineers, insurance company and broker loss control specialists, and research personnel.

3. Report

3.1 Report the following information for test preparation (see Fig. 1):

- 3.1.1 Client/customer.
- 3.1.2 Location/address.
- 3.1.3 Date and time of test(s).
- 3.1.4 ASTM test method used.
- 3.1.5 Name of tribometer operator and employing company.
- 3.1.6 Address and telephone number of tribometer operator.
- 3.1.7 Type of tribometer (for example, brand and model) and serial number.
- 3.1.8 Test foot preparation protocol.

3.2 Report the following information for test parameters and results:

- 3.2.1 Specific floor location and orientation of the tribometer where the test was performed.
- 3.2.2 Type of test foot material (for example, Neolite test liner, leather, or nitrile rubber).
- 3.2.3 Slope of the surface being tested.
- 3.2.4 Floor material and texture.
- 3.2.5 *Floor Finish*—Indicate the type of finish (for example, type of wax, polish, or paint) applied, if any. Also indicate the condition of the finish.
- 3.2.6 *Floor Conditions*—Indicate if clean or contaminated. If clean, indicate the method of cleaning. If contaminated, indicate the type, continuity, and thickness of the contaminant.
- 3.2.7 Wet or dry testing.
- 3.2.8 Temperature and relative humidity (if relevant).
- 3.2.9 Tribometer reading.

3.3 Provide any comments pertinent to the testing.

4. Keywords

4.1 floor testing; report form; report framework; slip resistance; slip test data; tribometer; walkway testing

Client/Customer: 3.1.1	Tribometer Operator (TO)/Company: 3.1.5
Location/Address: 3.1.2	TO Address & Telephone Number: 3.1.6
Date/Time of Tests: 3.1.3	Tribometer/Serial #: 3.1.7
ASTM Test Method: 3.1.4	Test Foot: 3.1.8 Preparation Protocol:

Location/Orientation	Test Sensor Material	Surface Slope	Floor Material & Texture	Floor Finish	Floor Condition	Wet/Dry	Temperature & RH	Reading
3.2.1	3.2.2	3.2.3	3.2.4	3.2.5	3.2.6	3.2.7	3.2.8	3.2.9

COMMENTS

3.3	

FIG. 1 Sample Slip Resistance Test Results Report

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/