



# Standard Test Methods for Evaluating Design and Performance Characteristics of Selectorized Strength Equipment<sup>1</sup>

This standard is issued under the fixed designation F2277; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

## INTRODUCTION

The goal of these test methods is to provide reliable and repeatable methods for the evaluation of selectorized strength equipment. Users of these machines must recognize, however, that conformance to a standard will not necessarily prevent injuries. Certain physical conditions or limitations may preclude some persons from using this equipment as intended by the manufacturer, and using this equipment may increase the risk of injury.

### 1. Scope

1.1 These test methods specify procedures and apparatus used for testing and evaluating selectorized strength equipment for compliance to Specification F2216. Both design and operational parameters will be evaluated. Where possible and applicable, accepted test methods from other recognized bodies will be used and referenced.

1.2 *Requirements*—Selectorized strength equipment is to be tested in accordance with these test methods or Test Methods F2571 for all of the following parameters:

- 1.2.1 Stability,
- 1.2.2 Edge and corner sharpness,
- 1.2.3 Tube ends,
- 1.2.4 Weight stack travel,
- 1.2.5 Weight stack selector pin retention,
- 1.2.6 Function of adjustments and locking mechanisms,
- 1.2.7 Handgrip design and retention,
- 1.2.8 Assist mechanisms,
- 1.2.9 Foot supports,
- 1.2.10 Rope and belt systems:
  - 1.2.10.1 Static load,
  - 1.2.10.2 End fitting design,
- 1.2.11 Chain drive design,
- 1.2.12 Pulley design:
  - 1.2.12.1 Rope pulley design,
  - 1.2.12.2 Belt pulley design,
- 1.2.13 Entrapment zones,
- 1.2.14 Pull in points,

<sup>1</sup> These test methods are under the jurisdiction of ASTM Committee F08 on Sports Equipment, Playing Surfaces, and Facilities and are the direct responsibility of Subcommittee F08.30 on Fitness Products.

Current edition approved May 15, 2017. Published August 2017. Originally approved in 2003. Last previous edition approved in 2012 as F2277 – 12. DOI: 10.1520/F2277-17.

- 1.2.15 Weight stack enclosure design,
- 1.2.16 Loading and deflection:
  - 1.2.16.1 Intrinsic loading and associated deflection,
  - 1.2.16.2 Extrinsic loading and associated deflection,
  - 1.2.16.3 Endurance loading,
- 1.2.17 Documentation and warnings verification, and
- 1.2.18 Additional universal design and construction requirements.

1.3 This test method<sup>2</sup> contains additional requirements to address the accessibility of the equipment for persons with disabilities.

1.4 The values stated in SI units are to be regarded as the standard. The values in parenthesis are for information only.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

### 2. Referenced Documents

- 2.1 *ASTM Standards*:<sup>3</sup>

<sup>2</sup> This work was funded, in part, by the Rehabilitation Engineering Research Center on RecTech through the National Institute on Disability, Independent Living, and Rehabilitation Research grant #90RE5009-01-00.

<sup>3</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.




FIG. 1 Tilt Test

[F1749 Specification for Fitness Equipment and Fitness Facility Safety Signage and Labels](#)

[F2216 Specification for Selectorized Strength Equipment](#)

[F2276 Specification for Fitness Equipment](#)

[F2571 Test Methods for Evaluating Design and Performance Characteristics of Fitness Equipment](#)

[F3022 Test Method for Evaluating the Universal Design of Fitness Equipment for Inclusive Use by Persons with Functional Limitations and Impairments](#)

upholstered pads from the sample. On machines that are fully assembled, verify according to the manufacturer’s instructions that all components are functioning and that they have been adjusted and aligned properly. Unless otherwise stated, the machine must pass the tests without adjustment from this initial condition. Selectorized strength equipment shall be provided with the largest weight stack offered by the manufacturer for the model to be tested.

5.2 The individual test methods will describe any variations or modifications that are required to the test sample.

## 6. Test Methods and Procedures

### 6.1 Stability:

6.1.1 Selectorized strength equipment shall be tested with and without the simulated user load in the orientation that is most obviously unstable. If the orientation that is most obviously unstable is not clear, it may be necessary to test several orientations.

6.1.2 *Apparatus and Set-Up*—Refer to [Fig. 1](#). Place sample on a non-skid surface inclined at 10° in the orientation that is least stable. The sample shall rest on the supporting surface without anchoring unless the installation instructions for the machine require that the sample be anchored to the floor. If this is the case, then anchor the specimen per the manufacturer’s recommendations. Determine how the user is placed on the machine to perform the exercise (that is, seating, standing, or prone) and then determine how the user’s body weight is

## 3. Terminology

### 3.1 Definitions of Terms Specific to This Standard:

3.1.1 *normal operation, n*—the operation of the selectorized strength equipment as defined by the manufacturer.

## 4. Significance and Use

4.1 The purpose of these test methods is to provide valid and repeatable test methods for the evaluation of selectorized strength equipment assembled and maintained according to the manufacturer’s specifications. Use of these test methods in conjunction with [Specification F2216](#) is intended to maximize the reliability of selectorized strength equipment design and reduce the risk of serious injury resulting from design deficiencies.

## 5. Sample Preparation

5.1 Assemble and adjust the selectorized strength equipment according to the manufacturer’s instructions. Remove

distributed onto the user support surfaces. For the simulated use test, a method of applying a steady state load equal to 100 kg (220 lb) simulating the user's weight and its distribution in the vertical direction at the point(s) of user contact must be provided. As an example, for a seated user, the user support surface shall be adjusted to the uppermost position (if adjustable) and the center of gravity of the 100 kg (220 lb) load shall be positioned approximately 300 mm (12 in.) above the user support surface. Possible methods of providing this load include, but are not limited to, pneumatic cylinder(s) or dead weights.

6.1.3 *Calibration*—Using an angle measuring instrument accurate to within  $0.1^\circ$ , verify the non-skid surface is  $10 \pm 0.5^\circ$ . Calibrate the load measurement apparatus to confirm accuracy to within  $\pm 20$  N (4.5 lb) over entire 981 N (220 lb) range.

6.1.4 *Procedure*—Test the sample as follows:

6.1.4.1 With the sample machine (no user load applied) positioned on the tilt surface, verify that the sample does not tip over with the resistance means in the rest position.

6.1.4.2 Using the aforementioned load apparatus, distribute a vertical load equal to 100 kg (220 lb)  $\pm 5\%$  in a non-impact manner to the specimen where the user contacts the machine during normal operation. (If only a portion of the user's body is supported by the machine during operation, the 100 kg (220 lb) simulated user weight shall be reduced by the appropriate amount.) Raise and support the lifting arms and weight stack to simulate the furthest point in the range of travel as encountered during normal operation of the machine by a user of 1.8 m (74 in.) stature. Verify that the sample does not tip over.

6.1.4.3 Repeat 6.1.4.1 and 6.1.4.2 with the sample oriented in any other directions of potential instability.

6.1.5 *Pass/Fail Criteria*—In none of the above test conditions shall the sample tip over.

6.1.6 *Precision and Bias*—No information is presented about either the precision or bias of test 6.1 for measuring stability since the test result is non-quantitative.

6.2 *Weight Stack Travel:*

6.2.1 This test is a visual inspection of the sample to ensure that the weight stack travels freely along its guide means and returns to its initial position after the displacing force has been removed.

6.2.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1.

6.2.3 *Calibration*—No calibration required. Visual inspection only.

6.2.4 *Procedure*—Move the lifting arm through its range of travel and verify that the weight stack moves along a guide means in a controlled manner and returns to its initial position as the lifting arm is returned to its initial rest position.

6.2.5 *Pass/Fail Criteria*—The weight stack must begin and end the test in the same rest position and must not move unless it is displaced intentionally by a lifting force applied to the lifting arm.

6.2.6 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.2 for evaluating weight stack travel since the test result is non-quantitative.

6.3 *Weight Stack Selector Pin Retention:*

6.3.1 This test is a visual and physical inspection of the weight stack selector pin to ensure that the design features a retention device and that it functions properly.

6.3.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1. Obtain instructions or a descriptive explanation of the function of the weight stack selector pin from the manufacturer.

6.3.3 *Calibration*—No calibration required. Visual and function inspection only.

6.3.4 *Procedure*—Inspect the weight stack selector pin and ensure that it features a retention device that will not allow the pin to be removed from the weight stack unless it is intentionally removed. Examples of retention devices include, but are not limited to, spring activated detent balls or a physical deformation of the pin and comparable retention zone on the weight plate. The operation of the retention system shall be self-evident. Insert the weight stack selector pin into a weight on the weight stack and verify that the retention mechanism functions properly.

6.3.5 *Pass/Fail Criteria*—Weight stack selector pins that do not have a retention means shall fail this test. Retention mechanisms that do not function according to the instructions provided by the manufacturer shall fail this test.

6.3.6 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.3 for evaluating weight stack selector pin design and function since the test result is non-quantitative.

6.4 *Entrance/Exit from Machine:*

6.4.1 This test is a visual and physical inspection of the machine to determine whether or not an assist means is required and then ensure that the design functions properly.

6.4.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1. Reinstall the upholstered pads for this test. Obtain instructions or a descriptive explanation of the function of the assist mechanism(s) used on the sample from the manufacturer.

6.4.3 *Calibration*—No calibration required. Visual and function inspection only.

6.4.4 *Procedure*—Adjust the machine for the evaluator's size according to the manufacturer's instructions. The evaluator shall enter the machine and attempt to get into the exercise start position as described in the operation instructions provided by the manufacturer. The evaluator shall be able to get into and back out of the starting position with relative ease. If the lifting or user means cannot be reached by the evaluator or if the evaluator cannot get into the starting position easily, then further adjustment of the machine may be required. If this is not the case (the machine is properly adjusted per the operation instructions for the given body size of the evaluator), then an assist means that moves the lifting or user means into the direction of lifting stroke must be provided.

6.4.4.1 If an assist means is provided, then operate the mechanism and ensure that it performs as described in the operation instructions. Upon actuation of the assist means, the lifting or user means shall move into the direction of machine motion allowing the user to get into the loaded exercise start position. Upon completion of the exercise and return of the lifting or user means to the rest position, actuation of the assist

means shall stop the lifting or user means prior to reaching the unloaded rest position, thereby allowing the user to exit from the loaded use position.

6.4.5 *Pass/Fail Criteria*—Machines that do not allow the user to enter or exit the machine easily shall fail the test. Assist mechanisms that do not function according to the instructions provided by the manufacturer shall fail test. Assist mechanisms that do not stop the lifting or user means far enough into the lifting stroke to allow the user to control and/or stop the final return travel of the lifting or user means shall fail the test.

6.4.6 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.4 for evaluating assist mechanism design and function since the test result is non-quantitative.

6.5 *Belt or Rope System Design and Load Testing:*

6.5.1 This test is a visual, physical, and functional inspection of the cables, belts, or ropes and their end fittings and attachment means used on the sample to route the load from the resistance means to the user means to ensure that the design functions as intended and meets the parameters of Specification F2216.

6.5.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1. Obtain instructions or a descriptive explanation of the function of the specimen from the manufacturer. Three cable, belt, or rope specimens measuring 150 mm (5.9 in.) replicating the system installed on sample including their attachment means shall be provided for a separate loading test.

6.5.3 *Calibration*—Calibrate the load measurement apparatus to confirm accuracy to within  $\pm 50$  N ( $\pm 11$  lb).

6.5.4 *Procedure:*

6.5.4.1 *Design Evaluation*—Select the minimum resistance level for the sample. Cycle the machine through several complete repetitions while observing the rope or belt attachment points. Ensure that all end fittings and attachments move freely with the lifting and resistance means and that the rope or belt does not cyclically bend or flex around these components by more than a total amount of 10°, as shown in Fig. 2.

6.5.4.2 *Load Testing*—Obtain and record from the manufacturer the maximum load amount that the belt or rope system is subjected to during operation of the sample machine through its recommended range of motion. This should take into account any multiplying effects designed into the system to increase the resistance to the user. Secure a 150 mm (5.9 in.) specimen at its end fittings or attachments points into a tensile loading apparatus capable of loading the specimen with 6 times the aforementioned maximum load. The apparatus shall be capable of recording the maximum load attained during the test. Apply a load to the system equal to 6 times the maximum load stated above. Maintain this load for 5 min. If the system fails before attaining the 6 times load, record the load attained at failure. If the system attains the load but fails before the 5 min test period has expired, record the load and the amount of time at that load. Repeat the test for each of the remaining specimens.

6.5.5 *Pass/Fail Criteria:*

6.5.5.1 *Design*—If the end fitting or termination point on a belt or rope cyclically flexes through an arc of more than 10° during normal or intended use as defined by the manufacturer




FIG. 2 Cable and Fitting Flexure

in either a combined or unidirectional amount then the cable, belt, or rope system shall fail the test.

6.5.5.2 *Load Testing*—If the belt or rope system fails to attain 6 times the maximum load and fails to maintain that load for 5 min then the system shall fail the test.

6.5.6 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.5 for evaluating belt or rope system design since the test result is non-quantitative.

6.6 *Pulley and Pulley Enclosure Design:*


6.6.1 This test is a visual, physical, and functional inspection of the pulleys used on the sample to route the load from the resistance means to the user means to insure that the design functions as intended and meets the parameters of Specification F2216. This test also verifies that the pulley enclosures prevent the ropes or belts from being inadvertently disengaged from the pulleys.

6.6.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1. Obtain instructions or a descriptive explanation of the function of the specimen from the manufacturer. A method of applying a force of 20 N (4.5 lb) perpendicularly to the rope or belt shall be provided.

6.6.3 *Calibration*—Calibrate the load measurement apparatus to confirm accuracy to within  $\pm 0.5$  N (0.1 lb). Verify that the measuring device is accurate to 1 mm (0.04 in.).

6.6.4 *Procedure*—Inspect and measure the pulley and verify that it falls within the parameters specified in Specification F2216 for the size wire rope being used on the machine. If the machine is belt driven, verify that the pulley is designed to





**FIG. 3 Probe Specifications**

prevent disengagement. Appropriate means would include convex or concave profile or retainment edges on each side of the pulley.

6.6.4.1 Examine the enclosures for the pulleys. Grasp the rope or belt as it exits/enters the enclosure and apply a pulling force of 20 N (4.5 lb) 90° to the direction of travel. The cable or belt shall not come off of the pulley. Repeat this process at other pulley locations on the machine.

6.6.4.2 Select the full resistance level of the sample and move the lifting means through one or more cycles at a slow and controlled rate of motion. The pulleys shall rotate as the lifting means is cycled.

6.6.5 *Pass/Fail Criteria*—Pulleys with dimensions falling outside of those specified in Specification F2216 shall fail test. Belt pulleys failing to feature a retention design shall fail the test. Enclosures that allow for disengagement of the cable or belt shall fail the test. Pulleys that do not rotate under full loading shall fail this test.

6.6.6 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.6 for evaluating pulley and pulley enclosure design and function since the test result is non-quantitative.

### 6.7 *Entrapment Testing:*

6.7.1 This test is to evaluate the risk of injury to the user or to a third party due to inadvertent contact with a moving mechanical part and a fixed component of the machine. The results of this test determine the adequacy of spacing between components. Methodology entails insertion of a sized probe into the entrapment areas discussed in Specification F2216. It has been assumed that contact in these areas is inadvertent and therefore the test will be perpendicular and through the area in question and not articulated into all possible areas around the potential hazard.

6.7.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1 with the upholstered pads reinstalled. This test requires a probe as specified in Fig. 3.

6.7.3 This test also requires sized probes of 9.5 mm (0.38 in.) and 25 mm (0.98 in.) for areas most susceptible to finger injury and 60 mm (2.36 in.) for all other areas. Verify that all guards are properly positioned and secured. An apparatus capable of measuring 4.4 N (1 lb) of pulling force shall be provided.

6.7.4 *Calibration*—Calibrate the load measurement apparatus to confirm accuracy to within  $\pm 0.5$  N (0.1 lb). Verify that the probe conforms to the dimensions shown in Fig. 3. Verify that the 9.5 mm (0.37 in.) sized probe is no less than the stated size and that the other sized probes are no greater than their stated sizes.

6.7.5 *Procedure*—Refer to Specification F2216 while conducting this test. The evaluator shall place himself/herself on the sample in the operational position and determine and note regions of the sample that are to be evaluated. Areas of concern that are 1800 mm (71 in.) or more above the floor are exempt from this requirement and do not need to be examined further. Areas that are blocked by the user of the equipment throughout the range of motion are also exempt from further examination. The evaluator shall pay attention to areas outside their field of view and areas outside their reach as discussed in Specification F2216. The evaluator shall determine, for the area of concern, the portion of the body most likely to be injured and then use the appropriate probe. Insert the probe perpendicular to this area and cycle the machine through one stroke with the minimum resistance selected to verify probe entrapment. Repeat with the full amount of resistance for the area of concern. Pay close attention to the deflection of the machine and its components as this deflection may create new areas of concern. If the probe becomes entrapped, apply a pulling force to remove the probe. Record the force required to remove the probe.

6.7.6 *Pass/Fail Criteria*—The probe shall not become entrapped in any mechanical hazard. Entrapment is defined to have occurred if the force to pull out the probe is greater than 4.4 N (1 lb).

6.7.7 *Precision and Bias*—No information is presented about either the precision or bias of test in 6.7 for evaluating entrapment points outside of the field of view of the user since the test result is non-quantitative.

### 6.8 *Pull-In Point Testing:*

6.8.1 This test is to evaluate the risk of injury to the user or to a third party due to inadvertent contact between either rotating and fixed components of the sample or between the belts/ropes/chains of the sample and their respective cams, pulleys, or sprockets. The results of this test determine the adequacy of spacing between components or the adequacy of the guarding of those components, or both. Methodology entails insertion of a sized probe into the pull in areas discussed in Specification F2216. It has been assumed that contact in these areas is inadvertent and therefore the test will be perpendicular and through the area in question and not articulated into all possible areas around the potential hazard.

6.8.2 *Apparatus and Set Up*—The sample shall be set up as described in 5.1 with the upholstered pads reinstalled. This test requires a probe as specified in Fig. 3. This test also requires a sized probe of 25 mm (0.98 in.). Verify that all guards are properly positioned and secured. An apparatus capable of measuring 4.4 N (1 lb) of pulling force shall be provided. Pressure measuring film capable of measuring 90 N/cm<sup>2</sup> (131 psi) shall be provided.<sup>4</sup>

6.8.3 *Calibration*—Calibrate the load measurement apparatus to confirm accuracy to within  $\pm 0.5$  N (0.1 lb). Verify that

<sup>4</sup> The sole source of supply of the film (Fuji Prescale Film—single sheet type for high pressure) known to the committee at this time is Fuji Photo Film Co. Ltd, Tokyo, Japan or their distributors. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee,<sup>1</sup> which you may attend.

the probe conforms to the dimensions shown in Fig. 3. Verify that the 9.5 mm (0.37 in.) sized probe is no less than the stated size and that the other sized probes are no greater than their stated sizes.

**6.8.4 Procedure**—The evaluator shall place himself/herself on the sample in the operational position and determine and note regions of the sample that are to be evaluated. Specification **F2216** must be referred to in order to determine which areas shall be evaluated. Areas of concern that are 1800 mm (71 in.) or more above the floor are exempt from this requirement and do not need to be examined further. Areas that are blocked by the user of the equipment through out the range of motion are also exempt from further examination. The evaluator shall pay attention to areas outside their field of view and areas outside their reach as discussed in Specification **F2216**. The evaluator shall insert the probe perpendicular to the area in question, parallel to the axis of rotation or plane of motion and cycle the machine through one stroke with the full amount of resistance for the specimen selected. If the probe becomes entrapped during either the outward or return stroke, apply a pulling force to remove the probe. Record the force required to remove the probe. For areas requiring more than 4.4 N (1 lb) of removal force apply the pressure measuring film per the manufacturer’s instructions and cycle the machine again with the full resistance selected. Record the pressure reading obtained from the film.

**6.8.5 Pass/Fail Criteria**—The probe shall not become entrapped in any mechanical hazard. Pull-in is defined to have occurred if the force to pull out the probe is greater than 4.4 N (1 lb). Pull in areas in rope and belt driven machines where the pressure recorded on the pressure measuring film is 90 N/cm<sup>2</sup> (131 psi) or less shall be exempt from guarding requirements.

**6.8.6 Precision and Bias**—No information is presented about either the precision or bias of test in 6.8 for evaluating pull in points since the test results are non-quantitative.

### 6.9 Weight Stack Enclosure Design:

**6.9.1** This test is a visual and physical test to evaluate the design of the weight stack enclosure provided with the sample. Methodology entails the visual examination of the weight stack enclosure relative to the user’s placement on the machine and the insertion of a sized probe into the areas between the weights and the enclosure.

**6.9.2 Apparatus and Set Up**—The sample shall be set up as described in 5.1 with the upholstered pads reinstalled. The sample shall have the weight stack enclosure installed per the manufacturer’s instructions. This test requires sized probes of 9.5 mm (0.37 in.), 25 mm (0.98 in.), and 60 mm (2.36 in.).

**6.9.3 Calibration**—Verify that the 9.5 mm (0.37 in.) sized probe is no less than the stated size and that the other sized probes are no greater than their stated sizes.

**6.9.4 Procedure**—The evaluator shall place himself/herself on the sample in the operational position and determine and note where the weight stack is relative to their field of vision while using the machine. Referring to Specification **F2216**, the evaluator shall determine the amount of guarding required around the weight stack. Measure and record the spacing provided between the enclosure halves for insertion of the weight selection pin. Measure and record the extension of the

enclosure beyond the furthest range of travel of the weight stack for a user of 1.8 m (74 in.) stature. With the weights in the rest position, measure and record the spacing between the weights and the enclosure.

**6.9.5 Pass/Fail Criteria**—Spacing for insertion of the weight selection pin that exceeds 75 mm (2.95 in.) shall fail the test. Enclosures that do not extend 60 mm (2.36 in.) past the furthest range of travel of the weight stack fail the test. Enclosures that are between 9.5 mm (0.37 in.) and 25 mm (0.98 in.) from the edges of the weights shall fail the test.

**6.9.6 Precision and Bias**—No information is presented about either the precision or bias of test in 6.9 for evaluating weight stack enclosure design since the test result is non-quantitative.

### 6.10 Load Testing:

**6.10.1 Endurance Cycle Testing**—This test is a visual and physical inspection of the specimen to ensure that it shall withstand endurance cycles set forth in Specification **F2216** without failure.

**6.10.1.1 Apparatus and Set Up**—The sample shall be set up as described in 5.1 with the maximum resistance available for the product. It is acceptable, for this test, to anchor the machine to the floor to prevent “walking.” Note and record whether the specimen is intended for consumer or institutional use. Obtain instruction or a descriptive explanation of the function of the sample machine from the manufacturer. A nonimpact method of cycling the machine through at least 80 % of its normal range of motion, as defined by the manufacturer, shall be provided. A method of recording the number of cycles shall be provided. A method of loading the machine with extrinsic loads experienced during the cycling of the machine shall be provided.

**6.10.1.2 Calibration**—Verify the accuracy of the cycle counting device to  $\pm 1$  cycle.

**6.10.1.3 Procedure**—Determine from the manufacturer’s specifications the maximum range of travel for the machine. Construct and attach to the user means of the machine an apparatus capable of moving the user means through 80 % of this range while loaded with the maximum resistance of the machine. The testing apparatus shall move the user means in the same manner that the user does. For example, if the user contacts the user means in two locations then the testing apparatus must do so as well. If during the course of operation the machine receives loading from the user via the user means then this shall be considered and figured into the design of the testing apparatus. If the user’s body weight is a factor in the loading of the machine during cyclic operation then 135 kg (300 lb), simulating a user, shall be attached to the user support surface at the point of user contact.

(1) The design of the testing apparatus will be unique and different for each product tested. Careful consideration shall be given by the testing facility as to how the test apparatus is constructed and they shall communicate with the manufacturer prior to commencing the test to verify that the apparatus functions in a manner similar to how a user would actually use and interface with the machine.

(2) Verify that the counter cycles for each repetition of the machine. Verify that after each repetition the load at the user

means returns to zero prior to the execution of the next repetition. This may be done with a load cell or simple visual examination of the system. If the test apparatus is to run unattended then it shall be outfitted with a means of stopping if failure occurs on the sample. Begin the test. Periodically make and record observations during the test.

(3) If the specimen has multiple stations then replace the shared components, as specified in Specification **F2216**, and repeat the test on the remaining stations.

(4) Upon completion of the cycles specified in Specification **F2216** reinstall the upholstered pads and use the machine according to the instructions provided by the manufacturer.

6.10.1.4 *Pass/Fail Criteria*—Machines or components that fail to attain the minimum number of cycles specified in Specification **F2216** shall fail the test. Machines that fail to function as per the operation instructions provided by the manufacturer after completion of the test shall fail the test.

6.10.1.5 *Precision and Bias*—No information is presented about either the precision or bias of test **6.10.1** for endurance cycling since the test result is non-quantitative.

#### 6.11 *Documentation and Warnings:*

6.11.1 This test is a confirmation that the documentation and warnings accompanying and affixed to the sample meet the requirements set forth in Specifications **F2216** and **F1749**.

6.11.2 *Apparatus and Set Up*—The sample shall be set up as described in **5.1**. Obtain all documentation for the sample from the manufacturer.

6.11.3 *Calibration*—No calibration is required. This is a visual test only.

6.11.4 *Procedure*—Examine the documentation provided with the sample. Verify that the documentation conforms to Specification **F2216**. Examine each of the warning labels affixed to the sample. Verify that the labels conform to Specification **F1749**.

6.11.5 *Pass/Fail Criteria*—Documentation must conform to requirements of Specification **F2216**.

6.11.6 *Precision and Bias*—No information is presented about either the precision or bias of test in **6.11** for documentation and warnings compliance since the test result is non-quantitative.

## 7. Additional Universal Design and Construction Requirements to Test Method **F3022** for Inclusive Use by Persons with Functional Limitations and Impairments

NOTE 1—If a conflict exists with the methods listed in Test Method **F3022**, then the specific requirements listed in Section 7 take precedence over the test methods listed in Test Method **F3022**.

### 7.1 *Access and Setup:*

7.1.1 *Access and Setup*—This test is a visual and performance inspection of the sample to ensure that joints work within a non-stressed range of motion and that start positions can be pre-set prior to mounting the equipment or self-adjusting once in the exercise position.

7.1.1.1 *Apparatus and Set Up*—The sample shall be set up as described in Section **5**.

7.1.1.2 *Calibration*—No calibration required. Visual and performance inspection only.

7.1.1.3 *Procedure*—Inspect all setup positions to ensure that the sample is adjustable. Document how many adjustments there are within each adjustment mechanism, that is, for seats, back supports, legs, handles, etc. Verify that either setup of all adjustments can be done prior to mounting equipment or that the equipment is self-adjusting across a range of multiple body sizes and shapes once in the exercise position.

7.1.1.4 *Pass/Fail Criteria*—Access and setup shall conform to the requirements of Subsection 5.1.1 of Specification **F2216**.

7.1.1.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in **7.1.1** for evaluating access and setup since the test result is non-quantitative.

NOTE 2—Performance tests to set up the equipment from the perspective of a broad range of people with disabilities, including people using wheelchairs, or those who have functional limitations, sensory deficits, cognitive impairments, or visual or hearing impairments, or a combination thereof, are suggested. One possible method would be to use testers with disabilities

7.1.2 *Start Position Setup*—This test is a performance inspection of the sample to ensure that upper body equipment does not require the use of the lower limbs to setup the start position.

7.1.2.1 *Apparatus and Set Up*—The sample shall be set up as described in Section **5**.

7.1.2.2 *Calibration*—No calibration required. Performance test only.

7.1.2.3 *Procedure*—Adjust the upper body equipment for commencement of exercise. Verify that the use of the lower limbs is not required.

7.1.2.4 *Pass/Fail Criteria*—Start position setup shall conform to the requirements of Subsection 5.1.2 of Specification **F2216**.

7.1.2.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in **7.1.2** for evaluating start position setup since the test result is non-quantitative.

### 7.2 *Seats, Sitting Surfaces, and Back Supports:*

7.2.1 *Integral Stabilization/Support*—This test is a visual inspection of the sample to ensure that seats have an adequate method of stabilization according to the exercise to be performed, that is, seats shall have an integral back support where pressing and pushing movements are required and seats shall have an integral chest pad, knee support, or similar method of stabilization where pulling movements are required.

7.2.1.1 *Apparatus and Set Up*—The sample shall be set up as described in Section **5**.

7.2.1.2 *Calibration*—No calibration required. Visual inspection only.

7.2.1.3 *Procedure*—Inspect the seat and ensure that seats have an integral back support where pressing and pushing movements are required and seats have an integral chest pad, knee support, or similar method of stabilization where pulling movements are required.

7.2.1.4 *Pass/Fail Criteria*—The integral stabilization/support shall conform to the requirements of Subsection 5.2.1 of Specification **F2216**.



7.2.1.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.2.1 for evaluating integral stabilization/support since the test result is non-quantitative.

### 7.3 Hand Grips:

7.3.1 *Fixed Stability Hand Grips*—This test is a visual inspection of the sample to ensure that fixed stability hand grips are provided on equipment where the movement path is primarily defined by the user.

7.3.1.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.1.2 *Calibration*—No calibration required. Visual inspection only.

7.3.1.3 *Procedure*—Inspect the equipment to ensure that there are fixed stability hand grips.

7.3.1.4 *Pass/Fail Criteria*—Fixed stability hand grips shall conform to the requirements of Subsection 5.3.1 of Specification F2216.

7.3.1.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.1 for evaluating fixed stability hand grips since the test result is non-quantitative.

7.3.2 *Fixed Hand Grip Dimensions*—This test is a dimensional inspection of the sample to ensure the dimensional compliance of the fixed hand grip length and location.

7.3.2.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.2.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.3.2.3 *Procedure*—Measure the height of the fixed hand grip(s) from the floor to the lowest and highest part of the fixed hand grip gripping surface. Note if there is one, continuous hand grip or multiple hand grips.

7.3.2.4 *Pass/Fail Criteria*—The height of the fixed hand grip location shall conform to dimensional requirements of Subsection 5.3.2 of Specification F2216.

7.3.2.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.2 for measuring fixed hand grip dimensions since the test result is non-quantitative.

7.3.3 *High Hand Grip Storage Position*—This test is a dimensional and functional inspection of the sample to ensure the dimensional compliance of the movable hand grip storage position.

7.3.3.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.3.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.3.3.3 *Procedure*—Set the movable hand grip in its highest storage position. Measure the height of the movable hand grip from the floor to the lowest part of the movable hand grip gripping surface.

7.3.3.4 *Pass/Fail Criteria*—The height of the high hand grip storage position shall conform to dimensional requirements of Subsection 5.3.3 of Specification F2216.

7.3.3.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.3

for measuring high hand grip storage position dimensions since the test result is non-quantitative.

7.3.4 *Low Hand Grip Storage Position*—This test is a dimensional and functional inspection of the sample to ensure the dimensional compliance of the movable hand grip storage position.

7.3.4.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.4.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.3.4.3 *Procedure*—Set the movable hand grip in its lowest storage position. Measure the height of the movable hand grip from the floor to the highest part of the movable hand grip gripping surface.

7.3.4.4 *Pass/Fail Criteria*—The height of the low hand grip storage position shall conform to dimensional requirements of Subsection 5.3.4 of Specification F2216.

7.3.4.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.4 for measuring low hand grip storage position dimensions since the test result is non-quantitative.

7.3.5 *Movable Hand Grip Storage Position Label*—This test is a visual and dimensional inspection of the sample to ensure that the movable hand grip storage position is labeled in a visible range of sight.

7.3.5.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.5.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.3.5.3 *Procedure*—Inspect movable hand grip storage position and verify that it is clearly labeled as the correct storage position for the hand grip. Measure the height of the movable hand grip storage position label from the floor to the bottom of the label.

7.3.5.4 *Pass/Fail Criteria*—The movable hand grip storage position shall conform to the requirements of Subsection 5.3.5 of Specification F2216.

7.3.5.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.5 for evaluating and measuring the movable hand grip storage position label since the test result is non-quantitative.

7.3.6 *Articulating Arms Adjustment Range*—This test is a dimensional inspection of the sample to ensure that the articulating arms adjustment mechanisms are within the specified range.

7.3.6.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.3.6.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.3.6.3 *Procedure*—Measure the height of the articulating arm adjustment mechanism from the floor to the center of the adjustment mechanism when in its lowest position. Measure the height of the articulating arm adjustment mechanism from the floor to the center of the adjustment mechanism when in its highest position.

7.3.6.4 *Pass/Fail Criteria*—The articulating arm adjustment range shall conform to the requirements of Subsection 5.3.6 of Specification F2216.



7.3.6.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.3.6 for evaluating and measuring the articulating arm adjustment mechanisms since the test result is non-quantitative.

7.4 *Instructions for Use and Labeling:*

7.4.1 *Instructions for Use Label*—This test is a dimensional and performance inspection of the sample to ensure that the instructions for use are in a clear line of sight from the exercise position.

7.4.1.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.4.1.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.4.1.3 *Procedure*—From the exercise position, verify that the main text and graphics for instructions for use are in a clear line of sight without obstruction. Measure the height of the text and graphics for the instruction label from the floor to the bottom and to the top of the instructions.

7.4.1.4 *Pass/Fail Criteria*—The height of the instructions for use label shall conform to the requirements of Subsection 5.4.1 of Specification F2216.

7.4.1.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.4.1 for evaluating and measuring the instructions for use label since the test result is non-quantitative.

7.4.2 *Instructions in Proximity to Components*—This test is a dimensional inspection of the sample to ensure that the instructions related to specific equipment components are located within proximity to that component.

7.4.2.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.4.2.2 *Calibration*—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

7.4.2.3 *Procedure*—Measure the distance between the specific component of the exercise equipment and the related instruction label.

7.4.2.4 *Pass/Fail Criteria*—The instructions in proximity to components shall conform to the requirements of Subsection 5.4.2 of Specification F2216.

7.4.2.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.4.2 for measuring the instructions in proximity to components since the test result is non-quantitative.

7.4.3 *Mobility Aid Warning Label*—This test is a visual and performance inspection of the sample to ensure that there is a maximum loading and stability warning label for personal mobility aids.

7.4.3.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.4.3.2 *Calibration*—No calibration required. Visual and performance inspection only.

7.4.3.3 *Procedure*—From the exercise position, verify that there is a maximum loading and stability warning label for personal mobility aids in the line of sight without obstruction.

7.4.3.4 *Pass/Fail Criteria*—The mobility aid warning label shall conform to the requirements of Subsection 5.4.3 of Specification F2216.

7.4.3.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.4.3 for evaluating the mobility aid warning label since the test result is non-quantitative.

7.4.4 *Owner's/User's Manual Mobility Aid Warning*—This test is a visual inspection of the sample to ensure that there is a maximum loading and stability warning for personal mobility aids.

7.4.4.1 *Calibration*—No calibration required. Visual inspection only.

7.4.4.2 *Procedure*—Inspect the product owner's/user's manual to ensure that there is a maximum loading and stability warning for personal mobility aids.

7.4.4.3 *Pass/Fail Criteria*—Owner's/user's manual mobility aid warning shall conform to the requirements of Subsection 5.4.4 of Specification F2216.

7.4.4.4 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.4.4 for evaluating the owner's/user's manual mobility aid warning since the test result is non-quantitative.

7.4.5 *Graphic Start/End Positions*—This test is a visual inspection of the sample to ensure that the instruction panel(s) graphically depicts the start and end exercise positions.

7.4.5.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.4.5.2 *Calibration*—No calibration required. Visual inspection only.

7.4.5.3 *Procedure*—Inspect the equipment to ensure that the instruction panel(s) graphically depicts the start and end exercise positions.

7.4.5.4 *Pass/Fail Criteria*—Graphic start/end positions shall conform to the requirements of Subsection 5.4.5 of Specification F2216.

7.4.5.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.4.5 for evaluating graphic start/end positions since the test result is non-quantitative.

7.5 *Weight/Resistance Settings:*

7.5.1 *Start/Incremental Resistance*—This test is a dimensional inspection of the sample to ensure the dimensional compliance of the start and incremental resistance.

7.5.1.1 *Apparatus and Set Up*—Secure the tested unit to a flat horizontal surface. The starting force required to move machine's user means shall be measured with a force gauge (for example, digital force gauge, mechanical force gauge, spring balance, or load cell with DAQ).

(1) For equipment with adjustable settings, such as handle arm lengths or footplate positions, the testing shall be performed according to 7.5.1.3 at the two extreme setups – for the shortest and the tallest user; the interface location with the largest force required to move machine's user means shall represent the machine.

(2) For equipment with multiple user means locations available for exercising the same or substantially similar muscle groups, each location should be measured with the procedure described in 7.5.1.3; the interface location with the lowest force required to move machine's user means shall represent the machine.

(3) For equipment with multiple user means locations available for exercising substantially different muscle groups, each location shall be measured with the procedure described in 7.5.1.3; the force required to move machine’s user means for each interface location shall individually meet the pass/fail criteria as defined in 7.5.1.4.

(4) For equipment with independently weighted sides, each side should be tested separately.

(5) For equipment with rigidly connected dual user interface locations with coupled sides, a single force gauge acting on one side only may be used for measurement if operation of the machine is not affected by the unbalanced force application. If multiple contact points are required to properly operate the machine, measurements can be made using either an intermediate device connected to a single force gauge or multiple force gauges at each interface location.

7.5.1.2 *Calibration*—Calibrate, or verify calibration of, the load measurement apparatus to confirm accuracy to within  $\pm 2$  N (0.45 lb).

7.5.1.3 *Procedure*—Test the sample as follows:

(1) The force gauge should be positioned at (attached to or otherwise stably contacting) the user means, specifically at the location of user force application during the test. The user means may be a handle, footplate, calf pad, or other such interface. The force gauge should be attached to or otherwise stably contact the user means with an  $80 \pm 5$  mm ( $3.1 \pm 0.2$  in.) wide belt or rigid pad for pulling or pushing, respectively. For testing equipment that requires multiple contact points using multiple force gauges, each force gauge should be attached to or otherwise stably contact the user means. Equipment requiring multiple contact points can also be tested using an intermediate device, such as the “Y” shaped strap illustrated in Fig. 4, attached to or otherwise stably contacting the user means at multiple locations and connected to a single force gauge. The axis of force measurement should be aligned with the direction of travel of the test equipment. When using multiple gauges or an intermediate device, the direction of force application from the gauge(s) needs to be aligned in the direction of travel. Example: If the force gauge is attached at a handle that moves in an arc, the direction the force gauge measures should be tangential to the arc at the measurement position.

(2) Select the lowest operational weight on the test equipment.

(3) Move the user means away from its resting position until the selected resistance weight is moved 25 mm (1.0 in.) from its resting place.

(4) Using the force gauge, apply the necessary force to keep the user means at the location achieved in the previous step by pushing or pulling in the appropriate direction, that is, the direction of force applied during regular exercise.

(5) Record the measured force. The measurement may be repeated multiple times to ensure that the appropriate direction of travel/force application was achieved. The lowest value of the measurements taken shall represent the force required to move the machine’s user means at its lowest operational weight.

NOTE 3—If multiple force gauges with multiple contact points are




FIG. 4 “Y” Shaped Strap Connecting Multiple Locations to Single Force Gauge

required for the intended operation of the machine, the measurements taken from all gauges shall be summed to provide a single measurement for the equipment.

7.5.1.4 *Pass/Fail Criteria*—The force required to hold machine’s user means at the lowest operational weight, as measured per the procedure described in Subsection 5.5.1 of Specification F2216, shall be equal to or less than the thresholds provided in the standard specifications.

7.5.1.5 *Precision and Bias*—No information is presented about either the precision or bias of this test since the test result is non-quantitative.

7.5.2 *Integral/Incremental Weights*—This test is a visual and performance inspection of the sample to ensure that all weights are an integral part of the equipment.

7.5.2.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

7.5.2.2 *Calibration*—No calibration required. Visual and performance inspection only.

7.5.2.3 *Procedure*—Test all weights, including incremental weights, to verify that they are an integral part of the equipment and cannot be removed.

7.5.2.4 *Pass/Fail Criteria*—Integral and incremental weights shall conform to the requirements of Subsection 5.5.2 of Specification F2216.

7.5.2.5 *Precision and Bias*—No information is presented about either the precision or bias of the test described in 7.5.2

for evaluating integral and incremental weights since the test result is non-quantitative.

**7.5.3 Single Numbering System**—This test is a visual inspection of the sample to ensure that a single numbering system is used on both the main and incremental weights.

**7.5.3.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**7.5.3.2 Calibration**—No calibration required. Visual inspection only.

**7.5.3.3 Procedure**—Inspect the equipment to ensure that a single numbering system is used on both the main and incremental weights.

**7.5.3.4 Pass/Fail Criteria**—The single numbering system shall conform to the requirements of Subsection 5.5.3 of Specification F2216.

**7.5.3.5 Precision and Bias**—No information is presented about either the precision or bias of the test described in 7.5.3 for evaluating the single numbering system since the test result is non-quantitative.

**7.5.4 Weight Markings Location**—This test is a visual and dimensional inspection of the sample to ensure that weight adjustment marking meets the location criteria.

**7.5.4.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**7.5.4.2 Calibration**—Verify that the distance measuring equipment is calibrated and accurate to within 1 mm (0.040 in).

**7.5.4.3 Procedure**—Measure the distance from the markings at the closest edge to the weight of the position of selection. Inspect any additional iconography to ensure that it points toward and aligns correctly with the appropriate selection position.

**7.5.4.4 Pass/Fail Criteria**—The weight markings location shall conform to the requirements of Subsection 5.5.4 of Specification F2216.

**7.5.4.5 Precision and Bias**—No information is presented about either the precision or bias of the test described in 7.5.4 for evaluating and measuring weight markings location since the test result is non-quantitative.

**7.5.5 First Weight Selection Position**—This test is a visual inspection of the sample to ensure that there is a method to secure the weight pin when selecting the minimum amount of weight on the weight stack.

**7.5.5.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**7.5.5.2 Calibration**—No calibration required. Visual inspection only.

**7.5.5.3 Procedure**—Inspect the equipment to ensure that there is a method to secure the weight pin when selecting the minimum amount of weight on the weight stack.

**7.5.5.4 Pass/Fail Criteria**—The first weight selection position shall conform to the requirements of Subsection 5.5.5 of Specification F2216.

**7.5.5.5 Precision and Bias**—No information is presented about either the precision or bias of the test described in 7.5.5 for evaluating first weight selection position since the test result is non-quantitative.

**7.5.6 Spot Meter Test**—See Test Method F3022, 7.3 Color Value Contrast.

**7.6 Foot Support/Platforms:**

**7.6.1 Foot Support Mechanism**—This test is a visual inspection of the sample to ensure that there is a method to secure the foot/heel on the leg press platform.

**7.6.1.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**7.6.1.2 Calibration**—No calibration required. Visual inspection only.

**7.6.1.3 Procedure**—Inspect the equipment to ensure that there is a method to secure the foot/heel on the leg press platform.

**7.6.1.4 Pass/Fail Criteria**—The foot support mechanism shall conform to the requirements of Subsection 5.6.1 of Specification F2216.

**7.6.1.5 Precision and Bias**—No information is presented about either the precision or bias of the test described in 7.6.1 for evaluating the foot support mechanism since the test result is non-quantitative.

**7.6.2 Spot Meter Test**—See Test Method F3022, 7.3 Color Value Contrast.

## 8. Documentation

**8.1 Documentation**—This test is a confirmation that the documentation accompanying the unit meets requirements and the marking on the unit meets the requirements of Specifications F2216 and F2276.

**8.1.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**8.1.2 Calibration**—No calibrations required.

**8.1.3 Procedure**—Examine the documentation provided with the unit. Verify that the documentation is legible. Examine the marking on the fitness equipment and verify it conforms to the requirements of Specifications F2216 and F2276.

**8.1.4 Pass/Fail Criteria**—Documentation must conform to requirements of Specifications F2216 and F2276.

**8.1.5 Precision and Bias**—No information is presented about either the precision or bias of this test for documentation compliance since the test is non-quantitative.

## 9. Marking

**9.1 Fitness equipment** shall have manufacturer identification affixed to the product in accordance with Specification F2216.

## 10. Warnings

**10.1 Warning Label Compliance**—This test is a visual confirmation that the test unit is properly labeled.

**10.1.1 Apparatus and Set Up**—The sample shall be set up as described in Section 5.

**10.1.2 Calibration**—No calibration required.

**10.1.3 Procedure**—Inspect the unit for warning labels and tags. Ensure that the labels are firmly affixed to the unit and cannot be readily removed.

**10.1.4 Pass/Fail Criteria**—Labeling must conform to requirements of Specification F2216 and Specification F1749.

**10.1.5 Precision and Bias**—No information is presented about either the precision or bias of the test for warning label compliance since the test result is non-quantitative.



10.2 *Documentation*—This test is a confirmation that the documentation accompanying the unit meets requirements and the marking on the trainer meets the requirements of Specification F2216 and Specification F2276.

10.2.1 *Apparatus and Set Up*—The sample shall be set up as described in Section 5.

10.2.2 *Calibration*—No calibration required.

10.2.3 *Procedure*—Examine the documentation provided with the unit. Verify that the documentation is legible. Examine the marking on the fitness equipment and verify it conforms to the requirements of Specification F2216 and Specification F2276.

10.2.4 *Pass/Fail Criteria*—Documentation must conform to requirements of Specification F2216 and Specification F2276.

10.2.5 *Precision and Bias*—No information is presented about either the precision or bias of this test for documentation compliance since the test is non-quantitative.

## 11. Certification

11.1 These test methods permit self-certification. It is recommended that each manufacturer employ an independent laboratory to evaluate and validate that their designs and test procedures conform and comply to these test methods and Specification F2216.

## 12. Report

12.1 *Record of Tests*—Maintain complete test records and test summary reports for all testing, whether performed by the manufacturer or an independent laboratory. The records can be stored on paper, electronically, or on photographs, or a com-

bination thereof. A copy of the test summary must be kept by the laboratory that performed the test for a minimum of five years from the date of the test and by the manufacturer for a minimum of five years past the end of production of the model tested. The summary shall include the signature of the technician(s) performing the tests and a management representative of the laboratory performing the test. The test summary shall include the following information:

12.1.1 Manufacturer's name and location.

12.1.2 Information provided by the manufacturer to accurately identify the configuration of, and specific unit provided to, the testing agency.

12.1.3 Dates over which the tests were conducted.

12.1.4 Name and location of the testing laboratory, if different from the manufacturer.

12.1.5 Summary and results of each test performed including method and apparatus used. This shall include what the desired requirement was and whether the test sample met that parameter or failed. If the test requires a specific number of cycles to be met, then the report must include the number of cycles actually conducted. If the sample fails to meet a parameter, then that failure must be noted in clear and accurate terms to enable a reader of the report to understand at a later date what transpired.

## 13. Keywords

13.1 accessibility; Americans with Disabilities Act (ADA); cable; disability; disabled; fitness; inclusive; pulley; strength equipment; weight stack

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/*