Designation: F438 - 17

An American National Standard

Standard Specification for Socket-Type Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 40¹

This standard is issued under the fixed designation F438; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 This specification covers chlorinated poly(vinyl chloride) (CPVC) Schedule 40 socket-type pipe fittings. Included are requirements for materials, workmanship, dimensions, and burst pressure.

Note 1—The CPVC fittings covered by this standard were covered previously in Specification D2466.

1.2 The products covered by this specification are intended for use with the distribution of pressurized liquids only, which are chemically compatible with the piping materials. Due to inherent hazards associated with testing components and systems with compressed air or other compressed gases, some manufacturers do not allow pneumatic testing of their products. Consult with specific product/component manufacturers for their specific testing procedures prior to pneumatic testing.

Note 2—Pressurized (compressed) air or other compressed gases contain large amounts of stored energy, which present serious safety hazards should a system fail for any reason.

- 1.3 The text of this specification references notes, footnotes, and appendixes which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the specification.
- 1.4 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.
- 1.5 The following safety hazards caveat pertains only to the test method portion, Section 8, of this specification: This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health and environmental practices and determine the applicability of regulatory limitations prior to use.
- 1.6 This international standard was developed in accordance with internationally recognized principles on standard-

¹ This specification is under the jurisdiction of ASTM Committee F17 on Plastic Piping Systems and is the direct responsibility of Subcommittee F17.10 on Fittings. Current edition approved Aug. 1, 2017. Published August 2017. Originally approved in 1974. Last previous edition approved in 2015 as F438 – 15. DOI: 10.1520/F0438-17.

ization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

2. Referenced Documents

2.1 ASTM Standards:²

D618 Practice for Conditioning Plastics for Testing

D1599 Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings

D1600 Terminology for Abbreviated Terms Relating to Plastics

D1784 Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds

D2122 Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings

D2466 Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40

D2749 Symbols for Dimensions of Plastic Pipe Fittings

F412 Terminology Relating to Plastic Piping Systems

F1498 Specification for Taper Pipe Threads 60° for Thermoplastic Pipe and Fittings

2.2 Federal Standard:³

Fed. Std. No. 123 Marking for Shipment (Civil Agencies)

2.3 Military Standard:⁴

MIL-STD-129 Marking for Shipment and Storage

2.4 NSF Standard:⁴

Standard No. 14 for Plastic Piping Components and Related Materials

Standard No. 61 for Drinking Water Systems Components— Health Effects

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website

³ DLA Document Services Building 4/D 700 Robbins Avenue Philadelphia, PA 19111-5094 http://quicksearch.dla.mil/

⁴ Available from NSF International, P.O. Box 130140, 789 N. Dixboro Rd., Ann Arbor, MI 48113-0140, http://www.nsf.org.



3. Terminology

- 3.1 Definitions:
- 3.1.1 Definitions are in accordance with Terminology F412 and abbreviations are in accordance with Terminology D1600, unless otherwise indicated. The abbreviation for chlorinated poly(vinyl chloride) is CPVC.

4. Classification

- 4.1 *General*—This specification covers Schedule 40 CPVC pipe fittings, socket-type, intended for use with Iron Pipe Size (IPS) outside-diameter plastic pipe.
- 4.1.1 Fittings covered by this specification are normally molded. In-line fittings, such as couplings, unions, bushings, caps, nipples, and the like, shall be molded or machined from extruded stock.
- 4.1.2 Fittings fabricated by backwelding are not included in this specification.

Note 3—This specification does not include requirements for pipe and fittings intended to be used to vent combustion gases.

5. Materials and Manufacture

5.1 This specification covers CPVC pipe fittings made from compounds meeting the requirements of Class 23447 as defined in Specification D1784.

Note 4—Mechanical strength, heat resistance, flammability, and chemical resistance requirements are covered in Specification D1784.

5.2 Rework Material—The manufacturers shall use only their own clean rework fitting material and the fittings produced shall meet all the requirements of this specification.

6. Requirements

- 6.1 Dimensions and Tolerances:
- 6.1.1 Fitting sockets, inside diameters (waterways), minimum wall thicknesses, and dimensions shall be as shown in Tables 1-4 and when measured in accordance with Test Method D2122.
- 6.1.2 When multistep reducer bushings are cored out, the inner socket shall be reinforced from the outer wall by a minimum of three ribs extending from the top of the inner socket in the deepest extremity of the coring. The transition from D to DJ (Table 3) shall be straight, tapered as shown, or radiused. A positive taper in the same direction of the taper in the socket on the outside diameter of the bushing is optional.
- 6.1.3 The maximum angular variation of any opening shall be not more than $\frac{1}{2}$ ° off the true centerline axis.
- 6.1.4 The minimum wall thickness of fittings shall be 125 % of the minimum wall thickness of the corresponding size of Schedule 40 pipe for which they are designed to be used, except that for the socket, the wall thickness shall be at least equal to the minimum wall thickness of the corresponding size of Schedule 40 pipe. For any threaded transition fitting, the minimum wall thickness of the threaded portion shall be at least equal to the thickness of material under the thread root of threaded Schedule 80 pipe of the same size.
- 6.1.5 The minimum inside diameter of the fittings shall be not less than the minimum specified inside diameter of the corresponding size of Schedule 40 pipe. Any fitting having a

male thread shall have an internal diameter not larger than Schedule 80 pipe of the same size.

- 6.1.6 Minimum dimensions have zero negative tolerance. Tolerances on other dimensions are shown in Table 1 and Table 3.
- 6.2 *Threads*—For all fittings having taper pipe threads, threads shall conform to Specification F1498 and be gaged in accordance with 8.4.
 - 6.3 Burst Pressure:
- 6.3.1 The minimum burst strength of the fittings shall be not less than that calculated for the size and wall thickness of the pipe with which it is to be used, when calculated from the following equation:

$$S = P(D_{O} - t)/2t$$

where:

S = hoop stress, psi (or MPa),

P = internal pressure, psi (or MPa),

 D_O = average outside diameter, in. (or mm), and

t = minimum wall thickness, in. (or mm).

Fittings tested in accordance with 8.5 shall withstand the minimum burst pressure shown in Table 4.

6.3.2 Pressures shown are minimum burst pressures and do not imply rated working pressures. The burst pressure shall be used only as an indication of quality.

7. Workmanship, Finish, and Appearance

7.1 The fittings shall be homogeneous throughout and free of cracks, holes, foreign inclusions, or other defects. The fittings shall be as uniform as commercially practicable in color, opacity, density, and other physical properties.

8. Test Methods

- 8.1 Conditioning—Condition the test specimens at 73.4 \pm 3.6°F (23 \pm 2°C) and 50 \pm 10 % relative humidity for not less than 40 h prior to test in accordance with Procedure A of Practice D618, for those tests where conditioning is required.
- 8.2 Test Conditions—Conduct tests in the Standard Laboratory Atmosphere of 73.4 \pm 3.6°F (23 \pm 2°C) and 50 \pm 10 % relative humidity, unless otherwise specified in the test methods or in this specification.
- 8.3 Sampling—A sufficient quantity of fittings as agreed upon between the seller and the purchaser shall be selected at random from each lot or shipment and tested to determine that the basic design is in conformance with this specification.

Note 5—For individual orders or specifications where supplemental tests are required, only those tests and numbers of tests specifically agreed upon between the purchaser and the seller need be conducted.

- 8.4 *Threads*—All taper pipe threads shall be gaged in accordance with Specification F1498.
- 8.5 Burst Pressure—Determine the minimum burst pressure in accordance with Test Method D1599, Procedure B. The pressure shall be applied at a uniform rate such that the minimum allowable burst pressure is attained in 60 and 70 s.

Note 6—Provided the minimum burst pressure is met or exceeded between 60 and 70 s, the time-to-failure may exceed 70 s.

TABLE 1 Tapered Sockets for CPVC Pipe Fittings, Schedule 40, in. $(mm)^4$




	- 1	Soci	Socket Bottom Diameter	eter	CB	D^{C} Inside	Wall Thickness, min	ness, min	Outside	Entrance, min	e, min
Tolerance Maximum Diameter Tolerance on Diameter Out-of-Round in. (mm) in. (mm) in. (mm)	Diameter in. (mm)	Toleran on Diam in. (mr		Maximum Out-of-Round in. (mm)	min in. (mm)	Diameter, min in. (mm)	<i>E</i> in. (mm)	F in. (mm)	of Hub, M, min	<i>EW</i> in. (mm)	EX, EZ in. (mm)
±0.004 (0.10) 0.016 (0.41) 0.536 (13.6) ±0.004 (0.10) ±0.004 (0.10) 0.016 (0.41) 0.671 (17.04) ±0.004 (0.10)	0.536 (13.6) 0.671 (17.04)			0.016 (0.41) 0.500 (12.70) 0.016 (0.41) 0.594 (15.08)	0.016 (0.41) 0.500 (12.70) 0.016 (0.41) 0.594 (15.08)	0.320 (8.13) 0.449 (11.40)	0.088 (2.23) 0.091 (2.31)	0.110 (2.79)	0.672	1/64 (0.40) 1/32 (0.79)	1/64 (0.40) 1/32 (0.79)
±0.004 (0.10) 0.016 (0.41) 0.836 (21.23) ±0.004 (0.10) ±0.004 (0.10) 0.020 (0.51) 1.046 (26.57) ±0.004 (0.10) ±0.005 (0.13) 0.020 (0.51) 1.310 (33.27) ±0.005 (0.13)	0.836 (21.23) 1.046 (26.57) 1.310 (33.27)		(0.10) (0.10) (0.13)	0.016 (0.41) 0.020 (0.51) 0.020 (0.51)	0.688 (17.48) 0.719 (18.26) 0.875 (22.23)	0.578 (14.68) 0.740 (18.80) 0.990 (25.15)	0.109 (2.76) 0.113 (2.87) 0.133 (3.38)	0.136 (3.45) 0.141 (3.58) 0.166 (4.22)	0.998 1.221 1.504	1/32 (0.79) 1/32 (0.79) 1/16 (1.59)	1/32 (0.79) 1/32 (0.79) 1/16 (1.59)
±0.005 (0.13) 0.024 (0.61) 1.655 (42.04) ±0.005 (0.13) ±0.006 (0.15) 0.024 (0.61) 1.894 (48.10) ±0.006 (0.15) ±0.006 (0.15) 0.024 (0.61) 2.369 (60.17) ±0.006 (0.15)	1.655 (42.04) 1.894 (48.10) 2.369 (60.17)		(0.13) (0.15) (0.15)	0.024 (0.61) 0.938 (23.83) 0.024 (0.61) 1.094 (27.79) 0.024 (0.61) 1.156 (29.36)	0.938 (23.83) 1.094 (27.79) 1.156 (29.36)	1.335 (33.91) 1.564 (39.73) 2.021 (51.33)	0.140 (3.56) 0.145 (3.68) 0.154 (3.91)	0.175 (4.45) 0.181 (4.60) 0.193 (4.90)	1.871 2.127 2.634	1/16 (1.59) 1/16 (1.59) 1/16 (1.59)	1/16 (1.59) 1/16 (1.59) 1/16 (1.59)
±0.007 (0.18) 0.030 (0.76) 2.868 (72.85) ±0.007 (0.18) ±0.008 (0.20) 0.030 (0.76) 3.492 (88.70) ±0.008 (0.20) ±0.008 (0.20) 0.030 (0.76) 3.992 (101.40) ±0.008 (0.20)		±0.007 (±0.008 () ±0.008 ((0.18) (0.20) (0.20)	0.030 (0.76) 0.030 (0.76) 0.030 (0.76)	1.750 (44.45) 1.875 (47.63) 2.000 (50.80)	2.414 (61.32) 3.008 (76.40) 3.486 (88.54)	0.203 (5.16) 0.216 (5.49) 0.226 (5.74)	0.254 (6.45) 0.270 (6.86) 0.283 (7.19)	3.170 3.841 4.374	3/32 (2.38) 3/32 (2.38) 3/32 (2.38)	1/8 (3.18) 1/8 (3.18) 1/8 (3.18)
±0.009 (0.23) 0.030 (0.76) 4.491 (114.07) ±0.009 (0.23) 0.030 (0.76) ±0.010 (0.25) 0.060 (1.52) 5.553 (141.05) ±0.010 (0.25) 0.060 (1.52) ±0.011 (0.28) 0.060 (1.52) 6.614 (168.00) ±0.011 (0.28) 0.060 (1.52)		±0.009 () ±0.010 ()	(0.23) (0.25) (0.28)		2.000 (50.80) 3.000 (76.20) 3.000 (76.20)	2.000 (50.80) 3.961 (100.61) 0.237 (6.02) 3.000 (76.20) 4.975 (126.37) 0.258 (6.55) 3.000 (76.20) 5.986 (152 04) 0.280 (7.11)	0.237 (6.02) 0.258 (6.55) 0.280 (7.11)	0.296 (7.52) 0.323 (8.20) 0.350 (8.89)	4.907 6.039	3/32 (2.38) 3/32 (2.38) 1/8 (3.18)	1/8 (3.18) 1/8 (3.18) 3/16 (4.76)

 $^{\rm A}$ The sketches and designs of fittings are illustrative only. $^{\rm B}$ Socket depth, measured from socket entrance face to socket bottom face. $^{\rm C}$ See 6.1.5.



TABLE 2 Minimum Dimension from Center to End of Sockets (Laying Length) for Couplings, Tees, 90° and 45° Elbows, CPVC Socket-Type Pipe Fittings, Schedule 40, in. (mm)^A



Nominal Pipe	G, min	J, min	N, min
	,	,	,
Size	in. (mm)	in. (mm)	in. (mm)
1/4	5/16 (7.94)	5/32 (3.97)	1/16 (1.59)
3/8	3/8 (9.53)	3/16 (4.76)	3/32 (2.38)
1/2	1/2 (12.70)	1/4 (6.35)	3/32 (2.38)
3/4	%16 (14.29)	5/16 (7.94)	3/32 (2.38)
1	11/16 (17.46)	5/16 (7.94)	3/32 (2.38)
11/4	7/8 (22.22)	3/8 (9.53)	3/32 (2.38)
11/2	1 (25.40)	7/16 (11.11)	3/32 (2.38)
2	11/4 (31.75)	5/8 (15.88)	3/32 (2.38)
21/2	1½ (38.10)	11/16 (17.46)	3/16 (4.76)
3	113/16 (46.04)	3/4 (19.05)	3/16 (4.76)
31/2	21/8 (53.98)	1 (25.40)	3/16 (4.76)
4	25/16 (58.74)	1 (25.40)	3/16 (4.76)
5	3 (76.20)	1% (34.92)	3/16 (4.76)
6	31/2 (88.90)	13/4 (44.45)	1/4 (6.35)

^A The sketches and designs of fittings are illustrative only.

9. Retest and Rejection

9.1 If the results of any test(s) do not meet the requirements of this specification, the tests(s) shall be conducted again only by agreement between the purchaser and seller. Under such agreement, minimum requirements shall not be lowered, changed, or modified, nor shall specification limits be changed.

If upon retest, failure occurs, the quantity of product represented by the test(s) does not meet the requirements of this specification.

10. Product Marking

- 10.1 *Quality of Marking*—The markings shall be applied to the fittings in such a manner that they remain legible under normal handling and installation practices.
 - 10.2 Content of Marking:
 - 10.2.1 Fittings shall be marked with the following:
 - 10.2.1.1 Manufacturer's name or trademark,
 - 10.2.1.2 Material designation CPVC for CPVC 23447,
- 10.2.1.3 The seal or mark of the laboratory making the evaluation for potable water contact,
 - 10.2.1.4 Size, and
- 10.2.1.5 This designation, F438, with which the fitting complies.
- 10.3 Where the size of the fitting does not allow complete marking, omit identification marking in the following sequence: size, material designation, F438, manufacturer's name or trademark.
- 10.4 Markings or symbols shall be molded, hot-stamped, or applied to fittings by any other suitable method, such as printing.
- 10.5 Where recessed marking is used, care shall be taken to see that in no case does marking cause cracks or reduce the wall thickness below the minimum specified.


11. Quality Assurance

11.1 When the product is marked with this designation, F438, the manufacturer affirms that the product was manufactured, inspected, sampled, and tested in accordance with this specification and has been found to meet the requirements of this specification.

12. Keywords

12.1 CPVC; fittings; pressure; Sch 40; sockets; threads

TABLE 3 Dimensions of Reducer Bushings, CPVC Socket-Type Pipe Fittings, Schedule 40,^A in.



Nominal Size	Outside Diameter XA	Tolerance on Outside Diameter	Outside Diameter XB	Tolerance on Outside Diameter	Maximum Out of Roundness (max. minus min.)
1/4 by 1/8	0.540 (13.72)	+ 0.007 - 0.004 (0.18 - 0.10)	0.540 (13.72)	±0.004 (0.10)	0.016 (0.41)
3/8 by 1/4, 1/8	0.675 (17.41)	+ 0.007 - 0.004 (0.18 - 0.10)	0.675 (17.41)	±0.004 (0.10)	0.016 (0.41)
½ by 3/8, 1/4	0.840 (21.34)	+ 0.007 - 0.004 (0.18 - 0.10)	0.840 (21.34)	±0.004 (0.10)	0.016 (0.41)
3/4 by 1/2, 3/8, 1/4	1.050 (26.67)	+ 0.007 - 0.004 (0.18 - 0.10)	1.050 (26.67)	±0.004 (0.10)	0.020 (0.51)
1 by ½,¾	1.315 (33.40)	+ 0.008 - 0.005 (0.20 - 0.13)	1.315 (33.40)	±0.005 (0.13)	0.020 (0.51)
11/4 by 1/2, 3/4, 1	1.660 (42.16)	+ 0.008 - 0.005 (0.20 - 0.13)	1.660 (42.16)	±0.005 (0.13)	0.024 (0.61)
1½ by ½, ¾, 1, 1¼	1.900 (48.26)	+ 0.010 - 0.006 (0.25 - 0.15)	1.900 (48.26)	±0.006 (0.15)	0.024 (0.61)
2 by ½, ¾, 1, 1¼, 1½	2.375 (60.33)	+ 0.010 - 0.006 (0.25 - 0.15)	2.375 (60.33)	±0.006 (0.15)	0.024 (0.61)
2½ by 2	2.875 (73.03)	+ 0.012 - 0.007 (0.30 - 0.18)	2.875 (73.03)	±0.007 (0.18)	0.030 (0.76)
3 by 2½, 2	3.500 (88.90)	+ 0.013 - 0.008 (0.33 - 0.20)	3.500 (88.90)	±0.008 (0.20)	0.030 (0.76)
31/2 by 21/2, 2	4.000 (101.60)	+ 0.013 - 0.008 (0.33 - 0.20)	4.000 (101.60)	±0.008 (0.20)	0.030 (0.76)
4 by 3½, 3, 2½, 2	4.500 (114.30)	+ 0.015 - 0.009 (0.38 - 0.23)	4.500 (114.30)	±0.009 (0.23)	0.030 (0.76)
5 by 4	5.563 (141.30)	+ 0.017 - 0.010 (0.43 - 0.25)	5.563 (141.30)	±0.010 (0.25)	0.060 (1.52)
6 by 5	6.625 (168.28)	+ 0.018 - 0.011 (0.46 - 0.28)	6.625 (168.28)	±0.011 (0.28)	0.070 (1.78)

^A The sketches and designs of fittings are illustrative only—per Symbols D2749.

TABLE 4 Burst Pressure Requirements for Water at 73°F (23°C) for CPVC Socket-Type Pipe Fittings, Schedule 40

	Min I	Burst Strength, ^A
Nominal Size, in.		Class 23447
	psi	(MPa)
1/4	2490	(17.17)
3/ ₈	1990	(13.72)
1/2	1910	(13.17)
3/4	1540	(10.62)
1	1440	(9.93)
11/4	1180	(8.14)
11/2	1060	(7.31)
2	890	(6.14)
21/2	970	(6.69)
3	840	(5.79)
31/2	770	(5.31)
4	710	(4.90)
5	620	(4.27)
6	560	(3.86)

 $^{^{}A}$ This table was calculated for Schedule 40 pipe using the ISO formula and a stress level as follows:

psi (MPa)
Class 23447 (Type IV, Grade 1 (CPVC)) 6400 (44.1)

SUPPLEMENTARY REQUIREMENTS

GOVERNMENT/MILITARY PROCUREMENT

These requirements apply only to Federal/Military procurement, not domestic sales or transfers.

S1. Responsibility for Inspection—Unless otherwise specified in the contract or purchase order, the producer is responsible for the performance of all inspection and test requirements specified herein. The producer may use his own or any other suitable facilities for the performance of the inspection and test requirements specified herein, unless the purchaser disapproves. The purchaser shall have the right to perform any of the inspections and tests set forth in this specification where such inspections are deemed necessary to ensure that material conforms to prescribed requirements.

Note S1.1—In U.S. Federal contracts, the contractor is responsible for inspection.

S2. Packaging and Marking for U.S. Government Procurement:

- S2.1 *Packaging*—Unless otherwise specified in the contract, the materials shall be packaged in accordance with the supplier's standard practice in a manner ensuring arrival at destination in satisfactory condition and which will be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification rules or National Motor Freight Classification rules.
- S2.2 *Marking*—Marking for shipment shall be in accordance with Fed. Std. No. 123 for civil agencies and MIL-STD-129 for military agencies.

Note S2.1—The inclusion of U.S. Government procurement requirements should not be construed as an indication that the U.S. Government uses or endorses the products described in this document.

POTABLE WATER REQUIREMENT

This requirement applies whenever a Regulatory Authority or user calls for product to be used to convey or to be in contact with potable water.

S3. Products intended for contact with potable water shall be evaluated, tested, and certified for conformance with ANSI/ NSF Standard No. 61 or the health effects portion of NSF Standard No. 14 by an acceptable certifying organization when required by the regulatory authority having jurisdiction.

SUMMARY OF CHANGES

Committee F17 has identified the location of selected changes to this standard since the last issue (F438–15) that may impact the use of this standard.

- (1) Revised 8.5 to clarify use of Test Method D1599, Procedure B, and to be consistent with language used in other ASTM standards for Schedule 40 and Schedule 80 fittings.
- (2) Added Note 6.
- (3) Deleted 8.5.1.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9555 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/