



Standard Practice for Testing for Leaks in the Filters Associated With Laminar Flow Clean Rooms and Clean Work Stations by Use of a Condensation Nuclei Detector¹

This standard is issued under the fixed designation F91; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers the testing of the integrity of high-efficiency particulate air (HEPA) filters installed in laminar flow clean rooms of the ceiling to floor or wall to wall type, and laminar flow clean work stations. The recommended practice may be used to detect faults or voids in the filter media itself or in the joints between the filter and the room or work station structure. The determination of filter media efficiency is not within the scope of this practice.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.2.1 *Exception*—The values given in parentheses in inch-pound units are for information only.

1.3 *This standard does not purport to address all of the safety concerns associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Terminology

2.1 Definitions:

2.1.1 *condensation nuclei*—particles within the size range from 0.001 to 0.1- μm radius.

2.1.2 *HEPA filter*—high-efficiency particulate air filter.

2.1.3 *laminar flow*—airflow in which the air confined within the walls of a room or a smaller work station moves as an isovelocity front along parallel flow lines.

2.1.4 *leak*—a gap or void in the filter media, or in the associated gaskets, which permits unfiltered room air to penetrate the clean room or clean work station.

¹ This practice is under the jurisdiction of ASTM Committee E21 on Space Simulation and Applications of Space Technology and is the direct responsibility of Subcommittee E21.05 on Contamination.

Current edition approved Sept. 1, 2011. Published February 2012. Originally approved in 1968. Last previous edition approved in 2006 as F91 – 06. DOI: 10.1520/F0091-06(2011).

3. Summary of Practice

3.1 This recommended practice takes advantage of the fact that a HEPA filter retains a high percentage of the condensation nuclei found in ordinary room air. In this recommended practice a nuclei counting apparatus is arranged to sample small areas at the filter surface and the joints at the filter edges. The HEPA filter effluent normally shows a low nuclei count (<100 particles/cm³). When a leaking filter area is encountered, an increase of at least ten-fold in the particle count is noticed within the 2-s response time of the nuclei counter.

4. Apparatus

4.1 *Condensation Nuclei Counter*.^{2,3}

4.2 *Plastic Tubing*⁴, 9.5 mm ($\frac{3}{8}$ in.) in outside diameter; 6.5 mm ($\frac{1}{4}$ in.) in inside diameter; of suitable length, not to exceed 1.5 m (5 ft).

4.3 *Glass Laboratory Funnel*, 50 mm in outside diameter, 7 mm in stem diameter, 80 mm over-all length.

4.4 *Double-Pole Single-Throw Relay*, 115 V, 8 A.

5. Preparation for Test

5.1 Assemble the apparatus by slipping one end of the plastic hose over the funnel stem, and the other end over the nuclei counter input nipple.

5.2 Turn on the electrical supply to the nuclei counter and allow 30 min warm up time with the input tube sampling the effluent from a HEPA filter.

5.3 Measure the nuclei concentration at the intake to the HEPA filter. A concentration of less than 1000 particles/cm³ indicates a concentration insufficient for conveniently detecting leaks in the filter or its gaskets.

5.3.1 In the event that a nuclei concentration of less than 1000 particles/cm³ occurs when sampling a clean work station,

² Rich, T. A., "A Continuous Recorder for Condensation Nuclei," *Geofisica Pura e Applicata*, Milano, Vol. 50, 1961, III, pp. 46–52.

³ General Electric Co., Schenectady, NY, Model No. 112L482G1 has been found satisfactory.

⁴ Tygon tubing or equivalent has been found satisfactory for this purpose.

move the work station into a room having a less clean ambient such as a room not supplied with filtered air.

5.3.2 In the event that the intake nuclei concentration of less than 1000 particles/cm³ occurs in a laminar flow room of the ceiling to floor or wall to wall type, make the filter leak test at a time when the room is operating on a full work schedule with the maximum number of occupants.

5.3.3 Should the nuclei concentration level of the input air fail to reach 1000 nuclei/cm³ after executing steps 5.3.1 or 5.3.2, set up a nuclei generator using a DPST relay (see 4.4).

5.3.3.1 Wire one side of the relay so that in the at-rest condition current flows through the relay field coil, drawing the armature toward the field coil pole piece. This wiring arrangement should provide for the flow of current to be broken by this action of the armature, resulting in its springing back into its original position. The resulting cyclic or buzzer-like action of the relay will generate a large number of nuclei at the arcing contacts which can be used to increase the number of nuclei at the HEPA filter input. In the event that an insufficient number of nuclei are still counted at the filter input, increase the arc nuclei concentration by employing the unused set of contacts on the relay to make and break the secondary circuit of a variable transformer, adjusting to provide moderate visible arcing.

6. Procedure

6.1 Sample the nuclei concentration of the effluent of the HEPA filter at the downstream face of the filter.

6.1.1 Operate the nuclei counter on the most sensitive scale possible.

6.1.2 Use the plastic sampling tube with the funnel tip to scan the entire downstream surface of the filter and the gasketed joints at the filter edges. Scan by traversing the filter face in straight sweeps from left to right and then from right to left shifting the line of travel of the probe tip by the diameter of the funnel after each pass.

6.1.2.1 Maintain the rate of traverse of the sampling probe between 2 and 4 in./s.

6.1.2.2 Have an assistant to the person making the test observe, at all times while the test is in progress, the nuclei concentration meter and quickly report any increase in concentration. Classify an increase of ten times, or more, above the background nuclei count (that is, from 30 nuclei to 300 nuclei/cm³) as a leak.

6.2 Reported increases in the nuclei level shall require that the test operator backtrack in his traverse procedure and determine the location of the leak.

6.2.1 Remove the funnel from the plastic hose and sample with the hose itself in order to pin-point the location of the leak.

6.2.2 Mark the location of the leak on the filter protecting grill using a grease pencil, and retest the filter after suitable remedial action has been taken.

7. Keywords

7.1 filter testing; HEPA filter testing; HEPA filters; leak testing; particle filters

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/