

Hygrothermal performance of buildings — Calculation and presentation of climatic data —

Part 4: Hourly data for assessing the annual energy use for heating and cooling

The European Standard EN ISO 15927-4:2005 has the status of a
British Standard

ICS 91.120.10; 07.060

National foreword

This British Standard is the official English language version of EN ISO 15927-4:2005. It is identical with ISO 15927-4:2005.

The UK participation in its preparation was entrusted to Technical Committee B/540, Energy performance of materials, components and buildings, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, the EN ISO title page, the EN ISO foreword page, the ISO title page, pages ii to v, a blank page, pages 1 to 5 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 7 December 2005

© BSI 7 December 2005

ICS 91.120.10; 07.060

English Version

Hygrothermal performance of buildings - Calculation and presentation of climatic data - Part 4: Hourly data for assessing the annual energy use for heating and cooling (ISO 15927-4:2005)

Performance hygrothermique des bâtiments - Calcul et présentation des données climatiques - Partie 4: Données horaires pour l'évaluation du besoin énergétique annuel de chauffage et de refroidissement (ISO 15927-4:2005)

Wärme- und feuchtetechnisches Verhalten von Gebäuden - Berechnung und Darstellung von Klimadaten - Teil 4: Stündliche Daten zur Abschätzung des Jahresenergiebedarfs für Heiz- und Kühlsysteme (ISO 15927-4:2005)

This European Standard was approved by CEN on 27 June 2005.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

EN ISO 15927-4:2005

Foreword

This document (EN ISO 15927-4:2005) has been prepared by Technical Committee CEN/TC 89 "Thermal performance of buildings and building components", the secretariat of which is held by SIS, in collaboration with Technical Committee ISO/TC 163 "Thermal insulation".

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2006, and conflicting national standards shall be withdrawn at the latest by January 2006.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

INTERNATIONAL
STANDARD

ISO
15927-4

First edition
2005-07-15

**Hygrothermal performance of
buildings — Calculation and presentation
of climatic data —**

Part 4:

**Hourly data for assessing the annual
energy use for heating and cooling**

*Performance hygrothermique des bâtiments — Calcul et présentation
des données climatiques —*

*Partie 4: Données horaires pour l'évaluation du besoin énergétique
annuel de chauffage et de refroidissement*



Reference number
ISO 15927-4:2005(E)

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions and symbols	1
4 Sources of meteorological data	2
5 Construction of reference year	2
6 Presentation of the reference years	4
Bibliography	5

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 15927-4 was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 89, *Thermal performance of buildings and building components*, in collaboration with Technical Committee ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 2, *Calculation methods* in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

ISO 15927 consists of the following parts, under the general title *Hygrothermal performance of buildings — Calculation and presentation of climatic data*:

- *Part 1: Monthly means of single meteorological elements*
- *Part 4: Hourly data for assessing the annual energy for heating and cooling*
- *Part 5: Data for design heat load for space heating*
- *Part 6: Accumulated temperature differences (degree days)*

Future parts are planned on the following subjects:

- *Hourly data for design cooling load*
- *Calculation of a driving rain index for vertical surfaces from hourly wind and rain data*

Introduction

This standard covers the selection of appropriate meteorological data for the assessment of the long-term mean energy use for heating and cooling of buildings. Means of selecting data to assess the maximum heating demand are specified in ISO 15927-5.

Correct simulation of building performance depends not only on the appropriate mean values of the meteorological parameters, but also on the frequency distributions of individual parameters and the cross correlations between them. As these can be difficult to retain in the type of artificially constructed reference year discussed in this part of ISO 15927, the use of long periods (at least ten years but preferably more) of hourly meteorological data is preferred where possible. This also takes into account long spells of unusually warm or cold weather, lasting several months, which is eliminated in the construction of a reference year. In practice, however, long runs of hourly data containing all the necessary parameters are very expensive and can be difficult to obtain for many areas. There is, therefore, still a need for annual sets of data that can be used to represent the long-term mean performance of buildings. These can be generated once from long runs of expensive data and then distributed more cheaply.

This part of ISO 15927 specifies a method for the construction of a reference year from a longer meteorological record. Other methods are possible for constructing reference years for specific purposes, including those methods that are based on an analysis of general weather situations.

Hygrothermal performance of buildings — Calculation and presentation of climatic data —

Part 4: Hourly data for assessing the annual energy use for heating and cooling

1 Scope

This part of ISO 15927 specifies a method for constructing a reference year of hourly values of appropriate meteorological data suitable for assessing the average annual energy for heating and cooling. Other reference years representing average conditions can be constructed for special purposes. The procedures in this part of ISO 15927 are not suitable for constructing extreme or semi-extreme years for simulation of, for example, moisture damage or energy demand in cold years.

Meteorological instrumentation and methods of observation are not covered; these are specified by the World Meteorological Organization.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

World Meteorological Organization (WMO): *Guide to meteorological instruments and methods of observation*. No. 8, 6th Edition, 1996

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

cumulative distribution function

normalized rank order of the values of a parameter, when drawn up in increasing order, within a specified period

3.1.2

reference year

year of hourly values of appropriate meteorological parameters representative of the long term climate

3.2 Symbols

$F(p)$	cumulative distribution function of p within each individual month
F_S	Finkelstein-Schafer statistic
J	rank order of daily means within a calendar month in one year
K	rank order of daily means within that calendar month in the whole data set
N	number of days in any calendar month in the whole data set
m	month of the year
n	number of days in an individual month
p	climate parameter (temperature, solar radiation or humidity)
\bar{p}	daily mean of any climate parameter
y	year
$\Phi(p)$	cumulative distribution function of p within each calendar month in all the years in a sample

4 Sources of meteorological data

Data used for calculations in accordance with this standard shall have been measured by the methods specified in *WMO Guide No. 8, 1996*.

Because the data used in the selection procedure [see 5.3.1, items a) to g)] are processed in a way different from that normally used by the weather services, much care has to be exercised in the quality control of the raw data. Missing values shall be generated by linear interpolation or by estimate, and sudden, unnatural jumps or singular values shall be examined and corrected. If the raw data are available only as three-hourly data (sometimes referred to as synoptic data), then the missing values shall be calculated by linear interpolation.

5 Construction of reference year

5.1 Necessary parameters

The reference year shall contain hourly values of at least the following meteorological parameters, taken from a location or locations representative of the climate concerned:

- dry-bulb air temperature;
- direct normal solar irradiance and diffuse solar irradiance on a horizontal surface;
- relative humidity, absolute humidity, water vapour pressure or dewpoint temperature;
- wind speed at a height of 10 m above ground.

As temperature, radiation and humidity are the key parameters for cooling and heating calculations, these are used to construct the reference year.

NOTE Other parameters can be used to develop reference years for special applications.

5.2 Principle of construction

In principle, if a year existed within the long-term data in which each month was representative of the long-term conditions, this year could be used as a reference year. However, that is unlikely and in practice the most appropriate months are selected from a number of different years and joined together, with smoothing at the joins, to construct a complete year.

The procedure specified below is designed to construct a year of hourly values in which

- the mean value of individual variables,
- their frequency distribution, and
- correlations between the different variables within each month

are as close as possible to the corresponding calendar month of the long term data set.

The procedure therefore has two stages:

- a) selection of the best month, as defined in 5.3, from the multi-year record for each calendar month;
- b) adjustment of the hourly values in the selected month so as to provide a smooth transition when the different months are joined to form a year.

The procedures in a) and b) are such that the correlations between variables are retained.

5.3 Procedure

5.3.1 Selection of months to form the reference year

In the procedure described below, dry-bulb temperature, solar radiation and humidity are taken as the primary parameters for selecting the “best” months to form the reference year, with wind speed as a secondary parameter. Other combinations of primary and secondary parameters can be used to develop reference years for special purposes; the variables chosen as the basis of the reference year shall always be stated in the accompanying documentation.

For each climatic parameter, p , where p is dry-bulb temperature, solar radiation or humidity, carry out the following operations.

- a) From at least 10 years (but preferably more) of hourly values of p , calculate the daily means, \bar{p} .
- b) For each calendar month, calculate the cumulative distribution function of the daily means over all years in the data set, $\Phi(p, m, i)$, by sorting all the values in increasing order and then using Equation (1):

$$\Phi(p, m, i) = \frac{K(i)}{N + 1} \quad (1)$$

where $K(i)$ is the rank order of the i th value of the daily means within that calendar month in the whole data set.

- c) For each year of the data set, calculate the cumulative distribution function of the daily means within each calendar month, $F(p, y, m, i)$, by sorting all the values for that month and that year in increasing order and then using Equation (2):

$$F(p, y, m, i) = \frac{J(i)}{n + 1} \quad (2)$$

where $J(i)$ is the rank order of the i th value of the daily means within that month and that year.

- d) For each calendar month, calculate the Finkelstein-Schafer statistic, $F_S(p,y,m)$, for each year of the data set using Equation (3):

$$F_S(p,y,m) = \sum_{i=1}^n |F(p,y,m,i) - \Phi(p,m,i)| \quad (3)$$

- e) For each calendar month, rank the individual months from the multiyear record in order of increasing size of $F_S(p,y,m)$.
- f) For each calendar month and each year, add the separate ranks for the three climate parameters.
- g) For each calendar month, for the three months with the lowest total ranking, calculate the deviation of the monthly mean wind speed from the corresponding multi-year calendar-month mean. The month with the lowest deviation in wind speed is selected as the “best” month to be included in the reference year.

Further parameters can be investigated if necessary.

5.3.2 Adjustment of the hourly values

Adjust the parameters in the last eight hours of each month and the first eight hours of the next month by interpolation to ensure a smooth transition when the “best” months are joined to form the reference year. This adjustment shall include the last eight hours of December and the first eight hours of January so that the reference year can be used repeatedly in simulations.

6 Presentation of the reference years

The reference years shall be sequences of 8 760 hourly values of dry-bulb temperature, water vapour pressure (or other humidity parameter), solar irradiation and wind speed and any other available climate parameters.

The details (location and altitude) of the station, the climate parameters used, the period of the original data set and the years from which the individual months were taken shall be reported. If reference years are produced for several places in a country, the geographical area of validity or preference should be specified for each of them.

Bibliography

- [1] SKARTVEIT, A.; LUND, H. AND OLSETH, J. DNMI: *The Design Reference Year*. Klima report 11/94.
- [2] ISO 15927-5, *Hygrothermal performance of buildings — Calculation and presentation of climatic data — Part 5: Data for design heat load for space heating*

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.
Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.
Fax: +44 (0)20 8996 7001. Email: orders@bsi-global.com. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.
Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: info@bsi-global.com.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.
Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.
Email: membership@bsi-global.com.

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager.
Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553.
Email: copyright@bsi-global.com.