

Non-domestic gas-fired forced convection air heaters for space heating not exceeding a net heat input of 300 kW, without a fan to assist transportation of combustion air and/or combustion products

ICS 97.100.20

National foreword

This British Standard is the UK implementation of EN 621:2009. It supersedes BS EN 621:1998 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GSE/20, Non-domestic space heaters (gas).

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2010

© BSI 2010

ISBN 978 0 580 58602 6

Amendments/corrigenda issued since publication

Date	Comments

EUROPEAN STANDARD

EN 621

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2009

ICS 97.100.20

Supersedes EN 621:1998

English Version

Non-domestic gas-fired forced convection air heaters for space heating not exceeding a net heat input of 300 kW, without a fan to assist transportation of combustion air and/or combustion products

Générateurs d'air chaud à convection forcée utilisant les combustibles gazeux pour le chauffage de locaux autres que l'habitat individuel, de débit calorifique sur Hi inférieur ou égal à 300 kW, sans ventilateur pour aider l'alimentation en air comburant et/ou l'évacuation des produits de combustion

Gasbefeuerte Warmluft erzeuger mit erzwungener Konvektion zum Beheizen von Räumen für den nicht-häuslichen Gebrauch mit einer Nennwärmebelastung nicht über 300 kW, ohne Gebläse zur Beförderung der Verbrennungsluft und/oder der Abgase

This European Standard was approved by CEN on 10 October 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions.....	7
3.1 Appliance and its constituent parts	7
3.2 Adjustment, control and safety devices.....	9
3.3 Operation of the appliance	11
3.4 Gases	14
3.5 Conditions of operation and measurement	15
3.6 Marking of the appliance and packaging	16
4 Classification.....	16
4.1 Classification of gases.....	16
4.2 Classification of appliances according to the gases capable of being used	17
4.3 Classification of appliances according to the mode of evacuation of the combustion products.....	18
5 Construction and design requirements.....	19
5.1 General.....	19
5.2 Adjusting, control and safety devices	25
5.3 Ignition devices.....	28
5.4 Flame supervision system	29
5.5 Start-gas flame establishment.....	30
5.6 Main flame establishment	31
5.7 Main burner	32
5.8 Facility for remote control	32
5.9 Thermostats and control of air temperature	32
5.10 Combustion chamber pressure reliefs.....	33
5.11 Facilities for commissioning and testing	33
6 Operational requirements	34
6.1 Safety of operation	34
6.2 Efficiency	38
7 Test methods.....	39
7.1 General.....	39
7.2 Construction and design	46
7.3 Safety of operation	47
7.4 Efficiency	69
8 Marking and instructions	75
8.1 Marking of the appliance.....	75
8.2 Marking of the packaging	76
8.3 Utilization of symbols on the appliance and packaging.....	76
8.4 Instructions	78
9 Evaluation of POCED conformity and their associated terminals.....	80
9.1 General.....	80
9.2 Type testing.....	80
9.3 Factory production control (FPC)	81
Annex A (informative) National situations	83
A.1 General.....	83
A.2 Categories listed in the body of the standard and marketed in different countries	83

A.3	Appliance supply pressures corresponding to the categories given in A.2	85
A.4	Special categories marketed nationally or locally	86
A.5	Test gases corresponding to the special categories given in A.4	90
A.6	Gas connections in the various countries	91
A.7	Flue connections in the various countries	93
Annex B	(informative) Equivalence rules	94
B.1	Conversion to categories within a restricted Wobbe index range	94
B.2	Conversion to categories within an identical Wobbe index range	94
B.3	Conversion to categories within a wider Wobbe index range	95
Annex C	(informative) Facilities for commissioning and testing	96
C.1	Appliances with automatic ignition of a start-gas flame	96
C.2	Appliances with direct automatic ignition of the main burner	96
Annex D	(informative) Identification of gas types in use in various countries	97
Annex E	(informative) A-deviations	98
E.1	General	98
E.2	Switzerland	98
Annex F	(normative) Special national conditions	99
F.1	General	99
F.2	Belgium	99
F.3	Italy	99
Annex G	(informative) National solutions for countries whose national bodies are Affiliate Members of CEN	100
G.1	Categories listed in the body of the standard and marketed in different countries	100
G.2	Appliance supply pressures corresponding to the categories given in G.1	100
G.3	Special categories marketed nationally or locally	100
G.4	Gases and test pressures corresponding to the special categories given in G.3	100
Annex H	(informative) Calculation of conversions of NOx	101
Annex I	(informative) An example of a sampling plan	102
I.1	Sampling plans	102
I.2	Inspection levels and procedures	103
Annex ZA	(informative) Relationship between this European Standard and the Essential Requirements of EU Directive 90/396/EEC	104
Annex ZB	(informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Directive	106
ZB.1	Scope and relevant characteristics	106
ZB.2	Procedure(s) for attestation of conformity of [construction products]	108
ZB.3	CE marking and labelling	110
Bibliography	112

Foreword

This document (EN 621:2009) has been prepared by Technical Committee CEN/TC 180 “Domestic and non-domestic gas fired air heaters and non-domestic overhead radiant heaters”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2010, and conflicting national standards shall be withdrawn at the latest by May 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 621:1998.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annexes ZA and ZB, which are integral parts of this document.

This revision modifies EN 621:1998. It has been prepared to incorporate requirements for combustion products evacuation ducts, POCEDs, supplied as an integral part of the system to support the EU Directive 89/106/EEC on construction products under mandate M105. To this end it extends the scope of the standard to cover Type B₄₁ appliances.

Furthermore, the opportunity presented by this revision has been taken to update the standard in respect to EN 437:2003.

NOTE For countries requesting special categories (specified in EN 437:2003), the absence of specific information concerning A.4.3 and A.4.4 implies that the general requirements described in the body of the standard (see 5.1.1, 5.2.2, 5.2.3 and 5.2.5) also apply to these special categories.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies the requirements and test methods for the safety and efficiency of non-domestic gas-fired air heaters not exceeding a net heat input of 300 kW with (an) atmospheric burner(s) and without a fan to assist the transportation of combustion air and/or flue gases, hereafter referred to as "appliances".

This European Standard applies to Type B₁₁, B₄₁, C₁₁ and C₃₁ appliances intended for use in other than single unit residential dwellings. Provision of the heated air may be by means of ducting or may be directly into the heated space.

This standard does not apply to:

- a) appliances intended for use in a single unit residential dwelling;
- b) appliances of the condensing type;
- c) appliances for outdoor installation;
- d) dual purpose air conditioning appliances (heating and cooling);
- e) appliances where the air is heated by an intermediate fluid;
- f) appliances with forced draught burners;
- g) appliances fitted with a manual or automatic means of adjusting the combustion air supply or the combustion products evacuation (including flue dampers);
- h) portable or transportable forced convection appliances;
- i) appliances having multiple heating units with a single draught diverter;
- j) appliances fitted with more than one flue outlet;
- k) appliances that are designed for continuous condensation within the flue system under normal operating conditions;
- l) appliances having combustion products evacuation ducts, POCEDs, that are non-metallic.

This standard is applicable to appliances which are intended to be type tested. It also includes requirements concerning the evaluation of conformity, including factory production control, but these requirements only apply to POCEDs and their associated terminals.

NOTE Requirements for appliances which are not type tested would need to be subject to further consideration.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 88-1, *Pressure regulators and associated safety devices for gas appliances – Part 1: Pressure regulators for inlet pressures up to and including 500 mbar*

EN 125, *Flame supervision devices for gas burning appliances – Thermoelectric flame supervision devices*

- EN 126, *Multifunctional controls for gas burning appliances*
- EN 161:2007, *Automatic shut-off valves for gas burners and gas appliances*
- EN 257, *Mechanical thermostats for gas-burning appliances*
- EN 298:2003, *Automatic gas burner control systems for gas burners and gas burning appliances with or without fans*
- EN 437:2003, *Test gases – Test pressures – Appliance categories*
- EN 1859:2000, *Chimneys – Metal chimneys – Test methods*
- EN 10226-1, *Pipe threads where pressure tight joints are made on the threads – Part 1: Taper external threads and parallel internal threads – Dimensions, tolerances and designation*
- EN 10226-2, *Pipe threads where pressure tight joints are made on the threads – Part 2: Taper external threads and taper internal threads – Dimensions, tolerances and designation*
- EN 60335-1, *Household and similar electrical appliances – Safety – Part 1: General requirements (IEC 60335-1:2001, modified)*
- EN 60335-2-102, *Household and similar electrical appliances – Safety – Part 2-102: Particular requirements for gas, oil and solid-fuel burning appliances having electrical connections (IEC 60335-2-102:2004, modified)*
- EN 60529:1991, *Degrees of protection provided by enclosures (IP code) (IEC 60529:1989)*
- EN 60584-1, *Thermocouples – Part 1: Reference tables (IEC 60584-1:1995)*
- EN 60584-2:1993, *Thermocouples – Part 2: Tolerances (IEC 60584-2:1982 + A1:1989)*
- EN 60730-1, *Automatic electrical controls for household and similar use – Part 1: General requirements (IEC 60730-1:1999, modified)*
- EN 60730-2-9:2002, *Automatic electrical controls for household and similar use – Part 2-9: Particular requirements for temperature sensing controls (IEC 60730-2-9:2000, modified)*
- EN 61058-1, *Switches for appliances – Part 1: General requirements (IEC 61058-1:2000 + A1:2001, modified)*
- EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads – Part 1: Dimensions, tolerances and designation (ISO 228-1:2000)*
- ISO 1182, *Reaction to fire tests for building products – Non-combustibility test*
- ISO 7005-1, *Metallic flanges – Part 1: Steel flanges*
- ISO 7005-2, *Metallic flanges – Part 2: Cast iron flanges*
- ISO 7005-3, *Metallic flanges – Part 3: Copper alloy and composite flanges*
- CR 1404, *Determination of emissions from appliances burning gaseous fuels during type-testing*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 Appliance and its constituent parts

3.1.1

non-domestic air heater

appliance designed for the heating and possibly ventilation of a building other than a single unit residential dwelling

3.1.2

forced convection air heater

appliance designed to provide space heating from a central source by distributing heated air, by means of an air moving device, either through ducting or directly into the heated space

3.1.3

gas inlet connection

the part of the appliance intended to be connected to the gas supply

3.1.4

mechanical joint

mechanical means of obtaining soundness

means of ensuring the soundness of an assembly of several (generally metallic) parts without the use of liquids (e.g. pastes and tapes)

EXAMPLE Metal to metal joints; conical joints; toroidal sealing rings ("O" rings); flat joints.

3.1.5

gas circuit

part of the appliance that conveys or contains the gas between the appliance gas inlet connection and the burner(s)

3.1.6

restrictor

device with an orifice, which is placed in the gas circuit so as to create a pressure drop and thus reduce the gas pressure at the burner to a predetermined value for a given supply pressure and rate

3.1.7

gas rate adjuster

component allowing an authorised person to set the gas rate of the burner to a predetermined value according to the supply conditions

NOTE 1 Adjustment can be progressive (screw adjuster) or in discrete steps (by changing restrictors).

NOTE 2 The adjusting screw of an adjustable regulator is regarded as a gas rate adjuster.

NOTE 3 The action of adjusting this device is called "adjusting the gas rate".

NOTE 4 A factory sealed gas rate adjuster is considered to be non-existent.

3.1.8

setting an adjuster

immobilization of an adjuster (by some means such as e.g. a screw) after the manufacturer or installer has adjusted it

3.1.9 sealing an adjuster

setting of an adjuster using a material such that any attempt to change the adjustment breaks the sealing material and makes the interference with the adjuster apparent

NOTE 1 The adjuster is then said to be "sealed" in its adjustment position.

NOTE 2 A factory sealed adjuster is considered to be non-existent.

NOTE 3 A regulator is considered to be non-existent if it has been factory sealed in a position such that it is not operational in the range of supply pressures corresponding to the appliance category.

3.1.10 putting an adjuster or a control out of service

putting an adjuster or a control (of temperature, pressure, etc.) out of action and sealing it in this position

NOTE The appliance then functions as if the adjuster or control had been removed.

3.1.11 injector

component that admits the gas into a burner

3.1.12 main burner

burner that is intended to assure the thermal function of the appliance

3.1.13 ignition device

means (e.g. flame, electrical ignition device or other device) used to ignite the gas at the ignition burner or at the main burner

NOTE This device can operate intermittently or permanently.

3.1.14 ignition burner

burner whose flame is intended to ignite another burner

3.1.15 aeration adjuster

device enabling the air to be set at the desired value according to the supply conditions

NOTE The action of adjusting this device is called "adjusting the aeration".

3.1.16 combustion products circuit

3.1.16.1 combustion chamber

enclosure inside which combustion of the air-gas mixture takes place

3.1.16.2 flue outlet

the part of a Type B appliance that connects with a flue to evacuate the products of combustion

3.1.16.3 draught diverter

device placed in the combustion products circuit to reduce the influence of flue-pull and that of down-draught on the burner performance and combustion

3.1.16.4

POCED

combustion products evacuation duct that is intended to be used only with a specific appliance/system, this duct being either supplied with the appliance/system or specified in the manufacturers instructions

3.2 Adjustment, control and safety devices

3.2.1

range rating device

component on the appliance intended to be used by the installer to adjust the heat input of the appliance, within a range of heat inputs stated by the manufacturer, to suit the actual heat requirements of the installation

NOTE This adjustment may be progressive (e.g. by use of a screw adjuster) or in discrete steps (e.g. by changing restrictors).

3.2.2

automatic burner control system

system comprising at least a programming unit and all the elements of a flame detector device

NOTE The various functions of an automatic burner control system may be in one or more housings. [EN 298:2003]

3.2.3

programming unit

device which reacts to signals from control and safety devices, gives control commands, controls the start-up sequence, supervises the burner operation and causes controlled shut-down, and if necessary safety shut-down and lock-out

NOTE The programming unit follows a predetermined sequence of actions and always operates in conjunction with a flame detector device. [EN 298:2003]

3.2.4

programme

sequence of control operations determined by the programming unit involving switching on, starting up, supervising and switching off the burner

NOTE Safety actions such as safety shut down and lock out are also part of the programme. [EN 298:2003]

3.2.5

flame detector device

device by which the presence of a flame is detected and signalled

NOTE A flame detector device can consist of a flame sensor, an amplifier and a relay for signal transmission. These parts, with the possible exception of the actual flame sensor, may be assembled in a single housing for use in conjunction with a programming unit. [EN 298:2003]

3.2.6

flame signal

signal given by the flame detector device, normally when the flame sensor senses a flame

[EN 298:2003]

3.2.7

flame simulation

condition which occurs when the flame signal indicates the presence of a flame when in reality no flame is present

[EN 298:2003]

3.2.8

pressure regulator¹⁾

device which maintains the outlet pressure constant independent of the variations in inlet pressure and/or flow rate within defined limits

3.2.9

adjustable pressure regulator

regulator provided with means for changing the outlet pressure setting

3.2.10

flame supervision device

device that, in response to a signal from the flame detector, keeps the gas supply open and shuts it off in the absence of the supervised flame

3.2.11

automatic shut-off valve

valve designed to open when energized and to close automatically when de-energized

3.2.12

control thermostat

device controlling the operation of the appliance (by on/off, high/low or modulating control) and enabling the temperature to be kept automatically, within a given tolerance, at a predetermined value

3.2.13

overheat cut-off device

device that shuts off and locks out the gas supply before the appliance is damaged and/or before safety is compromised and which requires manual intervention to restore the gas supply

NOTE This device is preset and sealed by the appliance manufacturer (see 5.9.4).

3.2.14

overheat control device

automatic reset device that shuts down the gas supply to the burner when the temperature of the delivered air exceeds a certain preset value during abnormal operating conditions

3.2.15

fan delay control

control that starts and/or stops the air delivery fan when the temperature of the delivered air reaches a certain predetermined value

3.2.16

temperature sensing element; temperature sensor

component that detects the temperature of the environment to be supervised or controlled

3.2.17

modulating control

automatic control by which the heat input of the appliance can be varied in a continuous manner between the nominal heat input and a minimum value

3.2.18

high/low control

automatic control which permits an appliance to operate either at the nominal heat input or at a fixed reduced heat input

1) The term "regulator" is used in this case and for a volume regulator.

3.2.19

closed position indicator switch

switch fitted to an automatic shut-off valve which indicates when the closure member is in the closed position

3.2.20

proof of closure switch

switch fitted to an automatic shut-off valve with mechanical overtravel which indicates when the closure member is in the closed position

3.2.21

valve proving system

system to check the effective closure of the start gas or main gas safety shut-off valves, and which is capable of detecting small gas leakage rates (e.g. by means of a pressure or vacuum proving system)

3.3 Operation of the appliance

3.3.1

volume flow rate

V

volume of gas consumed by the appliance in unit time during continuous operation

NOTE The volume flow rate is expressed in cubic metres per hour (m^3/h), litres per minute (l/min), cubic decimetres per hour (dm^3/h) or cubic decimetres per second (dm^3/s). [EN 437:2003].

3.3.2

mass flow rate

M

mass of gas consumed by the appliance in unit time during continuous operation

NOTE The mass flow rate is expressed in kilograms per hour (kg/h) or grams per hour (g/h). [EN 437:2003]

3.3.3

heat input

Q

quantity of energy used in unit time corresponding to the volumetric or mass flow rates: the calorific value used being the net or gross calorific value

NOTE The heat input is expressed in kilowatts (kW). [EN 437:2003].

3.3.4

nominal heat input

Q_n

value of the heat input, in kW, declared by the manufacturer

3.3.5

flame stability

characteristic of flames which remain on the burner ports or in the flame reception zone intended by the construction

3.3.6

flame lift

total or partial lifting of the base of the flame away from the burner port or the flame reception zone provided by the design

NOTE Flame lift may cause the flame to blow out (i.e. extinction of the air-gas mixture).

3.3.7

light-back

entry of a flame into the body of the burner

3.3.8

light-back at the injector

ignition of the gas at the injector, either as a result of light-back into the burner or by the propagation of a flame outside the burner

3.3.9

sooting

phenomenon appearing during incomplete combustion and characterized by deposits of soot on the surfaces or parts in contact with the combustion products or with the flame

3.3.10

yellow tipping

yellowing of the tip of the blue cone of an aerated flame

3.3.11

first safety time

interval between the ignition burner gas valve, the start gas valve or main gas valve, as applicable, being energized and the ignition burner gas valve, start gas valve or main gas valve, as applicable, being de-energized if the flame detector signals the absence of a flame at the end of this interval

NOTE Where there is no second safety time, this is called the safety time.

3.3.12

second safety time

where there is a first safety time to either a ignition burner or start gas flame only, the interval between the main gas valve being energized and the main gas valve being de-energized if the flame detector signals the absence of a flame

3.3.13

start gas

gas that is supplied at the start gas rate to establish the start gas flame

3.3.14

start gas rate

the restricted gas flow rate admitted either to a separate ignition burner or to the main burner during the first safety time

3.3.15

start gas flame

flame established at the start gas rate either at the main burner or at a separate ignition burner

3.3.16

running condition of the system

condition of the system in which the burner is in normal operation under the supervision of the programming unit and its flame detector device

3.3.17

automatic burner system

burner system in which, when starting from the completely shut-down condition, the gas is ignited and the flame is detected and proved without manual intervention

3.3.18

non-automatic burner system

burner system with an ignition burner which is ignited under manual supervision

3.3.19

controlled shut-down

process by which the power to the gas shut-off valve(s) is removed immediately, e.g. as a result of the action of a controlling function

[EN 298:2003]

3.3.20

safety shut-down

process which is effected immediately following the response of a protection device or a fault in the automatic burner control system and puts the burner out of operation

NOTE The resulting state of the system is defined by deactivated terminals for the gas shut-off valves and the ignition device. [EN 298:2003]

3.3.21 Lock-out

3.3.21.1

non-volatile lock-out

safety shut-down condition of the system, such that a restart can only be accomplished by a manual reset of the system and by no other means

[EN 298:2003]

3.3.21.2

volatile lock-out

safety shut-down condition of the system, such that a restart can only be accomplished by either the manual reset of the system or an interruption of the electrical supply and its subsequent restoration

[EN 298:2003]

3.3.22

spark restoration

process by which, after disappearance of the flame signal, the ignition device is energized again without the gas supply having been totally interrupted

NOTE This process ends with the restoration of the running condition or, if there is no flame signal at the end of the safety time, with non-volatile lock-out.

3.3.23

automatic recycling

process by which, after loss of flame during the running condition or accidental interruption of the operation of the appliance, the gas supply is interrupted and the complete start sequence is automatically re-initiated

NOTE This process ends with the restoration of the running condition or, if there is no flame signal at the end of the safety time or, if the cause of the accidental interruption has not been removed, with non-volatile lock-out.

3.3.24

ignition opening time

time interval between ignition of the supervised flame and the moment when the valve is held open

3.3.25

extinction safety time

time interval between extinction of the supervised flame and the gas supply being shut off:

- a) to the main burner; and/or
- b) to the ignition burner.

3.3.26

ignition interlock

part which prevents the operation of the igniter as long as the main gasway is open

3.3.27

re-start interlock

mechanism which prevents the re-opening of the gasway to the main burner or the main burner and the ignition burner until the armature plate has separated from the magnetic element

3.4 Gases

3.4.1

test gases

gases intended for the verification of the operational characteristics of appliances using combustible gases

[EN 437:2003]

NOTE Test gases comprise the reference and the limit gases. [EN 437:2003]

3.4.2

reference gases

test gases with which appliances operate under nominal conditions when they are supplied at the corresponding normal pressure

[EN 437:2003]

3.4.3

limit gases

test gases representative of the extreme variations in the characteristics of the gases for which appliances have been designed

[EN 437:2003]

3.4.4

gas pressure

static pressure, relative to the atmospheric pressure, measured at right angles to the direction of flow of the gas

NOTE Test pressures are expressed in millibars (mbar) or bars (bar).

3.4.5

test pressure

gas pressures used to verify the operational characteristics of appliances using combustible gases

NOTE 1 Test pressures consist of normal and limit pressures.

NOTE 2 Test pressures are expressed in millibars (mbar); 1 mbar = 10² Pa. [EN 437:2003]

3.4.6

normal pressure

p_n
pressure under which the appliances operate in nominal conditions when they are supplied with the corresponding reference gas

[EN 437:2003]

3.4.7

limit pressure

pressures representative of the extreme variations in the appliance supply conditions

[EN 437:2003]

NOTE Limit pressures consist of maximum limit pressure p_{\max} and minimum limit pressure p_{\min} .

3.4.8

pressure couple

combination of two distinct gas distribution pressures applied by reason of the significant difference existing between the Wobbe indices within a single family or group in which:

- the higher pressure corresponds only to gases of low Wobbe index;
- the lower pressure corresponds to gases of high Wobbe index

[EN 437:2003]

3.4.9

relative density

d

ratio of the masses of equal volumes of dry gas and dry air under the same conditions of temperature and pressure

3.4.10

calorific value

quantity of heat produced by the complete combustion, at a constant pressure equal to 1 013,25 mbar, of a unit volume or mass of gas, the constituents of the combustible mixture being taken at reference conditions and the products of combustion being brought back to the same conditions

NOTE 1 A distinction is made between:

- a) the gross calorific value H_s in which the water produced by combustion is assumed to be condensed;
- b) the net calorific value H_i in which the water produced by combustion is assumed to be in the vapour state.

NOTE 2 The calorific value is expressed either in megajoules per cubic metre of dry gas at the reference conditions (MJ/m^3) or in megajoules per kilogram of dry gas (MJ/kg). [EN 437:2003]

3.4.11

Wobbe index

gross Wobbe index: W_s ; net Wobbe index: W_i

ratio of the calorific value of a gas per unit volume and the square root of its relative density under the same reference conditions

NOTE 1 The Wobbe index is said to be gross or net according to whether the calorific value used is the gross or net calorific value.

NOTE 2 The Wobbe index is expressed either in megajoules per cubic metre of dry gas at the reference conditions (MJ/m^3) or in megajoules per kilogram of dry gas (MJ/kg). [EN 437:2003]

3.5 Conditions of operation and measurement

3.5.1

reference conditions

- for calorific values, temperature: 15 °C;
- for gas and air volumes dry, brought to 15 °C and to an absolute pressure of 1 013,25 mbar.

3.5.2

cold condition

condition of the appliance required for some tests and obtained by allowing the unlit appliance to attain thermal equilibrium at room temperature

3.5.3

hot condition

condition of the appliance required for some tests and obtained by heating to thermal equilibrium at the nominal heat input specified by the manufacturer, any thermostat remaining fully open

3.5.4

equivalent resistance

resistance to flow (in mbar) measured at the outlet of the appliance, which is equivalent to that of the actual flue

3.6 Marking of the appliance and packaging

3.6.1

direct country of destination

country for which the appliance has been certified and which is specified by the manufacturer as the intended country of destination

NOTE 1 At the time of putting the appliance on the market and/or of installation, the appliance shall be capable of operating, without adjustment or modification, with one of the gases distributed in the country concerned, at the appropriate supply pressure.

NOTE 2 More than one country can be specified if the appliance, in its current state of adjustment, can be used in each of these countries.

3.6.2

indirect country of destination

country for which the appliance has been certified, but for which, in its present state of adjustment, it is not suitable

NOTE Subsequent modification or adjustment is essential in order that the appliance can be utilized safely and correctly in this country.

4 Classification

4.1 Classification of gases

Gases are classified into three families, possibly divided into groups according to the value of the Wobbe index. Table 1 specifies the families and groups of gas used in this standard.

Table 1 — Gas classification

Gas families and groups	Gross Wobbe index at 15 °C and 1 013,25 mbar MJ/m ³	
	Minimum	Maximum
First family * Group a	22,4	24,8
Second family * Group H * Group L * Group E	39,1 45,7 39,1 40,9	54,7 54,7 44,8 54,7
Third family * Group B/P * Group P * Group B	72,9 72,9 72,9 81,8	87,3 87,3 76,8 87,3

4.2 Classification of appliances according to the gases capable of being used

4.2.1 Category I

4.2.1.1 General

Appliances of Category I are designed exclusively for the use of gases of a single family or of a single group.

4.2.1.2 Appliances designed for use on first family gases only

Category I_{1a}: Appliances using only gases of Group a of the first family at the prescribed supply pressure (this category is not used).

4.2.1.3 Appliances designed for use on second family gases only

Category I_{2H}: Appliances using only gases of Group H of the second family at the prescribed supply pressures.

Category I_{2L}: Appliances using only gases of Group L of the second family at the prescribed supply pressures.

Category I_{2E}: Appliances using only gases of Group E of the second family at the prescribed supply pressures.

Category I_{2E+}: Appliances using only gases of Group E of the second family, and operating with a pressure couple without adjustment on the appliance. The appliance gas regulator, if it exists, is not operative in the range of the two normal pressures of the pressure couple.

4.2.1.4 Appliances designed for use on third family gases only

Category I_{3B/P}: Appliances capable of using the third family gases (propane and butane) at the prescribed supply pressure.

Category I₃₊: Appliances capable of using the third family (propane and butane) and operating with a pressure couple without adjustment of the appliance other than a possible adjustment of the primary air in order to change from butane to propane and vice versa. No operational pressure regulating device is permitted on the appliance.

Category I_{3P}: Appliances using only gases of Group P of the third family (propane) at the prescribed supply pressure.

4.2.2 Category II

4.2.2.1 General

Appliances of Category II are designed for use on gases of two families.

4.2.2.2 Appliances designed for use on gases of the first and second families

Category II_{1a2H}: Appliances capable of using gases of Group a of the first family and gases of Group H of the second family. The first family gases are used under the same conditions as for Category I_{1a}. The second family gases are used under the same conditions as for Category I_{2H}.

4.2.2.3 Appliances designed for use on gases of the second and third families

Category II_{2H3B/P}: Appliances capable of using gases of Group H of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2H}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category II_{2H3+}: Appliances capable of using gases of Group H of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2H}. The third family gases are used under the same conditions as for Category I₃₊.

Category II_{2H3P}: Appliances capable of using gases of Group H of the second family and gases of Group P of the third family. The second family gases are used under the same conditions as for Category I_{2H}. The third family gases are used under the same conditions as for Category I_{3P}.

Category II_{2L3B/P}: Appliances capable of using gases of Group L of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2L}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category II_{2L3P}: Appliances capable of using gases of Group L of the second family and gases of Group P of the third family. The second family gases are used under the same conditions as for Category I_{2L}. The third family gases are used under the same conditions as for Category I_{3P}.

Category II_{2E3B/P}: Appliances capable of using gases of Group E of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2E}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category II_{2E3+}: Appliances capable of using gases of Group E of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2E+}. The third family gases are used under the same conditions as for Category I₃₊.

Category II_{2E+3P}: Appliances capable of using gases of Group E of the second family and gases of Group P of the third family. The second family gases are used under the same conditions as for Category I_{2E+}. The third family gases are used under the same conditions as for Category I_{3P}.

4.2.2.4 Category III

Category III appliances are designed for use on the three families.

This category is not in general use.

Category III appliances admitted in certain countries are given in A.3.

4.3 Classification of appliances according to the mode of evacuation of the combustion products

4.3.1 General

Appliances are classified into several types according to the method of evacuation of the combustion products and admission of the combustion air.

4.3.2 Type B

An appliance intended to be connected to a flue which evacuates the products of combustion to the outside of the room containing the appliance.

The combustion air is drawn directly from the room.

Type B₁: A Type B appliance incorporating a draught diverter.

Type B₁₁: A natural draught Type B₁ appliance.

Type B₄: A Type B appliance, incorporating a draught diverter that is designed for connection via its flue duct to its flue terminal.

Type B₄₁: A natural draught Type B₄ appliance.

4.3.3 Type C

An appliance in which the combustion circuit (air supply, combustion chamber, heat exchanger, evacuation of the combustion products) is sealed with respect to the room in which the appliance is installed.

Type C₁: A type C appliance that is designed for connection via its ducts to a horizontal terminal, which at the same time admits fresh air to the burner and discharges the products of combustion to the outside through orifices that are either concentric or close enough to come under similar wind conditions.

Type C₁₁: A natural draught Type C₁ appliance.

Type C₃: A Type C appliance which is designed for connection via its ducts to a vertical terminal which at the same time admits fresh air to the burner and discharges the products of combustion to the outside through orifices which are either concentric or close enough to come under similar wind conditions.

Type C₃₁: A natural draught Type C₃ appliance.

5 Construction and design requirements

5.1 General

5.1.1 Conversion to different gases

5.1.1.1 General

The only acceptable operations when converting from a gas of one group or family to a gas of another group or family and/or to adapt to different gas distribution pressures are given for each category.

NOTE It is recommended that these operations should be possible without disconnecting the appliance.

5.1.1.2 Category I

Category I_{2H}, I_{2L}, I_{2E}, I_{2E+}: no modification to the appliance.

Category I_{3B/P}: no modification to the appliance.

Category I₃₊: replacement of injectors or calibrated orifices but only in order to convert from one pressure couple to another (for example 28-30/37 mbar to 50/67 mbar or vice versa). In addition, it is permissible to adjust the primary air in order to change from butane to propane and vice versa.

Category I_{3P}: no modification to appliance relative to a change of gas. For a change of pressure, replacement of injectors and adjustment of gas rates.

5.1.1.3 Category II

5.1.1.3.1 Categories of appliance designed for use with gases of the first and second families

- a) adjustment of the gas rate with, if necessary, a change of injector, restrictors or regulator;
- b) adjustment of the gas rate of ignition burners, either by using an adjuster or by a change of injectors or restrictors and, if necessary, a change of complete ignition burners or of some of their parts;
- c) putting the regulator out of service under the conditions of 5.2.5;

- d) putting the gas rate adjusters out of service under the conditions of 5.2.2.2.

The adjustments or component changes are only acceptable when converting from a gas of the first family to a gas of the second family or vice versa.

5.1.1.3.2 Categories of appliance designed for use with gases of the second and third families

- a) adjustment of the gas rate with, if necessary, a change of injector, restrictors or regulator;
- b) adjustment of the gas rate of ignition burners, either by using an adjuster or by a change of injectors or restrictors and, if necessary, a change of complete ignition burners or of some of their parts;
- c) putting the regulator out of service under the conditions of 5.2.5;
- d) putting the gas rate adjusters out of service under the conditions of 5.2.2.2.

These adjustments or component changes are only acceptable when:

- e) converting from a gas of the second family to a gas of the third family or vice versa;
- f) converting from one butane/propane pressure couple to another (e.g. 28-30/37 mbar to 50/67 mbar or vice versa).

5.1.1.4 Category III

Category III appliances admitted in certain countries are given in A.4.3 and A.4.4.

5.1.2 Materials and method of construction

When the appliance is installed in accordance with the manufacturer's instructions, all components, including the heat exchanger and its POCED in the case of type B₄ appliances, shall withstand the mechanical, chemical and thermal conditions to which they may be subjected in the course of normal use.

In addition, the appliance shall be designed in such a way that there is no condensation at the operating temperature provided by the controls.

If condensation occurs at start-up, this shall not affect the operational safety. With the exception of the outlet of the flue system, any condensate formed shall not drop outside the appliance.

Copper shall not be used for gas carrying parts where its temperature is likely to exceed 100 °C.

Asbestos or materials containing asbestos shall not be used.

Solder that has a melting point below 450 °C after application shall not be used for gas carrying parts.

Where appropriate, materials used on the appliance shall be non-combustible in accordance with the requirements of ISO 1182.

5.1.3 Accessibility for maintenance and use

Parts that are intended to be removable for maintenance or cleaning shall be readily accessible, shall be readily capable of correct assembly and difficult to assemble incorrectly. Such parts shall be impossible to assemble incorrectly where incorrect assembly would create a hazardous condition or result in damage to the appliance and its controls.

It shall be possible to clean the combustion chamber and the parts in contact with combustion products in accordance with the manufacturer's instructions without using special tools unless these are supplied as necessary accessories with the appliance.

Access shall be possible to all handles, buttons, etc. required during normal use of the appliance, without having to remove any part of the case. For this purpose, the opening of a door or access panel is permitted.

Constructional parts accessible during use and maintenance shall be free from sharp edges and corners that might cause damage or personal injury during use or maintenance.

Panels that are required to be removed for normal servicing, maintenance and cleaning, shall be fitted with means of retention, where the appliance is intended to be installed more than 1,8 m above floor level, measured from the underside of the appliance. This requirement shall be deemed to be satisfied if suitable hinges are fitted.

The products of combustion shall not be drawn into the air distribution system when user access panels are removed.

5.1.4 Thermal insulation

Any thermal insulation shall retain its insulating properties under the influences of heat and ageing. The insulation shall withstand the normally expected thermal and mechanical stresses. The insulation shall be non-combustible, securely located and shall be protected against mechanical damage, condensate and vermin.

5.1.5 Gas connection

The appliance gas connection shall be accessible.

The clearance around the connection, after removing the case if necessary, shall be adequate to allow the use of tools required to make the connection. It shall be possible to make all the connections without special tools.

It shall be possible to connect the appliance by rigid metallic means to the gas supply.

If the appliance has a threaded connection, this thread shall comply with EN ISO 228-1, EN 10226-1 or EN 10226-2. In the first case (EN ISO 228-1), the end of the appliance inlet connection shall be sufficiently flat to allow the use of a sealing washer.

If flanges are used, they shall comply with ISO 7005-1, ISO 7005-2 or ISO 7005-3, as appropriate, and the manufacturer shall provide the counterflanges and sealing gaskets.

The conditions of connections prevailing in the various countries are given in A.6.

5.1.6 Soundness

5.1.6.1 Soundness of the gas circuit

Holes for screws, studs, etc., intended for the assembly of parts shall not open into gasways. The wall thickness between drillings and gasways shall be at least 1 mm. This does not apply to orifices for measurement purposes.

The soundness of parts and assemblies making up the gas circuit and likely to be dismantled for routine maintenance in situ shall be achieved by means of mechanical joints, e.g. metal-to-metal joints, gasket, or O-ring joints, i.e. excluding the use of all sealing materials such as tape, paste or liquid. However, the sealing materials mentioned above may be used for permanent assemblies. These sealing materials shall remain effective under normal conditions of appliance use.

5.1.6.2 Soundness of the combustion circuit

Any means to achieve soundness of the combustion circuit shall be such that it does not deteriorate under normal conditions of use and maintenance.

In particular, the soundness of parts likely to be removed in the course of routine maintenance shall be achieved by mechanical means.

5.1.7 Supply of combustion air and evacuation of combustion products

5.1.7.1 General

Openings for the access of primary air shall have dimensions greater than 4 mm.

5.1.7.2 Appliance combustion air inlet

The cross-section of the combustion air passageways to the appliance shall not be adjustable.

During the shut-down condition, the appliance shall have sufficient natural ventilation to ventilate safely any minor gas leakage.

5.1.7.3 Appliance flue gas outlet

The cross-section of the appliance flue gas outlet shall not be adjustable.

If the appliance has a POCEd that is capable of being installed in accordance with the manufacturer's instructions such that its outlet, when fitted with any terminal supplied with the appliance, or specified in the manufacturer's instructions, extends beyond the external surface of a building by more than 1,5 m, this duct, together with any associated air supply duct (Type C₁ and C₃ appliances), shall not undergo any permanent distortion when subjected to the wind load test specified in 4.3.2 of EN 1859:2000.

5.1.7.4 Type B₁₁ appliances

All appliances shall be designed so that there is an adequate supply of combustion air during ignition and over the whole range of possible heat inputs stated by the manufacturer.

Connection to the flue shall be made by means of a flue outlet preceded by a draught diverter. This device is part of the appliance.

The flue outlet shall be female and shall allow, if necessary by means of an adaptor supplied with the appliance, connection to a flue pipe whose diameter complies with the standards in force where the appliance is to be installed (see A.6).

The internal diameter of the flue outlet shall be such as to ensure compliance with requirements concerning operation.

It shall be possible to insert a flue pipe of nominal external diameter ($D - 2$) mm to a depth of at least $D/4$ but not so far that the evacuation of the combustion products is impaired. However, for a vertical connection, the depth of insertion can be reduced to 15 mm for an appliance with heat input up to 70 kW and 25 mm for an appliance with heat input exceeding 70 kW.

5.1.7.5 Type B₄₁ appliances

The draught diverter shall either be integral with the appliance or be supplied with the appliance by the manufacturer.

The POCED shall either be supplied with the appliance by the manufacturer or specified in the manufacturer's instructions. The specification shall include a description of the duct including any bends, its materials of construction and any critical tolerances (e.g. in length, diameter, thickness, insertion depth).

5.1.7.6 Type C₁₁ and C₃₁ appliances

5.1.7.6.1 Flue terminal and ducts

The terminal and any necessary combustion air and combustion products ducts shall be supplied by the appliance manufacturer.

The terminal shall be designed to prevent the penetration of rain or snow to the appliance or to the fabric of the building. Any opening in the terminal shall not permit the entry of a ball of 16 mm diameter when applied with a force of 5 N. If the terminal performance is dependent on a chamber within the wall, a chamber lining shall be provided with the appliance.

Any condensate formed when operating the appliance from cold shall either be retained and subsequently re-evaporated or discharged clear of the wall.

If a Type C₁₁ or C₃₁ appliance is fitted with separate air inlet and combustion products ducts, the outlet of these ducts shall be so positioned that the distance between the axes of the ducts is no more than $3D$ (where D is the mean outer diameter of the inlet and outlet ducts).

5.1.7.6.2 Terminal guard

A terminal guard shall be provided in accordance with the National Regulations applicable in the various Member States.

5.1.8 Supply and distribution of air for space heating

5.1.8.1 Air inlets

Where the air inlet is intended to be ducted to the heater, the appliance shall be provided with flanged or spigot connections on the air inlet.

NOTE If necessary, the manufacturer may supply a suitable adaptor in order to meet this requirement.

5.1.8.2 Air outlets

If a ductless heater is fitted with directional louvres, the appliance shall continue to operate satisfactorily i.e. the overheat cut-off device shall not operate when the louvres are in the position of maximum closure as marked and specified by the manufacturer.

Ducted air heaters shall have air outlets equipped with flanges or spigots to facilitate connection of ductwork or flexible connectors.

NOTE If necessary, the manufacturer may supply a suitable adaptor in order to meet this requirement.

5.1.9 Position of the combustion chamber and heat exchanger

The combustion chamber and heat exchanger shall be positioned on the pressure side of the air delivery fan.

5.1.10 Checking the state of operation

The installer shall be able to observe visually the ignition and correct operation of the burner(s) and also the length of the flame(s) of the ignition burner, if any. A door may be opened or a case removed provided that the operation of the burner is not disturbed.

If the means of observation is a viewing port, it shall, when located in an area of high temperature, be covered with a suitable material, for example, heat resistant, toughened glass and, if necessary, sealed with a suitable heat resistant sealant.

When the main burner is fitted with its own flame detector, an indirect means of observation (e.g. an indicator light) may be used. This indirect means shall be used only for indicating presence of a flame following a successful ignition or absence of a flame due to failure to ignite or the failure of the flame detector to detect a flame.

It shall be possible for the user, perhaps after opening a door or removing an access panel, to check at any time that the appliance is operating, either by visual observation of the flame or by some other indirect means, provided that the evacuation of the combustion products (in Type B₁₁ appliances) is not disturbed and that the soundness of the combustion circuit (in Type C₁₁ and C₃₁ appliances) is not altered.

5.1.11 Electrical equipment

The electrical equipment of the appliance shall comply with the relevant requirements of EN 60335-2-102, EN 60730-1 and EN 61058-1.

If the appliance is fitted with electronic components or electronic systems providing a safety function, these shall comply with the relevant requirements of EN 298 with regard to electromagnetic compatibility immunity levels.

If the manufacturer specifies the nature of the electrical protection of the appliance on the data plate, this specification shall comply with EN 60529:

- a) to give the degree of personal protection against contact with dangerous electrical components inside the appliance case;
- b) to give the degree of electrical protection, inside the appliance case, against harmful actions due to water penetration.

5.1.12 Operational safety in the event of fluctuation, interruption and restoration of the auxiliary energy

Interruption and subsequent restoration of the mains voltage electrical supply to the appliance at any time during the starting up and operation of the appliance shall result in:

- a) continued safe operation; or
- b) safety shut-down; or
- c) lock-out.

Interruption and subsequent restoration of the electrical supply to the appliance shall not override any non-volatile lock-out condition.

NOTE Requirements and test methods relating to the continued and safe operation of the appliance in the event of normal and abnormal fluctuation of auxiliary energy are specified in 6.1.5.1 and 7.3.5.3.4.

5.1.13 Motors and fans

The direction of rotation of fans shall be clearly marked.

Motors and fans, including any belt drives, shall be so protected by suitable guards, shields or screens of adequate size, strength and durability that they are not liable to be touched (see also EN 60529:1991, class IP 20). Removal of such guards, shields or screens shall be possible only with the use of commonly available tools.

Means shall be provided to facilitate the adjustment of the belt tension by the use of commonly available tools.

Motors and fans shall be mounted in such a way as to minimize noise and vibration.

Lubrication points, if provided, shall be readily accessible.

5.2 Adjusting, control and safety devices

5.2.1 General

All the following devices or the multifunctional control in which they might be fitted shall be removable or exchangeable if this is necessary for cleaning or replacement of the device. Adjusters for the devices shall not be interchangeable if this could result in confusion.

When there are several control knobs (taps, thermostats, etc.), they shall not be interchangeable if this could lead to confusion or they shall be clearly marked to identify their function.

For ducted appliances, gas connections shall be sited externally to the air duct so as to prevent ingress of gas into the duct system.

The functioning of any safety device shall not be overruled by that of any control device.

5.2.2 Gas rate adjusters and range-rating devices

5.2.2.1 Common requirements

Gas rate adjusters and range-rating devices shall be designed so that they are protected against accidental maladjustment by the user once the appliance has been installed and put into service. It shall be possible to seal them (e.g. with paint) after adjustment; this sealing shall resist the heat to which it is subjected during normal operation of the appliance. The adjusting screws of the gas rate adjusters and range-rating devices shall be located so that they cannot fall into the gasways.

The soundness of the gas circuit shall not be put at risk by the presence of gas rate adjusters and range-rating devices.

5.2.2.2 Gas rate adjusters

Appliances in Categories I_{2H}, I_{2L}, I_{2E}, I_{2E+}, I_{3B/P}, I_{3P}, II_{2H3B/P}, II_{2H3+}, II_{2H3P}, II_{2L3B/P}, II_{2E3B/P}, II_{2E+3+} and II_{2E+3P} shall not be fitted with gas rate adjusters. However, regulated appliances in all of these categories except Category II_{2E+3+} may have a gas rate adjuster consisting of an adjusting screw on the gas regulator.

Appliances in Category II_{1a2H} shall have a gas rate adjuster for the first family gases.

For appliances in Categories II_{2H3+} and II_{2E+3+} having a gas rate adjuster, it shall be possible to put these devices out of service when these appliances are supplied with a third family gas, and the same applies for appliances in Category II_{1a2H} when they are supplied with a second family gas. For appliances in Category II_{2E+3P} having a gas rate adjuster, it shall be possible to put these devices out of service fully or partially (see 5.2.5) when these appliances are supplied with a second family gas.

The adjusters shall be adjustable only with a tool and they shall be capable of being set in the operating position.

5.2.2.3 Range-rating devices

A range-rating device on an appliance is optional.

For appliances in Category II_{1a2H}, the gas rate adjuster and the range-rating device may be one and the same. However, if the gas rate adjuster has to be sealed, either completely or partially, when the appliance is supplied with a second family gas, the gas rate adjuster or its sealed part shall no longer be used by the installer as a range-rating device.

5.2.3 Aeration adjusters

Any means of adjusting the primary aeration shall be pre-set and sealed by the manufacturer to discourage unauthorized interference.

5.2.4 Manual controls

5.2.4.1 Application

Manual valves, push buttons or electrical switches that are essential for normal operation and commissioning of the appliance shall either be provided with the appliance or, where they are not integral with the appliance, specified in the manufacturer's installation instructions.

5.2.4.2 Manual valves (other than those incorporated in a multifunctional control)

Separate manual valves shall be of the 90° turn type.

Manual valves shall be so designed or positioned as to prevent inadvertent operation but shall be easy to operate when required. They shall be so designed that in operation the "OPEN" and "CLOSED" positions are readily distinguishable.

When an appliance isolating valve is provided as an integral part of the appliance, it shall be capable of operating at a pressure equal to 1,5 times the maximum supply pressure and shall be readily accessible.

Manual valves used solely for OPEN/CLOSED operation shall be provided with positive stops at the "OPEN" and "CLOSED" positions.

5.2.5 Regulators

Regulators shall comply with the requirements of EN 88-1.

Appliances in Categories I_{2H}, I_{2E}, I_{3B/P}, I_{3P}, II_{1a2H}, II_{2H3B/P}, II_{2H3+}, II_{2H3P}, II_{2E+3B/P} and II_{2E+3P} shall be fitted with a gas regulator.

Appliances in Categories I_{2L} and II_{2L3B/P} may be fitted with a gas regulator.

Appliances in Categories I_{2E+} and II_{2E+3+} may be fitted with a gas regulator. However, the gas regulator, if it exists, shall not be operational in the range of the two normal pressures of the second family pressure couple, i.e. 20 mbar to 25 mbar.

For appliances in Categories II_{2H3+} and II_{2E+3+}, it shall be possible to put the regulator, if any, out of service when they are supplied with third family gases. For appliances in categories II_{2E+3+} and II_{2E+3P}, it shall be possible to put the regulator partially out of service when they are supplied with second family gases, such that the regulator is not operational in the range of the two normal pressures of the second family pressure couple, i.e. 20 mbar to 25 mbar.

Where a gas regulator is fitted, it shall control the gas supply to the main burner and any ignition burner having a heat input of more than 2 kW.

NOTE Separate regulators for the main burner and the ignition burner are acceptable.

The design and accessibility of the regulator shall be such that it can be easily adjusted or put out of service for use with another gas, but precautions shall be taken to make unauthorized interference with the adjustment difficult.

5.2.6 Multifunctional controls

Any multifunctional control shall comply with the requirements of EN 126.

5.2.7 Flame supervision devices

Heat sensitive flame supervision devices shall comply with the requirements of EN 125.

5.2.8 Automatic shut-off valves

5.2.8.1 General requirements

Automatic shut-off valves shall comply with the requirements of EN 161.

5.2.8.2 Application

5.2.8.2.1 Appliances with a start gas flame

All gas supplies shall be under the control of automatic shut-off valves connected to the gas line in series, of a class according to Table 2.

However, for non-automatic systems with heat inputs of 135 kW and below only, the Class C start-gas valve may be replaced by a thermoelectric flame supervision device complying with EN 125 having a sealing force capability at least equivalent to a Class C valve complying with EN 161:2007.

5.2.8.2.2 Appliances with direct main burner ignition

Such appliances shall be fitted with two automatic shut-off valves in series. One of these shall be of either Class A or B, and the other of either Class A, B, C or D (also see 5.6.2).

5.2.8.2.3 Action of the flame supervision system and overheat cut-off device

The flame supervision system and the overheat cut-off device shall effect closure of all shut-off valves in the systems specified except for non-automatic systems having heat inputs less than 135 kW.

In the case of non-automatic systems with heat inputs less than 135 kW, the flame supervision system and the overheat cut-off device need only effect closure of the Class C valve or the alternative permitted in 5.2.8.2.1, in which instance the overheat cut-off device shall effect closure of the Class C valve as a minimum requirement.

In no case shall the air temperature and overheat cut-off devices effect closure of the same single shut-off valve.

Table 2 — Valving requirements

Heat Input kW	Main gas valves required		Start gas valves required	
	non-automatic systems	automatic systems	non-automatic systems	automatic systems
Less than 135 kW	1 x Class C plus 1x Class D	1 x Class B plus 1x Class D ^{e)}	1 x Class C ^{a)}	1 x Class B ^{b)} plus 1 x Class D ^{d) e)}
Between 135 kW and 300 kW	1 x Class B plus 1 x Class C	1 x Class B plus 1 x Class C	1 x Class B ^{b)}	1 x Class B ^{c)} plus 1 x Class D ^{d) e)}

a) This valve may be the start-gas valve component integral with a thermoelectric valve or multifunctional control conforming to the requirements of EN 125 or EN 126, as appropriate.

b) This valve may be the Class B valve controlling the main gas supply.

c) This valve may be the upstream valve of the main gas valves, subject to the requirements of 5.5.2.

d) For start gas rates > 0,6 kW or 1 % of the nominal heat input of the main burner up to a maximum of 1,5 kW this additional Class D valve shall be fitted.

e) If a Class D valve is used for automatic systems, a strainer shall be used such that it does not pass a 0,2 mm pin gauge. This strainer shall be fitted upstream of the valve.

5.2.9 Automatic burner control systems

5.2.9.1 General

Automatic burner control systems shall comply with the requirements of EN 298.

5.2.9.2 Manually operated devices

Operating push buttons, switches, etc., incorrectly or out of sequence shall not adversely affect the safety of the automatic burner control system.

In particular, under the test conditions described in 7.2.1, the rapid (on and off) operation of any start switch shall not set up a hazardous condition.

5.2.10 Gas strainers

A strainer shall be fitted at the inlet of any system incorporating automatic shut-off valve(s) of Class A, B or C to prevent the ingress of foreign matter. The maximum strainer hole dimension shall not be greater than 1,5 mm and the mesh shall not pass a 1 mm pin gauge. The strainer may be integral with the upstream automatic shut-off valve.

In systems comprising multiple automatic shut-off valves of Classes A, B or C, only one strainer need be fitted, provided it gives adequate protection to all valves.

Where a regulator is fitted upstream of the automatic shut-off valve system, the strainer may be fitted upstream of the regulator.

5.3 Ignition devices

5.3.1 General

It shall be possible to light the appliance from a readily accessible position.

Ignition burners and ignition devices shall be protected by design and position against external influences.

Ignition burners, ignition devices and their mountings shall be so designed that they can only be located rigidly and correctly in relation to every component and burner with which they are designed to operate.

5.3.2 Ignition device for the main burner

The main burner shall be fitted with an ignition burner or an ignition device for direct ignition.

5.3.3 Ignition burners

If different ignition burners are used for the different gases, they shall be marked, easy to substitute for one another and easy to fit. The same applies to injectors where only they have to be changed. Injectors shall carry an indelible means of identification and shall only be removable with the aid of a tool.

Ignition burners shall be protected against blockage by gas-borne particulate matter (see 5.2.10).

5.4 Flame supervision system

5.4.1 Non-automatic burner systems

The burner shall be fitted with a flame supervision device to monitor the ignition burner flame and protect the main flame.

The ignition opening time of heat sensitive flame supervision devices shall not exceed 20 s. This is verified under the test conditions of 7.2.2.

Upon flame failure, the control system shall cause non-volatile lock-out. The extinction safety time for the flame supervision system to shut down the burner shall not be more than 60 s for appliances with permanent ignition burners protected by a heat sensitive flame supervision system. However, for appliances with a heat input greater than 135 kW, the extinction safety time shall not exceed 3 s. The extinction safety time is verified under the test conditions of 7.2.3.

Flame supervision devices shall be designed such:

- a) that the failure of the sensor causes safe shut down of the burner (e.g. thermoelectric type); or
- b) as to prevent any automatic shut-off valve opening and/or any ignition attempt occurring if a flame or flame-simulating condition is signalled when the burner is started from the completely shut-down condition.

NOTE Care should be taken to prevent electrical interference from giving rise to flame detector signals that falsely indicate the presence of a flame.

Where thermoelectric flame supervision devices are used in conjunction with electric ignition, the control system shall incorporate a restart interlock. For the purposes of this requirement, a piezo-electric ignition is not regarded as electric ignition.

5.4.2 Automatic burner systems

The burner shall be fitted with a flame supervision device.

When the burner is started from the shut-down condition, the flame supervision system shall prevent any attempt at ignition or the opening of any gas valve if a flame or flame-simulating condition is present.

This safe-start check shall last for more than 5 s and shall cease not more than 5 s prior to any attempt at ignition.

NOTE Care should be taken to prevent electrical interference from giving rise to flame detector signals that falsely indicate the presence of a flame.

The extinction safety time for the flame supervision system to detect the absence of flame and shut down the burner(s) shall not be more than 3 s. This is verified under the test conditions of 7.2.3.

5.5 Start-gas flame establishment

5.5.1 Non-automatic burner systems

For appliances of heat input not exceeding 60 kW, the gas rate of a start-gas burner shall not exceed 0,6 kW. For an appliance of heat input greater than 60 kW, the gas rate of a start-gas burner shall not exceed 1 % of the gas rate of the main burner or 1,5 kW, whichever is the lower rate.

Provision shall be made to establish the start-gas flame safely and easily, either manually or by means of an ignition device incorporated in the appliance.

The main gas valve shall not admit gas to the burner until the start-gas flame has been detected by the flame supervision system.

If the start-gas flame is established at a separate burner, the flame detector, under all conditions of operation, shall detect the start-gas flame only at rates which will ignite the main gas reliably and smoothly.

5.5.2 Automatic burner systems

A start-gas flame shall be established either at the main burner or at a separate burner.

No start-gas rate shall exceed 25 % of the main burner rating.

Where the start-gas flame is established at a separate burner, the start-gas rate shall not exceed 10 % of the main burner rating.

Where the start-gas supply is taken from between the two main gas valves, either:

- a means shall be provided to prove closure of the downstream main shut-off valve prior to ignition; or

NOTE A valve proving system, proof of closure switch or a closed position indicator switch is deemed to satisfy this requirement.

- the requirements of 6.1.4.1.2 shall be met.

On burners with a heat input rating of 135 kW and above, the downstream main gas safety shut-off valve shall be checked for closure prior to start-up. If the check indicates the valve is not closed, the start-up shall be prevented.

The ignition source shall not be energized before a safe-start check has been made of the flame supervision system and shall be de-energized at, or before, the end of the first safety time. Where a hot surface ignition system is used, the ignition system shall be so energized that the ignition source is capable of igniting incoming gas before the gas valves are opened.

If the start-gas flame has not been detected by the end of the first safety time, safety shut-down and non-volatile lock-out shall result.

If the start-gas flame is established at a separate burner, the flame detector, under all conditions of operation, shall detect the start-gas flame only at rates which will ignite the main gas reliably and smoothly.

The first safety time shall not exceed:

- 30 s in case of start-gas burners having an input not exceeding 600 W;

- 15 s in case of start-gas burners having an input greater than 600 W and not exceeding 1,5 kW;
- 5 s (and preferably not less than 2 s) for appliances where the start-gas rate exceeds 1,5 kW.

The safety time is verified under the test conditions of 7.2.4.

In the event of start-gas flame failure after establishment of the start-gas flame, but before the main gas safety shut-off valves have been signalled to open, either safety shut-down shall occur or a single immediate attempt at re-ignition by direct spark restoration may occur. This single re-ignition attempt within 1 s shall only be permitted:

- a) for appliances with heat inputs of 135 kW and below and where the start-gas rate, established on a separate burner, does not exceed 0,6 kW or 1 % of the main burner rating, whichever is the greater;
- b) for appliances with heat inputs of more than 135 kW, and where the start-gas rate, established on a separate burner is less than 1 kW plus 1 % of the main burner rating.

If re-ignition is attempted and the start-gas flame is not detected within the first safety time, safety shut-down and non-volatile lock-out shall result.

For appliances where the start-gas exceeds the values given in a) and b) above, safety shut-down and non-volatile lock-out shall occur in the event of start-gas flame failure after its establishment and before the main gas safety shut-off valves have been signalled to open.

5.6 Main flame establishment

5.6.1 Establishment by means of a start-gas flame

5.6.1.1 Non-automatic burner systems

Main gas shall not be admitted to the burner until the start-gas flame has been detected by the flame supervision system and manual intervention has occurred (e.g. release of a push-button).

Flame failure in the running condition shall result in non-volatile lock-out.

5.6.1.2 Automatic burner systems

The main gas safety shut-off valves shall not be energized to admit the main gas flow rate to the burner until after the start-gas flame has been detected and proved.

However, the upstream safety shut-off valve in the main gas supply may be opened to permit gas flow where the start-gas supply is taken from downstream of the first main gas safety shut-off valve, provided that the conditions of 5.5.2 are complied with.

Flame failure at any time after the main gas safety shut-off valves have been signalled to open shall lead to safety shut-down and non-volatile lock-out.

5.6.2 Direct establishment of the main flame, e.g. spark ignition, hot surface igniter

Direct ignition of the main flame is permitted for appliances having a nominal heat input not exceeding 120 kW.

The ignition source shall not be energized before a safe-start check (see 5.4.2) has been made of the flame supervision system and shall be de-energized at, or before, the end of the safety time. Where a hot surface ignition system is used, the ignition system shall be so energized that the ignition source is capable of igniting incoming gas before the gas valves are opened.

If the flame has not been detected before the end of the safety time, safety shut-down and non-volatile lock-out shall result.

This safety time shall not exceed 5 s. This is verified under the test conditions of 7.2.4.

5.7 Main burner

The cross-sectional area of the flame ports shall not be adjustable.

Every injector and removable restrictor shall carry an indelible means of identification. It shall be possible to change injectors and restrictors without having to move the appliance from its installed position. However, injectors shall only be removable with the aid of a tool.

The burner shall be so located and arranged that misalignment cannot occur. It shall not be possible to remove the burner assembly without the use of tools.

5.8 Facility for remote control

Where the appliance is capable of being controlled remotely by means of thermostats or a time control, electrical connections of these controls shall be possible without disturbing any internal connections in the appliance other than a link exclusively designed for this purpose. When the heater is installed in accordance with the manufacturer's instructions, no hazardous condition shall occur as a result of failure of the normal means of air temperature control.

5.9 Thermostats and control of air temperature

5.9.1 General requirements

Integral mechanical thermostats shall comply with the requirements of EN 257.

Electrical thermostats shall comply with the requirements of EN 60730-2-9.

Overheat cut-off devices shall comply with Type 2K requirements of EN 60730-2-9:2002.

5.9.2 Overheat cut-off device

An overheat cut-off device shall be fitted to the appliance to cause shut-down and non-volatile lock-out in the event of an overheat condition occurring.

5.9.3 Overheat control device

Such a device may be fitted to cause shut-down of the main burner in the event of an overheat condition occurring, such as reduced air flow.

5.9.4 Overheat cut-off/control devices

The operating temperature of the overheat device shall be set and sealed by the manufacturer.

Where flame detection is achieved other than by means of a direct-acting thermoelectric heat sensitive type device, the non-volatile lock-out action shall not rely on the operation of the flame detection circuits. In particular, the device shall not be wired in series with either the flame sensor or the line supply from a programming unit to any automatic shut-off valve.

Such devices shall not operate during the normal operation of the appliance.

5.9.5 Fan delay controls

5.9.5.1 Delayed start

Where means are provided to delay the operation of the air delivery fan after ignition of the burner to prevent the discharge of cold air into the heated space, the fan start delay shall not be such as to cause the overheat device(s) to operate under normal conditions.

5.9.5.2 Delayed shut-down

Means shall be provided to delay the shut-down of the air delivery fan after shut-down of the burner(s).

5.9.6 Sensors

Control thermostats and overheat cut-off devices may have the same sensor if such controls are mechanical in operation and failure of the sensor results in non-volatile lock-out of the appliance.

With an electronic system, thermostats and overheat cut-off devices shall not have the same sensor unless it is break-safe.

5.9.7 Gas pressure test points

The appliance shall be fitted with at least two gas pressure test points. One shall be fitted upstream of the first control and safety device and the other downstream of the last gas flow rate control and in a position carefully selected so as to permit measurements to be made.

The test points shall have an external diameter of $\left(9 \frac{0}{-0,5}\right)$ mm and a useful length of at least 10 mm to enable a tube to be fitted. At the point of its minimum cross-section, the diameter of the bore shall not exceed 1 mm.

5.10 Combustion chamber pressure reliefs

Where a pressure relief device is fitted and it is on the same side of the appliance as any user-operated controls, means shall be provided to prevent hazard to personnel in the event of its operation. Any shields or deflectors shall not interfere with the operation of the relief, and the installation instructions shall draw attention to the location and free area required to provide safe operation. Any such pressure relief shall be capable of withstanding the temperature of the enclosed combustion products.

5.11 Facilities for commissioning and testing

To facilitate commissioning, permanent means shall be provided to prevent gas flowing at rates other than the start-gas flow rate.

Compliance with this requirement may be achieved by adopting one of the approaches given in Annex C.

6 Operational requirements

6.1 Safety of operation

6.1.1 Soundness

6.1.1.1 Soundness of the gas circuit

The gas circuit shall be sound.

External soundness is assured if, under the conditions specified in 7.3.1.1 the air leakage rate does not exceed $0,1 \text{ dm}^3/\text{h}$ regardless of the number of valves fitted in series or in parallel on the appliance.

6.1.1.2 Soundness of the combustion circuit and correct evacuation of combustion products

6.1.1.2.1 Type B₁₁ and B₄₁ appliances

When the appliance is tested under the conditions of 7.3.1.2.1 combustion products shall not escape except from the flue outlet.

6.1.1.2.2 Type C₁₁ and C₃₁ appliances

When the appliance is tested under the conditions of 7.3.1.2.2 the air leakage rate shall not exceed $0,5 \text{ m}^3/\text{h}$ per kW of heat input, with a maximum of $25 \text{ m}^3/\text{h}$.

6.1.2 Heat inputs

6.1.2.1 Nominal heat input

When measured under the conditions of 7.3.2.2, the heat input obtained at the normal pressure shall be within $\pm 5 \%$ of the nominal heat input.

6.1.2.2 Start gas heat input

When measured under the conditions of 7.3.2.3, the start gas heat input obtained at normal pressure shall be within $\pm 5 \%$ of the start gas heat input declared by the manufacturer.

However, this tolerance is extended to within $\pm 10 \%$ where the injector has a diameter of $0,5 \text{ mm}$ or less.

6.1.2.3 Effectiveness of gas rate adjusters

For appliances without a gas regulator but with a gas rate adjuster, the heat input obtained after adjustment of the device:

- a) shall not be less than the nominal heat input, under the conditions of Test 1 of 7.3.2.4;
- b) shall not exceed the nominal heat input, under the conditions of Test 2 of 7.3.2.4.

6.1.2.4 Effectiveness of the gas regulator

For appliances with an adjustable gas regulator, the heat input shall not differ by more than $+7,5 \%$ and -10% for first, second and third family gases, from the rate obtained at the adjustment pressure specified in 7.3.2.5, when the upstream pressure is varied between the minimum and maximum values stated in 7.1.4 for the reference gases of the category concerned.

6.1.2.5 Effectiveness of the range-rating device

For appliances fitted with a range-rating device, as distinct from a gas rate adjuster, and under the conditions specified in 7.3.2.6:

- a) the nominal heat input shall be obtained to within $\pm 5\%$ of the nominal heat input stated by the manufacturer with the range-rating device in the position giving the maximum rate;
- b) the minimum heat input shall be obtained to within $\pm 5\%$ of the minimum heat input stated by the manufacturer with the range-rating device in the position giving the minimum rate.

For appliances of Categories I_{2L} and I_{2H} fitted with a range-rating device not distinct from a gas rate adjuster, the minimum and maximum of the manufacturer's declared range of heat input shall be obtained to within $\pm 5\%$.

6.1.3 Limiting temperatures

6.1.3.1 The temperature of parts of the appliance which have to be touched during normal use

The surface temperatures of the control knobs and of all the parts to be touched during normal use of the appliance, measured only in the zones intended to be gripped, and under the conditions stated in 7.3.3.2 shall not exceed the ambient temperature by more than:

- a) 35 K for metals;
- b) 45 K for porcelain or similar materials;
- c) 60 K for plastics.

6.1.3.2 Temperatures of the side walls, the front and the top of the appliance

The temperature of the side walls, front and top of the appliance, except for the surfaces of the draught diverter and of any flue pipe between the case and the draught diverter, shall not exceed the ambient temperature by more than 80 K when measured under the conditions of 7.3.3.3. This requirement does not apply to those parts of the case within 150 mm of the flue pipe. It also does not apply to those parts of the appliance instrumental in the transmission of heat or parts which are higher than 1,8 m above the level of the floor when the appliance is installed.

6.1.3.3 Component temperatures

When the appliance is tested under the conditions of 7.3.3.4 the maximum temperature of the appliance components shall not exceed the maximum temperature specified by the individual component manufacturer.

6.1.3.4 Fan motor winding temperatures

When tested under the conditions of 7.3.3.5 the maximum temperature rise of the motor windings shall not exceed the maximum temperature rise stated by the motor manufacturer.

6.1.3.5 POCED (Type B₄₁, C₁₁ and C₃₁ appliances)

When the appliance is tested under the conditions of 7.3.3.6.1, the external temperature of any part of the POCED, which when installed in accordance with the manufacturer's instructions is capable of being less than 25 mm from combustible parts of the fabric of a building, shall not exceed the ambient temperature by more than 50 K.

If, in accordance with the manufacturer's installation instructions, the POCED is required to be enclosed within another duct, a sleeve or insulation when it passes through a combustible wall or ceiling, the external

temperatures of this duct, sleeve or insulation shall not exceed the ambient temperature by more than 50 K under the conditions of 7.3.3.6.2.

6.1.4 Ignition, cross-lighting, flame stability

6.1.4.1 Ignition and cross-lighting

6.1.4.1.1 All appliances (still air conditions)

Under the test conditions described in 7.3.4.2.1.2, correct and smooth ignition and cross-lighting shall be assured.

When, under the test conditions described in 7.3.4.2.1.3, the gas rate of any ignition burner is reduced to the minimum required to hold open the gas supply to the main burner, correct and smooth ignition of the main burner shall be assured.

6.1.4.1.2 Appliances where the start gas is taken from between the two main burner gas valves

Where the gas line is designed such that the gas supply to the start-gas burner is taken from between the two main gas valves, and means is not provided to prove closure of the downstream main shut-off valve prior to ignition, then under the conditions of test described in 7.3.4.2.2, it shall be verified that ignition of the start gas does not give rise to a hazardous situation.

6.1.4.1.3 Appliances with automatic ignition

Under the test conditions described in 7.3.4.2.3, the system shall be safe on ignition. In addition, the appliance shall not sustain any damage likely to affect its safe operation.

6.1.4.1.4 Special conditions

6.1.4.1.4.1 Type B₁₁ and B₄₁ appliances

Under the conditions of 7.3.4.2.4.1, the ignition burner or the main burner, if ignition occurs at a start gas rate on the main burner, shall ignite and remain stable without light back or lift and any flame supervision device shall continue to function normally.

Where ignition is by means of an ignition burner, the above requirements shall be assessed with and without the main burner alight.

6.1.4.1.4.2 Type C₁₁ appliances

Under the conditions of 7.3.4.2.4.2, ignition of any ignition burner, ignition of the main burner and complete cross-lighting of the main burner shall be assured.

6.1.4.1.4.3 Type C₃₁ appliances

Under the conditions of 7.3.4.2.4.3, ignition of any ignition burner, ignition of the main burner and complete cross-lighting of the main burner shall be assured.

6.1.4.2 Flame stability

6.1.4.2.1 All appliances (still air conditions)

Under the test conditions described in 7.3.4.3.2, the flames shall be stable. A slight tendency to lift at the moment of ignition is acceptable but the flames shall be stable during normal operation.

6.1.4.2.2 Special conditions

6.1.4.2.2.1 Type B₁₁ and B₄₁ appliances

Under the conditions of 7.3.4.2.4.1 and 7.3.4.3.3, the main burner and any ignition burner flames shall remain stable.

6.1.4.2.2.2 Type C₁₁ appliances

Under the conditions of 7.3.4.2.4.2, the main burner and any ignition burner flames shall remain stable.

6.1.4.2.2.3 Type C₃₁ appliances

Under the conditions of 7.3.4.2.4.3, the main burner and any ignition burner flames shall remain stable.

6.1.5 Combustion

6.1.5.1 All appliances (still air conditions)

The CO concentration in the dry air-free combustion products shall not exceed:

- a) 0,10 % when the appliance is supplied with the reference gas under the conditions of 7.3.5.3.1;
- b) 0,20 % when the appliance is supplied with the reference gas under the conditions of 7.3.5.3.2 and with the incomplete combustion gas under the conditions of 7.3.5.3.3;
- c) 0,20 % when the appliance is supplied with the reference gas under the conditions of 7.3.5.3.4. In addition, the appliance shall ignite and continue to operate.

The test methods are specified in 7.3.5.

6.1.5.2 Special conditions

6.1.5.2.1 Type B₁₁ and B₄₁ appliances

The CO concentration in the dry air-free combustion products shall not exceed 0,20 % when the appliance is supplied with reference gas under the conditions of 7.3.5.4.1.

6.1.5.2.2 Type C₁₁ appliances

The CO concentration in the dry air-free combustion products shall not exceed 0,20 % when the appliance is supplied with reference gas under the conditions of 7.3.5.4.2.

6.1.5.2.3 Type C₃₁ appliances

The CO concentration in the dry air-free combustion products shall not exceed 0,20 % when the appliance is supplied with reference gas under the conditions of 7.3.5.4.3.

6.1.5.3 Other pollutants

Under the test and calculation conditions of 7.3.5.5, the NO_x concentration in the dry air-free combustion products shall not exceed 260 mg/kWh or the manufacturer's declared maximum concentration, whichever is the lower. However, for appliances intended to use only third family gases, the limit NO_x value is multiplied by a factor of 1,60. For appliances intended to use propane only, the limit NO_x value is multiplied by a factor of 1,50.

6.1.6 Overheat cut-off device

Under the conditions of 7.3.6.1, the following requirements shall be satisfied:

- a) the gas supply to the burner shall be cut off to prevent:
 - 1) hazardous condition;
 - 2) any damage to the appliance;
 - 3) either the average temperature of the air at the appliance outlet exceeding 100 °C or, for appliances with multiple outlets and those intended to be installed with the base of the appliance more than 2,5 m from the floor level, whether or not they are fitted with multiple outlets, the average temperature at any one outlet exceeding 125 °C;
- b) the overheat control shall not operate during the normal cyclic action of the appliance, e.g. as a consequence of the operation of a room thermostat or other control;
- c) flame stability shall be satisfactory throughout the test.

In addition, when tested in accordance with the method described in 7.3.6.2, the gas supply to the burner shall be cut off to prevent:

- d) hazardous condition;
- e) any damage to the appliance.

6.1.7 Heat exchanger thermal cycling

When tested in accordance with 7.3.7:

- a) at the end of each 2 000 cycles of operation, the burner shall operate correctly when the air distribution fan is operating and, on visual examination of the heat exchanger (without removing it from the appliance) there shall be no slit, opening or perforation in the heat exchanger which is visible to the naked eye;
- b) at the end of 5 000 cycles of operation, there shall be no split, opening or perforation in the heat exchanger which is visible to the naked eye;
- c) at the end of the test there shall be no signs of corrosion that will adversely affect the life of any POCED.

6.2 Efficiency

The efficiency based on the net calorific value determined at the nominal heat input shall not be less than 84 % when measured in accordance with 7.4.

If the appliance has a modulating or high/low control, when measured in accordance with 7.4.6, the efficiency based on the net calorific value with the appliance adjusted to give the minimum rate shall be such that:

$$\eta_{\min} \geq \frac{(84 + \eta_n)}{2} - \frac{10(Q_n - Q_{\min})}{Q_n} \%$$

where

η_{\min} is the efficiency based on the net calorific value with the appliance adjusted to give the minimum rate in %;

η_n is the efficiency based on the net calorific value determined at the nominal heat input in %;

Q_n is the heat input at nominal rate in kW;

Q_{\min} is the heat input at minimum rate in kW.

Under no circumstances shall η_{\min} be < 79 %.

7 Test methods

7.1 General

7.1.1 Characteristics of test gases: reference and limit gases

Appliances are intended for use with gases of different qualities. One of the aims of this standard is to check that the performance of an appliance is satisfactory for each family or group of gases for which it is designed and for the pressures for which it is designed, if necessary using the adjusting devices.

The test gases, test pressures and appliance categories given in this standard are in accordance with those specified in EN 437.

The characteristics of the reference and limit gases are given in Tables 3 and 4. The values in Table 3, measured and expressed at 15 °C, are derived from EN ISO 6976:2005.

7.1.2 Conditions for preparation of the test gases

The composition of gases used for the tests shall be as near as possible to those given in Table 3. For the constitution of the gases:

- a) the Wobbe number of the gas used shall be within ± 2 % of the value in the table (this tolerance includes the errors of the measuring equipment);
- b) the purity of the gases used to constitute the mixtures shall be:
 - 1) nitrogen (N₂) - 99 %;
 - 2) hydrogen (H₂) - 99 %;
 - 3) methane (CH₄) - 95 % (with a total concentration of H₂, CO and O₂ below 1 %);
 - 4) propene (C₃H₆) - 95 % (and a total concentration of N₂ and CO₂ below 2 %);
 - 5) propane (C₃H₈) - 95 %;
 - 6) butane (C₄H₁₀)² - 95 %.

However, these conditions are not obligatory for each of the components if the final mixture has a composition identical to that of a mixture which would have been made from components satisfying the preceding conditions. One can therefore, in order to make up a mixture, start with a gas already containing, in suitable proportions, several components of the final mixture.

For gases of the second family:

-
- 2) Any mixture of iso-butane and n-butane can be used.

- c) for the tests carried out with reference gases G 20 or G 25, a gas belonging respectively to either Group H or Group L or Group E, may be used even if its composition does not satisfy the above conditions, provided that after the addition of either propane or nitrogen as appropriate, the final mixture has a Wobbe index within $\pm 2\%$ of the value given in Table 3 for the corresponding reference gas;
- d) for preparation of the limit gases, another gas may be used as the base gas instead of methane:
 - 1) for limit gases G 21, G 222, and G 23, a natural gas of Group H may be used;
 - 2) for limit gases G 27 and G 231, a natural gas of Group H or of Group L or of Group E may be used;
 - 3) for the limit gas G 26, a natural gas of Group L may be used.

In all cases the final mixture obtained by adding propane or nitrogen shall have a Wobbe index within $\pm 2\%$ of the value given in Table 3 for the corresponding limit gas and the hydrogen concentration of the final mixture shall be as given in Table 3.

Table 3 — Test gas characteristics^{a)} (gas dry at 15 °C and 1 013,25 mbar)

Gas family and group	Test gases	Designation	Composition volume %	W_i MJ/m ³	H_i MJ/m ³	W_s MJ/m ³	H_s MJ/m ³	d mm
Gases of the first family ^{b)}								
Group a	Reference gas Incomplete, combustion flame lift and sooting limit gases	G 110	CH ₄ = 26 H ₂ = 50 N ₂ = 24	21,76	13,95	24,75	15,87	0,411
	Light back limit gas	G 112	CH ₄ = 17 H ₂ = 59 N ₂ = 24	19,48	11,81	22,36	13,56	0,367
Gases of the second family								
Group H	Reference gas	G 20	CH ₄ = 100	45,67	34,02	50,72	37,78	0,555
	Incomplete combustion Sooting limit gas	G 21	CH ₄ = 87 C ₃ H ₈ = 13	49,60	41,01	54,76	45,28	0,684
	Light back limit gas	G 222	CH ₄ = 77 H ₂ = 23	42,87	28,53	47,87	31,86	0,443
	Flame lift limit gas	G 23	CH ₄ = 92,5 N ₂ = 7,5	41,11	31,46	45,66	34,95	0,586
Group L	Reference gas and Light back limit gas	G 25	CH ₄ = 86 N ₂ = 14	37,38	29,25	41,52	32,49	0,612
	Incomplete combustion and Sooting limit gas	G 26	CH ₄ = 80 C ₃ H ₈ = 7 N ₂ = 13	40,52	33,36	44,83	36,91	0,678
	Flame lift limit gas	G 27	CH ₄ = 82 N ₂ = 18	35,17	27,89	39,06	30,98	0,629
Group E	Reference gas	G 20	CH ₄ = 100	45,67	34,02	50,72	37,78	0,555
	Incomplete combustion and Sooting limit gas	G 21	CH ₄ = 87 C ₃ H ₈ = 13	49,60	41,01	54,76	45,28	0,684
	Light back limit gas	G 222	CH ₄ = 77 H ₂ = 23	42,87	28,53	47,87	31,86	0,443
	Flame lift limit gas	G 231	CH ₄ = 85 N ₂ = 15	36,82	28,91	40,90	32,11	0,617
Gases of the third family ^{c)}								
Third family and groups 3B/P and 3B	Reference gas, Incomplete combustion and Sooting limit gas	G 30	nC ₄ H ₁₀ = 50 iC ₄ H ₁₀ = 50	80,58	116,0 9	87,33	125,81	2,075
	Flame lift limit gas	G 31	C ₃ H ₈ = 100	70,69	88,00	76,84	95,65	1,550
	Light back limit gas	G 32	C ₃ H ₆ = 100	68,14	82,78	72,86	88,52	1,476
Group 3P	Reference gas, Incomplete combustion Sooting ^{d)} and flame lift limit gas	G 31	C ₃ H ₈ = 100	70,69	88,00	76,84	95,65	1,550
	Light back and Sooting limit gas ^{d)}	G 32	C ₃ H ₆ = 100	68,14	82,78	72,86	88,52	1,476

^{a)} For gases used nationally or locally, see A.4.

^{b)} For other groups, see A.4.

^{c)} See also Table 4.

^{d)} See 7.1.2 footnote 2).

Table 4 — Calorific values of third family test gases

Test gas designation	H_i MJ/kg	H_s MJ/kg
G 30	45,65	49,47
G 31	46,34	50,37
G 32	45,77	48,94

7.1.3 Practical application of test gases

7.1.3.1 Choice of test gases

Gases required for the tests described in 7.3.2, 7.3.4 and 7.3.5 shall be as specified in 7.1.1 and made up in accordance with 7.1.2.

For the tests described in other clauses, it is permissible, in order to facilitate testing, to replace the reference gas by a gas actually distributed, provided that its Wobbe index is within $\pm 5\%$ of that of the reference gas.

When an appliance can use gases of several groups or families, test gases selected from those listed in Table 3 and in accordance with the requirements of 7.1.5.1, are used. The selected gases, for each appliance category, are listed in Table 5.

Table 5 — Test gases corresponding to the appliance categories

Category	Reference gas	Incomplete combustion limit gas	Light back limit gas	Lift limit gas	Sooting limit gas
I _{2H}	G 20	G 21	G 222	G 23	G 21
I _{2L}	G 25	G 26	G 25	G 27	G 26
I _{2E} , I _{2E+}	G 20	G 21	G 222	G 231	G 21
I _{3B/P} , I ₃₊	G 30	G 30	G 32	G 31	G 30
I _{3P}	G 31	G 31	G 32	G 31	G 31, G 32
II _{1a2H}	G 110, G 20	G 21	G 112	G 23	G 21
II _{2H3B/P} , II _{2H3+}	G 20, G 30	G 21	G 222, G 32	G 23, G 31	G 30
II _{2H3P}	G 20, G 31	G 21	G 222, G 32	G 23, G 31	G 31, G 32
II _{2L3B/P}	G 25, G 30	G 26	G 32	G 27, G 31	G 30
II _{2L3P}	G 25, G 31	G 26	G 32	G 27, G 31	G 31, G 32
II _{2E3B/P} , II _{2E+3+}	G 20, G 30	G 21	G 222, G 32	G 231, G 31	G 30
II _{2E+3P}	G 20, G 31	G 21	G 222, G 32	G 231, G 31	G 31, G 32

NOTE Tests with the limit gases are carried out with the injector and adjustment corresponding to the reference gas of the group to which the limit gas used for the test belongs.

7.1.3.2 Conditions of supply and adjustment of the burners

7.1.3.2.1 Initial adjustment of appliance

Before all tests that are required to be carried out, the appliance shall be fitted with the appropriate equipment (injector(s)) corresponding to the gas family or gas group to which the specified test gas belongs (see Table 5). Any gas rate adjusters are set in accordance with the manufacturer's instructions using the appropriate reference gas(es) (see 7.1.5.1) and the corresponding normal pressure(s) given in 7.1.4.

This initial adjustment of the appliance is subject to the limitations given in 5.1.1.

7.1.3.2.2 Supply pressures

Except where an adjustment of the supply pressure is necessary (as described in 7.1.3.2.3 and 7.1.3.2.4) the normal, minimum and maximum supply pressures to be used for testing purposes shall be in accordance with the requirements given in 7.1.4.

Unless otherwise specified, the initial adjustment of the appliance is not altered.

7.1.3.2.3 Adjustment of heat inputs

For tests requiring adjustment of the burner to the nominal or another specified heat input, it shall be ensured that the pressure upstream of the injectors is such that the heat input obtained is within $\pm 2\%$ of that specified (by altering the preset adjusters or the appliance regulator, if adjustable, or the appliance supply pressure).

The specified heat input shall be calculated in accordance with 7.3.2 and with the appliance supplied with the appropriate reference gas(es).

7.1.3.2.4 Corrected pressures

Where, in order to obtain the nominal heat input within $\pm 2\%$, it is necessary to use a supply pressure, p , different from the normal pressure p_n , then those tests normally carried out at the minimum or maximum pressures p_{\min} and p_{\max} shall be carried out at the corrected pressures p' and p'' .

The corrected test pressures are calculated using Equation 1.

$$\frac{p'_{\min}}{p_{\min}} = \frac{p'_{\max}}{p_{\max}} = \frac{p}{p_n} \quad (1)$$

where

- p_n is the normal test pressure;
- p_{\min} is the minimum test pressure;
- p_{\max} is the maximum test pressure;
- p is the burner unit inlet pressure;
- p'_{\min} is the corrected minimum test pressure;
- p'_{\max} is the corrected maximum test pressure.

7.1.4 Test pressures

The test pressures, i.e. the pressures required at the gas inlet connection of the appliance, are given in Tables 6 and 7.

These pressures and the corresponding injectors are used in accordance with the special national conditions given in Annex A, for the country in which the appliance is to be installed.

Table 6 — Test pressures where no pressure couple exists^{a)}

Appliance categories having as index	Test gas	p_n mbar	p_{min} mbar	p_{max} mbar
first family: 1a	G 110, G 112	8	6	15
second family: 2H	G 20, G 21, G 222, G 23	20	17	25
second family: 2L	G 25, G 26, G 27	25	20	30
second family: 2E	G 20, G 21, G 222, G 231	20	17	25
third family: 3B/P	G 30, G 31, G 32	29 ^{b)}	25	35
	G 30, G 31, G 32	50	42,5	57,5
third family: 3P	G 31, G 32	37	25	45
	G 31, G 32	50	42,5	57,5

a) For test pressures corresponding to gases distributed nationally or locally, refer to Table A.5.

b) Appliances of this category may be used, without adjustment, at the specified supply pressures of 28 mbar to 30 mbar.

Table 7 — Test pressures where a pressure couple exists

Appliance categories having as index	Test gas	p_n mbar	p_{min} mbar	p_{max} mbar
second family: 2E+	G 20, G 21, G 222	20	17 ^{b)}	25
	G 231	(25) ^{a)}	17 ^{d)}	30
third family: 3+ (28-30/37 couple)	G 30	29 ^{c)}	20	35
	G 31, G 32	37	25	45
third family: 3+ (50-67 couple)	G 30	50	42,5	57,5
	G 31, G 32	67	50	80

a) This pressure corresponds to the use of low Wobbe index gas but in principle no test is carried out at this pressure.

b) See Annex F.

c) Appliances of this category may be used, without adjustment, at the specified supply pressures of 28 mbar to 30 mbar.

7.1.5 Test procedures

7.1.5.1 Tests requiring the use of reference gases

The tests, specified in 7.3.2 (Heat input), 7.3.4 (Ignition, cross-lighting, flame stability) and 7.3.5 (Combustion) shall be carried out with each of the reference gases appropriate to the country in which the appliance is to be installed, according to the information given in A.1.

The other tests are carried out with only one of the reference gases of the appliance category (see 7.1.1) at one of the normal test pressures required in 7.1.4 for the selected reference gas, hereafter referred to as "the reference gas".

However, the test pressure shall be one of those stated by the manufacturer and the appliance shall be fitted with the appropriate injector(s).

7.1.5.2 Tests requiring the use of limit gases

These tests shall be carried out with the limit gases appropriate to the appliance category (see Table 5) and with the injector(s) and the adjustments corresponding to the reference gas of the group, or family, to which each limit gas belongs.

7.1.6 General test conditions

7.1.6.1 General

7.1.6.2 to 7.1.6.8 are generally applicable except where otherwise specified.

7.1.6.2 Test room

The appliance is installed in a well-ventilated, draught-free room which has an ambient temperature of $(20 \pm 5) ^\circ\text{C}$. A wider temperature range is permissible provided that the effect on the test results can be taken into account.

7.1.6.3 Evacuation of the products of combustion

7.1.6.3.1 Type B₁₁ appliances

Appliances with a vertical flue outlet shall be tested with the minimum height of vertical flue downstream of the draught diverter specified by the manufacturer. The flue shall have the same nominal diameter as the flue outlet. Appliances with a horizontal flue outlet shall be fitted in accordance with the manufacturer's instructions; these shall include the maximum length of horizontal run and the method of adaption to a vertical flue; thereafter the vertical flue shall be fitted as above.

The vertical flue shall be made from sheet metal having a metal thickness not exceeding 1 mm. Unless otherwise stated, the flue shall be uninsulated.

Appliances shall be tested with the minimum diameter flue as specified in the installation instructions. If the flue has been adapted for another country, the modification required shall only involve an increase in the flue diameter.

7.1.6.3.2 Type B₄₁ appliances

Appliances shall be tested with the POCEd as supplied or specified by the appliance manufacturer, having the maximum equivalent resistance specified in the manufacturer's instructions.

7.1.6.3.3 Type C₁₁ appliances

Except where otherwise stated, the lengths of the air supply duct and combustion products duct, POCEd, are adjusted to suit a wall thickness of approximately 350 mm, and any terminal guard provided is not fitted. If appropriate, an external telescopic duct is sealed in accordance with the manufacturer's instructions.

7.1.6.3.4 Type C₃₁ appliances

Except where otherwise stated, the tests are carried out using combustion air duct and combustion products duct, POCEd, of the minimum and maximum equivalent resistance declared and supplied by the manufacturer.

7.1.6.4 Test installation

The appliance shall be installed in accordance with the manufacturer's instructions, with particular reference to minimum declared clearances around the appliance.

7.1.6.5 Influence of thermostats

Precautions shall be taken to prevent thermostats or other controls from operating and affecting the gas rate, unless this is necessary for the test.

7.1.6.6 Electrical supply

The appliance is connected to an electrical supply at the nominal voltage, except where otherwise stated in the clause concerned.

7.1.6.7 Range-rated appliances

For appliances that are designed to be range-rated, all tests are carried out at their maximum and minimum nominal heat inputs.

7.1.6.8 Modulating and high/low operation

For appliances with modulating or high/low operation, the tests are carried out at the nominal heat input unless otherwise stated in the particular test.

7.2 Construction and design

7.2.1 Automatic burner control systems (manually operated devices)

The appliance is installed as described in 7.1.6 and supplied with an appropriate reference gas (see Table 3) at the nominal heat input in accordance with 7.1.3.2.1. The start device is manually operated ten times, i.e. once every 5 s.

It is checked that the requirements of 5.2.9.2 are met.

7.2.2 Ignition opening time

With the appliance in the cold condition, the gas supply is turned on and the ignition burner is lit. 20 s after ignition of the ignition burner, manual intervention is withdrawn and it is checked that the ignition burner remains alight.

It is checked that the requirements of 5.4.1 are met.

7.2.3 Extinction safety time

With the appliance in the running condition, isolate the gas supply to the main burner. Measure the time between when the main burner is extinguished and the signal for valve closure is given.

It is checked that the requirements of 5.4.1 and 5.4.2 are met.

7.2.4 Safety time

Isolate the gas supply to the appliance. Attempt to light the appliance in accordance with the manufacturer's instructions, and measure the time between the signals for valve opening and closure. Compare this time with the manufacturer's specified safety time.

It is checked that the requirements of 5.5.2 and 5.6.2 are met.

7.3 Safety of operation

7.3.1 Soundness

7.3.1.1 Soundness of the gas circuit

For appliances using first and/or second family gases only, the tests are carried out with an air inlet pressure of 50 mbar; the inlet valve is however tested with an air pressure of 150 mbar. For appliances using third family gases, all the tests are carried out with an air pressure of 150 mbar.

Any regulator may be locked in its maximum open position to avoid damage.

Compliance with the requirements of 6.1.1.1 is checked under each of the following conditions:

- a) each valve in the main gas supply is tested in turn for soundness in its closed position, all other valves being open;
- b) with all gas valves open and the injectors for any ignition burner and main burner sealed, or, alternatively, with the injector(s) removed and the hole(s) sealed.

Where the design of any ignition burner is such that its gas outlet cannot be sealed, this test is carried out with the gasway to the ignition burner sealed at a convenient place. In this case an additional test is also carried out, using soap solution, to verify that there is no leakage from the gasway downstream of the previously tested section when the ignition burner is operating at its normal working pressure.

For the determination of the leakage rate a volumetric method is used which gives a direct reading of the leakage rate and which is of such accuracy that the error in its determination does not exceed $0,01 \text{ dm}^3/\text{h}$.

These tests are carried out first when the appliance as delivered and again, on completion of all the tests in this standard, after any assembly in the gas circuit that has a gas-tight joint whose removal is provided for in the manufacturer's instructions has been removed and replaced five times.

7.3.1.2 Soundness of the combustion circuit and correct evacuation of the combustion products

7.3.1.2.1 Type B₁₁ and B₄₁ appliances

7.3.1.2.1.1 General

The appliance is installed as described in 7.1.6 and connected to a flue as described in 7.1.6.3. The test is carried out with one of the reference gases for the category concerned at the nominal heat input under still air and draught free conditions.


Possible leaks are looked for with a dewpoint plate. This is carried out as described in 7.3.1.2.1.2 and 7.3.1.2.1.3.

7.3.1.2.1.2 Apparatus

Two forms of dewpoint plate are suitable:

- a) a chromium or rhodium plated, water cooled plate of rectangular cross section (see Figure 1). The overall length of the plate required is dependent upon the appliance design; or
- b) a chromium or rhodium plated, water cooled tube of circular or other similar suitable cross section, approximately 12 mm diameter.

All dimensions in millimetres



Key

- A water outlet
- B braze
- C hard Rhodium brass 1 mm thick
- D surface to be highly polished and free from wrinkles
- E water inlet
- F dull, nickel plated brass

Figure 1 — Leakage indicator

An essential characteristic of the detector is that it shall not affect the appliance in any way so as to cause leakage when it is in position; it may, therefore, have to be formed to match the shape of the area under test. Another requirement is that it shall not be placed so that it effectively extends the surface under test.

The detector shall be polished, but not with metal polishes containing anti-misting materials, and its surface shall be chemically degreased.

7.3.1.2.1.3 Method

Position the detector such that it will detect any leakage from the surface under test, and fix it in that position.

Allow water to flow from a constant head device through the spillage detector at approximately 90 l/h and adjust the inlet temperature of the water to $(11 \pm 0,5) ^\circ\text{C}$ above the dew point of the surrounding air. Turn the appliance on under the conditions specified in 7.3.1.2.1 above. After operating the appliance for 10 min starting from the cold condition check the surface of the detector for condensation. Condensation on the detector indicates leakage of products. However, short duration "puffs" of condensation, provided that there is at least 5 s intervals between each "puff", shall be ignored.

The condensation is best seen by illuminating the underside of the detector with a bright lamp and making observations from one side at glancing incidence along the length of the detector. It is advantageous to position a black surface so that it is reflected in the polished surface of the detector.

In doubtful cases, however, it is recommended that leaks should be found with a sampling probe connected to a CO₂ analyzer. Any instrument used shall be sensitive to a concentration of 0,01 % CO₂. An increase in the CO₂ level above the ambient of more than 0,05 % shall be regarded as unsatisfactory. The method of sampling used shall not disturb the normal flow of products of combustion.

7.3.1.2.2 Type C₁₁ and C₃₁ appliances

The appliance is installed as described in 7.1.6 and connected to a flue as described in 7.1.6.3. The terminal is sealed, any lighting door is closed and the gas inlet to the main burner and any ignition burner is blocked.

Air is passed into the appliance and the air flow rate is noted when the pressure inside the appliance is steady at 0,5 mbar above the atmospheric pressure.

NOTE A convenient method of testing the appliance is to enclose the terminal in a plastic bag into which an air entry pipe and tube connected to a pressure gauge can be fitted.

7.3.2 Heat inputs

7.3.2.1 General

For the purposes of this standard all heat inputs are determined from the volumetric rate (V_o) or mass rate (M_o) which relate to the rate obtained with reference gas under reference test conditions (dry gas, 15 °C, 1 013,25 mbar). The heat input (Q_o) in kW is given by:

$$Q_o = 0,278 M_o \cdot H_s; \text{ or}$$

$$Q_o = 0,278 M_o \cdot H_i; \text{ or}$$

$$Q_o = 0,278 V_o \cdot H_s; \text{ or}$$

$$Q_o = 0,278 V_o \cdot H_i$$

where

M_o is the mass input in kg/h obtained at reference conditions;

V_o is the volume input in m³/h obtained at reference conditions;

H_i is the net calorific value of the reference gas in MJ/kg or in MJ/m³ (dry gas, 15 °C, 1 013,25 mbar), as appropriate;

H_s is the gross calorific value of the reference gas in MJ/kg or in MJ/m³ (dry gas, 15 °C, 1 013,25 mbar), as appropriate.

The mass and volume rates correspond to a measurement and to a flow of reference gas, under reference conditions, in other words assuming the gas to be dry, at 15 °C and under a pressure of 1 013,25 mbar.

In practice, the values obtained during the tests do not correspond to these reference conditions so they shall then be corrected so as to bring them to the values that would actually have been obtained if these reference conditions had existed at the injector outlet during the test.

Depending whether the mass input is determined from the mass or volume rate, the corrected rate is calculated using Equations 2 and 3 respectively.

$$M_o = M \sqrt{\frac{1013,25 + p}{p_a + p} \times \frac{273 + t_g}{288} \times \frac{d_r}{d}} \quad (2)$$

$$V_0 = V \sqrt{\frac{1013,25 + p}{1013,25} \times \frac{p_a + p}{1013,25} \times \frac{288}{273 + t_g} \times \frac{d}{d_r}} \quad (3)$$

The corrected mass rate is calculated using Equation 4.

$$M_0 = 1,226 V_0 \times d \quad (4)$$

where

M_0 is the corrected mass flow rate (kg/h), obtained under test conditions;

M is the mass flow rate (kg/h), obtained under test conditions;

p_a is the atmospheric pressure (mbar);

p is the gas supply pressure (mbar);

t_g is the temperature of the gas at the measuring point (°C);

d is the density of dry gas relative to dry air;

d_r is the density of the reference gas relative to dry air.

Equations 2, 3 and 4 are used to calculate, from the mass input, M , or volume input, V , measured during the test, the corresponding rates M_0 or V_0 which would have been obtained under the reference conditions.

Equations 2, 3 and 4 are applicable if the test gas used is dry.

If a wet gas meter (water filled) is used or if the gas used is saturated, the value d (density of dry gas in relation to dry air) is replaced by the value of the density of the wet gas, d_h , given by Equation 5.

$$d_h = \frac{d(p_a + p - p_w) + 0,622 \times p_w}{p_a + p} \quad (5)$$

where

p_w is the saturation vapour pressure of the test gas expressed in mbar at the temperature t_g .

7.3.2.2 Nominal heat input

The test is carried out at the pressure specified by the manufacturer in accordance with the requirements of 7.1.4.

The appliance is fitted successively with each of the prescribed injectors and adjusted in accordance with 7.1.3.2.1. The heat input is determined as described in 7.3.2 for each reference gas.

The measurements are taken with the appliance at thermal equilibrium and with any thermostat put out of action.

The heat input obtained Q_0 is compared with the nominal heat input Q_n in order to verify the requirement of 6.1.2.1.

7.3.2.3 Start gas heat input

The test is carried out at the pressure specified by the manufacturer in accordance with the requirements of 7.1.4, using an arrangement which allows operation of the start gas flame on its own.

The appliance is fitted successively with each of the prescribed injectors and adjusted in accordance with 7.1.3.2.1. The heat input is determined as described in 7.3.2 for each reference gas.

The measurements are taken immediately after ignition of the start gas flame.

The heat input obtained is compared with the start gas heat input declared by the manufacturer in order to verify the requirement of 6.1.2.2.

7.3.2.4 Effectiveness of the gas rate adjusters

This clause concerns only appliances fitted with gas rate adjusters which are not put out of action.

Test 1 is where the heat input is measured with the adjuster fully open and with the minimum supply pressure given in 7.1.4 for the particular reference gas.

Test 2 is where the heat input is measured with the adjuster fully closed and with the maximum supply pressure given in 7.1.4 for the particular reference gas.

The tests are carried out for each reference gas for the appliance category with the exception of cases where the adjuster has been set and sealed by the manufacturer in a given position. In this case, the adjuster is regarded as non-existent.

7.3.2.5 Effectiveness of the gas regulator

If the appliance has an adjustable regulator, this is adjusted if necessary to give the volumetric rate corresponding to the nominal heat input with reference gas at the normal pressure given in 6.1.4 and corresponding to this gas. Keeping the initial adjustment, the supply pressure is varied between the corresponding minimum and maximum values. This test is carried out for all the reference gases for which the regulator is not put out of action. However, for first family gases, this check is made between the normal pressure and the maximum pressure.

7.3.2.6 Effectiveness of the range-rating device

The appliance is adjusted in accordance with the installation instructions.

The tests are carried out as described in 7.3.2.2 for the two extreme positions of the range-rating device.

7.3.3 Limiting temperatures

7.3.3.1 General

The appliance shall be operated with a typically distributed gas (see 7.1.3.1) or an appropriate reference gas corresponding to its category and operated within $\pm 2\%$ of the nominal heat input, using the minimum circulated air rate specified by the manufacturer and any adjustable thermostat at maximum setting.

For ductless heaters, the discharge louvres shall be set at the position of maximum closure as marked and specified by the manufacturer.

7.3.3.2 The temperature of parts of the appliance which have to be touched during normal use

The temperatures of the parts specified in 6.1.3.1 shall be measured at thermal equilibrium using an instrument with an accuracy of ± 2 K, for example using contact thermocouples, and compliance with the requirements of 6.1.3.1 is verified.

7.3.3.3 Temperatures of the side walls, front and top of the appliance

The test is carried out when the appliance has reached thermal equilibrium.

The temperatures of the hottest parts of the side walls, front and top of the appliance are measured by a suitable means having an accuracy of ± 2 K, for example using contact thermocouples, and compliance with the requirements of 6.1.3.2 is verified.

7.3.3.4 Component temperatures

Component temperatures are measured when thermal equilibrium has been reached in the test described in 7.3.3.2 and after the appliance has been turned off at the end of the test, and compliance with the requirements of 6.1.3.3 is verified.

The component temperatures are measured by means of attached thermocouples having thermoelectric junctions with an accuracy of ± 2 K. Alternative devices of equivalent accuracy may be used.

However, if an electrical component is itself likely to cause a rise in temperature (e.g. automatic shut-off valves) the temperature of the component is not measured. In this case, thermocouples or alternative devices, are placed so as to measure the air temperature around the device.

The temperature measurements of the components are deemed to be satisfactory if:

$$t_m \leq t_s + t_a - 25 \text{ }^\circ\text{C}$$

where

t_m is the maximum temperature measured in the test in $^\circ\text{C}$;

t_s is the maximum temperature specified by the component manufacturer in $^\circ\text{C}$;

t_a is the ambient room temperature in $^\circ\text{C}$.

If the maximum temperature of the component was specified for an ambient temperature other than $25 \text{ }^\circ\text{C}$, this shall be used.

7.3.3.5 Fan motor winding temperatures

The appliance is installed according to the conditions of 7.1.6 and supplied with electricity by means of a device that enables the voltage to be varied from 85 % of the minimum to 110 % of the maximum of the voltage range declared by the manufacturer (e.g. a variable voltage transformer).

The test is carried out in still air and with the appliance adjusted to its nominal heat input, using an appropriate reference gas (see Table 5). The voltage is adjusted to the most unfavourable value between the above limits.

Temperature measurements are made when the appliance has reached thermal equilibrium and after the appliance has been switched off by the normal means of control, and compliance with the requirements of 6.1.3.4 is verified.

The resistance of the windings is measured as soon as possible after switching off and then at short intervals so that a curve of the resistance against time from switch-off can be plotted, in order to determine the maximum resistance value.

The temperature rise of the windings is calculated using Equation 6.

$$\Delta t = \frac{R_2 - R_1}{R_1} (C + t_1) - (t_2 - t_1) \quad (6)$$

where

Δt is the temperature rise in K;

R_1 is the resistance at the beginning of the test in Ω ;

R_2 is the maximum resistance at the end of the test in Ω ;

t_1 is the room temperature at the beginning of the test in $^{\circ}\text{C}$;

t_2 is the room temperature at the end of the test in $^{\circ}\text{C}$;

C is 234,5 $^{\circ}\text{C}$ for copper.

7.3.3.6 POCED (Type B₄₁, C₁₁ and C₃₁ appliances)

7.3.3.6.1 Test 1

This test is carried out if, when the appliance is installed in accordance with the manufacturer's instructions, any part of the POCED is capable of being less than 25 mm from combustible parts of the fabric of the building.

Install the appliance in accordance with 7.1.6.4 and attach thermocouples junctions to the external surface of those parts of the POCED that are capable of being less than 25 mm from combustible parts of the fabric of the building. Thermocouples shall be used in accordance with EN 60584-1 with the limits of accuracy of the thermoelectric voltage used in accordance with class 2 of EN 60584-2:1993.

The appliance is supplied with one of the reference gases indicated in 7.1.1 according to its category and adjusted in accordance with 7.1.3.2.1.

The test is carried out with the appliance operating at its nominal heat input. All measurements are taken when thermal equilibrium has been reached. It is recommended that for this test the appliance should be placed in a room where the ambient temperature is approximately 20 $^{\circ}\text{C}$.

At the end of the test, check that the maximum temperature rise of the POCED does not exceed the limit specified in 6.1.3.5.

7.3.3.6.2 Test 2

This test is carried out if, in accordance with the manufacturer's installation instructions, the POCED is required to be enclosed within another duct, a sleeve or insulation when it passes through a combustible wall or ceiling.

Install the appliance in accordance with 7.1.6.4. The duct, sleeve or insulation enclosing the POCED shall be fitted in accordance with the manufacturer's instructions. This duct, sleeve or insulation shall be so dimensioned and arranged that it encloses a section of the POCED that is 350 mm in length, as close to the appliance as the manufacturer's instructions allow.

Attach thermocouples junctions to the external surface of the duct, sleeve or insulation and then enclose the duct, sleeve or insulation with a 25 mm thick layer of insulation. Thermocouples shall be used in accordance with EN 60584-1 with the limits of accuracy of the thermoelectric voltage used in accordance with class 2 of EN 60584-2:1993.

The appliance is supplied with one of the reference gases indicated in 7.1.1 according to its category and adjusted in accordance with 7.1.3.2.1.

The test is carried out with the appliance operating at its nominal heat input. All measurements are taken when thermal equilibrium has been reached. It is recommended that for this test the appliance should be placed in a room where the ambient temperature is approximately 20 °C.

At the end of the test, check that the maximum temperature rise at the external surface of the duct, sleeve or insulation enclosing the POCED does not exceed the limit specified in 6.1.3.5.

7.3.4 Ignition, cross-lighting, flame stability

7.3.4.1 General

These tests are carried out with the appliance in the cold condition and at thermal equilibrium unless otherwise stated.

7.3.4.2 Ignition and cross-lighting

7.3.4.2.1 All appliances (still air conditions)

7.3.4.2.1.1 General

These tests are carried out with the appliance installed in accordance with 7.1.6.

7.3.4.2.1.2 Ignition of the burner(s)

The requirements of 6.1.4.1.1 are verified using the tests given in 7.3.4.2.1.2 a), b) and c).

a) Test 1

The appliance is supplied with the appropriate reference and limit gases (see Table 5) at the normal pressure in accordance with 7.1.4.

Under these supply conditions it is checked that ignition of the main burner or the ignition burner occurs correctly and that ignition of the main burner by the ignition burner as well as cross-lighting of the various parts of the burner occurs correctly.

This test is repeated at the minimum heat input given by the controls, if ignition is possible under these conditions during normal operation in accordance with the manufacturer's instructions for use.

b) Test 2

For this test the initial burner and pilot adjustments are not altered and the appliance is supplied with reference gas with the pressure at the appliance inlet reduced to 70 % of the normal pressure or the minimum pressure given in 7.1.4, whichever is the lower.

Under these supply conditions it is checked that ignition of the main burner or the ignition burner occurs correctly and that ignition of the main burner by the ignition burner as well as cross-lighting of the various parts of the burner occurs correctly.

This test is repeated at the minimum heat input given by the controls, if ignition is possible under these conditions during normal operation in accordance with the manufacturer's instructions for use.

c) Test 3

Without altering the initial burner or ignition burner adjustment, the appropriate flame lift and light-back limit gases are substituted successively for the reference gas and the pressure is reduced at the appliance inlet to the minimum pressure given in 6.1.4.

Under these supply conditions it is checked that ignition of the main burner or the ignition burner occurs correctly and that ignition of the main burner by the ignition burner as well as cross-lighting of the various parts of the burner occurs correctly.

This test is repeated at the minimum heat input given by the controls, if ignition is possible under these conditions during normal operation in accordance with the manufacturer's instructions for use.

7.3.4.2.1.3 Ignition burner flame reduction

This test is carried out with the appliance installed in accordance with 7.1.6.

The appliance is initially adjusted in accordance with the requirements of 7.1.3.2.1 and supplied with the appropriate reference gases (see Table 5) at nominal heat input.

The ignition burner gas rate is then reduced to the minimum required to hold open the gas supply to the main burner.

The necessary reduction in the ignition burner gas rate may be achieved either by:

- the adjustment of the ignition burner gas rate adjuster, if this exists; or, if this is not possible,
- means of an adjuster inserted into the ignition burner gas supply for this purpose.

Correct ignition of the main burner by the ignition burner is then checked.

Where an ignition burner has several ports that are likely to become blocked, the test is carried out with all the ignition burner orifices blocked except for the one that produces the flame that heats the flame sensor.

7.3.4.2.2 Appliances where the start-gas is taken from between the two main burner gas valves

The appliance is initially adjusted in accordance with the requirements of 7.1.3.2.1 and supplied with an appropriate reference gas (see Table 5) at the nominal heat input.

With the downstream automatic gas valve in the main gas line kept open artificially, ignite the appliance.

7.3.4.2.3 Appliances with automatic ignition

The appliance is installed as described in 7.1.6.

The appliance is initially adjusted in accordance with the requirements of 7.1.3.2.1 and supplied with an appropriate reference gas (see Table 5) at the nominal heat input.

Ignition of the ignition burner, or the main burner if this is ignited directly, is checked. The test is repeated, progressively delaying the ignition up to a maximum of 25 % longer than the safety time declared by the manufacturer.

In order to delay the ignition it will generally be necessary to provide independent control of the main gas or start gas automatic shut-off valves and the operation of the ignition device. A suitable arrangement is to

provide a voltage supply, independent of the automatic burner control system, to the relevant gas valve(s) and to the ignition device.

NOTE For safety reasons the ignition delay should be increased in stages.

7.3.4.2.4 Special conditions


7.3.4.2.4.1 Type B₁₁ and B₄₁ appliances

The appliance is supplied with an appropriate reference gas (see Table 5) at the corresponding normal pressure (see Tables 6 and 7).

A Type B₁₁ appliance is connected to a flue of the same nominal diameter as the flue connection and straight for a length of not less than ten diameters immediately above the draught diverter. Down-draughts of up to 3 m/s are applied through the flue using a suitable down-draught apparatus (see Figure 2).

In the case of a Type B₄₁ appliance down-draughts of up to 3 m/s are applied through the POCED using a suitable down-draught apparatus (see Figure 2).

A second test is carried out with the outlet of the test flue, or POCED, blocked.




Key

- A diverter valve to obtain either an updraught or downdraught
- B diverter valve to obtain either an updraught or downdraught
- C fan
- D flexible
- E velocity measurement position using a Pitot tube

Figure 2 —Test of an appliance under abnormal draught conditions

7.3.4.2.4.2 Type C₁₁ appliances

The appliance is installed on the apparatus described in Figure 3, with a flue length of 350 mm, unless the manufacturer's instructions indicate that a shorter length of flue can be used. In this case, the minimum length of flue specified by the manufacturer is used.



Key

- A wind generator
- H horizontal plane
- V vertical plane
- α 0° (horizontal winds) + 30° and - 30°
- β 0° (glancing winds) 15°, 30°, 45°, 60°, 75°, 90° (perpendicular to the test wall)

When the terminal is not symmetrical, the tests are continued with incident angles of 105°, 120°, 135°, 150°, 165° and 180°.

Angle β may be varied either by modification of the position of the wind generator (fixed wall) or by rotation of the test wall about a central vertical axis.

The test wall consists of a strong vertical wall at least 1,8 m square with a removable panel at its centre. The terminal of the appliance is mounted so that its geometric centre is at the centre O of the test wall, and its projection from the wall is recommended by the manufacturer.

The characteristics of the wind generator and the distance from the test wall at which it is placed are chosen such that at the level of the test wall and after the central panel has been removed:

- a) the wind front is either approximately 90 cm square or a circular section with a diameter of 60 cm;
- b) wind speeds of 2,5 m/s, 5 m/s and 10 m/s can be obtained, with an accuracy of 10 %, over the whole of the wind front;
- c) the wind stream is essentially parallel and has no residual rotational movement.

When the central removable panel is not large enough to allow checking of these criteria, they are checked without the wall at a distance corresponding to the distance existing in practice between the wall and the wind generator discharge nozzle.

Figure 3 — Test apparatus for type C₁₁ appliances

The appliance is supplied with an appropriate reference gas in accordance with Table 5, and adjusted to obtain the nominal heat input.

Three series of tests are carried out:

a) Series 1

The appliance terminal is subjected to winds of different speeds in each of three planes:

- 1) horizontal;
- 2) ascending, at 30° to the horizontal;
- 3) plunging, at 30° to the horizontal.

In each of the three planes, the incident angle of the wind is varied by 15° increments between 0° and 90° inclusive. If the terminal is not symmetrical about the vertical axis, the tests are carried out at 15° increments between 0° and 180° inclusive.

The tests are carried out at three wind speeds 2,5 m/s, 5 m/s and 10 m/s.

At each of the 63 test points (117 if not symmetrical) a visual check is made of:

- 4) the ignition and stability of any ignition burner without the main burner alight;
- 5) the ignition of the main burner by any ignition burner;
- 6) the ignition and stability of the main burner at the nominal start-gas rate;
- 7) the cross-lighting of the main burner;
- 8) where applicable, the stability of any ignition burner (and the main burner when operating simultaneously).

The tests are carried out with the appliance at thermal equilibrium.

For each of the three incident planes, the three combinations of wind speed and incident angle that produce the highest CO concentration in the combustion products are noted.

b) Series 2

For each of the nine combinations that produce the highest combustion product CO concentration noted during the Series 1 tests, it is checked that, with the appliance cold, it is possible to light the ignition burner, if any, and then the main burner by means of either the ignition burner or the device for direct ignition.


c) Series 3

The tests performed in Series 1 and 2 are repeated at the minimum heat input given by the controls if such operation is intended by the manufacturer.

7.3.4.2.4.3 Type C₃₁ appliances

The appliance is installed on the apparatus described in Figures 4 and 5, with the shortest length of combustion air and combustion products ducts declared by the manufacturer.

All dimensions in millimetres




Key

- 1 combustion air intake and flue outlet
- 2 wind generator (shall be such that it can reproduce the wind speeds specified in 7.3.4.2.4.3 to within an accuracy of $\pm 10\%$ across the wind front)
- 3 diffuser
- 4 wind front (shall be sufficient to ensure that both the inlet and outlet of the terminal are covered)
- 5 test surface

Figure 4 — Test apparatus for Type C₃₁ appliances - Flat roof

All dimensions in millimetres



Key

- 1 combustion air intake and flue outlet
- 2 wind generator (shall be such that it can reproduce the wind speeds specified in 7.3.4.2.4.3 to within an accuracy of $\pm 10\%$ across the wind front)
- 3 diffuser
- 4 wind front (shall be sufficient to ensure that both the inlet and outlet of the terminal are covered)
- 5 test surface

Figure 5 — Test apparatus for Type C₃₁ appliances - Angled roof

The appliance is supplied with an appropriate reference gas in accordance with Table 5, and adjusted to obtain the nominal heat input.

Three series of tests are carried out:

a) Series 1

The appliance terminal is subjected to winds of different speeds in each of three planes:

- 1) horizontal;
- 2) ascending, at 20° to the horizontal;
- 3) plunging, at 45° to the horizontal.

In each of the three planes, the incident angle of the wind is varied between 0° and 90° inclusive, with intermediate tests carried out at 35° and 70°. In addition, if the terminal is suitable for use on a sloping roof, the tests are repeated with the test surface angled at 25° and 55° (see Figure 5).

The tests are carried out at five wind speeds 0,5 m/s, 1,5 m/s, 2,5 m/s, 5 m/s and 10 m/s.

At each of the test points a visual check is made of:

- 4) the ignition and stability of any ignition burner without the main burner alight;
- 5) the ignition of the main burner by any ignition burner;
- 6) the ignition and stability of the main burner at the nominal start-gas rate;
- 7) the cross-lighting of the main burner;
- 8) where applicable, the stability of any ignition burner (and the main burner when operating simultaneously).

These tests are carried out with the appliance at thermal equilibrium.

For each combination of wind speed and incident angle, the CO and CO₂ concentrations in the combustion products are noted.

b) Series 2

For each of the nine combinations resulting in the lowest CO₂ concentrations noted during the Series 1 tests, it is checked that, with the appliance cold, it is possible to light the ignition burner, if any, and then the main burner by means of either the ignition burner or the device for direct ignition.

c) Series 3

The tests performed in Series 1 and 2 are repeated at the minimum heat input given by the controls if such operation is intended by the manufacturer.

7.3.4.3 Flame stability

7.3.4.3.1 General

These tests are carried out with the appliance installed in accordance with 7.1.6.

7.3.4.3.2 All appliances (still air conditions)

The requirements of 6.1.4.2.1 are verified using the tests given in 7.3.4.3.2 a) and b).

a) Test 1

Without altering the initial main burner or ignition burner adjustment, the appropriate light-back gas is substituted successively for the reference gas and the pressure is reduced at the appliance inlet to the minimum pressure given in 7.1.4.

Under these conditions it is checked that the flames are stable.

This test is then repeated at the minimum input given by the controls at which the appliance can operate normally in accordance with the manufacturer's instructions.

b) Test 2

Without altering the initial main burner or ignition burner adjustment, the appropriate flame lift and light-back limit gases are substituted successively for the reference gas and the pressure is increased at the appliance inlet to the maximum given in 7.1.4.

Under these conditions it is checked that the flames are stable.

This test is then repeated at the minimum input given by the controls at which the appliance can operate normally in accordance with the manufacturer's instructions.

7.3.4.3.3 Special conditions (Type B₁₁ and B₄₁ appliances)

The appliance is supplied with the reference gas at normal pressure and is subjected at burner level to a wind stream of 2 m/s which has a minimum diameter (or minimum cross-sectional dimension if the wind stream is not circular) of 0,5 m.

The axis of the wind stream is in a horizontal plane and is moved through one or more (at the discretion of the laboratory) angles of incidence within a full 360° circle around the appliance, the centre of the circle passing through the two vertical planes of symmetry of the appliance.

The test is carried out with the main burner and any ignition burner alight together and, if appropriate, with only the ignition burner alight. Any lighting door remains closed during the test.

The test is repeated at the minimum input given by the controls if such operation is intended by the manufacturer.

During the test, precautions are taken to screen the draught diverter from the effects of the wind.

7.3.5 Combustion

7.3.5.1 Test installation

Unless otherwise specified hereafter, Type B₁₁ and B₄₁ appliances are installed in accordance with 7.1.6.3.

Unless otherwise specified hereafter, Type C₁₁ and C₃₁ appliances are installed in accordance with 7.1.6.3 but connected to ducts of the maximum length specified by the manufacturer.

7.3.5.2 Test procedure

The appliance is initially adjusted to the nominal heat input in accordance with 7.1.3.2.

The products of combustion shall be collected in such a manner as to ensure a representative sample, using a suitable sampling probe (see Figures 6, 7 and 8, as appropriate).

For all tests the sample shall be taken when the appliance has reached thermal equilibrium whilst operating under the specified conditions.

The concentrations of carbon monoxide, CO, carbon dioxide, CO₂, and oxygen, O₂, where appropriate, are measured by a method accurate to within ± 6 % of the reading.

The CO concentration of the dry, air-free products of combustion (neutral combustion) is given by Equation 7.

$$V_{\text{CO,N}} = V_{\text{CO}_2,\text{N}} \times \frac{V_{\text{CO,M}}}{V_{\text{CO}_2,\text{M}}} \quad (7)$$

where

$V_{\text{CO,N}}$ is the carbon monoxide concentration of the dry air-free products of combustion (%);

$V_{\text{CO}_2,\text{N}}$ the calculated carbon dioxide content of the dry air-free products of combustion (%);

$V_{\text{CO,M}}$ and $V_{\text{CO}_2,\text{M}}$ are the carbon monoxide and carbon dioxide concentrations measured in the sample during the combustion test (%).

The values of $V_{\text{CO}_2,\text{N}}$ (neutral combustion) are given for the test gases in Table 8.

Table 8 — $V_{\text{CO}_2,\text{N}}$ values

Gas designation	G 110	G 20	G 21	G 25	G 26	G 30	G 31
$V_{\text{CO}_2,\text{N}}$	7,6	11,7	12,2	11,5	11,8	14,0	13,7

The carbon monoxide concentration of the dry, air-free combustion products ($V_{\text{CO,N}}$) may also be calculated using Equation 8.

$$V_{\text{CO,N}} = \frac{21}{21 - V_{\text{O}_2,\text{M}}} \times V_{\text{CO,M}} \quad (8)$$

where

$V_{\text{CO,N}}$ is the carbon monoxide concentration (%) of the dry, air free combustion products;

$V_{\text{O}_2,\text{M}}$ is the oxygen concentration (%) measured in the sample;

$V_{\text{CO,M}}$ is the carbon monoxide concentration (%) measured in the sample.

The use of Equation 8 is recommended where it gives greater accuracy than the formula based on the CO₂ concentration (see Equation 7).

7.3.5.3 All appliances (still air conditions)

The following tests are carried out under still air conditions.

7.3.5.3.1 Test 1

Without altering the initial burner adjustment the appliance is supplied with the appropriate reference gases (see Table 5) according to its category and the pressure at the appliance inlet increased to the maximum pressure given in 7.1.4.

7.3.5.3.2 Test 2

Without altering the initial burner adjustment, the appliance is supplied with the appropriate reference gases (see Table 5) according to its category with the pressure at the appliance inlet reduced to 70 % of the normal pressure or the minimum pressure given in 7.1.4, whichever is the lower.

7.3.5.3.3 Test 3

Without altering the initial burner adjustment, the appropriate incomplete combustion limit gases are substituted successively for the reference gas and the pressure at the appliance inlet increased to the maximum pressure given in 7.1.4. It is checked that the requirements of 6.1.5.1 are assured.

Where necessary, the appropriate sooting limit gases are substituted successively for the incomplete combustion limit gases and the appliance is operated for three cycles of 30 min on and 30 min off. Following the test the appliance is inspected for soot deposition within the heat exchanger.

7.3.5.3.4 Test 4

Without altering the initial burner adjustment, the appliance is supplied with the appropriate reference gases (see Table 5) according to its category and operated at the nominal heat input.

The test is carried out with the appliance supplied with electricity at a voltage of 85 % of the minimum and then at a voltage of 110 % of the maximum of the voltage range stated by the manufacturer.

7.3.5.4 Special conditions

7.3.5.4.1 Type B₁₁ and B₄₁ appliances

Without altering the initial burner adjustment, the appliance is supplied with the appropriate reference gases (see Table 5) according to its category and operated at the nominal heat input.

A first test is carried out with the flue blocked.

A second test is carried out by applying a continuous down-draught of 3 m/s and 1 m/s within the test flue using a suitable down-draught apparatus (see Figure 2).

The combustion products are collected in such a manner as to ensure a representative sample using a suitable device located within the draught diverter.

7.3.5.4.2 Type C₁₁ appliances

The combustion products are sampled under the conditions of test given in 7.3.4.2.4.2. The average of the nine highest CO values noted in 7.3.4.2.4.2 is determined and its compliance with the requirement of 6.1.5.2.2 verified.

7.3.5.4.3 Type C₃₁ appliances

The combustion products are sampled under the conditions of test given in 7.3.4.2.4.3. The average of the nine highest CO values noted in 7.3.4.2.4.3 is determined and its compliance with the requirement of 6.1.5.2.3 verified.

7.3.5.5 Other pollutants

7.3.5.5.1 General

The appliance is installed as specified in 7.3.5.1.

For appliances intended to use second and third family gases, the tests are carried out with reference gas G 20. For appliances intended to use only G 25 as the reference gas, the tests are carried out with G 25. For appliances intended to use only third family gases, the tests are carried out with reference gas G 30. For appliances intended to use propane only, the tests are carried out with reference gas G 31.

The appliance is adjusted to its nominal heat input and, where appropriate, to other heat inputs provided by the controls.

Then NO_x measurements are carried out when the appliance is at thermal equilibrium, conforming with details as given in CR 1404.

The reference conditions for the combustion air are:

- a) temperature 20 °C;
- b) humidity: 10g H₂O/kg air.

If the test conditions are different from these reference conditions, it will be necessary to correct the NO_x values using Equation 9.

$$NO_{x,0} = NO_{x,m} + \frac{0,02NO_{x,m} - 0,34}{1 - 0,02(h_m - 10)}(h_m - 10) + 0,85(20 - T_m) \quad (9)$$

where

NO_{x,0} is the value of NO_x corrected to the reference conditions expressed in mg/kWh;

NO_{x,m} is the NO_x measured at h_m and T_m in mg/kWh in the range 50 mg/kWh to 300 mg/kWh;

h_m is the humidity during the measurement of NO_{x,m} in g/kg in the range 5 g/kg to 15 g/kg;

T_m is the ambient temperature during the measurement of NO_{x,m} in °C in the range 15 °C to 25 °C.

The measured NO_x values are weighted in accordance with 7.3.5.5.2. It is checked that the weighted NO_x value does not exceed the limit stated in 6.1.5.3.

For the calculation of conversions of NO_x, see Annex H.

7.3.5.5.2 Weighting

7.3.5.5.2.1 General

The measured NO_x values are weighted using Equations 10 to 17 which take into account the efficiency of the appliance, its heat capacity and its usage characteristics.

7.3.5.5.2.2 On/Off appliances

$$E_{Q_n} = \frac{9\eta_{ref}}{10\eta_{Q_n}} \quad (10)$$

7.3.5.5.2.3 High/low appliances

$$\text{with } Q_{\min} \geq 60 \% \quad 0,2E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,8E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (11)$$

$$\text{with } 60 \% > Q_{\min} \geq 50 \% \quad 0,25E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,75E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (12)$$

$$\text{with } 50 \% > Q_{\min} \geq 40 \% \quad 0,33E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,67E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (13)$$

$$\text{with } 40 \% > Q_{\min} \geq 30 \% \quad 0,5E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,5E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (14)$$

$$\text{with } Q_{\min} < 30 \% \quad E_{Q_n} = \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} \quad (15)$$

7.3.5.5.2.4 Modulating appliances

$$\text{with } Q_{\min} \geq 60 \% \quad 0,2E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,8E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (16)$$

$$\text{with } Q_{\min} < 60 \% \quad 0,2E_{Q_n} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_n}} + 0,4E_{Q_{60}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{60}}} + 0,4E_{Q_{\min}} \times \frac{9\eta_{\text{ref}}}{10\eta_{Q_{\min}}} \quad (17)$$

where

- E_{Q_n} is the emission figure at the nominal heat input;
- $E_{Q_{\min}}$ is the emission figure at the minimum heat input;
- $E_{Q_{60}}$ is the emission figure at 60 % of the nominal heat input;
- η_{ref} is the reference efficiency (i.e. the applicable efficiency requirement stated in 6.2);
- η_{Q_n} is the efficiency at nominal heat input;
- $\eta_{Q_{\min}}$ is the efficiency at minimum heat input;
- η_{60} is the efficiency at 60 % of the nominal heat input.

NOTE See also 6.2, where Q_{\min} is understood to be any heat input lower than the nominal heat input, and for which both the efficiency and the NO_x emission figure are measured.

7.3.6 Overheat cut-off device

7.3.6.1 Test 1

7.3.6.1.1 General

The appliance is installed as described in 7.1.6 and supplied with a typically distributed gas (see 7.1.3.1) or an appropriate reference gas corresponding to its category and operated within $\pm 2\%$ of the manufacturer's maximum nominal heat input. Any air temperature control or air flow control devices are rendered inoperative.

Dependent on the appliance design and test suitability, then carry out the test as described in 7.3.6.1.2, 7.3.6.1.3 or 7.3.6.1.4.

7.3.6.1.2 Appliances designed to be connected to distribution ductwork or appliances where the air flow static pressure is designed to be ≥ 100 Pa

Any air outlet louvres are set to give the least possible deflection of the delivered air. A duct of 1,0 m in length having the same cross section and dimensions as the appliance outlet shall be connected to each outlet (for the purposes of this test the manufacturer shall supply the necessary duct).

The open end of the duct is fitted with a device that will symmetrically reduce the cross sectional area of the duct outlet.

At the centre of the open end of the duct a single thermocouple or similar device is placed to measure the temperature of the air leaving the appliance.

The appliance is operated and the air flow is gradually reduced, using the restrictor device, until the overheat cut-off device operates to turn off the burner and the air temperature is noted.

The overheat cut-off device is then reset as soon as it is possible to do so and the test is repeated.

If the temperature recorded is higher than the first recorded temperature then the test is repeated until the worst condition is reached.

7.3.6.1.3 Appliances designed to be free blowing into the heated space and fitted with a single outlet

Any air outlet louvres are set to give the least possible deflection of the delivered air. A duct of 1,0 m in length having the same cross section and dimensions as the appliance outlet shall be connected to the outlet (for the purposes of this test the manufacturer shall supply the necessary duct).

Sufficient thermocouples, or similar devices are placed at 0,5 m from the appliance outlet and parallel to the plane of that outlet within the duct and positioned to give the average temperature of the delivered air. Five thermocouples in the shape of a cross will normally be suitable.

The appliance is operated and the air flow is gradually reduced, by reducing the voltage supply to the fan or other suitable means, until the overheat cut-off device operates to turn off the burner and the average air temperature is noted.

The overheat cut-off device is then reset as soon as it is possible to do so and the test is repeated.

If the temperature recorded is higher than the first recorded temperature then the test is repeated until the worst condition is reached.

7.3.6.1.4 Appliances designed to be free blowing into the heated space and fitted with multiple outlets

Any air outlet louvres are set to give the least possible deflection of the delivered air.

Sufficient thermocouples, or similar devices, are placed to measure the average air temperature at each outlet and in the plane of that outlet. Five thermocouples in the shape of a cross will normally be suitable.

The appliance is operated and the air flow is gradually reduced by progressively closing off the air inlet to the fan in a symmetrical manner, or other suitable means, until the overheat cut-off device operates to turn off the burner and the average air temperature is noted.

The overheat cut-off device is then reset as soon as it is possible to do so and the test is repeated.

If the temperature recorded is higher than the first recorded temperature then the test is repeated until the worst condition is reached.

7.3.6.2 Test 2

The appliance is installed in accordance with 7.1.6.

The air temperature control and the air distribution fan are rendered inoperative.

The appliance is operated from cold utilising a typically distributed gas (see 7.1.3.1) or an appropriate reference gas corresponding to its category and operated within $\pm 2\%$ of the manufacturer's maximum nominal heat input.

The appliance is operated until the overheat control operates to cut off the gas to the main burner, after which the control is reset as soon as possible in order to re-ignite the burner(s). The appliance is cycled on the overheat control for sufficient time to ensure that the worst condition has been reached.

7.3.7 Heat exchanger thermal cycling

Prior to the test being carried out, the heat exchanger is carefully examined and any manufacturing abnormalities noted (e.g. tool damage, welding faults, careless assembly, etc.). Any such abnormalities are not considered in the final examination of the heat exchanger.

The appliance is installed under the conditions of 7.1.6 and operated at the normal pressure using an appropriate reference gas.

A thermocouple wired to an independent control is attached to the body of the overheat cut-off device. The air temperature control device is disconnected and the appliance is operated until the overheat cut-off device operates to cut off the gas to the main burner. The temperature sensed by the thermocouple at the moment of shut-off is recorded by the independent control.

The overheat cut-off device is then disconnected and replaced by the independent control set to shut the appliance down at a temperature of 10 K above the temperature of the thermocouple previously recorded.

NOTE 1 If an appliance is fitted with a resettable temperature limiter (overheat control device) in addition to the overheat cut-off device, the former may be used as the basis for conducting the test (i.e. fixed at a temperature of 10 K above its set point).

The appliance is then operated with the gas on and the air distribution fan off until the independent control shuts the appliance down. The air distribution fan is then switched on and run for 3,5 min.

The cycle is repeated 5 000 times.

If components other than the heat exchanger are adversely affected during the thermal cycling test, action shall be taken to safeguard such components and avoid deleterious effects on the heat exchanger.

NOTE 2 If it can be shown that either the physical form of the heat exchanger, or the type of control adopted, make such a test inappropriate, an equivalent test may be devised and agreed by negotiation between the manufacturer and the notified body.

7.4 Efficiency

7.4.1 General conditions of test

7.4.1.1 Principle of method

The thermal efficiency is determined by the flue loss method from measurements of CO₂ concentration and the temperature of the products of combustion.

7.4.1.2 Test room

The room shall be adequately ventilated but free from draughts likely to affect the performance of the appliance. The room temperature shall be maintained at (20 ± 5) °C and, during the course of a test, it shall not vary by more than 2 K.

7.4.1.3 Preparation of appliance


The appliance is installed in accordance with 7.1.6 and operated, in accordance with the manufacturer's instructions, with reference gas (see Table 5) except that Type C₃₁ appliances are installed with combustion air and combustion products ducts of the shortest length declared by the manufacturer.

7.4.2 Test conditions

The appliance is supplied with typical distributed gas(es) or the reference test gas(es) corresponding to its category and operated within ± 2 % of the specified heat input(s) using the minimum delivered air flow declared by the manufacturer.

The CO₂ concentration and the temperature of the combustion products are measured by means of a suitable probe, incorporating a temperature-measuring device, located in the flue system after the draught diverter or combustion products duct, as appropriate. The sampling rate of combustion products for the measurement of temperature is approximately 100 l/h.

For Type B₁₁ and Type B₄₁ appliances, the test probe to be used is as shown in Figure 6 and is positioned 800 mm above the flue outlet connection on the appliance.



Key

1	thermocouple
D	sampling probe radius
d_1	$0,97 D$
d_2	$0,90 D$
d_3	$0,83 D$
d_4	$0,75 D$
d_5	$0,66 D$
d_6	$0,56 D$
d_7	$0,43 D$
d_8	$0,25 D$


Figure 6 — Sampling probe for Type B₁₁, B₄₁ and C₃₁ appliances

For Type C₁₁ appliances, the test probe to be used is as shown in Figure 7. Where possible, it is positioned as shown in Figure 8.

NOTE For Type C₁₁ appliances where the aforementioned location is not appropriate, the sampling position will be by agreement between the manufacturer and the test authority, sufficient measurements being taken to ensure consistency of results.

For Type C₃₁ appliances, the test probe to be used is as shown in Figure 6. It is positioned 800 mm above the flue outlet connection on the appliance.

Dimensions in millimetres



NOTE 1 The material is stainless steel with a polished finish.

NOTE 2 Dimension Y should be chosen according to the diameter of the air inlet duct and its insulation.

NOTE 3 Dimensions for 6 mm diameter probe (suitable for product outlet ducts of diameter (D) over 75 mm) are:

- a) outside diameter of probe (d) - 6 mm;
- b) wall thickness - 0,6 mm;
- c) diameter of sampling holes (x) - 1,0 mm;
- d) twin bore ceramic sleeve - Ø 3 mm x 0,5 mm bore;
- e) thermocouple wire - Ø 0,2 mm.


For products outlet ducts less than 75 mm diameter a smaller probe should be used with d and x chosen such that:

- f) the area obstructed by the probe is less than 5 % of the cross section of the duct;
- g) the total area of the sampling holes is less than three-quarters of the cross section of the probe.

Key

- A chromel/plumel thermocouple wire
- B insulating cement
- C twin bore ceramic sleeve
- D sampling holes

Figure 7 —Sampling probe for Type C₁₁ appliances



Key

- 1 lead to temperature indicator
- 2 to sampling pump

Figure 8 —Sampling position for Type C₁₁ appliances

7.4.3 Test procedure

With the appliance installed and adjusted as described in 7.4.1.3, the appliance is operated for a sufficient time to reach thermal equilibrium. Measurements are then made of the temperature and the CO₂ concentration of the combustion products and of the combustion air.

The gas rate is measured by timing an integral number of revolutions of the gas meter over a period of at least 100 s.

7.4.4 Accuracy of measurement

Measurements are made to the accuracy shown in Table 9.

Table 9 — Measurement accuracy

Quantity measured	Measurement accuracy
Combustion air temperature	± 0,5 °C
Combustion products temperature	± 2 °C
CO ₂ concentration of the combustion air and the combustion products	± 6 % of the sample concentration (%)
Calorific value	± 0,5 %

7.4.5 Calculation of efficiency

V_f is calculated from the volume of CO₂ (V_{CO_2}) produced by the combustion of 1 m³ of gas (see Table 10), and from the CO₂ concentration of the products of combustion ($V_{CO_2,M}$) as given by Equation 18.

$$V_f = 100 \frac{V_{CO_2}}{V_{CO_2,M}} \quad (18)$$

Table 10 — V_{CO_2} values

Gas designation	V_{CO_2}
G 110	0,26
G 120	0,32
G 20	1
G 25	0,86
G 30	4
G 31	3

The net efficiency, η_{net} , (in %) is given by Equation 19.

$$\eta_{net} = 100 - (q_1 + q_2) \quad (19)$$

where

$$q_1 = C_1 V_f \left(\frac{t_2 - t_1}{H_i} \right) 100$$

and

$$q_1 = 0,077(t_2 - t_1) \left(\frac{H_s - H_i}{H_i} \right)$$

where

q_1 is the heat of the dry products of combustion (percentage of heat released per unit volume of gas);

q_2 is the heat of the water vapour contained in the products of combustion (percentage of heat released per unit volume of gas);

C_1 is the mean specific heat of the dry products of combustion in MJ/m³·K (see Figure 9);


t_1 is the average combustion air temperature in °C;

t_2 is the average temperature of the products of combustion in °C;

H_i is the net calorific value of the gas at 1 013,25 mbar and 15 °C, dry in MJ/m³;

H_s is the gross calorific value of the gas at 1 013,25 mbar and 15 °C, dry in MJ/m³;

V_f is the volume of dry products of combustion per unit volume of gas in m³.



Key

- 1 % CO₂ in combustion products minus % CO₂ in air
- 2 mean specific heat of dry products of combustion in MJ/m³·K
- 3 temperature of combustion products in °C

Figure 9 — Mean specific heat of dry products of combustion

7.4.6 Supplementary test for appliances with a modulating or high/low control

The test is carried out and the efficiency measured as specified in 7.4.1, 7.4.2, 7.4.3, 7.4.4 and 7.4.5, with the appliance adjusted to give the minimum rate.

It is checked that the requirement of 6.2 is met.

8 Marking and instructions

8.1 Marking of the appliance

8.1.1 Description

Appliances are described by their:

- a) category;
- b) nominal input, or range of adjustable inputs.

8.1.2 Data plate

The appliance shall carry one or more data plates and/or labels that are firmly and durably attached to the appliance such that the information given is visible to, and can be read by, the installer. The data plate(s) and/or label(s) shall give at least the following information in indelible³⁾ characters:

- a) the manufacturer's⁴⁾ name and address;
- b) the nominal heat input and, where necessary, the range of input for an appliance with an adjustable input, expressed in kW, stating whether it is based on net or gross calorific value;
- c) the trade name of the appliance;
- d) the serial number;
- e) the Product Identification Number (PIN) of the notified body;
- f) the commercial identification of the appliance;
- g) the type of gas in relation to the pressure and/or the pressure couple for which the appliance has been adjusted; any pressure indication shall be identified in relation to the corresponding category index; if an intervention is necessary on the appliance in order to change from one pressure to the other within a pressure couple of the third family, only the pressure corresponding to the current adjustment of the appliance shall be indicated;
- h) the direct country or countries of destination of the appliance;
- i) the appliance category or categories: if more than one appliance category is specified, each of these categories shall be identified in relation with the appropriate direct country or countries of destination;
- j) the setting pressure for regulated appliances;

3) The indelibility of the marking is checked by a test carried out in accordance with 7.14 of EN 60335-1:2002.

4) "Manufacturer" means the person, organization or company who assumes responsibility for designing and manufacturing a product with a view to placing it on the market on their own behalf within the EU.

- k) the nature and voltage of the current used and the maximum electrical input power used (volts, amperes, frequency and kilowatts) for all intended electrical supply conditions.

No other information shall be included on the appliance if this could lead to confusion with regard to the current state of adjustment of the appliance, the corresponding appliance category (or categories) and the direct country (or countries) of destination.

For an appliance with an adjustable nominal input, there shall be room for the installer to durably mark the nominal heat input value for which it has been adjusted on commissioning.

8.1.3 Other marking

The appliance shall be marked with:

"This appliance must be installed in accordance with the rules in force, and used only in a sufficiently ventilated space. Consult instructions before installation and use of this appliance."

8.2 Marking of the packaging

The packaging shall show at least:

- a) the type of gas in relation to the pressure and/or the pressure couple, for which the appliance has been adjusted; any pressure indication shall be identified in relation to the corresponding category index; if an intervention is necessary on the appliance in order to change from one pressure to the other within a pressure couple of the third family, only the pressure corresponding to the current adjustment of the appliance shall be indicated;
- b) the direct country or countries of destination of the appliance;
- c) the appliance category or categories: if more than one appliance category is specified, each of these categories shall be identified in relation with the appropriate country or countries of destination.

In addition, it shall be marked with :

"This appliance must be installed in accordance with the rules in force, and used only in a sufficiently ventilated space. Consult instructions before installation and use of this appliance."

No other information shall be included on the packaging if this could lead to confusion with regard to the current state of adjustment of the appliance, the corresponding appliance category (or categories) and the direct country (or countries) of destination.

8.3 Utilization of symbols on the appliance and packaging

8.3.1 Electrical supply

The marking concerning electrical values shall be in conformity with EN 60335-1.

8.3.2 Type of gas

In order to represent all of the category indices corresponding to the adjustment of an appliance, the symbol of the reference gas shall be used which is common to all of these indices, in accordance with Table 11.

In order to satisfy the needs expressed by CEN members it is permitted that their countries declared means of identification may be included, in addition to the symbol. These additional means are given in Annex D.

Table 11 — Gas type symbol

Gas type symbol		Corresponding category index
First family ^{a)}	G 110	1a
	G 120	1b
	G 130	1c
Second family	G 20	2H, 2E, 2E+, 2Esi ^{b)} , 2Er ^{b)} , 2ELL ^{b)}
	G 25	2L, 2Esi ^{c)} , 2Er ^{c)} , 2ELL ^{c)}
Third family	G 30	3B/P, 3+ ^{d)} , 3B
	G 31	3+ ^{e)} , 3P
<p>^{a)} If, in its current state of adjustment, the appliance can use gases from different groups, all the reference gases corresponding to these groups shall be indicated.</p> <p>^{b)} When the appliance is adjusted for G 20.</p> <p>^{c)} When the appliance is adjusted for G 25.</p> <p>^{d)} Only applies to appliances which do not need any adjustment between G 30 and G 31, or to appliances which need an adjustment and which are adjusted for G 30.</p> <p>^{e)} Only applies to appliances which need an adjustment between G 30 and G 31, and which are adjusted for G 31.</p> <p>^{f)} For the appliances which need an adjustment between G 30 and G 31, the label concerning the adjustment to the other gas and the other pressure of the pressure couple shall be supplied with the technical instructions.</p>		

8.3.3 Gas supply pressure

The gas supply pressure can be expressed uniquely by the numerical value using the unit (mbar). Nevertheless, if it is necessary to explain this value, the symbol "p" shall be used.

8.3.4 Country of destination

In accordance with EN ISO 3166-1, the names of countries shall be represented by:

AT	Austria	IE	Ireland
BE	Belgium	IS	Iceland
BG	Bulgaria	IT	Italy
CH	Switzerland	LT	Lithuania
CY	Cyprus	LU	Luxembourg
CZ	Czech Republic	LV	Latvia
DE	Germany	NL	Netherlands
DK	Denmark	MT	Malta
EE	Estonia	NO	Norway
ES	Spain	PL	Poland
FI	Finland	PT	Portugal
FR	France	RO	Romania
GB	United Kingdom	SE	Sweden
GR	Greece	SI	Slovenia
HU	Hungary	SK	Slovakia

8.3.5 Category

The category can be expressed uniquely by its designation in accordance with EN 437:2003. Nevertheless, if it is necessary to explain it, the term "category" shall be symbolized by "cat".

8.3.6 Other information

The symbols given below are not obligatory, but are recommended under the title "preferential", and to the exclusion of any other symbol, to avoid the use of many and different markings:

- Nominal heat input of a burner: Q_n .
- Nominal heat input of all appliance burners: ΣQ_n .

8.3.7 Emissions

The manufacturer may choose to declare the weighted NO_x emission value or to express it by class as:

- a) Class 1, for values not exceeding 250 mg/kWh;
- b) Class 2, for values not exceeding 200 mg/kWh;
- c) Class 3, for values not exceeding 150 mg/kWh;
- d) Class 4, for values not exceeding 100 mg/kWh;
- e) Class 5, for values not exceeding 50 mg/kWh.

The value or class may be marked on the appliance or contained in the technical data.

8.4 Instructions

8.4.1 General

The instructions shall be written in the official language(s) of the country or countries of destination and shall be valid for that or those countries.

If the instructions are written in an official language that is used by more than one country, the country or countries for which they are valid shall be identified by the codes given in 8.3.4.

Instructions for countries other than those stated on the appliance may be supplied with the appliance, on condition that each set of instructions has the following initial statement:

"These instructions are only valid if the following country code is on the appliance: . . . If this code is not present on the appliance, it is necessary to refer to the technical instructions which will provide the necessary information concerning the modification of the appliance to the conditions of use for the country."

8.4.2 Technical instructions for installation and adjustment

In addition to the information given in 8.2, the technical instructions may include information indicating, where appropriate, that the appliance has been certified for use in countries other than those stated on the appliance⁵⁾. If such information is given, the instructions shall include a warning that modification of the appliance and its method of installation are essential in order to use the appliance safely and correctly in any of these additional countries. This warning shall be repeated in the official language(s) of each of these countries. Furthermore, the instructions shall indicate how to obtain the information, instructions and parts that are necessary for safe and correct use in the countries concerned.

5) Indirect country of destination.

The instructions shall include a statement saying:

"Before installation, check:

- that the local distribution conditions, nature of gas and pressure, and the current state adjustment of the appliance are compatible, and
- that the local electrical supply conditions are compatible with the electrical data given on the data plate."

The technical instructions for installation and adjustment shall explain the installation conditions for the appliance (e.g. on a floor or wall) and its accessories (e.g. room thermostat) they shall state the minimum distance necessary between the appliance surfaces (including surfaces of the POCED in the case of Type B₄, C₁ and C₃ appliances) and any nearby walls, and also any precautions to be taken to avoid overheating the floor, walls or ceiling if these are made from combustible materials. These precautions shall include details of any insulation or sleeve required when a POCED passes through a wall or ceiling made from combustible materials. The instructions shall also state the maximum ambient temperature in which the appliance is designed to operate. They shall include the heat output of the appliance and the NO_x class if declared by the manufacturer.

If the manufacturer claims that the appliance is suitable for use in garages, then the instructions for installation shall take into account the relevant national installation rules.

For Type B₁₁ appliances they specify the minimum flue height. For Type B₄₁, and C₃ appliances, they shall specify the minimum and maximum equivalent resistance⁶⁾.

For Type B₄₁, C₁₁ and C₃₁ appliances, the specification shall include a description of the POCED including any bends, its materials of construction and any critical tolerances (e.g. in length, diameter, thickness, insertion depth) the method of installing the POCED, including any necessary supporting elements, the method of attachment to the building and a statement confirming that the POCED is capable of withstanding its own weight.

They shall also give all relevant information for adjusting the gas rate. They shall also include a table for the appliance category, giving the various calorific values and the gas rate settings, in m³/h in relation to the average conditions of use (15 °C, 1 013,25 mbar) or in kg/h, together with the instructions about how to adjust the air rate.

They shall explain the operations and adjustment to be carried out when converting from one gas to another and, in particular, the markings on the parts and injectors supplied for each of the gases which may be used.

They shall deal with the assembly of parts which are likely to be replaced, and with the greasing of taps, the electric motor and the fan, and with cleaning.

To aid understanding, the technical instructions shall contain a description of the appliance and of the exchangeable or conversion parts with an illustration and, where necessary, a numbered key for identifying the main parts to be cleaned, serviced or replaced.

8.4.3 Instructions for use and maintenance

All the instructions shall be provided by the manufacturer. The instructions for use and maintenance shall provide all the necessary information for the safe and sensible use of the appliance.

6) In the case of Type B₄₁ and C₃₁ appliances the minimum and maximum equivalent resistance corresponds to the POCED supplied or specified by the manufacture with the minimum and maximum resistance to flow. Due account should be taken of the resistance to flow of any terminal supplied or specified by the manufacturer.

In particular, they shall deal with the operations of ignition and extinction, the use of the various controls with which the appliance may be fitted, simple cleaning and maintenance of the appliance, also mentioning, where necessary, the nature of the materials recommended. They shall also stress that a qualified installer is required to install, adjust and, where necessary, convert the appliance for use with other gases.

They shall also state the recommended frequency of periodic servicing.

9 Evaluation of POCED conformity and their associated terminals

9.1 General

The compliance of a POCED and its associated terminal shall be demonstrated by:

- a) initial type testing;
- b) factory production control by the manufacturer, including product assessment.

NOTE The requirements are given in the relevant Tables ZB.1 or ZB.2.

9.2 Type testing

9.2.1 Initial type testing

Initial type testing shall be performed to show conformity to the requirements of this standard.

NOTE The requirements are given in the relevant Tables ZB.1 or ZB.2.

Tests previously performed in accordance with the provisions of this standard (same product, same characteristic(s), test method, sampling procedure, system of attestation of conformity) may be taken into account. In addition, initial type testing shall be performed at the beginning of the production of a new POCED and/or its associated terminal, or at the beginning of a new method of production (where this may affect the stated properties).

Where characteristics are determined on the basis of conformity with other product standards (for metals including coatings, seals and sealants), these characteristics do not need to be reassessed provided that the designer ensures the validity of the results. Products CE marked in accordance with appropriate harmonised European specifications may be presumed to have the performances stated of them, although this does not replace the responsibility of the manufacturer to ensure that the POCED and any associated terminal as a whole is correctly designed and its component products have the necessary performance values.

9.2.2 Further type testing

Whenever a change occurs in the POCED, any associated terminal, the raw material or supplier of the components, or the production process, which would change the tolerances or one or more of the characteristics that are assessed by the requirements, the type tests shall be repeated for the appropriate characteristic(s).

9.2.3 Sampling for type testing

Unless otherwise stated in the particular test method given in Clause 7 of this standard, type testing is carried out utilising a POCED, and any associated terminal, having the minimum and maximum equivalent resistance.

The results of all type tests shall be recorded and held by the manufacturer, until superseded.

9.3 Factory production control (FPC)

9.3.1 General

NOTE 1 A FPC system conforming with the following requirements of the relevant part(s) of EN ISO 9001:2008, and made specific to the requirements of this standard, is considered to satisfy the above requirements.

The manufacturer shall establish, document and maintain a FPC system to ensure that the manufactured products conform to the stated performance characteristics. The FPC system shall consist of procedures, regular inspections and tests and/or assessments and the use of the results to e.g. control raw and other incoming materials or components, equipment, the production process and the product.

The manufacturer is responsible for organising the effective implementation of the factory production control system. Tasks and responsibilities in the production control organisation should be documented and this documentation should be kept up to-date. In each factory the manufacturer may delegate the action to a person having the necessary authority to:

- identify procedures to demonstrate conformity of the product at appropriate stages;
- identify and record any instance of non-conformity;
- identify procedures to correct instances of non conformity.

The manufacturer should draw up and keep up-to-date documents defining the factory production control which he applies. The manufacturer's documentation and procedures should be appropriate to the product and manufacturing process. All FPC systems should achieve an appropriate level of confidence in the conformity of the product. This involves:

- the preparation of documented procedures and instructions relating to factory production control operations, in accordance with the requirements of the reference technical specification;
- the effective implementation of these procedures and instructions;
- the recording of these operations and their results;
- the use of these results to correct any deviations, repair the effects of such deviations, treat any resulting instances of non-conformity and, if necessary, revise the FPC to rectify the cause of non-conformity.

The production control operations shall include some or all of:

- a) the specification and verification of raw materials and constituents;
- b) the controls and tests to be carried out during manufacture according to a frequency laid down;
- c) the verifications and tests to be carried out on finished products according to a frequency which may be laid down in the technical specifications and adapted to the product and its conditions of manufacture.

NOTE 2 Depending on the specific case, it may be necessary to carry out:

- 1) the operations referred to under 9.3.1 b) and 9.3.1 c),
- 2) only the operations under 9.3.1 b); or
- 3) only those under 9.3.1 c).

The operations under 9.3.1 c) centre as much on the intermediate states of the product as on manufacturing machines and their adjustment and equipment. These controls and tests and their frequency are chosen

based on product type and composition, the manufacturing process and its complexity, the sensitivity of product features to variations in manufacturing parameters, etc.

The manufacturer shall have or have available the installations, equipment and personnel which enable him to carry out the necessary verifications and tests. He may, as may his agent, meet this requirement by concluding a sub-contracting agreement with one or more organisations or persons having the necessary skills and equipment.

The manufacturer has responsibility to calibrate or verify and maintain the control, measuring or test equipment in good operating condition, whether or not it belongs to him, with a view to demonstrating conformity of the product with its technical specification. The equipment shall be used in conformity with the specification or the test reference system to which the specification refers.

If necessary, monitoring is carried out of the conformity of intermediate states of the product and at the main stages of its production.

This monitoring of conformity focuses where necessary on the product throughout the process of manufacture, so that only products having passed the scheduled intermediate controls and tests are dispatched.

The results of inspections, tests or assessments requiring action shall be recorded, as any action taken. The action to be taken when control values or criteria are not met shall be recorded.

9.3.2 Equipment

All weighing, measuring and testing equipment shall be calibrated and regularly inspected according to documented procedures, frequencies and criteria.

9.3.3 Raw materials and components

The specifications of all incoming raw materials and components shall be documented, as the inspection scheme for ensuring their conformity.

9.3.4 Product testing and evaluation

The manufacturer shall establish procedures to ensure that the stated values of the characteristics are maintained. An example of a sampling plan for FPC is given in Annex I.

9.3.5 Non-conforming products

The manufacturer shall establish procedures for dealing with non-conforming products.

Annex A (informative)

National situations⁷⁾

A.1 General

In each country in which this standard applies, appliances may be marketed only if they comply with the particular national supply conditions of that country.

In order to permit, both at the time of testing the appliance and at the time of its sale, the correct choice to be made from all the situations covered, the various national situations are summarized in A.2, A.3, A.4, A.5, A.6 and A.7.

A.2 Categories listed in the body of the standard and marketed in different countries

Tables A.1 and A.2 give the national situations concerning the marketing in the various countries of the appliance categories listed in the body of the standard.

The information given in the table indicates only that these categories may be sold throughout the whole of the country concerned and A.3 should be consulted for confirmation.

In all cases of doubt the local gas supplier should be consulted in order to identify the precise category applicable.

7) This annex does not apply to the POCEDS(chimneys).

Table A.1 — Category I (single categories) marketed

Country	I _{2H}	I _{2L}	I _{2E}	I _{2E+}	I _{2N} ^{a)}	I _{2R} ^{a)}	I _{3B/P}	I ₃₊	I _{3P}	I _{3B}	I _{3R} ^{a)}
AT	X						X				
BE				X				X	X		
BG											
CH	X						X	X	X		
CY ^{b)}											
CZ	X						X		X		
DE			X				X		X		
DK	X						X				
EE ^{b)}											
ES	X							X	X		
FI	X						X				
FR	X ^{c)}	X ^{c)}		X			X ^{d)}	X	X		
GB	X							X	X		
GR	X							X	X		
HU ^{b)}	X						X		X	X	
IE	X							X	X		
IS											
IT	X							X			
LT ^{b)}											
LU			X								
LV ^{b)}											
MT ^{b)}											
NL	X ^{c)}	X					X		X		
NO							X				
PL ^{b)}											
PT	X							X	X		
SE	X						X				
SI	X				X	X	X	X	X		X
SK ^{b)}											

^{a)} Category to be deleted if it is not selected by any country.

^{b)} Information on categories to be supplied by new CEN member.

^{c)} Categories applicable only to certain types of appliance, submitted to on site EC verification procedure, Annex II, article 6 of the Gas Appliance Directive (90/396/EEC) (France and Netherlands to clarify if applicable here).

^{d)} Categories applicable only to certain types of appliance specified in the individual standards (France to specify if applicable here).

Table A.2 — Double categories marketed

Country	II _{1a2H}	II _{2H3B/P}	II _{2H3+}	II _{2H3P}	II _{2H3B}	II _{2L3B/P}	II _{2L3P}	II _{2E3B/P}	II _{2E3+B/P}	II _{2E+3+}	II _{2E+3P}	II _{2R3R} ^a
AT		X										
BE												
BG												
CH	X	X	X	X								
CY ^b												
CZ		X		X								
DE								X				
DK	X	X										
EE ^b												
ES			X ^c	X								
FI		X										
FR				X ^d			X ^d		X ^e	X	X	
GB			X	X								
GR		X	X	X								
HU ^b		X		X	X							
IE			X	X								
IS												
IT	X		X									
LT ^b												
LU												
LV ^b												
MT ^b												
NL						X	X					
NO												
PL ^b												
PT			X	X								
SE	X	X										
SI		X	X	X								X
SK ^b												

^a Category to be deleted if it is not selected by any country.

^b Information on categories to be supplied by new CEN member.

^c Appliances of this Category set for Group H gases of the second family may use air and commercial propane gas mixtures where the gross Wobbe index (at 15 °C and 1 013,25 mbar) is between 46 MJ/m³ and 51,5 MJ/m³, at the same supply pressure, without additional tests.

^d Categories applicable only to certain types of appliance, submitted to on site EC verification procedure, Annex II, article 6 of the Gas Appliance Directive (90/396/EEC) (France to clarify if applicable here).

^e Categories applicable only to certain types of appliance specified in the individual standards (France to specify if applicable here).

A.3 Appliance supply pressures corresponding to the categories given in A.2

Table A.3 gives the conditions in the various countries concerning the supply pressures to appliances in the categories given in A.2

Other, higher supply pressures may be necessary and such pressures may be provided after consultation with the appropriate gas supplier(s) in the country(ies) concerned.

Table A.3 — Normal supply pressures

Gas	G 110	G 20	G 25		G 20 + G 25	G 30		G 31			G 30 + G 31	
Pressure (mbar)	8	20	20	25	Couple 20/25	30 28-30	50	30	37	50	Couple 28-30/37	Couple 50/67
Country												
AT		X					X			X		
BE					X					X ^a	X	X
BG												
CH		X					X			X	X	
CY ^{b)}												
CZ		X ^{c)}					X ^{d)}	X	X	X ^{e)}		
DE		X	X			X	X			X		
DK	X	X						X				
EE ^{b)}												
ES		X				X			X	X ^{a)}	X	
FI		X				X		X				
FR					X	X	X ^{a)}		x	X ^{a)}	X	
GB		X ^{f)}				X			X	X	X	
GR		X				X		X	X	X	x	
HU ^{b)}		X ^{g)}				X	X	X		x		
IE		X				X			X		X	
IS												
IT	X	X									X	
LT ^{b)}												
LU		X										
LV ^{b)}												
MT ^{b)}												
NL				X				X		X		
NO						X		X				
PL ^{b)}												
PT		X				X			X		X	
SE	X	X				X		X				
SI		X				X			X		X	
SK ^{b)}												

- a) Only for certain types of non-domestic appliances (countries to clarify).
b) Information on supply pressures to be supplied by new CEN member.
c) Currently 18 mbar.
d) For certain types of industrial appliances (CZ to clarify).
e) For certain types of appliances (CZ to clarify).
f) Normal supply pressure for this appliance: 17,5 mbar.
g) Pressures of 25 mbar and 85 mbar.

A.4 Special categories marketed nationally or locally

A.4.1 General

The national or local conditions of gas distribution (gas composition and supply pressures) lead to the definition of special categories which are marketed nationally or locally in certain countries, as shown in Table A.4.

Table A.4 — Test gases corresponding to categories marketed nationally or locally

Category	Reference gas	Incomplete combustion limit gas	Light back limit gas	Lift limit gas	Sooting limit gas	Country
I _{2Esi} , I _{2Er}	G 20, G 25	G 21	G 222	G 231	G 21	FR
I _{2E(S)B}	G 20, G 25	G 21	G 222	G 231	G 21	BE
I _{2E(R)B}	G 20, G 25	G 21	G 222	G 231	G 21	BE
I _{2ELL}	G 20, G 25	G 21	G 222	G 231, G 271	G 21	DE
I _{2S}	G 25.1	G 26.1	G 222	G 27.1	G 26.1	HU ^a
I _{2HS}	G 20, G 25.1	G 21, G 26.1	G 222	G 27.1	G 21, G 26.1	HU ^a
II _{2Esi3+} II _{2Er3+}	G 20, G 25 G 30	G 21	G 222 G 32	G 231 G 31	G 30	FR
II _{2Esi3P} II _{2Er3P}	G 20, G 25 G 31	G 21	G 222 G 32	G 231 G 271	G 31 G 32	FR
II _{2ELL3B/P}	G 20, G 25, G 30	G 21, G 30	G 222, G 32	G 231 G 271	G 30	DE
II _{2S3B/P}	G 25.1, G 30	G 26.1, G 30	G 32	G 27.1 G 31	G 26.1, G 30	HU ^a
II _{2S3P}	G 25.1, G 31	G 26.1, G 30	G 32	G 27.1, G 31	G 26.1, G 31, G 32	HU ^a
II _{2S3B}	G 25.1, G 30	G 26.1, G 30	G 32	G 27.1, G 31	G 26.1, G 30	HU ^a
II _{2HS3B/P}	G 20, G 25.1 G 30	G 21, G 26.1, G 30	G 222 G 32	G 23, G 27.1, G 31	G 21, G 26.1, G 30	HU ^a
II _{2HS3P}	G 20, G 25.1 G 31	G 21, G 26.1, G 30	G 222 G 32	G 23, G 27.1, G 31	G 21, G 26.1, G 31, G 32	HU ^a
II _{2HS3B}	G 20, G 25.1 G 30	G 21, G 26.1, G 30	G 222 G 32	G 23, G 27.1, G 31	G 21, G 26.1, G 30	HU ^a
III _{1a2H3B/P}	G 110, G 20 G 30	G 21	G 112 G 222, G 32	G 23 G 31	G 30	DK, IT
III _{1c2E+3+}	G 130, G 20 G 30	G 21	G 132 G 222, G 32	G 231 G 31	G 30	FR
III _{1c2E+3P}	G 130, G 20 G 31	G 21	G 132 G 222, G 32	G 231 G 31	G 32	FR
III _{1c2Esi3+} III _{1c2Er3+}	G 130, G 20 G 25, G 30	G 21	G 132 G 222, G 32	G 231 G 31	G 30	FR
III _{1c2Esi3P} III _{1c2Er3P}	G 130, G 20 G 25, G 31	G 21	G 132 G 222, G 32	G 231 G 31	G 32	FR
III _{1ab2H3B/P}	G 110, G 120 G 20, G 30	G 21	G 112 G 222, G 32	G 23 G 31	G 30	SE

^a Hungary to confirm selection.

A.4.2 Definition of special categories

A.4.2.1 General

The definitions of the special categories given in Table A.4 are derived in the same way as those categories listed in 4.2. The characteristics of the gases distributed regionally are given in A.5.

A.4.2.2 Category I

A.4.2.2.1 Appliances designed for the use of gases linked to the first family

Category I_{1b}: appliances using only gases of Group B linked to the first family, at a fixed supply pressure (this category is not used).

Category I_{1c}: appliances using only gases of Group C linked to the first family, at a fixed supply pressure (this category is not used).

Adjustment of the gas rate is optional for the replacement of a gas of one group to a gas of another group within the first family and of the gases which are linked to it.

A.4.2.2.2 Appliances designed for the use of gases of the second family and the gases linked to it

Category I_{2Esi}: appliances capable of using only gases of Group E of the second family, and operating under the appropriate pressure of a pressure couple. The replacement of a gas in the range Es of Group E (Wobbe index between 44,8 MJ/m³ and 54,7 MJ/m³) by a gas in the range Ei of Group E (Wobbe index in the range 40,9 MJ/m³ and 44,8 MJ/m³) or vice versa necessitates a modification to the burner setting and possibly a change of injectors, of calibrated orifices and of the atmosphere control device.

Category I_{2E}: appliances capable of using only gases of Group E of the second family and being able to operate with a pressure couple without adjustment on the appliance. However, specific adjustment of the burner gas rate is optional for the replacement of a gas of the range Es of Group E (Wobbe index between 44,8 MJ/m³ and 54,7 MJ/m³) by a gas of the range Ei of Group E (Wobbe index between 40,9 MJ/m³ and 44,8 MJ/m³). If this adjustment has been carried out, a re-adjustment to the previous setting is then necessary in order to return to the use of a gas in the range Es of Group E.

Category I_{2LL}: appliances using only gases of Group LL linked to the second family, at a fixed supply pressure. On condition that the Wobbe index of the second family gas distributed does not exceed the upper limit of 43,7 MJ/m³, the appliance may be adjusted according to a lower nominal value (this category is not used).

Category I_{2ELL}: appliances capable of using gases of Group E of the second family, and gases of Group LL linked to the second family. The gases of Group E of the second family are used under the same conditions as for Category I_{2E}. The gases of Group LL of the second family are used under the same conditions as for Category I_{2LL}.

Category I_{2S}: appliances using only gases of Group S linked to the second family, at the defined supply pressure.

Category I_{2HS}: appliances using only gases of Group H of the second family and gases of Group S linked to the second family. The Group H second family gases are used under the same conditions as for Category I_{2H}. The Group S second family gases are used under the same conditions as for Category I_{2S}.

A.4.2.3 Category II

A.4.2.3.1 Appliances designed to use gases of the first family or that are linked to it and gases of the second family or that are linked to it

A.4.2.3.2 Appliances designed to use gases of the second family or that are linked to it and gases of the third family

Category II_{2Esi3+}: appliances capable of using gases of Group E of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2Esi}. The third family gases are used under the same conditions as for Category I₃₊.

Category II_{2Esi3P}: appliances capable of using gases of Group E of the second family and gases of Group P of the third family. The second family gases are used under the same conditions as for Category I_{2Esi}. The gases of the third family are used under the same conditions as for Category I_{3P}.

Category II_{2Er3+}: appliances capable of using gases of Group E of the second family and gases of the third family. The second family gases are used under the same conditions as for Category I_{2Er}. The gases of the third family are used under the same conditions as for Category I₃₊.

Category II_{2Er3P}: appliances capable of using gases of Group E of the second family and gases of Group P of the third family. The second family gases are used under the same conditions as for Category I_{2Er}. The gases of the third family are used under the same conditions as for Category I_{3P}.

Category II_{2ELL3B/P}: appliances capable of using gases of Group E of the second family, gases of Group LL linked to the second family and gases of the third family. The second family gases or the gases that are linked to it are used under the same conditions as for Category I_{2ELL}. Gases of the third family are used under the same conditions as for Category I_{3B/P}.

Category II_{2S3B/P}: appliances capable of using gases of Group S linked to the second family and gases of the third family. The gases linked to the second family are used under the same conditions as for Category I_{2S}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category II_{2S3P}: appliances capable of using gases of Group S linked to the second family and gases of Group P of the third family. The gases linked to the second family are used under the same conditions as for Category I_{2S}. The third family gases are used under the same conditions as for Category I_{3P}.

Category II_{2S3B}: appliances capable of using gases of Group S linked to the second family and gases of Group B of the third family. The gases linked to the second family are used under the same conditions as for Category I_{2S}. The third family gases are used under the same conditions as for Category I_{3B}.

Category II_{2HS3B/P}: appliances capable of using gases of Group H of the second family, gases of Group S linked to the second family and gases of the third family. Gases of the second family or gases linked to it are used under the same conditions as for Category I_{2HS}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category II_{2HS3P}: appliances capable of using gases of Group H of the second family, gases of Group S linked to the second family and gases of Group P of the third family. Gases of the second family or gases linked to it are used under the same conditions as for Category I_{2HS}. The third family gases are used under the same conditions as for Category I_{3P}.

Category II_{2HS3B}: appliances capable of using gases of Group H of the second family, gases of Group S linked to the second family and gases of Group B of the third family. Gases of the second family or gases linked to it are used under the same conditions as for Category I_{2HS}. The third family gases are used under the same conditions as for Category I_{3B}.

A.4.2.4 Category III

Category III_{1a2H3B/P}: appliances capable of using gases of Group a of the first family, gases of Group H of the second family and gases of the third family. The first family gases are used under the same conditions as for Category I_{1a}. The second family gases are used under the same conditions as for Category I_{2H}. The third family gases are used under the same conditions as for Category I_{3B/P}.

Category III_{1c2E+3+}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of the third family. The gases linked to the first family are used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2E+}. The third family gases are used under the same conditions as for Category I₃₊.

Category III_{1c2E+3P}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of Group P of the third family. The gases linked to the first family are

used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2E+}. The third family gases are used under the same conditions as for Category I_{3P}.

Category III_{1c2Esi3+}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of the third family. The gases linked to the first family are used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2Esi}. The third family gases are used under the same conditions as for Category I₃₊.

Category III_{1c2Esi3P}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of the third family. The gases linked to the first family are used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2Esi}. The third family gases are used under the same conditions as for Category I_{3P}.

Category III_{1c2Er3+}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of the third family. The gases linked to the first family are used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2Er}. The third family gases are used under the same conditions as for Category I₃₊.

Category III_{1c2Er3P}: appliances capable of using gases of Group c linked to the first family, gases of Group E of the second family and gases of Group P of the third family. The gases linked to the first family are used under the same conditions as for Category I_{1c}. The second family gases are used under the same conditions as for Category I_{2Er}. The third family gases are used under the same conditions as for Category I_{3P}.

Category III_{1ab2H3B/P}: appliances capable of using gases of Group a of the first family, gases of Group b linked to the first family, gases of Group H of the second family and gases of the third family. The first family gases or the gases linked to it are used under the same conditions as for categories I_{1a} and I_{1b}. The second family gases are used under the same conditions as for Category I_{2H}. The third family gases are used under the same conditions as for Category I_{3B/P}.

A.4.3 Gas rate adjusters, aeration adjusters and regulators

This clause has been included to enable CEN members to provide information equivalent to that given in 5.2.2, 5.2.3, 5.2.4 and 5.2.6 in relation to the special categories they have requested, detailed in A.4.1.

A.4.4 Conversion to different gases

This clause has been included to enable certain member states to provide information equivalent to that given in 5.1.1.2 in relation to the special appliance categories listed in A.4.1.

A.5 Test gases corresponding to the special categories given in A.4

The characteristics of the test gases corresponding to the gases distributed nationally or locally and the corresponding test pressures are given in Table A.5 (reference conditions only).

Mixtures of gases of Group a with gases of Groups c or e, where the Wobbe index is between 21,1 MJ/m³ and 24,8 MJ/m³ are also linked to Group a of the first family.

These mixtures may only be used without supplementary tests in appliances in multiple categories including Group a of the first family.

Table A.5 — Test gases corresponding to local situations

Gas family and group		Nature of gas	Designation	Composition Volume %	W_l MJ/m ³	H_l MJ/m ³	W_s MJ/m ³	H_s MJ/m ³	d	Test Pressure mbar	Country
Gases linked to the first family	Group b	Reference Incomplete combustion Sooting	G 120	H ₂ = 47 CH ₄ = 32 N ₂ = 21	24,40	15,68	27,64	17,77	0,4 13	$\rho_n = 8$ $\rho_{min} = 6$	SE
		Light back	G 112	H ₂ = 59 CH ₄ = 17 N ₂ = 24	19,48	11,81	22,36	13,56	0,3 67		
	Group c	Reference (Propane-air)	G 130	C ₃ H ₈ = 26,9 Air = 73,1 ^{a)}	22,14	23,66	24,07	25,72	1,1 42	$\rho_n = 8$ $\rho_{min} = 6$	FR
		Light back	G 132	C ₃ H ₈ = 13,8 C ₃ H ₆ = 13,8 Air ^{a)} = 72,4	22,10	23,56	23,84	25,41	1,1 36		
Gases Linked to the second family	Group LL	Reference	G 25 ²⁾	CH ₄ = 86 N ₂ = 14	37,38	29,25	41,52	32,49	0,6 12	$\rho_n = 20$ $\rho_{min} = 18$ $\rho_{max} = 25$	DE
		Incomplete combustion Sooting	G 26	CH ₄ = 80 C ₃ H ₈ = 7 N ₂ = 13	40,52	33,36	44,83	36,91	0,6 78		
		Flame lift	G 271	CH ₄ = 74 N ₂ = 26	30,94	25,17	34,36	27,96	0,6 62		
	Group S	Reference	G 25.1	CH ₄ = 86 CO ₂ = 14	35,25	29,30	39,11	32,51	0,6 91	$\rho_n = 25$ $\rho_{min} = 20$ $\rho_{max} = 33$ 02 $\rho_n = 85$ $\rho_{min} = 73$ $\rho_{max} = 100$	HU
		Incomplete combustion Sooting	G 26.1	CH ₄ = 80 C ₃ H ₈ = 6 CO ₂ = 14	37,61	32,60	41,58	36,04	0,7 51		
		Lift limit	G 27.1	CH ₄ = 82 CO ₂ = 18	32,70	27,94	36,29	31,00	0,7 30		
Gases of the second family	Range Es of	Reference	G 20 ²⁾	CH ₄ = 100	45,67	34,02	50,72	37,78	0,5 55	$\rho_n = 20$ $\rho_{min} = 17$ $\rho_{max} = 25$	FR
		Incomplete combustion Sooting	G 21	CH ₄ = 87 C ₃ H ₈ = 13	49,60	41,01	54,76	45,28	0,6 84		
		Light back	G 222	CH ₄ = 77 H ₂ = 23	42,87	28,53	47,87	31,86	0,4 43		
	Group E	Lift limit	G 26	CH ₄ = 80 C ₃ H ₈ = 7 N ₂ = 13	40,52	33,36	44,83	36,91	0,6 78		
		Range Ei of Group E	Reference	G 25 ^{b)}	CH ₄ = 86 N ₂ = 14	37,38	29,25	41,52	32,49	0,6 12	$\rho_n = 25$ $\rho_{min} = 20$ $\rho_{max} = 30$
	Light back		G 26	CH ₄ = 80 C ₃ H ₈ = 7 N ₂ = 13	40,52	33,36	44,83	36,91	0,6 78		
	Incomplete combustion Sooting		G 26	CH ₄ = 80 C ₃ H ₈ = 7 N ₂ = 13	40,52	33,36	44,83	36,91	0,6 78		
Group E	Lift limit	G 231	CH ₄ = 85 N ₂ = 15	36,82	28,91	40,90	32,11	0,6 17			

a) Composition of the air (%): O₂ = 20,95; N₂ = 79,05.
b) For the characteristics of the reference gases G 20 and G 25, see Table 3.

A.6 Gas connections in the various countries

Table A.6 shows the national situations concerning the various types of gas connection specified in 5.1.5.

Table A.6 — Permitted inlet connections

Country	Category I ₃₊ , I _{3P} , I _{3B} , I _{3B/P}			Other categories		
	Threaded connections		Other connections	Threaded connections		Other connections
	EN 10226-1 EN 10226-2	EN ISO 228-1		EN 10226-1 EN 10226-2	EN ISO 228-1	
AT	Yes	—	Yes	Yes	—	—
BE	Yes	Yes	Yes	—	Yes	—
BG	—	—	—	—	—	—
CH	Yes	Yes	Yes	Yes	Yes	—
CY	—	—	—	—	—	—
CZ	—	—	—	—	—	—
DE	Yes	—	Yes	Yes	—	—
DK	Yes	Yes	Yes	—	Yes	—
EE	—	—	—	—	—	—
ES	—	—	—	—	—	—
FI	Yes	Yes	Yes	Yes	Yes	—
FR	—	Yes	Yes	—	Yes	—
GB	Yes	—	Yes	Yes	—	Yes
GR	Yes	—	Yes	Yes	—	—
HU	—	—	—	—	—	—
IE	Yes	—	Yes	Yes	—	Yes
IS	—	—	—	—	—	—
IT	Yes	—	Yes	Yes	—	—
LT	—	—	—	—	—	—
LU	—	—	—	—	—	—
LV	—	—	—	—	—	—
MT	—	—	—	—	—	—
NL	Yes	—	—	Yes	—	—
NO	Yes	Yes	Yes	—	—	—
PT	Yes	Yes	Yes	Yes	Yes	Yes
RO	—	—	—	—	—	—
SE	—	—	—	—	—	—
SI	Yes	Yes	Yes	Yes	Yes	Yes
SK	—	—	—	—	—	—

A.7 Flue connections in the various countries

Table A.7 shows the national situations concerning the diameters of standard flue pipes.

Table A.7 — Standard flue pipe diameters

Country	Standard flue pipe diameters (external) in mm																
AT	60	70	80	90	100	110	120	130	140	150	160	180	200				
BE	All diameters acceptable																
BG																	
CH	60	70	80	90	100	110	120	130	150	160	170	180	200				
CY																	
CZ																	
DE	60	70	80	90	100	110	120	130	150	200							
DK	Diameters not standardized																
EE																	
ES																	
FI	90	100	110	130	150	180	200										
FR	66	83	97	111	125	139	153	167	180								
GB	76	102	127	153	metal pipes (all 0, -1 tolerance)												
GR	60	70	80	90	100	110	120	130	150	180	200						
IE	76	102	127	153	metal pipes (all 0, -1 tolerance)												
	84	109	137	162	fibrous cement pipes (all ± 3 tolerance)												
IS																	
IT	60	80	100	110	120	150											
LT																	
LU																	
LV																	
MT																	
NL	60	70	80	90	100	110	130	150	180	200							
NO																	
PL																	
PT	60	85	90	95	105	110	115	120	125	130	135	145	155	205	255	305	355
RO																	
SE																	
SI	60	70	80	90	100	110	120	130	140	150	160	180	200				
SK																	

Annex B (informative)

Equivalence rules⁸⁾

B.1 Conversion to categories within a restricted Wobbe index range

Any appliance belonging to one category may be categorized as an appliance belonging to another category covering a more restricted range of Wobbe index provided that the requirements in 5.1.1, 5.2.2.2, 5.2.2.3 and 5.2.5 are satisfied, that its state of conversion corresponds to that of the country (or countries) of destination and that the information provided on the appliance corresponds to its adjustment.

In principle, this equivalence is recognized without the appliance having to be submitted to new tests.

However, supplementary tests may be necessary using the pressures and the test gases currently in force in the intended country (or countries) of destination:

- a) when the supply pressures are different in the country (or countries) for which the appliance has been tested from those in the intended country of destination; or
- b) when an appliance fitted with adjusters⁹⁾, even though sealed, has been tested under the conditions of the original category with test gases different from those of the country where it is to be sold; or
- c) when the requirements for regulators (see 5.2.5) with respect to the existing category differ from those of the new category.

In all cases these supplementary tests are at most those stated in 6.1.5.1.

EXAMPLE 1 An appliance in category I_{2E} for G 20 at 20 mbar may be categorized as an appliance in category I_{2H} for G 20 at 20 mbar without additional tests. If, however, the pressures are different, the tests specified in 6.1.5.1 shall be carried out, after changing the injectors, if necessary.

EXAMPLE 2 An appliance in category I_{2E+} for G 20 at 20 mbar may be categorized as an appliance in category I_{2H} for G 20 at 20 bar provided that it satisfies the corresponding tests specified in 6.1.5.1 after changing the injectors, if necessary, and after adjusting the regulator in accordance with 5.2.5.

B.2 Conversion to categories within an identical Wobbe index range

Any appliance belonging to one category may be categorized as an appliance belonging to another category covering an identical range of Wobbe index provided that the requirements in 5.1.1, 5.2.2.2, 5.2.2.3 and 5.2.5 are satisfied, that its state of conversion corresponds to that of the country (or countries) of destination and that the information provided on the appliance corresponds to its adjustment.

In principle, this equivalence is recognized without the appliance having to be submitted to new tests.

However, supplementary tests may be necessary using the pressures and the test gases currently in force in the intended country (or countries) of destination:

8) This annex does not apply to the POCEDS(chimneys).

9) Throughout Annex B the word "adjuster" refers to gas rate adjusters and to fixed primary aeration adjusters as appropriate.

- a) when the supply pressures are different in the country (or countries) for which the appliance has been tested from those in the intended country of destination; or
- b) when an appliance fitted with adjusters, even though sealed, has been tested under the conditions of the original category with test gases different from those of the country where it is to be sold; or
- c) when the requirements for regulators (see 5.2.5) with respect to the existing category differ from those of the new category.

In all cases these supplementary tests are at most those stated in 6.1.5.1.

EXAMPLE 1 An appliance in Category I_{2E+} may be categorized as an appliance in Category I_{2Esi} or I_{2Er} provided that it satisfies the tests specified in 6.1.5.1 for the test pressures and the test gases relating to Category I_{2Esi} or I_{2Er} and with the corresponding injectors and adjustments. These adjustments shall take into account the requirements of 5.2.5.

EXAMPLE 2 An appliance in Category I_{2Esi} or I_{2Er} may be categorized as an appliance in Category I_{2E+} provided that it satisfies the tests specified in 6.1.5.1 for the test pressures corresponding to Category I_{2E+} . In addition, any adjusters shall be locked and sealed in the appropriate positions, taking account the requirements of 5.2.5.

NOTE Where the intended country of destination is Belgium, account should be taken of the Special Conditions given in Annex G.

B.3 Conversion to categories within a wider Wobbe index range

An appliance belonging to one category may be categorized as an appliance in another category covering a wider range of Wobbe index if it complies with all the constructional requirements of the proposed new category.

In addition, the appliance shall be submitted to the tests specified in 6.1.5.1 using the test gases and test pressures for the proposed new category. Where appropriate, account shall be taken of the Special Conditions given in Annex G.

Annex C (informative)

Facilities for commissioning and testing¹⁰⁾

C.1 Appliances with automatic ignition of a start-gas flame

To facilitate commissioning:

- a) a manual valve downstream of the main gas safety shut-off valve; or
- b) a removable air-break electrical link other than a disconnection of the electrical wiring (e.g. a fuse holder/cartridge or purpose made link) in the electrical supply to the main gas safety shut-off valves or the main gas control function within a safety shut-off valve; or
- c) an air-break switch requiring the use of a tool for its operation to isolate the electrical supply to the main gas safety shut-off valves or the main gas control function within a safety shut-off valve; or
- d) an air-break switch not requiring the use of a tool for its operation to isolate the electrical supply to the main gas safety shut-off valves or the main gas control function within a safety shut-off valve

should be provided.

In this particular case, where the main gas valve(s) is (are) fitted with a closed position indicator switch, or a proof of closure switch, then the switch should be checked for correct position throughout the start-gas ignition period and subsequent period of main gas isolation. Failure to prove correct positioning should cause safety shut-down.

NOTE 1 Additional circuitry over and above that provided by the control box may be necessary to satisfy requirement C.1 d).

NOTE 2 Designers should be aware that the intention of this requirement is to prevent inadvertent release of the main gas supply at all times that the commissioning engineer is setting or checking the start-gas flame.

All air heaters should be provided with such manual valves as are essential for the normal operation and commissioning of the appliance.

Means should be provided for checking the gas soundness of safety shut-off valves.

Means should be provided for checking the regulator inlet and outlet pressures and the burner manifold pressure.

Connections or test points should be provided for measurement of the flame detector signal on all appliances except those fitted with thermoelectric flame supervision devices.

C.2 Appliances with direct automatic ignition of the main burner

To facilitate commissioning, means should be provided for:

- a) checking the soundness of the gas circuit;
- b) initial checking of the operation of the burner control system while the gas supply is isolated.

A means of achieving this is to fit a manual valve downstream of the safety shut-off valves.

10) This annex does not apply to the POCEDS(chimneys).

Annex D (informative)

Identification of gas types in use in various countries¹¹⁾

Table D.1 — Means of identification of gas types in use in various countries

Type of gas	G 110	G 120	G 130	G 150	G 20	G 25	G 30	G 31
Country code ^{b)}								
AT					Erdgas		Flüssiggas	
BE					Aardgas, Gaz naturel	Aardgas, Gaz naturel	Butaan, Butane	Propaan, Propane
BG								
CH					Erdgas H		Butan	Propan
CY								
CZ								
DE					Erdgas E W _o (12,0 – 15,7) kWh/m ³ 0 °C	Erdgas LL W _o (10,0 – 13,1) kWh/m ³ 0 °C	Flüssiggas B/P Butan	Propan
DK	Bygas				Naturgas		F-Gas	F-Gas
EE								
ES	Gas manufacturado		Aire propanado	Aire metanado	Gas natural		Butano	Propano
FI					Maakaasu, Naturgas		Butaani, Butan	Propaani, Propan
Fr ^{a)}			Air propané/ Air butané		Gaz naturel Lacq	Gaz naturel Groningue	Butane	Propane
GB					Natural Gas		Butane	Propane
GR					Φυσικό Αέριο		Υγραέριο Μείγμα	Προπύλιο
HU								
IE					Natural Gas		Butane	Propane
IS								
IT	Gas di Città				Gas naturale/ Gas metano		GPL	
LT								
LU								
LV								
MT								
NL						Aardgas	Butaan	Propaan
NO							Butan	Propan
PL								
PT					Gás Natural		Butano	Propano
SE								
SI					Zemeljski plin		Utekočinje ni naftni plin (UNP) Butan	Utekočinje ni naftni plin (UNP) Propan
SK								

a) The meaning of the symbol corresponding to the type of gas should be explained in detail in the technical instructions. Concerning the system and its packaging, if an additional marking is intended by the manufacturer to explain the symbol, this text should be in conformity with the description given in this table. In the case of pressure couples, the two descriptions of the family should be mentioned.

b) See 8.3.4 for codes.

11) This annex does not apply to the POCEDS(chimneys).

Annex E (informative)

A-deviations¹²⁾

E.1 General

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CEN/CENELEC member.

This European Standard falls under Directive 90/396/EEC on the approximation of the laws of Member States concerning gas appliances.

A-deviations in an EFTA country are valid instead of the relevant provisions of the European Standard in that country until they have been removed.

E.2 Switzerland

The Swiss law (Ordinance on Air Pollution Control (OAPC) of 1985-12-16 (state on 2009-01-01) is applicable instead of the requirements of 6.1.5 and 6.2 regarding energy efficiency (chimney losses, standby losses) and emissions of CO and NO_x.

¹²⁾ This annex does not apply to the POCEDS(chimneys).

Annex F (normative)

Special national conditions¹³⁾

F.1 General

Special national conditions are national characteristics or practice that cannot be changed even over a long period (e.g. climatic conditions, electrical earthing conditions). If it affects harmonization, it forms part of the European Standard or Harmonization Document.

For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.

F.2 Belgium

Appliances of categories I_{2E+}, I_{2E(R)B} and I_{2E(S)B} marketed in Belgium have to undergo a test for ignition, crosslighting and flame stability with the limit gas G 231 at the minimum pressure of 15 mbar.

F.3 Italy

Appliances of categories I_{3B/P}, II_{2H3B/P} and III_{1a2H3B/P} without pressure regulators marketed in Italy should have successfully undergone a test for flame stability with the limit gas G 31 at the pressure of 45 mbar.

13) This annex does not apply to the POCEDS(chimneys).

Annex G (informative)

National solutions for countries whose national bodies are Affiliate Members of CEN¹⁴⁾

G.1 Categories listed in the body of the standard and marketed in different countries

G.2 Appliance supply pressures corresponding to the categories given in G.1

G.3 Special categories marketed nationally or locally

G.4 Gases and test pressures corresponding to the special categories given in G.3

¹⁴⁾ This annex does not apply to the POCEDS(chimneys).

Annex H (informative)

Calculation of conversions of NO_x¹⁵⁾

Table H.1 — Conversion of the emission value of NO_x for first family gases

$1 \times 10^{-6} = 2,054 \text{ mg/m}^3$ $(1 \times 10^{-6} = 1 \text{ cm}^3/\text{m}^3)$		G 110	
		mg/kWh	mg/MJ
O ₂ = 0 %	$1 \times 10^{-6} =$	1,714	0,476
	$1 \text{ mg/m}^3 =$	0,834	0,232
O ₂ = 3 %	$1 \times 10^{-6} =$	2,000	0,556
	$1 \text{ mg/m}^3 =$	0,974	0,270

Table H.2 — Conversion of the emission value of NO_x for second family gases

$1 \times 10^{-6} = 2,054 \text{ mg/m}^3$ $(1 \times 10^{-6} = 1 \text{ cm}^3/\text{m}^3)$		G 20		G 25	
		mg/kWh	mg/MJ	mg/kWh	mg/MJ
O ₂ = 0 %	$1 \times 10^{-6} =$	1,764	0,490	1,797	0,499
	$1 \text{ mg/m}^3 =$	0,859	0,239	0,875	0,243
O ₂ = 3 %	$1 \times 10^{-6} =$	2,059	0,572	2,098	0,583
	$1 \text{ mg/m}^3 =$	1,002	0,278	1,021	0,284

Table H.3 — Conversion of the emission value of NO_x for third family gases

$1 \times 10^{-6} = 2,054 \text{ mg/m}^3$ $(1 \times 10^{-6} = 1 \text{ cm}^3/\text{m}^3)$		G 30		G 31	
		mg/kWh	mg/MJ	mg/kWh	mg/MJ
O ₂ = 0 %	$1 \times 10^{-6} =$	1,792	0,498	1,778	0,494
	$1 \text{ mg/m}^3 =$	0,872	0,242	0,866	0,240
O ₂ = 3 %	$1 \times 10^{-6} =$	2,091	0,581	2,075	0,576
	$1 \text{ mg/m}^3 =$	1,018	0,283	1,010	0,281

15) This annex does not apply to the POCEDS(chimneys).

Annex I (informative)

An example of a sampling plan

I.1 Sampling plans

I.1.1 General

In this example sampling plans are selected from the tables published in ISO 2859-1.

I.1.2 Acceptable quality level (AQL)

In this example the AQL is decided in relation to the nature of the inspection feature being controlled. For defects classed as Major, the sampling plan is based on an AQL of 4,0.

NOTE Classification of defects should be the responsibility of the person responsible for the manufacturing process.

I.1.3 Inspection level

The inspection level defines the relationship between the batch size and the sample size. In this example all incoming goods are subjected to inspection level II.

I.1.4 Normal, tightened or reduced inspection

In this example the normal inspection is used initially on all incoming materials, after which, the following rules apply:

- a) when ten successive batches have been accepted on original there can be a switch to reduced inspection. This should remain in operation until one batch is rejected, at which point normal inspection is resumed;
- b) when two out of any five successive batches have been rejected on original inspection, there can be a switch to tightened inspection. This should remain in operation until five successive batches have been accepted, at which point normal inspection is resumed.

I.1.5 Single, double, multiple or sequential sampling

Unless otherwise specified, all incoming material should be subjected to single sampling plans.

I.1.6 Batch quality

Once the first four variables have been decided, the sampling plan tables should indicate the amount of samples to be inspected for any given batch quantity.

All information regarding levels of inspection should be indicated where appropriate on the inspection records.

I.2 Inspection levels and procedures

I.2.1 Incoming material

In this example sample inspected to ISO 2859-1 using an AQL = 2,5, general inspection level II, single sampling plan for normal inspection incorporating the switching rules to tighten or reduce inspection if necessary. All mill certification should be checked against the relevant technical specification.

I.2.2 In-process aspects

For all dimensional aspects an inspection feature should be introduced each time the material changes form during the process.

A first inspection should be implemented and verified by the setter or supervisor at each machine operation and from then on the operators should carry out each required dimensional check at a rate of four per batch – unrecorded, using go-no go gauges.

For the purposes of this example this is supplemented by a beginning and end of shift full dimensional check by the line supervisor using measuring equipment. This is a record check, a register of all results being maintained.

I.2.3 Finished goods checks

- a) at the end of the manufacturing process, each unit should be visually inspected for damage;
- b) at the warehouse, once a week, the goods inwards inspector should randomly select four samples from a particular product range and subject each item to full dimensional checks. This should also be carried out to a formalised programme.

Annex ZA (informative)

Relationship between this European Standard and the Essential Requirements of EU Directive 90/396/EEC

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 90/396/EEC.

Once this standard is cited in the Official Journal of the European Union under that Directive and has been implemented as a national standard in at least one Member State, compliance with the clauses of this standard given in Table ZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding Essential Requirements of that Directive and associated EFTA regulations.

Table ZA.1 - Correspondence between this European Standard and the EU Directive 90/396/EEC on the approximation of the laws of Member States concerning gas appliances

Essential Requirement	Subject	Relevant clause(s) in EN 621
1	General conditions	
1.1	Safe design and construction	Whole standard
1.2	Instructions - installer - user Warning notices - appliance - packaging Official language	8.4.2 8.4.3 8.1, 8.3 8.2, 8.3 8.4.1
1.2.1	Installer's instructions contain: - type of gas used - gas supply pressure - fresh air for combustion - products dispersal - forced draught burners	8.1.2, 8.2, 8.4.2 8.1.2, 8.2, 8.4.2 8.1.2, 8.2, 8.4.2 8.4.2 Not applicable
1.2.2	User instructions contain: - all instructions - restrictions on use	8.4.1, 8.4.3 8.4.2
1.2.3	Warning notices state: - type of gas - gas supply pressure - restrictions on use	8.1, 8.2, 8.4 8.1, 8.2, 8.4 8.1.3
1.3	Fittings - manual valves - regulators - multifunctional control - flame supervision device - automatic valves - automatic burner control systems - thermostats Instructions	5.2.2 5.2.5 5.2.6 5.2.7 5.2.8 5.2.9 5.9 Not applicable
2.1	Fitness for purpose	5.1.2, 6.1.7
2.2	Properties of materials	Foreword, Clause 1
3.1.1	Durability	5.1.2, 6.1.7

Essential Requirement	Subject	Relevant clause(s) in EN 621
3.1.2	Condensation	5.1.2
3.1.3	Explosion risk	Clause 5
3.1.4	Air/water penetration	Not applicable
3.1.5	Normal auxiliary energy fluctuation - appliance - controls	5.1.12 , 6.1.5.1, 7.3.5.3.4 5.2.6, 5.2.7, 5.2.8, 5.2.9.1
3.1.6	Abnormal auxiliary energy fluctuation - appliance - controls	5.1.12 , 6.1.5.1, 7.3.5.3.4 5.2.6, 5.2.7, 5.2.8, 5.2.9.1
3.1.7	Electrical hazards	5.1.11
3.1.8	Deformation	Not applicable
3.1.9	Safety/control device failure: - regulator - multifunctional control - flame supervision device - automatic shut-off valves - automatic burner control system - thermostats/cut-off device	5.2.5 5.2.6 5.2.7, 5.4 5.2.8, 5.5.2 5.2.9.1, 5.4 5.9
3.1.10	Overruling of safety devices	5.2.1
3.1.11	Pre-set adjuster protection	5.2.2.1, 5.2.3
3.1.12	Levers and setting devices	5.2.4.2, 5.2.9.2
3.2.1	Gas leakage	5.1.6.1, 6.1.1
3.2.2	Gas release during ignition, re-ignition and extinction	5.4, 5.5, 5.6, 6.1.4
3.2.3	Unburned gas accumulation	5.4
3.3	Ignition: ignition, re-ignition and cross-lighting	6.1.4
3.4.1	Flame stability Harmful substances	6.1.4 6.1.5
3.4.2	Combustion products release	6.1.1.2
3.4.3	Combustion products release	Not applicable
3.4.4	Flueless domestic appliances	Not applicable
3.5	Rational use of energy	6.2
3.6.1	Floor, etc. temperatures	6.1.3.2
3.6.2	Temperature of knobs/levers	6.1.3.1
3.6.3	External parts	6.1.3.2
3.7	Foodstuffs and water	Not applicable
Annex II	Certification	Foreword, Clause 1

WARNING — Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

Annex ZB (informative)

Clauses of this European Standard addressing the provisions of the EU Construction Products Directive

ZB.1 Scope and relevant characteristics

This European Standard has been prepared under Mandate M105 “Chimneys, flues and specific products” given to CEN by the European Commission and the European Free Trade Association.

The clauses of this European Standard shown in this annex meet the requirements of the mandate given under the EU Construction Products Directive (89/106/EEC).

Compliance with these clauses confers a presumption of fitness of the chimneys covered by this annex for the intended uses indicated herein; reference shall be made to the information accompanying the CE marking.

WARNING — Other requirements and other EU Directives, not affecting the fitness for intended uses, can be applicable to the chimneys falling within the scope of this European Standard.

NOTE 1 In addition to any specific clauses relating to dangerous substances contained in this standard, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the EU Construction Products Directive, these requirements need also to be complied with, when and where they apply.

NOTE 2 An informative database of European and national provisions on dangerous substances is available at the Construction web site on EUROPA (accessed through http://ec.europa.eu/enterprise/construction/internal/dangsub/dangmain_en.htm).

This annex establishes the conditions for the CE marking of the chimneys intended for the uses indicated in Table ZB.1 and shows the relevant clauses applicable.

This annex has the same scope as Clause 1 of this standard and is defined by Tables ZB.1 and ZB.2.

Table ZB.1 — Scope and relevant requirement clauses

Product: Metal system POCEs as covered in Clause 1 of this standard, except terminals and supports. Intended use: Single- and multi-wall POCEs			
Essential Characteristics	Requirement clauses in this European Standard(s)	Levels and/or classes	Notes
Compressive strength	8.4.2	None	Manufacturer's declaration
Fire reaction	None	None	Not applicable ^a
Resistance to fire Soot fire resistance, integrity E and insulation I	None	None	Not applicable ^{b c}
Classification O	8.4.2	None	Manufacturer's declaration of minimum distance from combustible material
	6.1.3.5	None	Pass/fail criteria
Gas tightness /leakage	6.1.1.2	None	Pass/fail criteria
Flow resistance	8.4.2	None	Manufacturer's declaration of minimum and maximum equivalent resistance
Thermal resistance/	None	None	Not applicable ^d
Dimensioning	8.4.2	None	Manufacturer's declaration
Thermal shock resistance	None	None	Not applicable ^b
Flexural tensile strength	5.1.7.3 8.4.2	None	Pass/ fail criteria. Manufacturer's declared value
Durability against chemicals	5.1.2 6.1.7	None	Pass-fail criteria
Durability against corrosion	5.1.2 6.1.7	None	Pass-fail criteria
Resistance to freeze - thaw	None	None	Not applicable ^e
^a Fire reaction - No requirements for metal POCEs. ^b Soot fire resistance G - is not applicable to gas-fired appliances. ^c Insulation I - is not required for metal POCEs. Integrity E - is not required for metal POCEs. ^d This characteristic is only relevant when it is required to match the chimney with the appliance. The Performance of the POCE is verified as part of the performance testing of the appliance. ^e This characteristic is only relevant to construction materials that absorb water. This standard only applies to appliances with metal POCEs.			

Table ZB.2 — Scope and relevant requirement clauses

Product: Terminals as covered in Clause 1 of this standard			
Intended use: Single- and multi-wall POCEDs			
Essential Characteristics	Requirement clauses in this European Standard(s)	Levels and/or classes	Notes
Flow resistance	8.4.2	None	Manufacturer's declaration

The requirement on a certain characteristic is not applicable in those Member States (MSs) where there are no regulatory requirements on that characteristic for the intended use of the product. In this case, manufacturers placing their products on the market of these MSs are not obliged to determine nor declare the performance of their products with regard to this characteristic and the option "No performance determined" (NPD) in the information accompanying the CE marking (see ZB.3) may be used. The NPD option may not be used, however, where the characteristic is subject to a threshold level.

ZB.2 Procedure(s) for attestation of conformity of [construction products]

ZB.2.1 System(s) of attestation of conformity

The system(s) of attestation of conformity of the POCEDs indicated in Tables ZB.1 and ZB.2 in accordance with the Decision of the Commission 95/467/EC of 27-09-95 amended by the decisions 01/596/EC of 8 January 2001 and 2002/592/EC of 15 July 2002 and as given in Annex III of the mandate for "Chimneys, flues and specific products", is shown in Table ZB.3 for the indicated intended use(s) and relevant level(s) or class(es).

Table ZB.3 — System(s) of attestation of conformity

Product(s)	Intended use(s)	Level(s) or class(es)	Attestation of conformity system(s)
Metal system chimney products	Chimneys	Any	2+
Terminals			4
System 2+: See Directive 89/106/EEC (CPD) Annex III.2.(ii), First possibility, including certification of the factory production control by an approved body on the basis of initial inspection of factory and of factory production control as well as of continuous surveillance, assessment and approval of factory production control.			
System 4: See Directive 89/106/EEC (CPD) Annex III.2.(ii), Third possibility.			

The attestation of conformity of the POCEDs in Tables ZB.1 and ZB.2 shall be based on the evaluation of conformity procedures indicated in Tables ZB.4 and ZB.5 respectively resulting from application of the clauses of this or other European Standard indicated therein.

Table ZB.4 – Assignment of evaluation of conformity tasks for chimneys under system 2+ in Table ZB.1

Tasks		Content of the task	Evaluation of conformity clauses to apply
Tasks under the responsibility of the manufacturer	Factory production control (FPC)	Parameters related to all relevant characteristics of Table ZB.1	9.3
	Initial type testing by the manufacturer	All relevant characteristics of Table ZB.1	9.2
	Possibly testing of samples taken at the factory	All relevant characteristics of Table ZB.1	9.3
Tasks of the Approved body	Certification of the FPC by the FPC certification body on the basis of :	Initial inspection of factory and of FPC	9.3
		Continuous surveillance, assessment and approval of FPC	9.3

Table ZB.5 — Assignment of evaluation of conformity tasks for terminals under system 4 in Table ZB.2

Tasks		Content of the task	Evaluation of conformity clauses to apply
Tasks for the manufacturer	Factory production control (F.P.C)	Parameters related to all relevant characteristics of Table ZB.2	9.3
	Initial type testing	All relevant characteristics of Table ZB.2	9.2

ZB.2.2 EC Certificate and Declaration of conformity

When, in the case of products under system of conformity 2+, compliance with the conditions of this annex is achieved, and once the notified body has drawn up the certificate mentioned below, the manufacturer or his agent established in the EEA shall prepare and retain a declaration of conformity, which entitles the manufacturer to affix the CE marking. This declaration shall include:

- a) name and address of the manufacturer, or his authorised representative established in the EEA, and the place of production;

NOTE 1 The manufacturer may also be the person responsible for placing the product onto the EEA market, if he takes responsibility for CE marking.

- b) description of the product (type, identification, use, etc.), and a copy of the information accompanying the CE marking;

NOTE 2 Where some information required for the declaration is already given in the CE marking information, it does not need to be repeated.

- c) provisions to which the product conforms (i.e. Annex ZB of this EN);
- d) particular conditions applicable to the use of the product (e.g. provisions for use under certain conditions);
- e) the number of the accompanying factory production control certificate;
- f) name of, and position held by, the person empowered to sign the declaration on behalf of the manufacturer or his authorised representative.

The declaration shall be accompanied by a factory production control certificate, drawn up by the notified body, which shall contain, in addition to the information above:

- g) the name and address of the notified body;
- h) the number of the factory production control certificate;
- i) the conditions and period of validity of the certificate, where applicable;
- j) the name of, and position held by, the person empowered to sign the certificate.

The above mentioned declaration and certificate shall be presented in the official language or languages of the Member State in which the product is to be used.

When, in the case of products under system of conformity 4, compliance with the conditions of this annex is achieved, the manufacturer or his agent established in the EEA shall prepare and retain a declaration of conformity (EC Declaration of conformity), which entitles the manufacturer to affix the CE marking. This declaration shall include:

- k) name and address of the manufacturer, or his authorised representative established in the EEA, and the place of production;

NOTE 3 The manufacturer may also be the person responsible for placing the product onto the EEA market, if he takes responsibility for CE marking.

- l) description of the product (type, identification, use, etc.), and a copy of the information accompanying the CE marking;

NOTE 4 Where some information required for the declaration is already given in the CE marking information, it does not need to be repeated.

- m) provisions to which the product conforms (i.e. Annex ZB of this EN), and a reference to the ITT report(s) and factory production control records (if appropriate);
- n) particular conditions applicable to the use of the product (e.g. provisions for use under certain conditions);
- o) name of, and position held by, the person empowered to sign the declaration on behalf of the manufacturer or his authorised representative.

ZB.3 CE marking and labelling

The manufacturer or his authorised representative established within the EEA is responsible for the affixing of the CE marking.

The CE marking symbol to affix shall be in accordance with Directive 93/68/EC and shall be shown on the appliance Data Badge. The following information shall accompany the CE marking symbol and may be on the Data Badge, the packaging, in the appliance Installation instructions or as a separate insert with the appliance instruction pack. Where it is not possible for this information to appear with the CE marking symbol on the appliance Data Badge, the CE marking symbol will be repeated at the head of the information (see Figure ZB.1):

- a) identification number of the certification body (only for products under systems 2+);

NOTE 1 The certification body is the “Notified Body” (notified under the CPD) responsible for the Factory Production Control Certificate (FPC certificate).

- b) name or identifying mark and registered address of the appliance manufacturer;
- c) the last two digits of the year in which the marking is affixed;
- d) number of the factory production control certificate (if relevant);
- e) reference to this European Standard.

Figure ZB.1 gives an example of the information to be given on the product, label, packaging and/or commercial documents.




Figure ZB.1 — Example of CE marking information of a POCED

In addition to any specific information relating to dangerous substances shown above, the product should also be accompanied, when and where required and in the appropriate form, by documentation listing any other legislation on dangerous substances for which compliance is claimed, together with any information required by that legislation.

NOTE 2 European legislation without national derogations need not be mentioned.

NOTE 3 Affixing the CE marking symbol to a product means that it complies with all applicable directives.

Bibliography

- [1] ISO 2859-1, *Sampling procedures for inspection by attributes — Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection*
- [1] EN ISO 6976:2005, *Natural gas — Calculation of calorific values, density, relative density and Wobbe index from composition (ISO 6976:1995 including Corrigendum 1:1997, Corrigendum 2:1997 and Corrigendum 3:1999)*
- [2] EN ISO 3166-1, *Codes for the representation of names of countries and their subdivisions — Part 1: Country codes (ISO 3166-1:2006)*

This page has been intentionally left blank

BSI - British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001. Fax: +44 (0)20 8996 7001 Email: orders@bsigroup.com You may also buy directly using a debit/credit card from the BSI Shop on the Website <http://www.bsigroup.com/shop>

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact Information Centre. Tel: +44 (0)20 8996 7111 Fax: +44 (0)20 8996 7048 Email: info@bsigroup.com

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: +44 (0)20 8996 7002 Fax: +44 (0)20 8996 7001 Email: membership@bsigroup.com

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsigroup.com/BSOL>

Further information about BSI is available on the BSI website at <http://www.bsigroup.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright and Licensing Manager. Tel: +44 (0)20 8996 7070 Email: copyright@bsigroup.com