

BS EN 1434-5:2015



BSI Standards Publication

Heat meters

Part 5: Initial verification tests

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 1434-5:2015. It supersedes BS EN 1434-5:2007 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee CPI/30, Measurement of fluid flow in closed conduits.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.
Published by BSI Standards Limited 2015

ISBN 978 0 580 84656 4

ICS 17.200.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2015.

Amendments/corrigenda issued since publication

| Date | Text affected |
|------|---------------|
|------|---------------|

EUROPEAN STANDARD

EN 1434-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2015

ICS 17.200.10

Supersedes EN 1434-5:2007

English Version

Heat meters - Part 5: Initial verification tests

Compteurs d'énergie thermique - Partie 5: Essais de
vérification primitive

Wärmezähler - Teil 5: Ersteinrichtung

This European Standard was approved by CEN on 5 September 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

| Contents | Page |
|--|-------------|
| European foreword | 3 |
| 1 Scope | 5 |
| 2 Normative references | 5 |
| 3 Terms and definitions | 5 |
| 4 General | 5 |
| 5 Uncertainty of test equipment | 6 |
| 6 Tests to be carried out | 6 |
| 6.1 General | 6 |
| 6.2 Flow sensors | 6 |
| 6.3 Temperature sensor pair | 7 |
| 6.3.1 Error in temperature difference | 7 |
| 6.3.2 Insulation resistance | 7 |
| 6.3.3 Single temperature sensor for smart metering applications | 8 |
| 6.4 Calculator | 8 |
| 6.5 Calculator and temperature sensor pair | 8 |
| 6.5.1 Heating and cooling applications | 8 |
| 6.5.2 Calculator with single temperature sensor for smart metering applications | 9 |
| 6.6 Combined heat meter | 9 |
| 6.7 Complete meter | 9 |
| 7 Documentation to be supplied | 9 |
| Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2004/22/EC, MID | 11 |

European foreword

This document (EN 1434-5:2015) has been prepared by Technical Committee CEN/TC 176 “Heat meters”, the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2016, and conflicting national standards shall be withdrawn at the latest by May 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1434-5:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

EN 1434, *Heat meters* consists of the following parts:

- *Part 1: General requirements*
- *Part 2: Constructional requirements*
- *Part 3: Data exchange and interfaces¹⁾*
- *Part 4: Pattern approval tests*
- *Part 5: Initial verification tests*
- *Part 6: Installation, commissioning, operational monitoring and maintenance*

In comparison to EN 1434-5:2007, the following changes have been made:

- metrological requirements for smart metering applications are added;
- additional functionalities for smart metering applications are added;
- bath constructions are added;
- tests for cooling applications are added;
- single temperature sensor for smart metering are added;
- test for bi-functional meters for change-over between heating and cooling are added.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria,

¹⁾ EN 1434-3 is maintained by CEN/TC 294.

Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard specifies initial verification tests for heat meters. Heat meters are instruments intended for measuring the energy which in a heat-exchange circuit is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The heat meter indicates the quantity of heat in legal units.

Electrical safety requirements are not covered by this European Standard.

Pressure safety requirements are not covered by this European Standard.

Surface mounted temperature sensors are not covered by this European Standard.

This standard covers meters for closed systems only, where the differential pressure over the thermal load is limited.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1434-1:2015, *Heat meters — Part 1: General*

EN 60751, *Industrial platinum resistance thermometers and platinum temperature sensors (IEC 60751)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1434-1:2015 apply.

4 General

Initial verification of a measuring instrument is a series of tests and visual examinations carried out to determine whether an instrument manufactured to replicate a given pattern conforms to that pattern and to regulations, and that its metrological characteristics lie within the limits of the maximum permissible errors. If the instrument passes all tests and examinations, it is given legal character by its acceptance as evidenced by stamping and/or issuance of a certificate of verification.

The provisions of this standard also apply to the re-verification of heat meters.

The instrument shall be tested under rated operating conditions at the extremes and midpoints of its ranges.

Initial verification is divided into metrological, technical and administrative phases.

In tests of a heat meter as a combined instrument, the flow sensor, the temperature sensors and the calculator shall each be tested separately.

Unless otherwise stated in the certificate of pattern approval, the verification shall be carried out in accordance with this standard.

NOTE Modern heat meters are mainly equipped with CMOS microprocessors with a very low power consumption, allowing battery operation. Testing and adjusting of this type of meter needs a completely different approach. Until now, almost every meter type needed its own test equipment to handle the manufacturer's specific requirements. This is a very complicated and expensive way for users of several types of meters and for initial verification institutes. The more different types of heat meters a user has installed, the more testing equipment he may need. An economical testing of several meters should be possible and an easy adaptation to the existing test bench is of great interest.

Since this problem came up, experts have been researching an acceptable solution to it. Details of one example of an acceptable solution are given in “Normierter Wärmezähler Adapter” (Standardised heat meter adapter) Version 1.5 of September 2000, AGFW Merkblatt 6, Band 2, Frankfurt, Germany.

5 Uncertainty of test equipment

Standards, instruments and methods used in verification shall suit the purpose, be traceable to more precise standards and be part of a reliable calibration programme.

The uncertainties associated with these standards, methods and measuring instruments shall always be known. They shall either:

- a) not exceed $1/5$ of the MPE (maximum permissible error) of the EUT (equipment under test),
- or, if exceeding $1/5$ of the MPE,
- b) if the uncertainty is higher than $1/5$ of MPE, the value of the difference between uncertainty and $1/5$ MPE shall be subtracted from MPE, to calculate a new reduced MPE.

It is recommended that option a) is used.

6 Tests to be carried out

6.1 General

If the error determined lies outside the MPE, the test shall be repeated twice. The test is then declared satisfactory if both

- the arithmetic mean of the result of the three tests,

and

- at least two of the test results are within or at the MPE.

The meters shall not exploit the MPE or systematically favour any party. Each individual meter with electronic abilities for adjustments of their error curves, where the errors are aligned into the same sign (\pm) in the complete measuring range, shall only pass the verification assessment if any of the errors does not exceed half of the MPE. Mechanical meters (e.g. Woltman Turbine Meters) with no abilities by electronic adjustments shall be produced as close as possible to zero error.

For information regarding bath constructions, see EN 1434-4:2015, Annex A. For initial verification tests for temperature sensors the recommended ambient temperature is (23 ± 2) °C.

6.2 Flow sensors

The verification of the flow sensor shall be carried out within each of the following flow rate ranges at a liquid temperature of (50 ± 5) °C for heating applications and (15 ± 5) °C for cooling applications.

- a) $q_i \leq q \leq 1,2 q_i$;
- b) $0,1 q_p \leq q \leq 0,11 q_p$;
- c) $0,9 q_p \leq q \leq 1,1 q_p$.

If the pattern approval certificate so provides, the verification may be carried out with cold water in accordance with the procedures laid down in the certificate.

When testing the flow sensors, the guidelines in the pattern approval certificate shall be followed (e.g. requirements for water conductivity, water temperature, straight inlet/outlet tubes).

To enable rapid testing of the flow sensor, it is customary to bypass the output signal used by the calculator. However, for at least one test, this signal shall be included.

Test of flow sensors shall be done above minimum operation pressure specified by the manufacturer with examination of absence of cavitation.

6.3 Temperature sensor pair

6.3.1 Error in temperature difference

The individual temperature sensors of the temperature sensor pair shall be tested, without their pockets, in the same temperature bath at temperatures within each of the three temperature ranges in Table 1.

Table 1 — Test temperature ranges

| Test points | Test temperature range | |
|---|---|---|
| θ_1 | θ_{\min} to $(\theta_{\min} + 10\text{K})$ | |
| θ_2 | $\frac{\theta_1 + \theta_3}{2} \pm 5\text{K}$ | |
| θ_3 | $\theta_{\max} \leq 150\text{ }^\circ\text{C}$ | $(\theta_{\max} - 10\text{K})$ to θ_{\max} |
| | $\theta_{\max} > 150\text{ }^\circ\text{C}$ | $(\theta_{\max} - 20\text{K})$ to θ_{\max} but in any case more than $140\text{ }^\circ\text{C}$ |
| NOTE If specified in the pattern approval certificate, variations in the temperature ranges and the number of temperatures are permissible. | | |

The immersion depth of the sensor under test shall be at least 90 % of the total length.

The determined resistance values shall be used in a system of three equations to calculate the three constants of the temperature/resistance equation of EN 60751 and a curve shall be drawn through the three test points. Thereby the characteristic curve for the temperature sensor is known.

The “ideal” curve using the standard constants of EN 60751 shall be generated. To give the error at any temperature, the “ideal” curve shall be subtracted from the characteristic curve for each temperature sensor.

As a further step, the worst case error of the temperature sensor pair shall be determined over the temperature range and over the temperature difference range specified for the sensors.

For outlet temperatures above $80\text{ }^\circ\text{C}$, only temperature differences over 10 K shall be taken into account.

The error determined as described above shall be within the limits stated in EN 1434-1:2015, 9.2.2.2.

When measuring resistance, the current shall be such, that the power dissipation does not exceed 0,2 mW RMS.

6.3.2 Insulation resistance

The resistance between each terminal and the sheath shall be measured with a test DC-voltage between 10 V and 100 V and under ambient conditions between $15\text{ }^\circ\text{C}$ and $35\text{ }^\circ\text{C}$ and at a relative humidity not exceeding 80 %. The polarity of the test current shall be reversed. In all cases, the resistance shall not be less than 100 M Ω .

6.3.3 Single temperature sensor for smart metering applications

The compliance with the permissible error of the temperature sensor of $\pm 0,7$ K compared to the performance curve according to EN 60751, including the signal cables thereof, shall be tested for each temperature sensor at three typical temperature points for field applications (e.g. 10 °C; 30 °C; 50 °C).

6.4 Calculator

The calculator shall be tested, at least within each of the following temperature difference ranges:

For heating applications:

- a) $\Delta\theta_{\min}$ $\leq \Delta\theta \leq$ $1,2 \Delta\theta_{\min}$
- b) 10 K $\leq \Delta\theta \leq$ 20 K
- c) $\Delta\theta_{\max} - 5$ K $\leq \Delta\theta \leq$ $\Delta\theta_{\max}$

For cooling applications:

- a) $\Delta\theta_{\min}$ $\leq \Delta\theta \leq$ $1,2 \Delta\theta_{\min}$
- b) $0,8\Delta\theta_{\max}$ $\leq \Delta\theta \leq$ $\Delta\theta_{\max}$

The simulated flow rate signal shall not exceed the maximum acceptable by the calculator.

The outlet temperature shall be in the temperature range between (50 ± 5) °C for heating applications and (15 ± 5) °C for cooling applications, if not otherwise stated in the pattern approval certificate.

To enable rapid testing of the calculator, it is customary to by-pass the indicating device of the heat meter. However, for at least one test, the meter's indicating device shall be included.

Additional test for bifunctional meters for change-over systems between heating and cooling:

An example for the switching over from heating to cooling register and reversed is given in EN 1434-1:2015, Figure 1.

It shall be tested that:

- heating energy shall only be recorded at $\Delta\theta > \Delta\theta_{hc}$ and at $\theta_{inlet} > \theta_{hc}$.
- cooling energy shall only be recorded at $\Delta\theta < -\Delta\theta_{hc}$ and at $\theta_{inlet} < \theta_{hc}$.

no heating and cooling energies shall be recorded between $-\Delta\theta_{hc}$ and $\Delta\theta_{hc}$. The general test in this clause shall be performed both for the heating and the cooling function using the correct heat coefficient (depending on installation of the flow sensor in higher respectively lower temperature).

6.5 Calculator and temperature sensor pair

6.5.1 Heating and cooling applications

The sub-assembly of calculator and temperature sensor pair shall be tested using temperature ranges of 6.4 and the temperature difference ranges of 6.3.

Additionally, a final test of the sub-assembly is necessary, with the temperature sensor pair immersed in two temperature regulated baths. The temperature difference of the baths shall be between 3 K and 4 K. The simulated flow rate shall not create a signal exceeding the maximum signal acceptable by the calculator.

If the calculator and temperature sensor pair are tested as an inseparable sub-assembly, it shall be tested in accordance with 6.4.

6.5.2 Calculator with single temperature sensor for smart metering applications

The compliance with the permissible error on temperature indication of the inlet and outlet temperatures compared to the correct value of the absolute temperature of $\pm 1,0$ K shall be tested. The test shall be examined in accordance with 6.3.3 and 6.4.

6.6 Combined heat meter

The flow sensor, the temperature sensor pair and the calculator shall be each tested separately, in accordance with 6.2 to 6.4.

6.7 Complete meter

The verification of the complete meter shall be carried out, at least within each of the following ranges.

For heating applications:

- | | | | | | | |
|----|-----------------------------|--------------------------|---------------------------|-----|-----------------------|------------|
| a) | $\Delta\theta_{\min}$ | $\leq \Delta\theta \leq$ | $1,2 \Delta\theta_{\min}$ | and | $0,9 q_p \leq q \leq$ | $1,1 q_p$ |
| b) | 10 K | $\leq \Delta\theta \leq$ | 20 K | and | $0,1 q_p \leq q \leq$ | $0,11 q_p$ |
| c) | $\Delta\theta_{\max} - 5$ K | $\leq \Delta\theta \leq$ | $\Delta\theta_{\max}$ | and | $q_i \leq q \leq$ | $1,2 q_i$ |

For cooling applications:

- | | | | | | | |
|----|--------------------------|--------------------------|---------------------------|-----|-----------------------|------------|
| a) | $\Delta\theta_{\min}$ | $\leq \Delta\theta \leq$ | $1,2 \Delta\theta_{\min}$ | and | $0,9 q_p \leq q \leq$ | $1,1 q_p$ |
| b) | $0,8\Delta\theta_{\max}$ | $\leq \Delta\theta \leq$ | $\Delta\theta_{\max}$ | and | $0,1 q_p \leq q \leq$ | $0,11 q_p$ |
| c) | $0,8\Delta\theta_{\max}$ | $\leq \Delta\theta \leq$ | $\Delta\theta_{\max}$ | and | $q_i \leq q \leq$ | $1,2 q_i$ |

The outlet temperature shall be in the temperature range of (50 ± 5) °C for heating applications and (15 ± 5) °C for cooling applications, if not otherwise stated in the pattern approval certificate.

To enable rapid testing of the complete meter, it is customary to bypass the indicating device of the heat meter. However, for at least one test, the meter's indicating device shall be included.

Additional test for bifunctional meters for change-over systems between heating and cooling:

An example for the switching over from heating to cooling register and reversed is given in EN 1434-1:2015, Figure 1. It shall be tested that:

- heating energy shall only be recorded at $\Delta\theta > \Delta\theta_{hc}$ and at $\theta_{inlet} > \theta_{hc}$;
- cooling energy shall only be recorded at $\Delta\theta > \Delta\theta_{hc}$ and at $\theta_{inlet} < -\theta_{hc}$.

No heating and cooling energies shall be recorded between $-\Delta\theta_{hc}$ and $\Delta\theta_{hc}$. The general test in this clause shall be performed both for the heating and the cooling function using the correct heat coefficient (depending on installation of the flow sensor in higher respectively lower temperature).

7 Documentation to be supplied

The supplier shall make available data sheets with at least the following information:

- heat meter specification;
- sensor specification;
- type and specification of the battery;

- assembly instruction;
- installation instruction;
- security sealing plan;
- initial functional check and operating instruction;
- test outputs, their use and their relationship to parameters being measured;
- test conditions for initial verification;
- additional qualifying information supplied with the pattern approval certificate (e.g. additional recommended test conditions).

Annex ZA
(informative)

Relationship between this European Standard and the Essential Requirements of EU Directive 2004/22/EC, MID

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 2004/22/EC, MID.

Once this standard is cited in the Official Journal of the European Union under that Directive and has been implemented as a national standard in at least one Member State, compliance with the clauses of this standard given in Table ZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding Essential Requirements of that Directive and associated EFTA regulations.

Table ZA.1 — Correspondence between this European Standard and Directive 2004/22/EC, MID

| Clause(s)/sub-clause(s) of this EN | Essential Requirements (ERs) of Directive 2004/22/EC, MID | Qualifying remarks/Notes |
|------------------------------------|---|-------------------------------|
| | Annex I, Essential Requirements, Definitions: | |
| Scope | Measurand | In scope of standard defined. |
| 6 “Tests to be carried out” | 1.4.1 Basic rules for testing 1.4.2 Ambient humidity | |

WARNING — Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™