

Test methods for primary wound dressings —

Part 2: Moisture vapour transmission rate of permeable film dressings

The European Standard EN 13726-2:2002 has the status of a
British Standard

ICS 11.120.20

National foreword

This British Standard is the official English language version of EN 13726-2:2002.

The UK participation in its preparation was entrusted by Technical Committee CH/117, Medical textiles, to Subcommittee CH/117/1, Test methods for non-wovens for use in compresses, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled "International Standards Correspondence Index", or by using the "Find" facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Health and Environment Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 15 April 2002

Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 9 and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

ICS 11.120.20

English version

Test methods for primary wound dressings - Part 2: Moisture vapour transmission rate of permeable film dressings

Méthodes d'essai pour les pansements primaires en contact avec la plaie - Partie 2: Perméabilité & la vapeur d'eau des pansements comprenant un film perméable

Prüfverfahren für primäre Verbandstoffe (Wundauflagen) - Teil 2: Feuchtigkeitsdurchdringungsrate durchlässiger Folienverbände

This European Standard was approved by CEN on 22 February 2002.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPAISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	page
Foreword.....	3
Introduction.....	4
1 Scope.....	5
2 Terms and definitions.....	5
3 Test methods for moisture vapour transmission rate (MVTR).....	5
3.1 Test conditions.....	5
3.2 MVTR of a wound dressing when in contact with water vapour.....	5
3.3 MVTR of a wound dressing when in contact with liquid.....	7

Foreword

This document EN 13726-2:2002 has been prepared by Technical Committee CEN/TC 205 "Non-active medical devices", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2002, and conflicting national standards shall be withdrawn at the latest by September 2002.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

EN 13726 will consist of the following parts under the general title Test methods for primary wound dressings:

- Part 1 : Aspects of absorbency
- Part 2 : Moisture vapour transmission rate of permeable film dressings
- Part 3 : Waterproofness
- Part 4 : Conformability
- Part 5 : Bacterial barrier properties
- Part 6 : Odour control

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

EN 13726 specifies test methods and does not contain performance requirements. Part 2 of this standard describes test methods for the determination of the moisture vapour transmission rate of permeable film dressings.

Test methods for other aspects of primary wound dressings are described in other parts of EN 13726.

1 Scope

Part 2 of EN 13726 describes test methods recommended for the evaluation of moisture vapour transmission rate of permeable film primary wound dressings.

2 Terms and definitions

For the purposes of this standard the following terms and definitions apply.

2.1

moisture vapour transmission rate (MTVR)

permeability of materials to the passage of water molecules from the skin contact side to the external atmosphere under controlled conditions of humidity and temperature

2.2

permeable wound dressing

wound dressing that permits water vapour to pass from the skin or wound through it to the external atmosphere

2.3

primary wound dressing

material or combination of materials, in any shape, form or size that is intended to remain in direct contact with a wound

NOTE Primary wound dressings are used as mechanical barriers, for the absorption or transmission of exudates, to manage the micro-environment of the wound, and can enable the wound to heal by primary or secondary intent. Devices which have a metabolic, pharmacological or immunological interaction as their primary intent are excluded.

3 Test methods for moisture vapour transmission rate (MVTR)

3.1 Test conditions

Unless otherwise stated, condition the test samples and carry out the tests at a temperature of (21 ± 2) °C and a relative humidity of $60 \% RH \pm 15 \% RH$.

3.2 MVTR of a wound dressing when in contact with water vapour

3.2.1 Significance and use

The test is intended for the evaluation of the MVTR of a wound dressing when it is in contact with water vapour.

This test measures moisture vapour transmission through dressings by mass differential. Entrapment of fluid can lead to serious consequences for skin integrity. Dressings should have sufficient permeability to moisture vapour to prevent fluid collecting under the dressings.

NOTE The test is suitable for use with, for example, thin film wound dressings.

3.2.2 Equipment

3.2.2.1 Five clean, dry cylinders, made of corrosion-resistant material with an internal diameter of $(35,7 \pm 0,1)$ mm (cross-sectional area 10 cm^2) having a flange at each end and able each to accommodate 20 ml of deionised water. (An example of a cylinder that has been found to be adequate is given in Figure 1).

At one end of the cylinder is an annular clamping plate with an orifice area of 10 cm^2 . At the other end of the cylinder is a solid metal plate the full diameter of the flange. A sealing ring is also advisable to ensure an effective seal against the flange. The plates at both ends are clamped in position against the flanges.

3.2.2.2 Balance, capable of weighing 100 g with an accuracy of 0,000 1 g.

3.2.2.3 Humidity meter, capable of detecting whether or not the 20 % RH limit has been exceeded.

3.2.2.4 Oven or incubator, having a circulating fan and capable of maintaining a temperature of $(37 \pm 1) ^\circ\text{C}$, and being of a design to distribute the air evenly throughout the oven or incubator so as to maintain humidity at less than 20 % RH throughout the test.

3.2.2.5 Scalpel, or alternative cutting equipment.

3.2.3 Procedure

3.2.3.1 Using the flange of clamping plate as a template, cut out a sample of the material to be tested.

3.2.3.2 Add sufficient deionised water at room temperature (minimum $20 ^\circ\text{C}$) to leave an air gap of (5 ± 1) mm between the liquid surface and the sample when clamped in place.

3.2.3.3 Place the circular sample exactly over the flange of the test container. Clamp it in place without stretching the sample, using the clamping plate / clamps to give a watertight seal. If the specimen has an adhesive coated surface, place the adhesive side to the cylinder flange. For non-adhesive or pattern coated materials, take care to ensure a complete seal. Repeat the procedure four times so as to prepare five samples.

NOTE To ensure a good seal a small amount of sealant such as petrolatum can be applied to the flange.

3.2.3.4 Weigh and record the mass of the container, sample and liquid (V^{\wedge}) to the nearest 0,000 1 g.

3.2.3.5 Place the container in the oven / incubator at temperature of $(37 \pm 1) ^\circ\text{C}$ with the sample uppermost.

3.2.3.6 After 18 h to 24 h remove the container from the oven / incubator and record the test period (T) to the nearest 5 min.

3.2.3.7 Immediately reweigh the container and sample and liquid and record the mass (W_2) to the nearest 0,000 1 g.

3.2.4 Calculation of results

3.2.4.1 Calculate the MTVR using the formula:

$$X = (W_1 - W_2) \times 1\,000 \times 24 / T$$

where

X is MVTR ($\text{g}\cdot\text{m}^2\cdot 24 \text{ h}^{-1}$);

W_1 is the mass of the container, sample and liquid;

W_2 is the mass of the container, sample and liquid after test period;

T is the test period in hours.

3.2.4.2 Calculate the mean result of at least five samples.

3.2.4.3 Discard values differing by more than 20 % from the mean and repeat the test.

3.2.4.4 The test is invalid if the humidity levels within the oven / incubator rise to more than 20 % RH during the test period.

3.2.5 Test report

The report shall include at least the following information:

- a) type of dressing, including lot number;
- b) any deviations from the test method;
- c) individual and average results;
- d) date of test;
- e) identity of the person(s) who carried out the test.

3.3 MVTR of a wound dressing when in contact with liquid

3.3.1 Significance and use

This test is intended for the evaluation of the MVTR of a waterproof wound dressing when it is in contact with liquid. It measures the MVTR through dressings by mass differential. Entrapment of liquid can lead to serious consequences for skin integrity.

3.3.2 Equipment

- 3.3.2.1 **Five clean, dry cylinders**, as specified in 3.2.2.1.
- 3.3.2.2 **Balance**, as specified in 3.2.2.2.
- 3.3.2.3 **Humidity meter**, as specified in 3.2.2.3.
- 3.3.2.4 **Oven or incubator**, as specified in 3.2.2.4.
- 3.3.2.5 **Cutting equipment**, as specified in 3.2.2.5.

3.3.3 Procedure

- 3.3.3.1 Perform the procedures described in 3.2.3.1 to 3.2.3.4.
- 3.3.3.2 Invert the container and place it in the oven / incubator at temperature of (37 ± 1) °C so that the deionised water is in contact with the sample. Ensure there is a sufficient gap between the surface of the sample and the surface of the oven/incubator shelf to allow good airflow across the surface of the sample.
- 3.3.3.3 After approximately 4 h remove the container from the oven / incubator and record the test period (T) to the nearest 5 min.
- 3.3.3.4 Immediately reweigh the container and sample and record the mass (W_2) to the nearest 0,000 1 g.

3.3.4 Calculation of results

- 3.3.4.1 Calculate the results as described in 3.2.4.1 to 3.2.4.4.
- 3.3.4.2 If the MVTR of the test sample is less than $1\ 000\ \text{gm}^{-2}\ 24\text{h}^{-1}$, repeat the test using a time of 18 h to 24 h in 3.3.3.3.


3.3.5 Test report

The report shall include at least the following information:

EN 13726-2:2002 (E)

- a) type of dressing, including lot number;
- b) any deviations from the test method;
- c) individual and average results;
- d) date of test;
- e) **identity of the person(s) who carried out the test.**

Dimensions in millimetres

**Key**

1 Sealing ring

Figure 1 - Example of a cylinder that has been found to be adequate

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.
Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.
Fax: +44 (0)20 8996 7001. Email: orders@bsi-global.com. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.
Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: info@bsi-global.com.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.
Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.
Email: membership@bsi-global.com.

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means — electronic, photocopying, recording or otherwise — without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager.
Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553.
Email: copyright@bsi-global.com.