



BSI Standards Publication

Pumps — Rotodynamic pumps — Glandless circulators

Part 2: Calculation of energy efficiency index (EEI) for standalone circulators

National foreword

This British Standard is the UK implementation of EN 16297-2:2012. Together with BS EN 16297-1:2012, it supersedes BS EN 1151-1:2006, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee MCE/6, Pumps and pump testing.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012. Published by BSI Standards Limited 2012

ISBN 978 0 580 75132 5

ICS 23.080

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2012.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

ICS 23.080

English Version

Pumps - Rotodynamic pumps - Glandless circulators - Part 2: Calculation of energy efficiency index (EEI) for standalone circulators

Pompes - Pompes rotodynamiques - Circulateurs sans
presse-étoupe - Partie 2: Calcul de l'indice d'efficacité
énergétique (EEI) pour les circulateurs indépendants

Pumpen - Kreiselpumpen - Umwälzpumpen in
Nassläuferbauart - Teil 2: Berechnung des
Energieeffizienzindex (EEI) von externen
Umwälzpumpen

This European Standard was approved by CEN on 18 August 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Symbols and units	5
5 Performance requirements and safety requirements	5
6 Calculation of energy efficiency index (EEI).....	5
6.1 General conditions	5
6.2 Procedure	6
6.2.1 Load profile for calculation of average compensated power input, $P_{L,avg}$	6
6.2.2 Part load operating points	6
6.2.3 Calculation of average compensated power input, $P_{L,avg}$	6
6.2.4 Calibration factor	6
6.2.5 Calculation of energy efficiency index (EEI), ε_{EEI}	6
Annex ZA (informative) Relationship between this European Standard and the requirements of Commission Regulation (EC) No 641/2009	8

Foreword

This document (EN 16297-2:2012) has been prepared by Technical Committee CEN/TC 197 “Pumps”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2013, and conflicting national standards shall be withdrawn at the latest by April 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

This document, together with EN 16297-1:2012, supersedes EN 1151-1:2006.

EN 16297 consists of the following parts under the general title *Pumps — Rotodynamic pumps — Glandless circulators*:

- Part 1: General requirements and procedures for testing and calculation of energy efficiency index (EEI);
- Part 2: Calculation of energy efficiency index (EEI) for standalone circulators;
- Part 3: Energy efficiency index (EEI) for circulators integrated in products.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The European Standard has been prepared under mandate M/469 EN of 22 June 2010 given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Requirements of the EU Directive 2005/32/EC of 6 July 2005 and Commission Regulation (EC) 641/2009 of 22 July 2009 by describing procedures for measurement and calculation of hydraulic power, power consumption, and energy efficiency index of circulators.

1 Scope

This European Standard specifies the procedure for calculating the energy efficiency index (EEI) of standalone circulators.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 809:1998+A1 :2009, *Pumps and pump units for liquids – Common safety requirements*

EN 16297-1:2012, *Pumps – Rotodynamic pumps – Glandless circulators – Part 1: General requirements and procedures for testing and calculation of energy efficiency index (EEI)*

EN 60335-2-51:2003, *Household and similar electrical appliances – Safety – Part 2-51: Particular requirements for stationary circulation pumps for heating and service water installations*

3 Terms and definitions

For the purpose of this document, the terms and definitions given in EN 16297-1:2012 and the following apply.

3.1

standalone circulator

circulator designed to operate independently from a product that generates and/or transfers heat

Note 1 to entry For the purpose of this document, the term **circulator** is used in the following in place of **standalone circulator**.

3.2

differential pressure controlled circulator

circulator adapting in time the differential pressure to the demand by varying the speed

4 Symbols and units

For the purpose of this document, the symbols, quantities and units given in Table 1 of EN 16297-1:2012 apply.

5 Performance requirements and safety requirements

The requirements of EN 16297-1, EN 809 and EN 60335-2-51 apply.

6 Calculation of energy efficiency index (EEI)

6.1 General conditions

Standalone circulators with pump housing shall be measured as a complete unit.

Standalone circulators without pump housing shall be measured in pump housing identical to the pump housing in which they are intended to be used.

6.2 Procedure

6.2.1 Load profile for calculation of average compensated power input, $P_{L,avg}$

The load profile for calculation of average compensated power input, $P_{L,avg}$, for standalone circulators is shown in Table 1.

Table 1 — Load profile for calculation of average compensated power input, $P_{L,avg}$

Q in % of $Q_{100\%}$	Time in % of annual operating hours
100	L1 = 6
75	L2 = 15
50	L3 = 35
25	L4 = 44

6.2.2 Part load operating points

Part load operating points are measured by using following procedure:

- Calculate H_{ref} at each part load point on the reference control curve (see Figure 4 in EN 16297-1:2012).
- Select and set a control curve (control curve or non-controlled curve) which is as close as possible to the reference control curve and reaches point $(Q_{100\%}, H_{100\%})$ within the tolerance of $H_{100\%}$.
- Change the system curve to reach the part load operating points.

6.2.3 Calculation of average compensated power input, $P_{L,avg}$

The average compensated power input, $P_{L,avg}$, is calculated as:

$$\begin{aligned}
 P_{L,avg} &= L_1 \times P_{L,100\%} + L_2 \times P_{L,75\%} + L_3 \times P_{L,50\%} + L_4 \times P_{L,25\%} \\
 &= 0,06 \times P_{L,100\%} + 0,15 \times P_{L,75\%} + 0,35 \times P_{L,50\%} + 0,44 \times P_{L,25\%}
 \end{aligned}$$

$P_{L,avg}$ must be based on measurements from 100 % flow to 0 % flow or as average of $P_{L,avg}$ based on data measured from 0% flow to 100% flow and 100 % flow to 0 % flow. If more than one control curve reaches the point $(Q_{100\%}, H_{100\%})$ within the tolerance of $H_{100\%}$, it is recommended to make the calculation on more than one curve and use the curve which gives the lowest $P_{L,avg}$.

6.2.4 Calibration factor

The calibration factor for standalone circulators is $C_{xx\%} = C_{20\%} = 0,49$.

6.2.5 Calculation of energy efficiency index (EEI), ϵ_{EEI}

The energy efficiency index (EEI), ϵ_{EEI} , for standalone circulators is calculated as:

$$\varepsilon_{\text{EEI}} = \frac{P_{\text{L,avg}}}{P_{\text{ref}}} \times C_{20\%} = \frac{P_{\text{L,avg}}}{P_{\text{ref}}} \times 0,49$$

It is permissible to substitute the parameter ε_{EEI} by the abbreviation EEI in data sheets, manuals, leaflets, brochures etc.

Annex ZA (informative)

Relationship between this European Standard and the requirements of Commission Regulation (EC) No 641/2009

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to requirements

Commission Regulation (EC) No 641/2009 of 22 July 2009:

implementing Directive 2005/32/EC¹ of the European Parliament and of the Council with regard to ecodesign requirements for glandless standalone circulators and glandless circulators integrated in products

Once this standard is cited in the Official Journal of the European Union under that Commission Regulation, compliance with the clauses of this standard given in Table ZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding requirements of that and associated EFTA regulations.

**Table ZA.1 — Correspondence between this European Standard and
Commission Regulation (EC) No 641/2009**

Clauses and sub-clauses of this EN	Requirements of Commission Regulation (EC) No 641/2009	Qualifying remarks/Notes
Part 1: 6.2.1	Annex II, 2., 3.	Calculation of Phyd
Part 1: 6.2.2	Annex II, 2., 4.	Calculation of Pref
Part 1: 6.2.4	Annex II, 2., 5.	Reference control curve
Part 1: 6.2.9	Annex II, 2., 9.	Calculation of EEI
Part 2: 6.2.5	Annex II, 2., 9.	Calculation of EEI
Part 3: 6.2.5	Annex II, 2., 9.	Calculation of EEI

WARNING — Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

¹ The Directive was replaced by the Directive 2009/125/EC.

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™