

BS EN 16905-3:2017



BSI Standards Publication

Gas-fired endothermic engine driven heat pumps

Part 3: Test conditions

National foreword

This British Standard is the UK implementation of EN 16905-3:2017.

The UK participation in its preparation was entrusted to Technical Committee GSE/37, Gas fired sorption and laundering appliances.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017.
Published by BSI Standards Limited 2017

ISBN 978 0 580 90766 1

ICS 27.080

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 March 2017.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD

EN 16905-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2017

ICS 27.080

English Version

Gas-fired endothermic engine driven heat pumps - Part 3: Test conditions

Pompes à chaleur à moteur endothermique alimenté
au gaz - Partie 3 : Conditions d'essai

Gasbefeuerte endothermische Motor-Wärmepumpen -
Teil 3: Prüfbedingungen

This European Standard was approved by CEN on 9 January 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents		Page
European foreword		3
1	Scope	4
1.1	Scope of EN 16905 series	4
1.2	Scope of EN 16905-3	4
2	Normative references	5
3	Terms and definitions	5
4	Test conditions	5
4.1	Environmental conditions and electrical power supply requirements	5
4.2	Rating conditions in cooling and in heating	6
4.3	Rating conditions for engine heat recovery	15
Annex ZA (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 aimed to be covered		16
Annex ZB (informative) Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 aimed to be covered		18
Bibliography		20

European foreword

This document (EN 16905-3:2017) has been prepared by Technical Committee CEN/TC 299 “Gas-fired sorption appliances, indirect fired sorption appliances, gas-fired endothermic engine heat pumps and domestic gas-fired washing and drying appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2017, and conflicting national standards shall be withdrawn at the latest by September 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA and Annex ZB, which are integral parts of this document.

This standard comprises the following parts under the general title, *Gas-fired endothermic engine driven heat pumps*:

- *Part 1: Terms and definitions*;
- *Part 2: Safety* (WI 00299025; currently in preparation);
- *Part 3: Test conditions*;
- *Part 4: Test methods*;
- *Part 5: Calculation of seasonal performances in heating and cooling mode* (currently being voted).

EN 16905-1, prEN 16905-2, EN 16905-3, EN 16905-4 and EN 16905-5 have been prepared to address the essential requirements of the European Directive 2009/142/EC relating to appliances burning gaseous fuels (see prEN 16905-2:201X, Annex ZA for safety aspects and EN 16905-5:2017, Annex ZA for rational use of energy aspects).

These documents are linked to the Energy Related Products Directive (2009/125/EC) in terms of tests conditions, tests methods and seasonal performances calculation methods under Mandate M/535; (see EN 16905-3:2017, Annex ZA, EN 16905-4:2017, Annex ZA, EN 16905-5:2017, Annex ZA and prEN 16905-2:201X, Annex ZB).

These documents will be reviewed whenever new mandates could apply.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

1.1 Scope of EN 16905 series

This European Standard specifies the requirements, test methods and test conditions for the rating and performance calculation of air conditioners and heat pumps using either air, water or brine as heat transfer media, with gas-fired endothermic engine driven compressors when used for space heating, cooling and refrigeration, hereafter referred to as “GEHP appliance”.

This European Standard only applies to appliances with a maximum heat input (based on net calorific value) not exceeding 70 kW at standard rating conditions.

This European Standard only applies to appliances under categories I_{2H}, I_{2E}, I_{2Er}, I_{2R}, I_{2E(S)B}, I_{2L}, I_{2LL}, I_{2ELL}, I_{2E(R)B}, I_{2ESi}, I_{2E(R)}, I_{3P}, I_{3B}, I_{3B/P}, II_{2H3+}, II_{2Er3+}, II_{2H3B/P}, II_{2L3B/P}, II_{2E3B/P}, II_{2ELL3B/P}, II_{2L3P}, II_{2H3P}, II_{2E3P} and II_{2Er3P} according to EN 437.

This European Standard only applies to appliances having:

- a) gas fired endothermic engines under the control of fully automatic control systems;
- b) closed system refrigerant circuits in which the refrigerant does not come into direct contact with the fluid to be cooled or heated;
- c) where the temperature of the heat transfer fluid of the heating system (heating water circuit) does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the
 - 1) heating water circuit (if installed) does not exceed 6 bar;
 - 2) domestic hot water circuit (if installed) does not exceed 10 bar.

This European Standard applies to appliances only when used for space heating or space cooling or for refrigeration, with or without heat recovery.

The appliances having their condenser cooled by air and by the evaporation of external additional water are not covered by this European Standard.

Packaged units, single split and multisplit systems are covered by this European Standard. Single duct and double duct units are covered by this European Standard.

The above appliances can have one or more primary or secondary functions.

This European Standard is applicable to appliances that are intended to be type tested. Requirements for appliances that are not type tested would need to be subject to further consideration.

In the case of packaged units (consisting of several parts), this European Standard applies only to those designed and supplied as a complete package.

NOTE All the symbols given in this text are used regardless of the language used.

1.2 Scope of EN 16905-3

This part of the EN 16905 series specifies the test conditions for the rating of energy parameters of gas-fired endothermic engine driven heat pumps for heating and/or cooling mode including the engine heat recovery.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 16905-1, *Gas-fired endothermic engine driven heat pumps — Part 1: Terms and definitions*

EN 16905-4:2017, *Gas-fired endothermic engine driven heat pumps — Part 4: Test methods*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 16905-1 apply.

4 Test conditions

4.1 Environmental conditions and electrical power supply requirements

The tests shall be carried out under the environmental conditions specified in Table 1 or Table 2 depending on the location of the unit.

For all units, electrical power voltage and frequency shall be stated in the instructions.

Table 1 — Environmental conditions and electrical power supply requirements for units designed for installation indoors

Type	Measured quantities	Rating test
Water-to-water and brine-to-water units ^a	Dry bulb temperature	15 °C to 30 °C
Water-to-air and brine-to-air units with duct connection on the air inlet and outlet side	Dry bulb temperature	15 °C to 30 °C
Water-to-air and brine-to-air units without duct connection on the air inlet side	Dry bulb temperature Wet bulb temperature	Inlet temperature (see Table 6 and Table 7)
Air-to-water units with duct connection on the air inlet and outlet side	Dry bulb temperature	15 °C to 30 °C
Air-to-water units without duct connection on the air inlet side	Dry bulb temperature Wet bulb temperature	Inlet temperature (see Tables 12 to 15)
Air-to-air units with duct connection on the outdoor air inlet and outlet side	Dry bulb temperature	15 °C to 30 °C
Air-to-air units without duct connection on the outdoor air inlet and outlet side	Dry bulb temperature Wet bulb temperature	As inlet temperature see Table 3 and Table 4
All appliances	Voltage	Rated voltage
All appliances	Frequency	Rated frequency
^a Rating conditions for water to water or water to brine appliances can be extended to brine to water and brine to brine appliances respectively (e.g. for reversible applications).		

Table 2 — Environmental conditions and electrical power supply requirements for units designed for installation outdoors

Type	Measured quantities	Rating test
Air-to-water units	Dry bulb temperature Wet bulb temperature	Inlet temperature (see Tables 12 to 14 and Table 15)
Water-to-air units	Dry bulb temperature Wet bulb temperature	Inlet temperature (see Table 6 and Table 7)
Water-to-water and brine-to-water operating in cooling mode ^a	Dry bulb temperature	15 °C to 30 °C
Water-to-water and brine-to-water operating in heating mode	Dry bulb temperature	0 °C to 7 °C
Air-to-air units with duct connection on the indoor air inlet and outlet side	Dry bulb temperature Wet bulb temperature	Inlet temperature (see Table 3 and Table 4)
All appliances	Voltage	Rated voltage
All appliances	Frequency	Rated frequency
^a Rating conditions for water to water or water to brine appliances can be extended to brine to water and brine to brine appliances respectively (e.g. for reversible applications).		

4.2 Rating conditions in cooling and in heating

For the rating tests, the appropriate test conditions shall be applied in accordance with:

- Table 3 for air-to-air units and air-cooled multisplit systems in heating mode;
- Table 4 for air-to-air units and air-cooled multisplit systems in cooling mode;
- Table 5 for air-to-air simultaneous heating and cooling mode multisplit systems;
- Table 6 for water-to-air, brine-to-air units and water-cooled multisplit systems in heating mode;
- Table 7 for water-to-air, brine-to-air units and water-cooled multisplit systems in cooling mode;
- Tables 8 to 10 for water-to-water and brine-to-water units in heating mode, depending on the temperature applications;
- Table 11 for water-to-water, brine-to-water, water-to-brine and brine-to-brine units in cooling mode;
- Tables 12 to 14 for air-to-water units in heating mode, depending on the temperature applications;
- Table 15 for air-to-water and air-to-brine units in cooling mode.

For units with brine, the test shall be carried out with the brine specified in the instruction, see EN 16905-4:2017, 4.5.1.6.

NOTE 1 For air-to-water, brine-to-water and water-to-water units, the instructions declare the water temperatures levels (lower, medium, high) applicable to the heating mode.

NOTE 2 For comparison purposes between reverse cycle and non reverse cycle units, the conditions on the water side are given by the inlet and outlet water temperatures, possibly leading to different water flow rates in heating and cooling modes.

Table 3 — Air-to-air units and air-cooled multisplit systems - Heating mode

		Outdoor heat exchanger		Indoor heat exchanger	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet dry bulb temperature °C	Inlet wet bulb temperature °C
Standard rating conditions	Outdoor air / recycled air (split units and air-cooled multisplit systems)	7	6	20	15 max
	Exhaust air / recycled air (e.g. single duct heat pump)	20	12	20	12
	Exhaust air / outdoor air	20	12	7	6
Application rating conditions	Outdoor air / recycled air (split units and air-cooled multisplit systems)	2	1	20	15 max.
	Outdoor air / recycled air (split units and air-cooled multisplit system)	-7	-8	20	15 max.
	Outdoor air / recycled air (split units and air-cooled multisplit system)	-15	-	20	15 max.
	Outdoor air / recycled air (split units and air-cooled multisplit system)	12	11	20	15 max.
	Exhaust air / outdoor air	20	12	2	1
	Exhaust air / outdoor air	20	12	-7	-8

Table 4 — Air-to-air units and air-cooled multisplit systems - Cooling mode

		Outdoor heat exchanger		Indoor heat exchanger	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet dry bulb temperature °C	Inlet wet bulb temperature °C
Standard rating conditions	Comfort (outdoor air / recycled air) (split units) and air-cooled multisplit systems	35	24 ^a	27	19
	Comfort (outdoor air / recycled air) (split units) and air-cooled multisplit systems	27	19	27	19
	Comfort (exhaust air / outdoor air)	27	19	35	24
	Single duct ^{b, c}	35	24	35	24
	Control cabinet	35	24	35	24
	Close control	35	24	24	17
Application rating conditions	Comfort (outdoor air / recycled air) (split units and air-cooled multisplit systems)	27	19 ^a	21	15
	Single duct ^{b, c}	27	19	27	19
	Comfort (outdoor air / recycled air) (split units and air-cooled multisplit systems)	46	24 ^a	29	19
	Control cabinet	50	30	35	24
	Close control	27	19	21	15
<p>^a The wet bulb temperature condition is not required when testing units which do not evaporate / condensate.</p> <p>^b When using the calorimeter room method, pressure equilibrium between indoor and outdoor compartments shall be obtained by introducing into indoor compartment, air at the same rating temperature conditions.</p> <p>^c The pressure difference between the two compartments of the calorimeter room shall not be greater than 1,25 Pa. This pressure equilibrium can be achieved by using an equalizing device or by creating an open space area in the separation partition wall, which dimensions shall be calculated for the maximum airflow of the unit to be tested. If an open space is created in the partition wall, an air sampling device or several temperature sensors shall be used to measure the temperature of the air from the outdoor compartment to the indoor compartment.</p>					

Table 5 — Simultaneous heating and cooling mode multisplit systems

			Three room calorimeter or air enthalpy		Two room air enthalpy	
			Dry bulb temperature °C	Wet bulb temperature °C	Dry bulb temperature °C	Wet bulb temperature °C
Application rating conditions	Outdoor side		7	6	7	6
	Indoor side	Heating	20	-	20	19
		Cooling	27	19	20	19

Table 6 — Water-to-air, brine-to-air units and water-cooled multisplit systems - Heating mode

		Outdoor heat exchanger		Inlet heat exchanger	
		Inlet temperature °C	Outlet temperature °C	Inlet dry bulb temperature °C	Inlet wet bulb temperature °C
Standard rating conditions	Water ^a	10	7	20	15 max.
	Brine	0	-3	20	15 max.
	Water loop	20	17	20	15 max.
Application rating conditions	Water	15	b	20	15 max.
	Brine	5	b	20	15 max.
	Brine ^c	-5	b	20	15 max.

^a The term “water” include indifferently water from a river or a lake, round water or water in a close water loop.
^b The test is performed at the flow rate obtained during the test at the corresponding standard.
^c Test condition only for water-cooled multisplit systems.

Table 7 — Water-to-air, brine-to-air units and water-cooled multisplit systems - Cooling mode

		Outdoor heat exchanger		Indoor heat exchanger	
		Inlet temperature °C	Outlet temperature °C	Inlet dry bulb temperature °C	Inlet wet bulb temperature °C
Standard rating conditions	Cooling tower	30	35	27	19
	Ground coupled ^b (water or brine)	10	15	27	19
	Control cabinet ^b	15	20	35	24
	Close control ^b	30	35	24	17
Application rating conditions	Cooling tower	40	a	27	19
	Ground coupled (water or brine)	15	a	27	19
	Close control ^b	15	a	21	15
	Close control ^b	40	a	24	17

^a The test is performed at the water flow rate obtained during the test at the corresponding standard rating conditions.

^b Tests conditions only for water-to-air and brine-to-air units (no for water cooled multisplit systems).

Table 8 — Water-to-water and brine-to-water units - Heating mode (Low temperature)

		Outdoor heat exchanger		Indoor heat exchanger low temperature applications	
		Inlet temperature °C	Outlet temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Water ^a	10	7	30	35
	Brine	0	-3	30	35
Application rating conditions	Water	15	b	b	35
	Brine	5	b	b	35
	Brine	-5	b	b	35

^a The term “water” includes indifferently water from a river or a lake, ground water or water in a dose water loop.

^b The test is performed at the flow rate obtained during the test at the corresponding standard rating conditions.

Table 9 — Water-to-water and brine-to-water units - Heating mode (Medium temperature)

		Outdoor heat exchanger		Indoor heat exchanger medium temperature applications	
		Inlet temperature °C	Outlet temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Water ^a	10	7	40	45
	Brine	0	-3	40	45
Application rating conditions	Water	15	b	b	45
	Brine	5	b	b	45
	Brine	-5	b	b	45

^a The term “water” includes indifferently water from a river or a lake, ground water or water in a dose water loop.

^b The test is performed at the flow rate obtained during the test at the corresponding standard rating conditions.

Table 10 — Water-to-water and brine-to-water units - Heating mode (High temperatures)

		Outdoor heat exchanger		Indoor heat exchanger high temperature applications	
		Inlet temperature °C	Outlet temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Water ^a	10	7	47	55
	Brine	0	-3	47	55
Application rating conditions	Water	15	b	b	55
	Brine	5	b	b	55
	Brine	-5	b	b	55

^a The term “water” includes indifferently water from a river or a lake, ground water or water in a dose water loop.

^b The test is performed at the flow rate obtained during the test at the corresponding standard rating conditions.

Table 11 — Water (/brine)-to-water(/brine) units - Cooling mode

		Outdoor heat exchanger		Indoor heat exchanger	
		Inlet temperature °C	Outlet temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Water-to-water (for medium temperature cooling applications heating applications) from cooling tower ^a	30 ^b	35	12	7
	Water-to-water (for low temperature heating applications) from cooling tower ^a	30 ^b	35	23	18
	Water-to-brine ^a	30 ^b	35	0	-5

^a Rating condition for water to water or brine to water appliances can be extended to water to brine and brine to brine appliances respectively (e.g. for reversible applications).

^b The water can contain any additives specified in the instructions, but the test conditions remains the same as for water.

Table 12 — Air-to-water and air-to-brine units - Heating mode (Low temperatures)

		Outdoor heat exchanger		Indoor heat exchanger Low temperature applications	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Outdoor air	7	6	30	35
	Exhaust air	20	12	30	35
Application rating conditions	Outdoor air	2	1	a	35
	Outdoor air	-7	-8	a	35
	Outdoor air	-15	-	a	35
	Outdoor air	12	11	a	35

^a The test is performed at the flow rate obtained during the test at the standard rating conditions.

Table 13 — Air-to-water and air-to-brine units - Heating mode (Medium temperatures)

		Outdoor heat exchanger		Indoor heat exchanger medium temperature applications	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Outdoor air	7	6	40	45
	Exhaust air	20	12	40	45
Application rating conditions	Outdoor air	2	1	a	45
	Outdoor air	-7	-8	a	45
	Outdoor air	-15	-	a	45
	Outdoor air	12	11	a	45

^a The test is performed at the flow rate obtained during the test at the standard rating conditions.

Table 14 — Air-to-water and air-to-brine units - Heating mode (High temperatures)

		Outdoor heat exchanger		Indoor heat exchanger high temperature applications	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Outdoor air	7	6	47	55
	Exhaust air	20	12	47	55
Application rating conditions	Outdoor air	2	1	a	55
	Outdoor air	-7	-8	a	55
	Outdoor air	-15	-	a	55
	Outdoor air	12	11	a	55

^a The test is performed at the flow rate obtained during the test at the standard rating conditions.

Table 15 — Air-to-water and air-to-brine units - Cooling mode

		Outdoor heat exchanger		Indoor heat exchanger	
		Inlet dry bulb temperature °C	Inlet wet bulb temperature °C	Inlet temperature °C	Outlet temperature °C
Standard rating conditions	Water (for medium temperature heat pump applications)	35	~	12	7
	Water (for low temperature heat pump applications)	35	-	23	18
	Brine	35	-	0	-5
Application rating conditions	Water (for medium temperature heat pump applications)	27	-	a	7
	Water (for low temperature heat pump applications)	27	-	a	18
	Water (for medium temperature heat pump applications)	46	-	a	7
	Brine	27	-	a	-5
	Brine	46	-	a	-5

^a The test is performed at the water flow rate obtained during the test at the corresponding standard rating conditions.

4.3 Rating conditions for engine heat recovery

For the rating tests of engine heat recovery, the appropriate test conditions shall be applied in accordance with following table:

Table 16 — Rating conditions engine heat recovery

	Engine heat exchanger	
	Inlet water temperature °C	Outlet water temperature °C
Standard rating conditions in cooling mode (air to air; water-to-air and brine-to-air units; for water-to-water and brine-to-water units; air-to-water and air-to-brine)	60	65
All other conditions	a	65

^a The test is performed at the flow rate obtained during the test at the standard rating conditions.

Annex ZA
(informative)

Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 aimed to be covered

This European Standard has been prepared under a Commission's standardization request "M/535" to provide one voluntary means of conforming to the ecodesign requirements of Commission Regulation (EU) No 813/2013 of 2 August 2013 implementing Directive 2005/32/EC ¹⁾ / 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters.

Once this standard is cited in the Official Journal of the European Union under that Regulation, compliance with the normative clauses of this standard given in Table ZA.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding ecodesign requirements of that Regulation and associated EFTA regulations.

1) The Directive was replaced by Directive 2009/125/EC.

Table ZA.1 — Correspondence between this European Standard and Commission Regulation (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters and Commission’s standardization request M/535

Ecodesign Requirements of Regulation (EU) No 813/2013	Clause(s)/subclause(s) of this EN	Remarks/Notes
Annex II.1 (a) and (b)	Not applicable	
Annex II.2 (a) and (b)	Not applicable	
Annex II.3	Not applicable	
Annex II.4	Not applicable	
Annex II.5 (a), (b) and (c)	Not applicable	
Annex II.1 Table 1	Not applicable	
Annex II.1 Table 2	Not applicable	
Annex III.2	4.1 Table 1 (indoor installations) and Table 2 (outdoor installations)	General condition for measurements and calculations
Annex III.3	Not applicable	
Annex III.4	Not applicable	
Annex III.5	Not applicable	
Annex III. Table 3	4.2 Table 8, Table 9, Table 10, Table 11, Table 12, Table 13 and Table 14	Standard rating conditions for heat pump space heaters and heat pump combination heaters
Annex III. Table 4	Not applicable	
Annex III. Table 5	Not applicable	
Annex III. Table 6	Not applicable	
Annex III. Table 7	Not applicable	

WARNING 1 — Presumption of conformity stays valid only as long as a reference to this European Standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

WARNING 2 — Other Union legislation may be applicable to the products falling within the scope of this standard.

Annex ZB
(informative)

Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 aimed to be covered

This European Standard has been prepared under a Commission’s standardization request “M/535” to provide one voluntary means of conforming to the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling requirements for space heaters and combination heaters.

Once this standard is cited in the Official Journal of the European Union under that Regulation, compliance with the normative clauses of this standard given in Table ZB.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding energy labelling requirements of that Regulation and associated EFTA regulations.

Table ZB.1 — Correspondence between this European Standard and Commission Delegated Regulation (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling of space heaters and combination heaters and Commission’s standardization request M/535

Energy labelling requirements of Regulation (EU) No 811/2013	Clause(s)/subclause(s) of this EN	Remarks/Notes
Article 3, 1(a), Annex II, 1	Not applicable	Energy efficiency classes
Article 3, 1(a), Annex II, 2	Not applicable	Water heating energy classes
Article 3, 1(a), Annex III and IV	Not applicable	Sound power level
Article 3, 1(a), Annex III, 1.1 and Annex III, 3	4.1 Table 1 (indoor installations) and Table 2 (outdoor installations)	Tests conditions for measuring the rated heat output to be inserted in the Energy label for space heater
Article 3, 1(b), Annex IV, 1 and Annex IV, 5	4.1 Table 1 (indoor installations) and Table 2 (outdoor installations)	Tests conditions for measuring the data to be inserted in the product fiche for space heater
Article 3, 1(c), Annex IV, 1	Not applicable	Technical documentation for space heater
Article 3, 2(a), Annex III, 2.1 and Annex III, 4	Not applicable	Energy label for combination heater
Article 3, 2(b), Annex IV, 2 and Annex IV, 6	Not applicable	Product fiche for combination space heater
Article 3, 2(c), Annex V, 2	Not applicable	Technical documentation for combination heater

WARNING 1 — Presumption of conformity stays valid only as long as a reference to this European Standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

WARNING 2 — Other Union legislation may be applicable to the products falling within the scope of this standard.

Bibliography

- [1] EN 437, *Test gases — Test pressures — Appliance categories*
- [2] EN 12309-1, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 1: Terms and definitions*
- [3] EN 12309-2, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 2: Safety*
- [4] EN 12309-3, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 3: Test conditions*
- [5] EN 12309-4, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 4: Test methods*
- [6] EN 12309-5, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 5: Requirements*
- [7] EN 12309-6, *Gas-fired sorption appliances for heating and/or cooling with a net heat input not exceeding 70 kW - Part 6: Calculation of seasonal performances*
- [8] EN 14511-1, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling - Part 1: Terms, definitions and classification*
- [9] EN 14511-2, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling - Part 2: Test conditions*
- [10] EN 14511-3, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling - Part 3: Test methods*
- [11] EN 14511-4, *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling - Part 4: Operating requirements, marking and instructions*
- [12] EN 14825, *Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance*
- [13] prEN 16905-2²⁾, *Gas-fired endothermic engine driven heat pumps — Part 2: Safety*
- [14] EN 16905-5, *Gas-fired endothermic engine driven heat pumps — Part 5: Calculation of seasonal performances in heating and cooling mode*

2) Currently in preparation.

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Copyright in BSI publications

All the content in BSI publications, including British Standards, is the property of and copyrighted by BSI or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use.

Save for the provisions below, you may not transfer, share or disseminate any portion of the standard to any other person. You may not adapt, distribute, commercially exploit, or publicly display the standard or any portion thereof in any manner whatsoever without BSI's prior written consent.

Storing and using standards

Standards purchased in soft copy format:

- A British Standard purchased in soft copy format is licensed to a sole named user for personal or internal company use only.
- The standard may be stored on more than 1 device provided that it is accessible by the sole named user only and that only 1 copy is accessed at any one time.
- A single paper copy may be printed for personal or internal company use only.

Standards purchased in hard copy format:

- A British Standard purchased in hard copy format is for personal or internal company use only.
- It may not be further reproduced – in any format – to create an additional copy. This includes scanning of the document.

If you need more than 1 copy of the document, or if you wish to share the document on an internal network, you can save money by choosing a subscription product (see 'Subscriptions').

Reproducing extracts

For permission to reproduce content from BSI publications contact the BSI Copyright & Licensing team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email subscriptions@bsigroup.com.

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Useful Contacts

Customer Services

Tel: +44 345 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 345 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK