

BS EN 60695-11-4:2011



BSI Standards Publication

Fire hazard testing

Part 11-4: Test flames — 50 W flame —
Apparatus and confirmational test method

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 60695-11-4:2011. It is identical to IEC 60695-11-4:2011. It supersedes DD IEC/TS 60695-11-4:2004, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/89, Fire hazard testing.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012
Published by BSI Standards Limited 2012

ISBN 978 0 580 68527 9

ICS 13.220.40; 29.020

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 29 February 2012.

Amendments issued since publication

Amd. No.	Date	Text affected
-----------------	-------------	----------------------

English version

**Fire hazard testing -
Part 11-4: Test flames -
50 W flame -
Apparatus and confirmational test method
(IEC 60695-11-4:2011)**

Essais relatifs aux risques du feu -
Partie 11-4: Flammes d'essai -
Flamme de 50 W -
Appareillage et méthodes d'essai de
vérification
(CEI 60695-11-4:2011)

Prüfungen zur Beurteilung der
Brandgefahr -
Teil 11-4: Prüfflammen -
50 W Prüf Flamme -
Prüfeinrichtungen und Prüfverfahren zur
Bestätigung
(IEC 60695-11-4:2011)

This European Standard was approved by CENELEC on 2011-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 89/1060/FDIS, future edition 1 of IEC 60695-11-4, prepared by IEC/TC 89 "Fire hazard testing" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60695-11-4:2011.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-08-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-11-01

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60695-11-4:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 60695-11-2:2003 NOTE Harmonized as EN 60695-11-2:2003 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60584-1	1995	Thermocouples - Part 1: Reference tables	EN 60584-1	1995
IEC 60584-2 + A1	1982 1989	Thermocouples - Part 2: Tolerances	EN 60584-2	1993
IEC Guide 104	1997	The preparation of safety publications and the - use of basic safety publications and group safety publications	-	-
ISO/IEC Guide 51	1999	Safety aspects - Guidelines for their inclusion - in standards	-	-
ISO 13943	2008	Fire safety - Vocabulary	EN ISO 13943	2010
ASTM B187	-	Standard Specification for Copper, Bus Bar, Rod, and Shapes and General Purpose Rod, Bar, and Shapes	-	-

CONTENTS

INTRODUCTION	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Production of a standardized 50 W nominal test flame	7
4.1 Requirements	7
4.2 Apparatus and fuel	8
4.2.1 Burner	8
4.2.2 Flowmeter	8
4.2.3 Manometer	8
4.2.4 Control valve	8
4.2.5 Copper block	8
4.2.6 Thermocouple	8
4.2.7 Temperature/time indicating/recording devices	9
4.2.8 Fuel gas	9
4.2.9 Laboratory fumehood/chamber	9
4.3 Production of the test flame	9
4.4 Confirmation of the test flame	9
4.4.1 Principle	9
4.4.2 Procedure	10
4.4.3 Verification	10
5 Classification and designation	10
Annex A (normative) Test arrangements	13
Annex B (informative) Recommended arrangements for the use of the test flame	17
Annex C (informative) Clearance gauge	18
Annex D (informative) Test arrangements for tests on equipment	19
Annex E (informative) Test arrangements for tests on bar test specimens	20
Bibliography	21
Figure 1 – Copper block	11
Figure 2 – Flame height gauge	12
Figure A.1 – Burner – General assembly	13
Figure A.2 – Burner details	14
Figure A.3 – Supply arrangement for burner (example)	15
Figure A.4 – Confirmatory test arrangement	16
Figure C.1 – Clearance gauge	18
Figure D.1 – Examples of test arrangements	19
Figure E.1 – Examples of test arrangements	20

INTRODUCTION

The best method for testing electrotechnical products with regard to fire hazard is to duplicate exactly the conditions occurring in practice. In most instances, this is not possible. Accordingly, for practical reasons, the testing of electrotechnical products with regard to fire hazard is best conducted by simulating as closely as possible the actual effects occurring in practice.

Work initiated by ACOS resulted in a series of standards that make available standardized test flames covering a range of powers for the use of all product committees needing such test flames. A needle flame is described in IEC 60695-11-5, two 500 W flames are described in IEC 60695-11-4, and a 1 kW flame is described in IEC 60695-11-2.

This international standard provides a description of the apparatus required to produce a 50 W test flame and a description of a calibration procedure to check that the test flame produced meets given requirements. Guidance on confirmatory tests for test flames is given in IEC 60695-11-40.

Three 50 W test flame methods (A, B and C) were originally specified in IEC/TS 60695-11-4:2000, with the intention that users would determine a ranking preference. This process has resulted in two of these flame methods being withdrawn, as shown below:

50 W test flame method	Flame type	Gas	Approximate flame height / mm
A	Pre-mixed	Methane	20
B	Withdrawn		
C	Withdrawn		

The method described in Clause 4 of this standard is the method that was originally designated as Method A. It produces a 50 W nominal test flame using a single gas supply tube, a needle valve to adjust the gas back pressure, a flowmeter to adjust the gas flow rate, and adjustable air ports on the burner tube.

The flame is produced by burning methane, and the method makes use of a more tightly specified version of a burner that was used in some countries for many years.

The method has been developed as a technical enhancement of previous technology.

FIRE HAZARD TESTING –

Part 11-4: Test flames – 50 W flame – Apparatus and confirmational test method

1 Scope

This part of IEC 60695 provides detailed requirements for the production of a 50 W nominal, pre-mixed type test flame. The approximate overall height of the flame is 20 mm. Details are given for confirmation of the test flame.

This basic safety publication is intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this basic safety publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60584-1:1995, *Thermocouples – Part 1: Reference tables*

IEC 60584-2:1989, *Thermocouples – Part 2: Tolerances*
Amendment 1

IEC Guide 104:1997, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO/IEC Guide 51:1999, *Safety aspects – Guidelines for their inclusion in standards*

ISO/IEC 13943:2008, *Fire safety – Vocabulary*

ASTM-B187/B187M-06, *Standard Specification for Copper, Bus Bar, Rod, and Shapes and General Purpose Rod, Bar, and Shapes*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO/IEC 13943, some of which are reproduced below for the users' convenience, as well as the following apply..

3.1

burn, intransitive verb
undergo combustion

[ISO/IEC 13943, definition 4.28]

3.2

burn, transitive verb
cause combustion

[ISO/IEC 13943, definition 4.29]

3.3

combustion

exothermic reaction of a substance with an oxidizing agent

NOTE Combustion generally emits fire effluent accompanied by flames and/or glowing.

[ISO/IEC 13943, definition 4.46]

3.4

draught-free environment

space in which the results of experiments are not significantly affected by the local air speed

NOTE A qualitative example is a space in which a wax candle flame remains essentially undisturbed. Quantitative examples are small-scale fire tests in which a maximum air speed of $0,1 \text{ m}\cdot\text{s}^{-1}$ or $0,2 \text{ m}\cdot\text{s}^{-1}$ is sometimes specified.

[ISO/IEC 13943, definition 4.70]

3.5

fire hazard

physical object or condition with a potential for an undesirable consequence from fire

[ISO/IEC 13943, definition 4.112]

3.6

flame, noun

rapid, self-sustaining, sub-sonic propagation of combustion in a gaseous medium, usually with emission of light

[ISO/IEC 13943, definition 4.133]

3.7

pre-mixed flame

flame in which combustion occurs in an intimate mixture of fuel and oxidizing agent

[ISO/IEC 13943, definition 4.259]

3.8

standardized 50 W nominal test flame

test flame that conforms to this international standard and meets all of the requirements given in Clause 4

4 Production of a standardized 50 W nominal test flame

4.1 Requirements

A standardized 50 W nominal test flame, according to this method, is one that is

- produced using hardware according to Figures A.1 and A.2,
- supplied with methane gas of purity not less than 98 % at a flow rate equivalent to $105 \text{ ml/min} \pm 5 \text{ ml/min}$ at $23 \text{ }^\circ\text{C}$, $0,1 \text{ MPa}^1$, using the arrangement of Figure A.3.

¹ When corrected from measurements taken under actual conditions of use.

NOTE The expected back pressure is less than 10 mm of water.

The flame shall be symmetrical, stable and give a result of $44 \text{ s} \pm 2 \text{ s}$ in the confirmatory test described in 4.4.

The confirmatory test arrangement shown in Figure A.4 shall be used.

The overall height of the flame should be typically within the range 18 mm to 22 mm, but targeted towards 20 mm when measured using the flame height gauge as described in Figure 2, in the laboratory fumehood/chamber (see 4.2.9).

4.2 Apparatus and fuel

4.2.1 Burner

The burner shall be in accordance with Figures A.1 and A.2.

NOTE The burner tube, gas injector and needle valve are removable for cleaning purposes. Care should be taken on re-assembly that the needle valve tip is not damaged and that the needle valve and valve seat (gas injector) are correctly aligned.

4.2.2 Flowmeter

The flowmeter shall be appropriate for the measurement of a gas flow rate of 105 ml/min at $23 \text{ }^\circ\text{C}$, $0,1 \text{ MPa}$ to a tolerance of $\pm 2 \%$.

NOTE A mass flowmeter is the preferred means of controlling accurately the input flow rate of fuel to the burner. Other methods may be used if they can show equivalent accuracy.

4.2.3 Manometer

The manometer shall be appropriate for the measurement of pressure in the range of 0 kPa to 7,5 kPa. Water manometers may be used for this purpose. They should be adapted to read 0 kPa to 7,5 kPa.

NOTE A manometer is required in conjunction with a mass flowmeter in order to maintain the required back pressure.

4.2.4 Control valve

A control valve is required to set the gas flow rate.

4.2.5 Copper block

The copper block shall be 5,50 mm in diameter, of mass $1,76 \text{ g} \pm 0,01 \text{ g}$ in the fully machined but undrilled state as shown in Figure 1.

There is no verification method for the copper block. Laboratories are encouraged to maintain a standard reference unit, a secondary standard reference unit and a working unit, cross-comparing them as appropriate to verify the working system.

4.2.6 Thermocouple

A mineral insulated, metal sheathed fine-wire thermocouple with an insulated junction, is used for measuring the temperature of the copper block. The thermocouple shall be Class 1 in accordance with IEC60584-2. It shall have an overall nominal diameter of 0,5 mm and wires of, for example, NiCr and NiAl (type K in accordance with IEC 60584-1) with the welded point located inside the sheath. The sheath shall consist of a metal resistant to continuous operation at a temperature of at least $1\ 050 \text{ }^\circ\text{C}$. Thermocouple tolerances shall be in accordance with IEC 60584-2, Class 1.

NOTE A sheath made from a nickel-based, heat-resistant alloy (such as Inconel 600²) will satisfy the above requirement.

The preferred method of fastening the thermocouple to the block, after first ensuring that the thermocouple is inserted to the full depth of the hole, is by compressing the copper around the thermocouple to retain it without damage, as shown in Figure A.4.

4.2.7 Temperature/time indicating/recording devices

The temperature/time indicating/recording devices shall be appropriate for the measurement of the time for the block to heat up from $100\text{ °C} \pm 2\text{ °C}$ to $700\text{ °C} \pm 3\text{ °C}$ with a tolerance on the measured time of $\pm 0,5\text{ s}$.

4.2.8 Fuel gas

The fuel gas shall be methane with a purity of not less than 98 %.

4.2.9 Laboratory fumehood/chamber

The laboratory fumehood/chamber shall have an inside volume of at least $0,5\text{ m}^3$, which has been shown to be satisfactory, unless otherwise stated in the test method for burning behaviour. The chamber shall permit observation of tests in progress and shall provide a draught-free environment, whilst allowing normal thermal circulation of air past the test specimen during burning. The inside walls of the chamber shall be of a dark colour. When a lux meter facing towards the rear of the chamber is positioned in place of the test flame, the recorded light level shall be less than 20 lx. For safety and convenience, it is desirable that this enclosure (which can be completely closed) is fitted with an extraction device, such as an exhaust fan, to remove products of combustion, which may be toxic. If fitted, the extraction device shall be turned off during the test and turned on immediately after the test to remove the fire effluents. A positive closing damper may be needed.

NOTE 1 The amount of oxygen available to support combustion of the test specimen is naturally important for the conduct of flame tests. For tests conducted by these methods when burning times are prolonged, chambers having an inside volume of $0,5\text{ m}^3$ may not be sufficient to produce accurate results.

NOTE 2 Placing a mirror in the chamber, to provide a rear view of the test specimen, has been found useful.

4.3 Production of the test flame

Set up the burner supply arrangement according to Figure A.3 ensuring leak-free connections and place the burner in the laboratory fumehood/chamber.

Ignite the gas and adjust the gas flow rate to the required value. The needle valve shall be adjusted to set the gas flow rate. The air inlet shall be adjusted until the flame is completely blue in colour with no inner cone.

The overall height of the flame shall be as described in 4.1. The flame shall appear stable and symmetrical on examination.

4.4 Confirmation of the test flame

4.4.1 Principle

The time taken for the temperature of the copper block, described in Figure 1, to increase from $100\text{ °C} \pm 2\text{ °C}$ to $700\text{ °C} \pm 3\text{ °C}$ shall be $44\text{ s} \pm 2\text{ s}$, when the flame confirmatory test arrangement of Figure A.4 is used.

² This information is given for the convenience of users of this international standard and does not constitute an endorsement by the IEC of the product named. Equivalent products may be used if they can be shown to lead to the same results.

4.4.2 Procedure

Set up the burner supply and confirmatory test arrangements according to Figures A.3 and A.4 in the laboratory fumehood/chamber as described in 4.2.9, ensuring leak-free gas connections.

Temporarily remove the burner away from the block to ensure that there is no influence of the flame on the copper block during the preliminary adjustment of the gas and air flow rates.

Ignite the gas and adjust the gas flow rate to the required value. Adjust the air inlet by turning the burner tube until the moment the yellow tip of the flame disappears. Ensure that the overall height of the flame, when measured using the gauge described in Figure 2, is within the required limits, and that the flame is symmetrical. Wait for a period of at least 5 min to allow the burner conditions to reach equilibrium. Measure the gas flow rate and determine that they are within the required limits.

With the temperature/time indicating/recording devices operational, re-position the burner under the copper block.

Determine the time for the temperature of the copper block to increase from $100\text{ °C} \pm 2\text{ °C}$ to $700\text{ °C} \pm 3\text{ °C}$. If the time is $44\text{ s} \pm 2\text{ s}$, repeat the procedure two additional times until three successive determinations are within specification. Allow the copper block to cool naturally in air to below 50 °C between determinations. If the time of any determination is not $44\text{ s} \pm 2\text{ s}$, adjust the flame accordingly, allow the flame to reach equilibrium, and restart the procedure.

NOTE At temperatures above 700 °C , the thermocouple can easily be damaged, therefore it is advisable to remove the burner immediately after reaching 700 °C .

If the copper block has not been used before, make a preliminary run to condition the block surface. Discard the result.

4.4.3 Verification


The flame is confirmed and may be used for test purposes if the results of three successive determinations are within the range $44\text{ s} \pm 2\text{ s}$.

5 Classification and designation

Apparatus that conforms with the requirements of this international standard and produces the 50 W nominal test flame may be labelled:

"50 W nominal test flame apparatus, conforming to IEC 60695-11-4".

Dimensions in millimetres



Copper block - polished all over

032/2000


Material: high conductivity electrolytic copper Cu-ETP UNS C 11000 (see ASTM-B187/B187M-06)

Weight: $1,76 \text{ g} \pm 0,01 \text{ g}$ before drilling

Tolerances: $\pm 0,1$, $\pm 30 \text{ min}$ (angular) unless otherwise stated

Figure 1 – Copper block

Dimensions in millimetres




Tolerances: $\pm 0,1$, ± 30 min (angular) unless otherwise stated

Figure 2 – Flame height gauge

033/2000

Annex A
(normative)


Test arrangements



IEC 034/2000

Figure A.1 – Burner – General assembly

Dimensions in millimetres




IEC 035/2000

Material: brass or any other suitable material

Tolerances on linear dimensions:
 xx (e.g. 20) means $\pm 0,5$ mm
 xx,x (e.g. 20,0) means $\pm 0,1$ mm
 unless otherwise stated.

Tolerances on angular dimensions:
 x (e.g. 45) means ± 30 min
 unless otherwise stated.


Figure A.2 – Burner details



NOTE A manometer is required in conjunction with a mass flowmeter in order to maintain the required back pressure.

The inner diameter of the tubes connecting the flowmeters to the burner must be of adequate size to minimize pressure drop.

Figure A.3 – Supply arrangement for burner (example)



The mode of suspension of the copper block shall be such that the block remains essentially stationary during the test.

Figure A.4 – Confirmatory test arrangement

Annex B (informative)

Recommended arrangements for the use of the test flame

The criteria to be used for the selection of the appropriate test arrangements are given in Annexes D and E. Examples of test arrangements are shown in Figures D.1 and E.1.

When used for testing equipment, the recommended distance from the top of the burner tube to the point on the surface of the test specimen to be tested is 20 mm and the burner may be tilted to an angle of 45 ° or less and fixed in position during the test, unless otherwise stated in the relevant specification.

When used for testing bar test specimens of materials, the operator may move the flame during the test to follow the distorting or burning test specimen, and the recommended distance from the top of the burner tube to the point on the surface of the test specimen to be tested is 10 mm, unless otherwise stated in the relevant specification.

NOTE The distance of 10 mm was chosen to give better reproducibility than that obtained in the position where the tip of the flame is in contact with the bar test specimen.


If necessary, the burner may be tilted in such a way that debris falling from the test specimen under test does not fall into the burner.

The clearance gauge shown in Figure C.1 may be secured to the top of the burner tube to assist the operator in maintaining the specified spacing between the top of the burner tube and the test specimen.

Annex C (informative)

Clearance gauge

Dimensions in millimetres




Material: stainless steel

Tolerances: $\pm 0,1$, ± 30 min (angular) unless otherwise stated

Figure C.1 – Clearance gauge

Annex D (informative)

Test arrangements for tests on equipment



IEC 045/2000

NOTE The test flame is applied to an inside surface of the test specimen at a point judged likely to become ignited because of its proximity to a source of ignition. If ventilation openings are involved, the flame is applied to an opening, otherwise to a solid surface. In all cases, the tip of the flame should just touch the test specimen. If a vertical part is involved, the test flame is applied at any convenient angle from the vertical.

Figure D.1 – Examples of test arrangements

For the evaluation of materials located within a fire enclosure, namely that part of the equipment intended to minimize the spread of fire or flames from within, it is permitted to apply the test flame to an external surface of the test specimen if its size limits application internally.

Bibliography

IEC 60695-11-2:2003, *Fire hazard testing – Part 11-2: Test flames – 1 kW nominal pre-mixed flame – Apparatus, confirmatory test arrangement and guidance*

IEC 60695-11-3:2011, *Fire hazard testing – Part 11-3: Test flames – 500 W flames – Apparatus and confirmational test methods*

IEC/TS 60695-11-40:2002, *Fire hazard testing – Part 11-40: Test flames – Confirmatory tests – Guidance*

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™