

BS EN 60811-412:2012



BSI Standards Publication

Electric and optical fibre cables — Test methods for non-metallic materials

Part 412: Miscellaneous tests — Thermal ageing methods — Ageing in an air bomb

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 60811-412:2012. It is identical to IEC 60811-412:2012.

In the UK, the relationship between the supersessions of BS EN 60811 series can be summarized as follows.

BS EN 60811-100 together with	Supersedes -
-201, -202, -203, -501	BS EN 60811-1-1:1995
-301, -302, -411, -601, -602, -603, -604	BS EN 60811-5-1:2000
-401, -412	BS EN 60811-1-2:1995
-402, -502, -503, -606	BS EN 60811-1-3:1995
-403, -404, -507	BS EN 60811-2-1:1998
-405, -409	BS EN 60811-3-2:1995
-406, -511, -605, -607	BS EN 60811-4-1:2004
-407, -408, -410, -510, -512, -513	BS EN 60811-4-2:2004
-504, -505, -506	BS EN 60811-1-4:1995
-508, -509	BS EN 60811-3-1:1995

Superseded standards are withdrawn

The UK participation in its preparation was entrusted by Technical Committee GEL/20, Electric cables, to Subcommittee GEL/20/17, Electric Cables - Low voltage.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012

Published by BSI Standards Limited 2012

ISBN 978 0 580 65322 3

ICS 29.035.01; 29.060.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2012.

Amendments issued since publication

Amd. No.	Date	Text affected
<hr/>		

English version

**Electric and optical fibre cables -
Test methods for non-metallic materials -
Part 412: Miscellaneous tests -
Thermal ageing methods -
Ageing in an air bomb
(IEC 60811-412:2012)**

Câbles électriques et à fibres optiques -
Méthodes d'essai pour les matériaux non-
métalliques -
Partie 412: Essais divers -
Méthodes de vieillissement thermique -
Vieillessement dans une bombe à air
(CEI 60811-412:2012)

Kabel, isolierte Leitungen und
Glasfaserkabel -
Prüfverfahren für nichtmetallene
Werkstoffe -
Teil 412: Sonstige Prüfungen -
Thermische Alterungsverfahren -
Alterung in einer Druckkammer
(IEC 60811-412:2012)

This European Standard was approved by CENELEC on 2012-04-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 20/1296/FDIS, future edition 1 of IEC 60811-412, prepared by IEC/TC 20 "Electric cables" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60811-412:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-01-16
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-04-16

This document supersedes 8.2 of EN 60811-1-2:1995 + A2:2000 (partially). Full details of the replacements are shown in Annex A of EN 60811-100:2012.

There are no technical changes with respect to EN 60811-1-2:1995 + A2:2000, but see the Foreword to EN 60811-100:2012.

This standard is to be read in conjunction with EN 60811-100.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC)

Endorsement notice

The text of the International Standard IEC 60811-412:2012 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60811-100	2012	Electric and optical fibre cables - Test methods for non-metallic materials - Part 100: General	EN 60811-100	2012
IEC 60811-501	-	Electric and optical fibre cables - Test methods for non-metallic materials - Part 501: Mechanical tests - Tests for determining the mechanical properties of insulating and sheathing compounds	EN 60811-501	-

CONTENTS

INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 Test method	6
4.1 General	6
4.2 Apparatus.....	6
4.3 Sample and test pieces preparation.....	6
4.4 Ageing procedure	7
4.5 Measurements.....	7
4.6 Expression of the result.....	7
5 Test report.....	8
Bibliography.....	9

INTRODUCTION

The IEC 60811 series specifies the test methods to be used for testing non-metallic materials of all types of cables. These test methods are intended to be referenced in standards for cable construction and for cable materials.

NOTE 1 Non-metallic materials are typically used for insulating, sheathing, bedding, filling or taping within cables.

NOTE 2 These test methods are accepted as basic and fundamental and have been developed and used over many years principally for the materials in all energy cables. They have also been widely accepted and used for other cables, in particular optical fibre cables, communication and control cables and cables for ships and offshore applications.

ELECTRIC AND OPTICAL FIBRE CABLES – TEST METHODS FOR NON-METALLIC MATERIALS –

Part 412: Miscellaneous tests – Thermal ageing methods – Ageing in an air bomb

1 Scope

This Part 412 of IEC 60811 gives the procedure for ageing in an air bomb, which typically applies to crosslinked and thermoplastic compounds used for insulating and sheathing materials.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60811-100:2012, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 100: General*

IEC 60811-501, *Electric and optical fibre cables – Test methods for non-metallic materials – Part 501: Mechanical tests – Tests for determining the mechanical properties of insulating and sheathing compounds*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60811-100 apply.

4 Test method

4.1 General

This part of IEC 60811 shall be used in conjunction with IEC 60811-100.

Unless otherwise specified, tests shall be carried out at room temperature.

4.2 Apparatus

The ageing is realized in an air bomb which can be filled with air, which shall be free from oil and moisture, to a pressure of $(0,55 \pm 0,02)$ MPa.

4.3 Sample and test pieces preparation

A sample of cable or sheath, removed from the cable, or samples of core, cut into pieces of sufficient length, shall be taken, preferably from positions close to that from which the samples for the tensile tests without ageing are taken, in accordance with IEC 60811-501.

Test pieces, dumb-bell or tubular, shall be prepared according to IEC 60811-501.

4.4 Ageing procedure

This test shall be carried out not less than 16 h after the extrusion or cross-linking, if any, of the insulating or sheathing compounds.

Compounds of obviously different compositions shall not be tested at the same time in the same air bomb.

Five test pieces shall be placed in the air bomb at ambient temperature without touching each other and shall be kept in the bomb at the temperature and for the time specified for the material in the relevant standard for the type of cable.

The test pieces shall not occupy more than one-tenth of the effective capacity of the bomb.

The bomb shall be filled with air, which shall be free from oil and moisture, to a pressure of $(0,55 \pm 0,02)$ MPa.

As soon as the ageing period is completed, the pressure shall be released gradually so as to reach atmospheric pressure in not less than 5 min, in order to avoid formation porosity in the test pieces.

The test pieces shall then be removed from the bomb and left at ambient temperature, avoiding direct sunlight, for at least 16 h.

4.5 Measurements

Determination of the mechanical properties on aged dumb-bell and/or tubular test pieces obtained directly after ageing shall then be carried out in accordance of IEC 60811-501.

4.6 Expression of the result

Calculate the tensile strength and the elongation at break, according to the definitions given in IEC 60811-501.

If required by the standard for the material in the relevant standard for the type of cable, the values found for the aged test pieces shall be calculated, as variation compared to the untreated test pieces according to the following formulae:

$$V_T = \frac{T_E - T_U}{T_U} \times 100 \quad (1)$$

$$V_E = \frac{E_E - E_U}{E_U} \times 100 \quad (2)$$

where

V_T is the variation of the tensile strength in per cent;

T_E is the tensile strength of aged test piece;

T_U is the tensile strength of untreated test piece;

V_E is the variation of the elongation at break in per cent;

E_E is the elongation at break of aged test piece in per cent;

E_U is the elongation at break of untreated test piece in per cent.

The untreated test piece shall be kept at ambient temperature.

The value and the variation between the median value obtained for the aged test pieces and the median value of the values obtained for the untreated test pieces (see IEC 60811-501), expressed as a percentage of the latter shall not exceed the percentage specified in the standard for the material in the relevant standard for the type of cable.

5 Test report

The test report shall be in accordance with that given in IEC 60811-100.

Bibliography

IEC 60811-1-2:1985, *Common test methods for insulating and sheathing materials of electric cables – Part 1: Methods for general application – Section Two – Thermal ageing methods* (withdrawn)

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™