



BSI Standards Publication

Photovoltaic devices

Part 5: Determination of the equivalent cell temperature (ECT) of photovoltaic (PV) devices by the open-circuit voltage method

National foreword

This British Standard is the UK implementation of EN 60904-5:2011. It is identical to IEC 60904-5:2011. It supersedes BS EN 60904-5:1996 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/82, Photovoltaic Energy Systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 70929 6

ICS 27.160

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2011.

Amendments issued since publication

Amd. No.	Date	Text affected
----------	------	---------------

English version

**Photovoltaic devices -
Part 5: Determination of the equivalent cell temperature (ECT) of
photovoltaic (PV) devices by the open-circuit voltage method
(IEC 60904-5:2011)**

Dispositifs photovoltaïques -
Partie 5: Détermination de la température
de cellule équivalente (ECT) des
dispositifs photovoltaïques (PV) par la
méthode de la tension en circuit ouvert
(CEI 60904-5:2011)

Photovoltaische Einrichtungen -
Teil 5: Bestimmung der gleichwertigen
Zellentemperatur von photovoltaischen
(PV) Betriebsmitteln nach dem
Leerlaufspannungs-Verfahren
(IEC 60904-5:2011)

This European Standard was approved by CENELEC on 2011-03-24. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 82/595/CDV, future edition 2 of IEC 60904-5, prepared by IEC TC 82, Solar photovoltaic energy systems, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60904-5 on 2011-03-24.

This European Standard supersedes EN 60904-5:1995.

The main technical changes with regard to EN 60904-5:1995 are as follows:

- added and updated normative references;
- added reporting section;
- added method on how to extract the input parameters;
- rewritten method on how to calculate ECT;
- reworked formulae to be in line with EN 60891.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2011-12-24 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2014-03-24 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60904-5:2011 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60891	-	Photovoltaic devices - Procedures for temperature and irradiance corrections to measured I-V characteristics	EN 60891	-
IEC 60904-1	-	Photovoltaic devices - Part 1: Measurement of photovoltaic current-voltage characteristics	EN 60904-1	-
IEC 60904-2	-	Photovoltaic devices - Part 2: Requirements for reference solar devices	EN 60904-2	-
IEC 60904-7	-	Photovoltaic devices - Part 7: Computation of the spectral mismatch correction for measurements of photovoltaic devices	EN 60904-7	-
IEC 60904-10	-	Photovoltaic devices - Part 10: Methods of linearity measurement	EN 60904-10	-
IEC 61215	-	Crystalline silicon terrestrial photovoltaic (PV) modules - Design qualification and type approval	EN 61215	-
IEC 61829	-	Crystalline silicon photovoltaic (PV) array - On-site measurement of I-V characteristics	EN 61829	-
ISO/IEC 17025	-	General requirements for the competence of testing and calibration laboratories	EN ISO/IEC 17025	-

CONTENTS

INTRODUCTION.....	5
1 Scope and object.....	6
2 Normative references	6
3 Measurement principle and requirements	6
3.1 Principle.....	6
3.2 General measurement requirements.....	7
4 Apparatus.....	7
5 Determination of required input parameters	7
6 Procedure	8
6.1 General.....	8
6.2 Operating in a controlled environment	8
6.3 Taking measurements under arbitrary irradiance conditions	8
7 Calculation of equivalent cell temperature	8
8 Test report.....	9

INTRODUCTION

When temperature sensors, such as thermocouples, are used to determine the cell temperature of PV devices under natural or simulated steady-state irradiance, two main problems arise. First, a considerable spread of temperature can be observed over the area of the module. Second, as the solar cells are usually not accessible, sensors are attached to the back of the module and the measured temperature thus is influenced by the thermal conductivity of the encapsulant and back materials. These problems are aggravated when determining the equivalent cell temperature for on-site measurements of array performance where all cells have slightly different temperatures and one cannot easily determine the average cell temperature.

The equivalent cell temperature (ECT) is the average temperature at the electronic junctions of the device (cells, modules, arrays of one type of module) which equates to the current operating temperature if the entire device were operating uniformly at this junction temperature.

PHOTOVOLTAIC DEVICES –

Part 5: Determination of the equivalent cell temperature (ECT) of photovoltaic (PV) devices by the open-circuit voltage method

1 Scope and object

This part of IEC 60904 describes the preferred method for determining the equivalent cell temperature (ECT) of PV devices (cells, modules and arrays of one type of module), for the purposes of comparing their thermal characteristics, determining NOCT (nominal operating cell temperature) and translating measured I-V characteristics to other temperatures.

This standard applies to linear devices with logarithmic V_{OC} dependence on irradiance and in stable conditions. It may be used for all technologies but one has to verify that there is no preconditioning effect influencing the measurement.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60891, *Photovoltaic devices – Procedures for temperature and irradiance corrections to measured I-V characteristics*

IEC 60904-1, *Photovoltaic devices – Part 1: Measurement of photovoltaic current-voltage characteristics*

IEC 60904-2, *Photovoltaic devices – Part 2: Requirements for reference solar devices*

IEC 60904-7, *Photovoltaic devices – Part 7: Computation of the spectral mismatch correction for measurements of photovoltaic devices*

IEC 60904-10, *Photovoltaic devices – Part 10: Methods of linearity measurement*

IEC 61215, *Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval*

IEC 61829, *Crystalline silicon photovoltaic (PV) array – On-site measurement of I-V characteristics*

ISO/IEC 17025, *General requirements for competence of testing and calibration laboratories*

3 Measurement principle and requirements

3.1 Principle

The method described below is based on the fact that the open-circuit voltage (V_{OC}) of a solar cell changes with temperature in a predictable fashion. If the open-circuit voltage of the device at standard test conditions is known, together with its temperature coefficient, the

equivalent temperature of all the cells in the device can be determined. The open-circuit voltage is also slightly affected by the irradiance, so an additional correction may be required as outlined in IEC 60891. Experience shows that the equivalent cell temperature can be determined more precisely by the method described here than by any alternative technique. However, as the temperature coefficient β drops rapidly at irradiances below 200 W/m^2 , this method should only be used at irradiances above this threshold.

3.2 General measurement requirements

- a) The device under test needs to match the following criteria:
- 1) The variation of V_{OC} needs to be linear as defined in IEC 60904-10 with respect to temperature.
 - 2) The variation of V_{OC} needs to follow a logarithmic dependence with irradiance.
 - 3) It needs to have an ohmic series resistance as otherwise there will be different ECT-coefficients for different temperature regions.
 - 4) The shunt resistances of the device need to be reasonably high, as for the majority of commercially available devices, as otherwise there will be different ECT-coefficients for different temperature regions.
- b) The irradiance measurements shall be made using a PV reference device packaged and calibrated in conformance with IEC 60904-2 or a pyranometer. The PV reference device shall either be spectrally matched to the test specimen, or a spectral mismatch correction shall be performed in conformance with IEC 60904-7. The reference device shall be linear in short-circuit current as defined in IEC 60904-10 over the irradiance range of interest.

In accordance with IEC 60904-2, to be considered spectrally matched, a reference device shall be constructed using the same cell technology and encapsulation package as the test device. Otherwise the spectral mismatch will have to be reported.

NOTE Some devices might have a significant spectral dependency in the open-circuit voltage. In such a case, a spectroradiometer would be needed to ensure stable incident spectrum.

- c) The active surface of the specimen shall be coplanar within $\pm 2^\circ$ of the active surface of the reference device.
- d) Voltages shall be measured to an accuracy of $\pm 0,2 \%$ of the open-circuit voltage using independent leads from the terminals of the specimen and keeping them as short as possible. The measurement ranges of the data acquisition should be carefully chosen. If the test specimen is a module, the 4-wire connection should start at the terminals or connectors. If the test specimen is a cell, the 4-wire connection should start at the bus bars.

4 Apparatus

In addition to the general measurement requirements of Clause 3 the following equipment is required to perform I-V characteristic measurements:

- a) A PV reference device that meets the conditions stated in 3 a).
- b) Equipment to measure the open-circuit voltage to a precision better than $\pm 0,2 \%$.
- c) Equipment to measure temperature to a precision $\pm 1 \text{ K}$.

5 Determination of required input parameters

The procedure requires a number of input parameters. These are:

- Temperature coefficient of the open circuit voltage, β . This shall be determined from cell or module measurements of representative samples in accordance with IEC 60891.
- Open-circuit voltage (V_{OC1}) at a reference condition (G_1, T_1) in accordance with IEC 60904-1 for a cell or module or in accordance with IEC 61829 for a PV array. The

reference condition is often chosen to be the standard test conditions as defined in IEC 61215, i.e. $G_{\text{STC}} = 1\,000\text{ W/m}^2$ and $T_{\text{STC}} = 25\text{ °C}$.

- The procedure requires a constant, a , which is also interpreted as the thermal diode voltage. The determination of this requires the measurement of the open-circuit voltage at two different irradiance levels G_3 and G_4 , one of which may be the point G_1, T_1 .

6 Procedure

6.1 General

The procedure can be carried out either in a controlled environment or by taking measurements at arbitrary irradiances and correcting to the reference irradiance G_1 .

6.2 Operating in a controlled environment

- Mount the radiation sensor coplanar with the test device to an agreement better than $\pm 2^\circ$.
- Set the irradiance to be equal to that of the reference condition G_1 using the reference device.
- Take simultaneous readings of the open-circuit voltage of the test device V_{OC2} and the incident irradiance (G_2). Should there be any variation in the irradiance, treat as a measurement in arbitrary irradiance conditions as given in 6.3 and carry out the appropriate correction. An irradiance correction should be carried out if the scatter in the determined ECT is more than 1 K.
- Calculate the ECT as described in Clause 7.

6.3 Taking measurements under arbitrary irradiance conditions

- Mount the radiation sensor coplanar with the test device to an agreement better than $\pm 2^\circ$.
- Take simultaneous readings of the open-circuit voltage of the test device V_{OC2} and the incident irradiance G_2 .
- Carry out a correction of V_{OC2} to an irradiance equal to G_1 .
- Calculate the ECT as described in Clause 7.

7 Calculation of equivalent cell temperature

The equivalent cell temperature ECT is derived from the single diode equations describing the current voltage characteristic.

Solving the equation for $V_2 = V_{\text{OC2}}$, with $V_1 = V_{\text{OC1}}$ and $I_2 = I_1 = 0$ results in the following dependence of the open circuit voltage:

$$V_{\text{OC2}} = V_{\text{OC1}} + V_{\text{OC1}} \left[\beta(T_2 - T_1) + a \ln \frac{G_2}{G_1} \right] \quad (1)$$

where

V_{OC1} is the open-circuit voltage measured in Clause 5 at the irradiance G_1 and module temperature T_1 ;

V_{OC2} is the open-circuit voltage measured in Clause 6 at irradiance G_2 and module temperature T_2 .

the temperature coefficient of the open-circuit voltage β has also been measured as part of Clause 5 in accordance with IEC 60891;

the parameter, a , is the thermal diode voltage, which can be determined from measurements at different light intensities but identical temperatures as:

$$a = \frac{V_{OC4} - V_{OC3}}{V_{OC3} \ln(G_4/G_3)} \quad (2)$$

where V_{OC3} and V_{OC4} are the voltages measured in Clause 5 at the same module temperatures but at different irradiances G_3 and G_4 , respectively.

Instead of the irradiances G_1 and G_2 , one can also use the ratio of short-circuit currents, which then is called self-reference. This requires short circuit current to be linear according to IEC 60904-10. This simplifies the measurements to be taken significantly as one essentially eliminates the requirement for measuring the irradiance and the dependence on the spectrally matched devices.

The relation between the different values of V_{OC} can then be rewritten to calculate the equivalent ECT as:

$$ECT = T_2 = T_1 + \frac{1}{\beta} \left[\frac{V_{OC2}}{V_{OC1}} - 1 - a \ln\left(\frac{G_2}{G_1}\right) \right] \quad (3)$$

NOTE This assumes that the spatial and thermal non-uniformity between the two V_{OC} is identical. For non-uniform temperature or illumination there will be a small error in ECT because the equivalent circuit model assumes uniform temperature and illumination.

In the case of base measurements described in Clause 5 being taken at standard test conditions, the ECT can be determined as:

$$ECT = 25^\circ\text{C} + \frac{1}{\beta} \left[\frac{V_{OC2}}{V_{OC,STC}} - 1 - a \ln\left(\frac{G_2}{1\,000}\right) \right] \quad (4)$$

This equation is closely related to the formulation of method 1 in the standard for temperature and irradiance corrections (IEC 60891). The factor a is linked to the number of cells (junctions) in series in the module (n_s) as well as the thermal voltage D as defined in IEC 60891. Thus one can write the ECT in terms of this standard as:

$$ECT = T_2 = T_1 + \beta^{-1} \left[\frac{V_{OC2}}{V_{OC1}} - 1 + D \times n_s \times \ln\left(\frac{G_2}{G_1}\right) \right] \quad (5)$$

8 Test report

A test report with measured performance characteristics and test results shall be prepared by the test agency in accordance with ISO/IEC 17025. The test report shall contain the following data:

- a) A title.
- b) Name and address of the test laboratory and location where the tests were carried out.
- c) Unique identification of the report and of each page.
- d) Name and address of client.
- e) A description and identification of the specimen (solar cell, sub-assembly of solar cells or PV module).
- f) Description of the test environment (natural or simulated sunlight and, in the latter case, brief description and class of simulator).
- g) Date of receipt of test item and date(s) of calibration or test, where appropriate.
- h) Reference to sampling procedure, where relevant.

- i) Identification of calibration or test method used.
 - j) Any deviations from, additions to or exclusions from the calibration or test method, and any other information relevant to a specific calibration or test, such as environmental conditions.
 - k) Identification of the method for determination of input parameters.
 - l) A statement of the result and the estimated uncertainty of test results.
 - m) A signature and title, or equivalent identification of the person(s) accepting responsibility for the content of the test report, and the date of issue.
 - n) A statement to the effect that the results relate only to the specimen tested.
 - o) A statement that the test report shall not be reproduced except in full, without the written approval of the laboratory.
-

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™