

BS EN 61400-21:2008



BSI British Standards

Wind turbines —

Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide™

BSI
British Standards

National foreword

This British Standard is the UK implementation of EN 61400-21:2008. It is identical to IEC 61400-21:2008. It supersedes BS EN 61400-21:2002 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/88, Wind turbines.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2009.

© BSI 2009

ISBN 978 0 580 56750 6

ICS 27.180

Amendments issued since publication

Amd. No.	Date	Text affected
-----------------	-------------	----------------------

English version

**Wind turbines -
Part 21: Measurement and assessment
of power quality characteristics of grid connected wind turbines
(IEC 61400-21:2008)**

Eoliennes -
Partie 21: Mesurage et évaluation
des caractéristiques de qualité
de puissance des éoliennes
connectées au réseau
(CEI 61400-21:2008)

Windenergieanlagen -
Teil 21: Messung und Bewertung
der Netzverträglichkeit
von netzgekoppelten
Windenergieanlagen
(IEC 61400-21:2008)

This European Standard was approved by CENELEC on 2008-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 88/317/FDIS, future edition 2 of IEC 61400-21, prepared by IEC TC 88, Wind turbines, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61400-21 on 2008-10-01.

This European Standard supersedes EN 61400-21:2002.

EN 61400-21:2008 includes the following new items with respect to EN 61400-21:2002:

- interharmonics and current distortions (< 9 kHz),
- response to voltage dips,
- active power ramp rate limitation and set-point control,
- reactive power capabilities and set-point control,
- grid protection and reconnection time after grid faults.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2009-07-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2011-10-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61400-21:2008 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61000-3-3	NOTE Harmonized as EN 61000-3-3:2008 (not modified).
IEC 61000-4-30	NOTE Harmonized as EN 61000-4-30:2003 (not modified).
IEC 61400-1	NOTE Harmonized as EN 61400-1:2005 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60044-1 (mod)	- ¹⁾	Instrument transformers - Part 1: Current transformers	EN 60044-1	1999 ²⁾
IEC 60044-2 (mod)	- ¹⁾	Instrument transformers - Part 2: Inductive voltage transformers	EN 60044-2	1999 ²⁾
IEC 60050-161	- ¹⁾	International Electrotechnical Vocabulary (IEV) - Chapter 161: Electromagnetic compatibility	-	-
IEC 60050-415	- ¹⁾	International Electrotechnical Vocabulary (IEV) - Part 415: Wind turbine generator systems	-	-
IEC 61000-4-7	2002	Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto	EN 61000-4-7	2002
IEC 61000-4-15	- ¹⁾	Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications	EN 61000-4-15	1998 ²⁾
IEC 61400-12-1	- ¹⁾	Wind turbines - Part 12-1: Power performance measurements of electricity producing wind turbines	EN 61400-12-1	2006 ²⁾
IEC 61800-3	2004	Adjustable speed electrical power drive systems - Part 3: EMC requirements and specific test methods	EN 61800-3	2004
IEC 62008	- ¹⁾	Performance characteristics and calibration methods for digital data acquisition systems and relevant software	EN 62008	2005 ²⁾

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Symbols and units	11
5 Abbreviations	13
6 Wind turbine power quality characteristic parameters	14
6.1 General.....	14
6.2 Wind turbine specification	14
6.3 Voltage fluctuations.....	14
6.3.1 General	14
6.3.2 Continuous operation	14
6.3.3 Switching operations	15
6.4 Current harmonics, interharmonics and higher frequency components	15
6.5 Response to voltage drops	16
6.6 Active power	16
6.6.1 Maximum measured power	16
6.6.2 Ramp rate limitation	16
6.6.3 Set-point control	17
6.7 Reactive power	17
6.7.1 Reactive power capability	17
6.7.2 Set-point control	17
6.8 Grid protection	18
6.9 Reconnection time.....	18
7 Test procedures	18
7.1 General.....	18
7.1.1 Test validity.....	19
7.1.2 Test conditions	19
7.1.3 Test equipment.....	20
7.2 Wind turbine specification	21
7.3 Voltage fluctuations.....	21
7.3.1 General	21
7.3.2 Fictitious grid.....	21
7.3.3 Continuous operation	23
7.3.4 Switching operations	26
7.4 Current harmonics, interharmonics and higher frequency components	27
7.5 Response to temporary voltage drop	28
7.6 Active power	30
7.6.1 Maximum measured power	30
7.6.2 Ramp rate limitation	31
7.6.3 Set point control	31
7.7 Reactive power	31
7.7.1 Reactive power capability	31
7.7.2 Set point control	32
7.8 Grid protection	32

7.9	Reconnection time.....	33
8	Assessment of power quality	34
8.1	General.....	34
8.2	Voltage fluctuations.....	34
8.2.1	General	34
8.2.2	Continuous operation	35
8.2.3	Switching operations	35
8.3	Current harmonics, interharmonics and higher frequency components	36
Annex A (informative)	Sample report format.....	38
Annex B (informative)	Voltage fluctuations and flicker.....	48
Annex C (informative)	Measurement of active power, reactive power and voltage	56
Bibliography	58
Figure 1	– Adjustment of active power set-point.....	17
Figure 2	– Adjustment of reactive power set-point.....	18
Figure 3	– Assumed elements of measurement system.....	20
Figure 4	– Fictitious grid for simulation of fictitious voltage	22
Figure 5	– System with short circuit emulator for testing wind turbine response to temporary voltage drop.....	29
Figure 6	– Tolerance of voltage drop	30
Figure B.1	– Measurement and assessment procedures for flicker during continuous operation of the wind turbine.....	48
Figure B.2	– Measurement and assessment procedures for voltage changes and flicker during switching operations of the wind turbine.....	49
Figure B.3	– Flicker coefficient as a function of wind speed	50
Table 1	– Specification of voltage drops. The specified magnitudes, duration and shape are for the voltage drop occurring when the wind turbine under test is not connected.....	16
Table 2	– Specification of requirements for measurement equipment.....	21
Table 3	– Specification of exponents according to IEC 61000-3-6.....	37
Table B.1	– Number of measurements $N_{m,i}$ and frequency of occurrence of $f_{m,i}$ and $f_{y,i}$ for each wind speed bin in the range from cut-in wind speed to 15 m/s	51
Table B.2	– Weighting factor w_i for each wind speed bin.....	51
Table B.3	– Total sum of weighting factor multiplied by number of measurements for all wind speed bins	52
Table B.4	– Weighted accumulated distribution of the flicker coefficients $Pr(c < x)$ for each wind speed distribution.....	52
Table B.5	– Resulting flicker coefficient in continuous operation	53
Table B.6	– Probabilities and percentiles for different wind speeds	53

INTRODUCTION

The purpose of this part of IEC 61400 is to provide a uniform methodology that will ensure consistency and accuracy in the presentation, testing and assessment of power quality characteristics of grid connected wind turbines (WTs). The power quality characteristics here include wind turbine specifications, voltage quality (emissions of flicker and harmonics), voltage drop response, power control (control of active and reactive power), grid protection and reconnection time.

This part of IEC 61400 has been prepared with the anticipation that it would be applied by:

- the WT manufacturer striving to meet well-defined power quality characteristics;
- the WT purchaser in specifying such power quality characteristics;
- the WT operator who may be required to verify that stated, or required power quality characteristics are met;
- the WT planner or regulator who has to be able to accurately and fairly determine the impact of a WT on the voltage quality to ensure that the installation is designed so that voltage quality requirements are respected;
- the WT certification authority or component testing organization in evaluating the power quality characteristics of the wind turbine type;
- the planner or regulator of the electric network who has to be able to determine the grid connection required for a WT.

This part of IEC 61400 provides recommendations for preparing the measurements and assessment of power quality characteristics of grid connected WTs. This part of IEC 61400 will benefit those parties involved in the manufacture, installation planning, obtaining of permission, operation, utilization, testing and regulation of WTs. The measurement and analysis techniques recommended in this part of IEC 61400 should be applied by all parties to ensure that the continuing development and operation of WTs are carried out in an atmosphere of consistent and accurate communication.

This part of IEC 61400 presents measurement and analysis procedures expected to provide consistent results that can be replicated by others.

WIND TURBINES –

Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines

1 Scope

This part of IEC 61400 includes:

- definition and specification of the quantities to be determined for characterizing the power quality of a grid connected wind turbine;
- measurement procedures for quantifying the characteristics;
- procedures for assessing compliance with power quality requirements, including estimation of the power quality expected from the wind turbine type when deployed at a specific site, possibly in groups.

The measurement procedures are valid for single wind turbines with a three-phase grid connection. The measurement procedures are valid for any size of wind turbine, though this part of IEC 61400 only requires wind turbine types intended for PCC (Point of Common Coupling) at MV or HV to be tested and characterized as specified in this part of IEC 61400.

The measured characteristics are valid for the specific configuration and operational mode of the assessed wind turbine type only. Other configurations, including altered control parameters that cause the wind turbine to behave differently with respect to power quality, require separate assessment.

The measurement procedures are designed to be as non-site-specific as possible, so that power quality characteristics measured at for example a test site can be considered valid also at other sites.

The procedures for assessing compliance with power quality requirements are valid for wind turbines with PCC at MV or HV in power systems with fixed frequency within ± 1 Hz, and sufficient active and reactive power regulation capabilities. In other cases, the principles for assessing compliance with power quality requirements may still be used as a guidance.

This part of IEC 61400 is for testing of wind turbines, though it contains information that may also be useful for testing of wind farms.

NOTE This part of IEC 61400 uses the following terms for system voltage:

- low voltage (LV) refers to $U_n \leq 1$ kV;
- medium voltage (MV) refers to $1 \text{ kV} < U_n \leq 35$ kV;
- high voltage (HV) refers to $U_n > 35$ kV.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044-1, *Instrument transformers – Part 1: Current transformers*

IEC 60044-2, *Instrument transformers – Part 2: Inductive voltage transformers*

IEC 60050-161, *International Electrotechnical Vocabulary – Part 161: Electromagnetic compatibility*

IEC 60050-415, *International Electrotechnical Vocabulary – Part 415: Wind turbine generator systems*

IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*

IEC 61000-4-15, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 15: Flickermeter – Functional and design specifications*

IEC 61400-12-1, *Wind turbines – Part 12-1: Power performance measurements of electricity producing wind turbines*

IEC 61800-3:2004, *Adjustable speed electrical power drive systems – Part 3: EMC requirements and specific test methods*

IEC 62008, *Performance characteristics and calibration methods for digital data acquisition systems and relevant software*

3 Terms and definitions

For purposes of this document, the following terms and definitions apply.

3.1

continuous operation (for wind turbines)

normal operation of the wind turbine excluding start-up and shutdown operations

3.2

cut-in wind speed (for wind turbines)

lowest wind speed at hub height at which the wind turbine starts to produce power

[IEV 415-03-05]

3.3

flicker coefficient for continuous operation (for wind turbines)

normalized measure of the flicker emission during continuous operation of the wind turbine:

$$c(\psi_k) = P_{st, fic} \times \frac{S_{k, fic}}{S_n}$$

where

$P_{st, fic}$ is the flicker emission from the wind turbine on the fictitious grid;

S_n is the rated apparent power of the wind turbine;

$S_{k, fic}$ is the short-circuit apparent power of the fictitious grid

NOTE The flicker coefficient for continuous operation is the same for a short-term (10 min) and long-term period (2 h).

3.4

flicker step factor (for wind turbines)

a normalized measure of the flicker emission due to a single switching operation of the wind turbine:

$$k_f(\psi_k) = \frac{1}{130} \times \frac{S_{k, \text{fic}}}{S_n} \times P_{\text{st, fic}} \times T_p^{0,31}$$

where

T_p is the measurement period, long enough to ensure that the transient of the switching operation has abated, though limited to exclude possible power fluctuations due to turbulence;

$P_{\text{st, fic}}$ is the flicker emission from the wind turbine on the fictitious grid;

S_n is the rated apparent power of the wind turbine;

$S_{k, \text{fic}}$ is the short-circuit apparent power of the fictitious grid

NOTE The flicker coefficient $P_{\text{st, fic}}$ is here evaluated over the time period T_p .

3.5 maximum measured power (for wind turbines)

power (with a specified averaging time) which is observed during continuous operation of the wind turbine

3.6 network impedance phase angle

phase angle of network short-circuit impedance:

$$\psi_k = \arctan (X_k/R_k)$$

where

X_k is the network short-circuit reactance;

R_k is the network short-circuit resistance

3.7 normal operation (for wind turbines)

fault free operation complying with the description in the wind turbine manual

3.8 operational mode (for wind turbines)

operation according to control setting, for example voltage control mode, frequency control mode, reactive power control mode, active power control mode, etc.

3.9 output power (for wind turbines)

electric active power delivered by the wind turbine at its terminals

[IEV 415-04-02, modified]

3.10 point of common coupling PCC

point of a power supply network, electrically nearest to a particular load, at which other loads are, or may be, connected

NOTE 1 These loads can be either devices, equipment or systems, or distinct customer's installations.

NOTE 2 In some applications, the term "point of common coupling" is restricted to public networks.

[IEV 161-07-15, modified]

3.11 power collection system (for wind turbines)

electrical system that collects the power from a wind turbine and feeds it into an electrical supply network

[IEV 415-04-06, modified]

3.12

rated apparent power (for wind turbines)

apparent power from the wind turbine while operating at rated current and nominal voltage and frequency:

$$S_n = \sqrt{3}U_n I_n$$

where

U_n is the nominal voltage;

I_n is the rated current

3.13

rated current (for wind turbines)

maximum continuous electric output current which a wind turbine is designed to achieve under normal operating conditions

3.14

rated power (for wind turbines)

maximum continuous electric output power which a wind turbine is designed to achieve under normal operating conditions

[IEV 415-04-03, modified]

3.15

rated wind speed (for wind turbines)

wind speed at which a wind turbine's rated power is achieved

[IEV 415-03-04, modified]

3.16

standstill (for wind turbines)

condition of a wind turbine that is stopped

[IEV 415-01-15, modified]

3.17

start-up (for wind turbines)

transitional state of a wind turbine between standstill and power production

3.18

switching operation (for wind turbines)

start-up or switching between generators

3.19

turbulence intensity

ratio of the wind speed standard deviation to the mean wind speed, determined from the same set of measured data samples of wind speed, and taken over a specified period of time

[IEV 415-03-25]

3.20

voltage change factor (for wind turbines)

a normalized measure of the voltage change due to a switching operation of the wind turbine:

$$k_u(\psi_k) = \sqrt{3} \times \frac{U_{\text{fic,max}} - U_{\text{fic,min}}}{U_n} \times \frac{S_{k,\text{fic}}}{S_n}$$

where

$U_{\text{fic,min}}$ and $U_{\text{fic,max}}$ are the minimum and maximum one period RMS value of the phase-to-neutral voltage on the fictitious grid during the switching operation;

U_n is the nominal phase-to-phase voltage;

S_n is the rated apparent power of the wind turbine;

$S_{\text{k, fic}}$ is the short-circuit apparent power of the fictitious grid.

NOTE The voltage change factor k_u is similar to k_i being the ratio between the maximum inrush current and the rated current, though k_u is a function of the network impedance phase angle. The highest value of k_u will be numerically close to k_i .

3.21

wind turbine

WT

system which converts kinetic wind energy into electric energy

3.22

wind turbine terminals

point being a part of the WT and identified by the WT supplier at which the WT may be connected to the power collection system

4 Symbols and units

In this part of IEC 61400, the following symbols and units are used.

$\frac{\Delta U_{\text{dyn}}}{U_n}$ maximum permitted voltage change (%)

ψ_k network impedance phase angle (°)

$\alpha_m(t)$ electrical angle of the fundamental of the measured voltage (°)

β exponent associated with summation of harmonics

$c(\psi_k)$ flicker coefficient for continuous operation

d relative voltage change (%)

E_{Plti} long-term flicker emission limit

E_{Psti} short-term flicker emission limit

f_g nominal grid frequency (50 Hz or 60 Hz)

$f_{\text{m,i}}$ frequency of occurrence of flicker coefficient values within the i'th wind speed bin

f_{over} over-frequency protection level

f_{under} under-frequency protection level

$f_{\text{y,i}}$ frequency of occurrence of wind speeds within the i'th wind speed bin

h harmonic order

$I_{h,i}$	h'th order harmonic current distortion of i'th wind turbine (A)
$i_m(t)$	measured instantaneous current (A)
I_n	rated current (A)
$k_f(\psi_k)$	flicker step factor
k_i	ratio of maximum inrush current and rated current
$k_u(\psi_k)$	voltage change factor
L_{fic}	inductance of fictitious grid (H)
N_{10m}	maximum number of one type of switching operations within a 10 min period
N_{120m}	maximum number of one type of switching operations within a 120 min period
N_{bin}	total number of wind speed bins between v_{cut-in} and 15 m/s
n_i	ratio of the transformer at the i'th wind turbine
N_m	total number of measured flicker coefficient values
$N_{m,i}$	number of measured flicker coefficient values within the i'th wind speed bin
$N_{m,i,c<x}$	number of flicker coefficient values less than x within the i'th wind speed bin
N_{wt}	number of wind turbines
P	active power (W)
$P_{0,2}$	maximum measured active power (0,2 s average value) (W)
P_{60}	maximum measured active power (60 s average value) (W)
P_{600}	maximum measured active power (600 s average value) (W)
P_{lt}	long-term flicker disturbance factor
P_n	rated active power of wind turbine (W)
$Pr(c<x)$	accumulated distribution of c
P_{st}	short-term flicker disturbance factor
$P_{st,fic}$	short-term flicker disturbance factor at fictitious grid
Q	reactive power (var)
R_{fic}	resistance of fictitious grid (Ω)

S_k	short-circuit apparent power of grid (VA)
$S_{k, \text{fic}}$	short-circuit apparent power of the fictitious grid (VA)
S_n	rated apparent power of wind turbine (VA)
THC	total harmonic current distortion (% of I_n)
T_p	transient time period of a switching operation (s)
U	phase-to-phase voltage (V)
$u_0(t)$	instantaneous phase-to-neutral voltage of an ideal voltage source (V)
$u_{\text{fic}}(t)$	instantaneous phase-to-neutral voltage simulated at fictitious grid (V)
$U_{\text{fic,max}}$	maximum phase-to-neutral voltage at fictitious grid (V)
$U_{\text{fic,min}}$	minimum phase-to-neutral voltage at fictitious grid (V)
U_n	nominal phase-to-phase voltage (V)
U_{under}	under-voltage protection level
U_{over}	over-voltage protection level
v_a	annual average wind speed (m/s)
$v_{\text{cut-in}}$	cut-in wind speed (m/s)
v_i	mid-point of the i 'th wind speed bin
w_i	weighting factor for the i 'th wind speed bin
X_{fic}	reactance of fictitious grid (Ω)
Z_1	impedance for limiting the effect of the short-circuit on the upstream grid (Ω)
Z_2	impedance between phases or to ground during short-circuit (Ω)

5 Abbreviations

The following abbreviations are used in this part of IEC 61400.

A/D converter	analogue to digital converter
DFT	discrete Fourier transform
HV	high voltage
LV	low voltage

MV	medium voltage
PCC	point of common coupling
RMS	root mean square
SCADA	supervisory control and data acquisition
THC	total harmonic current distortion
WT	wind turbine

6 Wind turbine power quality characteristic parameters

6.1 General

This clause gives the quantities that shall be stated for characterizing the power quality of a wind turbine, i.e. wind turbine specifications (6.2), voltage quality (6.3 to 6.4), voltage drop response (6.5), power control (6.6 to 6.7), grid protection and reconnection (6.8 to 6.9). a sample report format is given in Annex A.

Generator sign convention shall be used, i.e. the positive direction of the power flow is defined to be from the generator to the grid. If the wind turbine is replaced with a resistor and an inductor, both active and reactive power will be negative.

6.2 Wind turbine specification

The rated data of the wind turbine (referred to the wind turbine terminals) shall be specified, including P_n , S_n , U_n and I_n .

NOTE The rated data are used only for normalizing purposes in this part of IEC 61400.

6.3 Voltage fluctuations

6.3.1 General

The voltage fluctuations (flicker and voltage changes) imposed by the wind turbine shall be characterized as described in 6.3.2 and 6.3.3.

6.3.2 Continuous operation

The wind turbine flicker coefficient for continuous operation, $c(\psi_k, v_a)$ shall be stated as the 99th percentile for the network impedance phase angles $\psi_k = 30^\circ, 50^\circ, 70^\circ$ and 85° in a Table for four different wind speed distributions with annual average wind speed $v_a = 6$ m/s, 7,5 m/s, 8,5 m/s and 10 m/s respectively. The 10 min average values of the wind speed shall be assumed to be Rayleigh distributed (see Note). The annual average wind speed refers to the hub height of the wind turbine.

The characteristics shall be stated for the wind turbine operating with reactive power as close as possible to zero, i.e. if applicable, the reactive set-point control shall be set to $Q=0$. If any other operational mode is used, this shall be clearly stated.

NOTE The Rayleigh distribution is a probability distribution that commonly fits the annual wind speed distribution. The Rayleigh distribution may be described by:

$$F(v) = 1 - \exp\left(-\frac{\pi}{4}\left(\frac{v}{v_a}\right)^2\right)$$

where

$F(v)$ is the Rayleigh cumulative probability distribution function for the wind speed;

v_a is the annual average wind speed at hub height;

v is the wind speed.

6.3.3 Switching operations

The characteristics shall be stated for the following types of switching operations:

- a) Wind turbine start-up at cut-in wind speed.
- b) Wind turbine start-up at rated wind speed or higher wind speed.
- c) The worst case of switching between generators (applicable only to wind turbines with more than one generator or a generator with multiple windings). See also Note 1.

For each of the above types of switching operations, the values of the parameters below shall be stated (see also Notes 2 and 3):

- The maximum number N_{10m} of the switching operation within a 10 min period.
- The maximum number N_{120m} of the switching operation within a 2 h period.
- The flicker step factor $k_f(\psi_k)$ for the network impedance phase angles $\psi_k = 30^\circ, 50^\circ, 70^\circ$ and 85° .
- The voltage change factor $k_u(\psi_k)$ for the network impedance phase angles $\psi_k = 30^\circ, 50^\circ, 70^\circ$ and 85° .

The characteristics shall be stated for the wind turbine operating with reactive power as close as possible to zero, i.e. if applicable the reactive set-point control shall be set to $Q=0$. If other operational mode is used, this shall be clearly stated.

NOTE 1 The worst case of switching between generators is in the context of flicker step factor defined as the switching operation that gives the highest flicker step factor, and in the context of voltage change factor defined as the switching operation that gives the highest voltage change factor.

NOTE 2 The parameters N_{10m} and N_{120m} may be based on manufacturers information, whereas $k_f(\psi_k)$ and $k_u(\psi_k)$ should be measured and computed.

NOTE 3 Depending on the control system of the wind turbine, the maximum number of the switching operation within a 2 h period may be less than twelve times the maximum number of the switching operation within a 10 min period.

6.4 Current harmonics, interharmonics and higher frequency components

The emission of current harmonics, interharmonics and higher frequency components during continuous operation shall be stated (see Note).

The values of the individual current components (harmonics, interharmonics and higher frequency components) and the total harmonic current distortion shall be given in tables in percentage of I_n and for operation of the wind turbine within the active power bins 0, 10, 20, ... , 100 % of P_n . 0, 10, 20, ... , 100 % are the bin midpoints.

The individual harmonic current components shall be specified as subgrouped values for frequencies up to 50 times the fundamental grid frequency, and the total harmonic current distortion shall be stated as derived from these.

The interharmonic current components shall be specified as subgrouped values for frequencies up to 2 kHz in accordance to Annex A of IEC 61000-4-7:2002.

The higher frequency current components shall be specified as subgrouped values for frequencies between 2 kHz and 9 kHz in accordance to Annex B of IEC 61000-4-7:2002.

The current harmonics, interharmonics and higher frequency components shall be stated for the wind turbine operating with reactive power as close as possible to zero, i.e. if applicable the reactive set-point control shall be set to $Q=0$. If other operational mode is used, this shall be clearly stated.







NOTE Harmonics are considered harmless as long as the duration is limited to a short period of time. Hence, this part of IEC 61400 does not require specification of short-duration harmonics caused by wind turbine start-up or other switching operations.

6.5 Response to voltage drops

The response of the wind turbine to the voltage drops specified in Table 1 shall be stated for the wind turbine operating at a) between $0,1 P_n$ and $0,3 P_n$ and b) above $0,9 P_n$. The stated response shall include results from 2 consecutive tests of each case (VD1-VD6) by time-series of active power, reactive power, active current, reactive current and voltage at the wind turbine terminals for the time shortly prior to the voltage drop and until the effect of the voltage drop has abated, but also the wind turbine operational mode shall be specified.

The test is basically for verifying wind turbine response to voltage drops (due to grid faults) and providing a basis for wind turbine numerical simulation model validation. Optional tests and measurements (for example pitch angle and rotational speed) may be carried out and reported for more detailed assessment of simulation models and compliance with specific grid code requirements.

Table 1 – Specification of voltage drops. The specified magnitudes, duration and shape are for the voltage drop occurring when the wind turbine under test is not connected

Case	Magnitude of voltage phase to phase (fraction of voltage immediately before the drop occurs)	Magnitude of positive sequence voltage (fraction of voltage immediately before the drop occurs)	Duration (s)	Shape
VD1 – symmetrical three-phase voltage drop	$0,90 \pm 0,05$	$0,90 \pm 0,05$	$0,5 \pm 0,02$	
VD2 – symmetrical three-phase voltage drop	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,5 \pm 0,02$	
VD3 – symmetrical three-phase voltage drop	$0,20 \pm 0,05$	$0,20 \pm 0,05$	$0,2 \pm 0,02$	
VD4 – two-phase voltage drop	$0,90 \pm 0,05$	$0,95 \pm 0,05$	$0,5 \pm 0,02$	
VD5 – two-phase voltage drop	$0,50 \pm 0,05$	$0,75 \pm 0,05$	$0,5 \pm 0,02$	
VD6 – two-phase voltage drop	$0,20 \pm 0,05$	$0,60 \pm 0,05$	$0,2 \pm 0,02$	

NOTE 1 A voltage drop may cause a wind turbine to cut-out for many reasons, not only related to the electrical drive train but also due to mechanical vibrations or ancillary system low voltage capabilities. It is therefore necessary to do the test on the complete wind turbine rather than relying on drive train testing only.

NOTE 2 The purpose of VD1 and VD4 is basically for testing of wind turbines that have no capabilities to ride-through any deep voltage drops, and the tests are generally relevant as basis for validation of numerical simulation models.

6.6 Active power

6.6.1 Maximum measured power

The maximum measured power of the wind turbine shall be specified as a 600 s average value, P_{600} , a 60 s average value, P_{60} and as a 0,2 s average value, $P_{0,2}$.

6.6.2 Ramp rate limitation

The ability of the wind turbine to operate in ramp rate limitation control mode shall be characterized by test results presented in a graph. The graph shall show available and

measured active power output during operation at a ramp rate value of 10 % of rated power per minute for a test period of 10 min.

The test results shall be reported as 0,2 s average data.

6.6.3 Set-point control

The ability of the wind turbine to operate in active power set-point control mode shall be characterized by test results presented in a graph. The graph shall show available and measured active power output during operation at set point values being adjusted from 100 % down to 20 % of rated power in steps of 20 % with 2 min operation at each set-point value, i.e. according to Figure 1.

The test results shall be reported as 0,2 s average data.

NOTE The ability of a wind turbine to participate in an automatic frequency control scheme is closely linked to its ability to operate in active power set-point control mode. Participation in automatic frequency control can for instance be achieved through the SCADA system of a modern wind farm that may continuously update the active power set-point of the individual wind turbines to achieve a requested frequency response.




Figure 1 – Adjustment of active power set-point

6.7 Reactive power

6.7.1 Reactive power capability

The capability of the WT concerning the maximum inductive reactive power and the maximum capacitive reactive power of the WT shall be specified in a Table as 1 min average values as a function of the 1 min average output power for 0, 10, 90, 100 % of the rated power.

6.7.2 Set-point control

The reactive power set-point control shall be described by a table and a graph as follows.

- The table shall show measured reactive power at reactive set point value = 0 for operation at 0, 10, 20, ... 100 % active power output.
- The active and reactive power shall be 1 min average values.

The graph shall show measured reactive power during a step change of the reactive power set-point as specified in Figure 2. The active power output, measured as 1 min average values, shall be approximately 50 % of rated power. The reactive power shall be 0,2 s average data.




Figure 2 – Adjustment of reactive power set-point

NOTE The ability of a wind turbine to participate in an automatic voltage control scheme is closely linked to its ability to operate in reactive power set-point control mode. Participation in automatic voltage control can, for instance, be achieved through the SCADA system of a modern wind farm that may continuously update the reactive power set-point of the individual wind turbines to achieve a requested voltage response.

6.8 Grid protection

The functionality of the wind turbine grid protection system is tested. With the given settings of disconnection levels and disconnection times, the actual disconnection levels and disconnection times of the WT shall be determined for over- and under-voltage and over- and under-frequency.

The disconnection level is the voltage or frequency that causes the wind turbine to disconnect.

The disconnection time is the time duration from start of the under-/over- voltage or frequency and until the wind turbine has disconnected.

6.9 Reconnection time

The reconnection time after the wind turbine has been disconnected due to a grid failure shall be characterized by test results presented in a Table. The Table shall show the reconnection time after the grid has failed for 10 s, 1 min and 10 min respectively. The reconnection time is the time from the instant when the grid is available on the wind turbine terminals to the instant when the wind turbine starts to produce power.

7 Test procedures

7.1 General

This Subclause 7.1 gives general information about the validity of the measurements, required test conditions and equipment. Subclauses 7.2 to 7.9 state the required measurements to be taken to determine the characteristic power quality parameters of the assessed wind turbine, i.e. wind turbine specifications (7.2), voltage quality (7.3 to 7.4), voltage drop response (7.5), power control (7.6 to 7.7), grid protection and reconnection (7.8 to 7.9).

The measurement procedures are valid for single wind turbines with a three-phase grid connection.

The measurements aim in general to verify the characteristic power quality parameters for the full operational range of the assessed wind turbine. Measurements are however not required for wind speeds above 15 m/s (see Note 1). This is because requiring measurements at higher wind speeds would normally give a significantly longer measurement period due to the rare appearance of higher wind speeds, and are not expected to give significantly better verification of the characteristic power quality parameters of the assessed wind turbine. See also Note 2.

NOTE 1 If measurements are taken above 15 m/s, they can be omitted. If they are included however, the applied wind speed range should be stated in the test report.

NOTE 2 Inclusion of measurements above 15 m/s may improve the accuracy of the determined flicker coefficient, and for some wind turbine design give greater maximum measured power (0,2 s average). Aiming for a balance between cost and accuracy however, inclusion of measurements above 15 m/s is not required. If measurements above 15 m/s are included, this will improve confidence in the results of the procedures of 8.2 for high-wind speed sites. See also Note 5 in 7.3.3.

7.1.1 Test validity

The measured characteristics are valid for the specific configuration of the assessed wind turbine type only. Other configurations, including altered control parameters, that cause the wind turbine to behave differently with respect to power quality, require separate assessment. Such assessment can be made by simulation.

Some wind turbine designs include a built-in transformer. The measurements of the electrical characteristics shall be made at the wind turbine terminals. It is up to the WT supplier to define the wind turbine terminals to be at the lower-voltage or higher-voltage side of the transformer. Changing the transformer from one output voltage to another is not expected to cause the wind turbine to behave differently with respect to power quality. Thus, separate assessment is not required if the transformer output voltage is changed, except that rated voltage and current shall be updated.

The location of the wind turbine terminals (being the measurement point) and the specific configuration of the assessed wind turbine including the relevant control parameter settings shall be clearly stated in the test report (Annex A).

Any selection of tests can be done and reported separately, for example voltage quality (7.3 to 7.4), power control (7.6 to 7.7) and voltage drop response (7.5).

7.1.2 Test conditions

The following test conditions are required, and shall be measured and reported as part of the test procedure (see Note 1). Any test data measured during periods not complying with the given test conditions shall be excluded.

- The wind turbine shall be connected directly to the MV-network through a standard transformer with rated apparent power at least corresponding to the rated apparent power of the assessed wind turbine.
- The total harmonic distortion of the voltage including all harmonics up to the order of 50 shall be less than 5 % measured as 10 min average data at the wind turbine terminals while the wind turbine is not generating. The total harmonic distortion of the voltage may be determined by measurement prior to testing the wind turbine.
- The grid frequency measured as 0,2 s average data shall be within ± 1 % of the nominal frequency, and the rate of change of the grid frequency measured as 0,2 s average data shall be less than 0,2 % of the nominal frequency per 0,2 s. If the grid frequency is known to be very stable and well within the above requirements, which would commonly be the case in a large interconnected power system, this need not be assessed any further. Otherwise, the grid frequency shall be measured during the test.

- The voltage shall be within $\pm 10\%$ of its nominal value measured as 10 min average data at the wind turbine terminals.
- The voltage unbalance factor shall be less than 2 % measured as 10 min data at the wind turbine terminals. The voltage unbalance factor may be determined as described in IEC 61800-3:2004, Clause B.3. If the voltage unbalance factor is known to be well within the above requirement, it need not be assessed any further. Otherwise, the voltage unbalance factor shall be measured during the test.
- The environmental conditions shall comply with the manufacturer's requirements for the instruments and the wind turbine. Commonly, this does not call for any online measurements of the environmental conditions, though it is required that these are described in general terms as part of the measurement report. See also Note 2.

Tests may be prepared at any turbulence intensity and at any short-circuit ratio, but conditions (average turbulence intensity, short-circuit apparent power and network impedance angle) shall be stated as part of the test report/certificate. The turbulence intensity shall be stated based on sector-wise identification of obstacles and terrain variations or based on wind speed measurements.

NOTE 1 The specified conditions are required to achieve reliable test results, and should not be interpreted as conditions for reliable grid connection and operation of wind turbines.

NOTE 2 The maximum measured power may for some wind turbine designs to some degree depend on the air density. Hence, the maximum measured power determined following the procedure in 7.6.1 and measured at a site with low air density may be less than at a site with higher air density. It is, however, found that the uncertainty introduced by not specifying a limited air density range cannot justify the cost of additional equipment and procedures associated with this.

7.1.3 Test equipment

The description of the measurements assumes application of a digital data acquisition system with elements as illustrated in Figure 3.




Figure 3 – Assumed elements of measurement system

The anemometer, voltage transducers (transformers) and current transducers (transformers) are the required sensors of the measurement system. The signal conditioning is for connecting these to the low-pass filter that are required for anti-aliasing. The analogue to digital conversion (A/D) shall be of at least 12 bit resolution, i.e. to maintain the required measurement accuracy. See Table 2 for specification of equipment accuracy.

Table 2 – Specification of requirements for measurement equipment

Equipment	Required accuracy	Compliance with standard
Voltage transformers	Class 1,0	IEC 60044-2
Current transformers	Class 1,0	IEC 60044-1
Anemometer	±0,5 m/s	IEC 61400-12-1 (as a guidance)
Filter + A/D converter + data acquisition system	1 % of full scale	IEC 62008

The digital data acquisition system is assumed to log, calculate and store results as specified in the subsequent clauses. General guidance for calculation of RMS voltage, active and reactive power in a system as outlined in Figure 3 is given in Annex C. This requires a sample rate of at least 2 kHz per channel of the voltage and current signals. For measurement of harmonics (higher frequency components) the minimum sample rate shall be at least 20 kHz per channel.

The wind speed signal shall be sampled with at least 1 Hz.

Ideally, a hub-height anemometer located at a position unaffected by wind turbine blockage or wind turbine wakes should be applied for measuring the wind speed. A position 2,5 rotor diameters upstream will generally give good definition. Alternatively, hub-height wind speed can be estimated from lower level measurement or from corrected nacelle wind speed measurement possibly in conjunction with power measurements and knowledge of the power curve. Either way, uncertainties due to anemometer location should not exceed ± 1 m/s.

7.2 Wind turbine specification

Based on manufacturer's information, the wind turbine specifications as outlined in 6.2 shall be stated.

7.3 Voltage fluctuations

7.3.1 General

As stated in 7.1.2, the wind turbine under test shall be connected to an MV-network. The MV-network will normally have other fluctuating loads that may cause significant voltage fluctuations at the wind turbine terminals where the test measurements are taken. Moreover, the voltage fluctuations imposed by the wind turbine will depend on the characteristics of the grid. The aim is, however, to achieve test results which are independent of the grid conditions at the test site. To accomplish this, this part of IEC 61400 specifies a method that uses current and voltage time-series measured at the wind turbine terminals to simulate the voltage fluctuations on a fictitious grid with no source of voltage fluctuations other than the wind turbine (see Note).

The application of the fictitious grid is further described in 7.3.2. The measurement procedures for voltage fluctuations are separated into procedures for continuous operation (see 7.3.3) and switching operations (see 7.3.4). This separation reflects that the flicker emission from a wind turbine has the character of stochastic noise during continuous operation, whereas the flicker emission and voltage changes during switching operations have the character of a number of time limited, non-coincident events.

NOTE Although the specified method to simulate the voltage fluctuations on a fictitious grid avoids the direct influence of the real voltage fluctuations of the grid at the measurement point on flicker, there may be an influence of these voltage fluctuations, imposed by other sources, on the measured current from the wind turbine. This in turn may influence the simulated voltage fluctuations on the fictitious grid. However, this effect is relatively small and does not justify changing the procedure for determining the flicker coefficient.

7.3.2 Fictitious grid

The phase diagram of the fictitious grid is shown in Figure 4.




Figure 4 – Fictitious grid for simulation of fictitious voltage

The fictitious grid is represented by an ideal phase-to-neutral voltage source with the instantaneous value $u_0(t)$ and a grid impedance given as a resistance R_{fic} in series with an inductance L_{fic} . The wind turbine is represented by the current generator $i_m(t)$, which is the measured instantaneous value of the line current. This simple model gives a simulated voltage with the instantaneous value $u_{fic}(t)$ according to equation (1):

$$u_{fic}(t) = u_0(t) + R_{fic} \times i_m(t) + L_{fic} \times \frac{di_m(t)}{dt} \quad (1)$$

The ideal voltage source $u_0(t)$ can be generated in different ways. But two properties of the ideal voltage should be fulfilled:

- the ideal voltage should be without any fluctuations, i.e. the flicker on the voltage should be zero;
- $u_0(t)$ shall have the same electrical angle $\alpha_m(t)$ as the fundamental of the measured voltage. This ensures the phase angle between $u_{fic}(t)$ and $i_m(t)$ is correct, provided that $|u_{fic}(t) - u_0(t)| \ll |u_0(t)|$.

To fulfil these properties, $u_0(t)$ is defined as:

$$u_0(t) = \sqrt{\frac{2}{3}} \times U_n \times \sin(\alpha_m(t)) \quad (2)$$

where U_n is the r.m.s. value of the nominal voltage of the grid.

The electrical angle of the fundamental of the measured voltage may be described by equation (3).

$$\alpha_m(t) = 2\pi \times \int_0^t f(t) dt + \alpha_0 \quad (3)$$

where

$f(t)$ is the frequency (that may vary over time);

t is the time since the start of the time-series;

α_0 is the electrical angle at $t = 0$.

R_{fic} and L_{fic} shall be selected to obtain the appropriate network impedance phase angle ψ_k applying equation (4) below:

$$\tan(\psi_k) = \frac{2\pi \times f_g \times L_{fic}}{R_{fic}} = \frac{X_{fic}}{R_{fic}} \quad (4)$$

where f_g is the nominal grid frequency (50 or 60 Hz).

The three-phase short-circuit apparent power of the fictitious grid is given by equation (5) below:

$$S_{k, \text{fic}} = \frac{U_n^2}{\sqrt{R_{\text{fic}}^2 + X_{\text{fic}}^2}} \quad (5)$$

A proper short-circuit ratio $S_{k, \text{fic}}/S_n$ shall be used to assure that the applied flickermeter algorithm or instrument gives P_{st} values that are well within the measurement range required in IEC 61000-4-15. Because the intention of the procedure described in IEC 61000-4-15 is to determine if a specific fluctuating voltage causes flicker, the procedure in IEC 61000-4-15 does not treat small voltage fluctuations very accurately. Larger voltage fluctuations can be obtained by decreasing the short-circuit ratio. On the other hand, if the short-circuit ratio becomes too small, the mean RMS value of $u_{\text{fic}}(t)$ will deviate significantly from the RMS value of $u_0(t)$, which will influence the relative voltage changes because the absolute voltage changes are normalised with a different mean value. To obtain simulated voltage fluctuations within the flickermeter range, this part of IEC 61400 therefore suggests using a short-circuit ratio $S_{k, \text{fic}}/S_n$ between 20 and 50, though it is the responsibility of the assessor to select the appropriate ratio. It is also recommended to use 6 400 classifier levels instead of the 64 levels proposed in IEC 61000-4-15 to obtain a better resolution. The accuracy of the calculated P_{st} values should be better than 5 %.

7.3.3 Continuous operation

The flicker coefficient $c(\psi_k, v_a)$ shall be determined so it can be stated according to 6.3.2. This shall be done by measurement and simulation.

This subclause gives the detailed procedure, whereas an informative outline is provided in Clause B.1.

The following measurements shall be performed:

- a) The three instantaneous line currents and the three instantaneous phase-to-neutral voltages shall be measured at the wind turbine terminals. See also Note 1.
- b) Measurements shall be taken so that at least fifteen 10 min time-series of instantaneous voltage and current measurements (five tests and three phases) are collected for each 1 m/s wind speed bin between cut-in wind speed and 15 m/s. Here, the wind speed is measured as 10 min-average values.
- c) The wind speed shall be measured according to 7.1.3.
- d) Switching operations are excluded except such as switching of capacitors that occur during continuous operation of the wind turbine.

The voltage flicker during the test shall be reported. The voltage flicker shall be measured at the wind turbine terminals and according to IEC 61000-4-15. See also Note in 7.3.1.

The measurements shall be taken with a measurement set-up as specified in Figure 3, and by applying voltage and current transformers and an anemometer with specifications according to Table 2. The cut-off frequency of the voltage and current measurements shall be at least 400 Hz. See Note 2.

The measurements shall be treated to determine the flicker coefficient of the wind turbine as a function of the network impedance phase angle and wind speed distribution. This shall be done repeating the following procedure for each of the network impedance phase angles and wind speed distributions specified in 6.3.2.

First, the flicker coefficient for each set of 10 min measured voltage and current time-series shall be determined. The procedure for this is given in steps 1) to 3) below.

- 1) The measured time-series shall be combined with equation (1) to give voltage time-series of $u_{\text{fic}}(t)$.
- 2) The voltage time-series of $u_{\text{fic}}(t)$ shall be input to the flicker algorithm in compliance with IEC 61000-4-15 to give one flicker emission value $P_{\text{st, fic}}$ on the fictitious grid for each 10 min time-series.
- 3) The flicker coefficient shall be determined for each of the calculated flicker emission values by applying the equation (6)

$$c(\psi_k) = P_{\text{st, fic}} \times \frac{S_{k, \text{fic}}}{S_n} \quad (6)$$

where

S_n is the rated apparent power of the wind turbine;

$S_{k, \text{fic}}$ is the short-circuit apparent power of the fictitious grid.

See also Note 3.

Secondly, a weighting factor shall be determined for each wind speed bin to scale the measured frequency of occurrence of the flicker coefficients to correspond with the assumed wind speed distribution. The procedure for finding the weighting factor is described in steps 4) to 6) below.

- 4) As specified in 6.3.2, the assumed frequency of occurrence $f_{y,i}$ of wind speeds within the i 'th wind speed bin shall correspond to a Rayleigh distribution, i.e.:

$$f_{y,i} = \exp\left(-\frac{\pi}{4} \times \left(\frac{v_i - 0,5}{v_a}\right)^2\right) - \exp\left(-\frac{\pi}{4} \times \left(\frac{v_i + 0,5}{v_a}\right)^2\right) \quad (7)$$

where

v_i is the midpoint of the i 'th wind speed bin;

v_a is the assumed annual average wind speed.

- 5) The actual frequency of occurrence $f_{m,i}$ of measured flicker coefficients within the i 'th wind speed bin is given by:

$$f_{m,i} = \frac{N_{m,i}}{N_m} \quad (8)$$

where

$N_{m,i}$ is the number of flicker coefficient values measured within the i 'th wind speed bin;

N_m is the total number of flicker coefficient values.

- 6) The weighting factor shall be determined for each 1 m/s wind speed bin between $v_{\text{cut-in}}$ and 15 m/s by inserting calculated values of $f_{y,i}$ and $f_{m,i}$ in the equation (9) below:

$$w_i = \frac{f_{y,i}}{f_{m,i}} \quad (9)$$

Finally, the weighted accumulated distribution of the measured flicker coefficient values shall be found, and the flicker coefficient $c(\psi_k, v_a)$ shall be determined as the 99th percentile of this distribution (see Notes 4 and 5). The procedure for this is given in steps 7) to 8) below:

- 7) The weighted accumulated distribution of the flicker coefficient values is given by equation (10):

$$\Pr(c < x) = \frac{\sum_{i=1}^{N_{\text{bin}}} w_i \times N_{m,i,c < x}}{\sum_{i=1}^{N_{\text{bin}}} w_i \times N_{m,i}} \quad (10)$$

where

$N_{m,i,c < x}$ is the number of flicker coefficient values less than or equal to the value x within the i 'th wind speed bin;

N_{bin} is the total number of wind speed bins.

8) The flicker coefficient shall be determined as the 99th percentile of the weighted accumulated distribution of the flicker coefficient values. This shall be done by calculating $\Pr(c < x)$ and reading the 99th percentile from that.

The above procedure steps 4) to 8) are further illustrated in Clause B.3.

The long-term flicker emission can, according to IEC 61000-3-7, be calculated as the cubic average of 12 consecutive short-term values. Considering that the flicker emission from a wind turbine is a function of the wind speed, and that wind conditions are likely to persist for a 2 h period, 12 consecutive short-term values are likely to be equal. Hence, for wind turbines the long-term flicker emission coefficient becomes equal to the short-term value.

NOTE 1 If the phase-to-neutral voltages are not available, the phase-to-phase voltages should be measured and the phase-to-neutral voltages calculated from the measured phase-to-phase voltages. The phase-to-neutral voltages may be calculated from measured phase-to-phase voltages according to the equations below:

$$u_1 = \frac{u_{12} - u_{31}}{3}$$

$$u_2 = \frac{u_{23} - u_{12}}{3}$$

$$u_3 = \frac{u_{31} - u_{23}}{3}$$

where

u_1 , u_2 and u_3 are the instantaneous phase-to-neutral voltages;

u_{12} , u_{31} and u_{23} are the instantaneous phase-to-phase voltages.

NOTE 2 The flicker algorithm described in IEC 61000-4-15 generates the RMS value of $u_{\text{fic}}(t)$, and then cuts off variations faster than 35 Hz. Still a minimum cut-off frequency of 400 Hz, corresponding to a minimum sampling frequency of 800 Hz is required for flicker measurements of continuous operation in this part of IEC 61400. Test calculations have shown that this sampling frequency is necessary to obtain consistent results. A lower sampling frequency will reduce the accuracy of the electrical angle of the fundamental of the measured voltage $\alpha_m(t)$.

NOTE 3 The formula defining the flicker coefficient is further explained in B.4.1.

NOTE 4 The 99th percentile is applied as flicker emission limits usually relate to this percentile.

NOTE 5 As stated in 6.3.2, $c(\psi_k, v_a)$ should be determined for $v_a = 6$ m/s, 7,5 m/s, 8,5 m/s and 10 m/s respectively. Furthermore, as stated in this subclause, measurements are only required up to 15 m/s. Assuming the wind speed to be Rayleigh distributed, it can be calculated that 15 m/s corresponds to the 99th percentile for $v_a = 6$ m/s, and a further 96 %, 91 % and 83 % for $v_a = 7,5$ m/s, 8,5 m/s and 10 m/s respectively. Hence, although $c(\psi_k, v_a)$ is determined according to this subclause as the 99th percentile of the data set, it may represent lower percentiles for Rayleigh distributed wind speed distributions with $v_a = 7,5$ m/s, 8,5 m/s and 10 m/s. This is further explained in Clause B.3. It is however judged that the uncertainty of the actual percentiles do not justify requiring measurements at higher wind speeds to expand the data set to ensure 99th percentiles also for $v_a = 7,5$ m/s, 8,5 m/s and 10 m/s, as this would often dramatically increase the required testing period. It is however open for users of this part of IEC 61400 to agree to include measurements above 15 m/s in order to improve the accuracy of $c(\psi_k, v_a)$ for $v_a > 6$ m/s.

7.3.4 Switching operations

Based on manufacturer's information, the maximum number of switching operations, N_{10m} and N_{120m} shall be determined for each type of switching operation specified in 6.3.3. In the event that the wind turbine manufacturer cannot provide these numbers, or the manufacturer cannot provide sufficient specification of the wind turbine control system to support the provided numbers, the following shall be assumed:

- a) Wind turbine start-up at cut-in wind speed: $N_{10m} = 10$ and $N_{120m} = 120$.
- b) Wind turbine start-up at rated wind speed or higher wind speed: $N_{10m} = 1$ and $N_{120m} = 12$.
- c) The worst case of switching between generators: $N_{10m} = 10$ and $N_{120m} = 120$.

Measurements and subsequent simulations and calculations shall be prepared to determine the voltage change factor $k_u(\psi_k)$, and the flicker step factor $k_f(\psi_k)$ for each type of switching operation specified in 6.3.3.

This subclause gives the detailed procedure, whereas an informative outline is provided in Clause B.2.

Whereas 6.3.3 a) and 6.3.3 b) each specify a switching at a specific wind speed, it is the task of the assessor to identify the conditions of 6.3.3 c). This may be done by assessment of the wind turbine design, or if this does not give sufficient evidence, measurements shall be taken to identify the conditions for 6.3.3 c). See also Note 1 in 6.3.3.

To determine the voltage change factor $k_u(\psi_k)$, and the flicker step factor $k_f(\psi_k)$, the following measurements shall be prepared:

- i) The three instantaneous line currents and the three instantaneous phase-to-neutral voltages shall be measured at the wind turbine terminals.
- ii) The measurements shall be taken for a period, T_p , long enough to ensure that the transient of the switching operation has abated, though limited to exclude possible power fluctuations due to turbulence.
- iii) In order to ensure that the results of the measurements are representative of the normal average conditions, each case should be performed five times.
- iv) The wind speed shall be measured according to 7.1.3. The 1 min average wind speed during the switching operation shall be within a range of ± 2 m/s of the required wind speed.

The measurements shall be taken with a measurement set-up as specified in Figure 3, and by applying voltage and current transformers and an anemometer with specifications according to Table 2. The cut-off frequency of the voltage and current measurements shall be at least 1 500 Hz (see Note 1). As a guidance, for wind turbines applying soft-starters or other effective limitation of the inrush currents, the current transformers should be rated two to four times the rated current. For wind turbines without any inrush current limitation, as a guidance, the current transformers should be rated 10 to 20 times the rated current of the wind turbine.

The measurements shall be treated to determine the voltage change factor and the flicker step factor. This shall be done applying the following procedure.

- 1) The measured time-series shall be combined to give voltage time-series of $u_{fic}(t)$.
- 2) The simulated voltage time-series of $u_{fic}(t)$ shall be input to the flicker algorithm in compliance with IEC 61000-4-15 to give one flicker emission value $P_{st, fic}$ on the fictitious grid for each time-series of $u_{fic}(t)$. This will result in 15 values of $P_{st, fic}$ for each case, i.e. five tests and three phases.
- 3) The flicker step factor $k_f(\psi_k)$ shall be calculated according to its equation (11) below.

$$k_f(\psi_k) = \frac{1}{130} \times \frac{S_{k, \text{fic}}}{S_n} \times P_{\text{st, fic}} \times T_p^{0,31} \quad (11)$$

See also Note 2 and 3.

4) The voltage change factor $k_u(\psi_k)$ shall be determined according to the equation (12) below.

$$k_u(\psi_k) = \sqrt{3} \times \frac{U_{\text{fic, max}} - U_{\text{fic, min}}}{U_n} \times \frac{S_{k, \text{fic}}}{S_n} \quad (12)$$

where

$U_{\text{fic, min}}$ is the minimum one period RMS value of the voltage on the fictitious grid during the switching operation;

$U_{\text{fic, max}}$ is the maximum one period RMS value of the voltage on the fictitious grid during the switching operation.

See also Note 4.

5) The flicker step factor and the voltage change factor shall be determined as the average result of the 15 values.

NOTE 1 The cut-off frequency should be at least 1 500 Hz to ensure that the fluctuating harmonics due to "soft-start" power electronics are correctly included in the voltage change factors and flicker step factors. See also Note 2 in 7.3.3.

NOTE 2 The formula defining the flicker step factor is deduced from IEC 61000-3-3 as explained in B.4.2.

NOTE 3 The flicker coefficient $P_{\text{st, fic}}$ is here evaluated over the time period T_p .

NOTE 4 The formula defining the voltage change factor is further explained in B.4.3.

7.4 Current harmonics, interharmonics and higher frequency components

The emission of current harmonics, interharmonics and higher frequency components from the wind turbine during continuous operation shall be measured so that these can be stated in accordance with 6.4.

The results shall be based on observation times of 10 min for each active power bin, (i.e. the bin midpoints 0, 10, 20, ..., 100 % of P_n as stated in 6.4) and shall be for situations with minimum distortion from the grid. The measurement procedure shall be suitable for wind turbines, i.e. where the magnitude of the current harmonics produced can be expected to change over the periods of a few seconds.

Measurements which are clearly influenced by grid background noise shall be excluded.

At least nine 10 min time-series of instantaneous current measurements (three tests and three phases) shall be collected for each 10% power bin.

The measurements and grouping of the spectral components shall be performed according to IEC 61000-4-7. The choice of grouping method is made reflecting that measurements are made on a fluctuating source. The accuracy class I as defined in IEC 61000-4-7 shall be applied.

The 10-cycle window for 50 Hz and 12-cycle window for 60 Hz systems is recommended. The window size shall be stated in the test report (see Annex A).

Harmonic currents below 0,1 % of I_n for any of the harmonic orders need not be reported.

The DFT (Discrete Fourier Transform) is applied to each of measured currents with rectangular weighting, i.e. no special weighting function (Hanning, Hamming, etc.) shall be applied to measured time-series. The active power shall be evaluated over the same time window as the harmonics.

The harmonic current components for frequencies up to 50 times the fundamental grid frequency shall be subgrouped as given in Clause 5.6 of IEC 61000-4-7:2002. See Note.

The total harmonic current distortion (THC) shall be calculated according to equation (13)

$$\text{THC} = \frac{\sqrt{\sum_{h=2}^{50} I_h^2}}{I_n} \times 100 \quad (13)$$

where

I_h is the subgrouped RMS current harmonic of harmonic order h ;

I_n is the rated current of the wind turbine.

The interharmonic current components below 2 kHz shall be subgrouped in accordance with Annex A of IEC 61000-4-7:2002 (equations (A3) and (A4) for 50 and 60 Hz systems respectively).

The higher frequency components, i.e. the 2 to 9 kHz current components, shall be measured and grouped according to Annex B of IEC 61000-4-7:2002 (equation (B1)). The output of raw DFT shall be grouped in bands of 200 Hz.

The 10 min averages of each frequency band (i.e. each subgrouped harmonic, interharmonic and higher frequency current component) shall be calculated for each 10 min time-series, and subsequently the maximum 10 min averages of each frequency band in each 10 % power bin shall be reported.

The voltage harmonics during the test shall be reported. The voltage harmonics shall be measured at the wind turbine terminals and according to IEC 61000-4-7. As a minimum, the 10 min average values of the total harmonic distortion of the voltage shall be reported.

NOTE IEC 61000-4-7:2002, Subclause 5.6 is on voltage harmonics. This grouping procedure is still recommended for assessing the current harmonics of a fluctuating source like wind turbines.

7.5 Response to temporary voltage drop


The response of the wind turbine to the temporary voltage drops specified in Table 1 shall be measured so that these can be stated in accordance with 6.5. The stated response shall include time-series of active power, reactive power, active current, reactive current and voltage at wind turbine terminals for the time shortly prior to the voltage drop and until the effect of the voltage drop has abated. The wind turbine operational mode and the 10 min average wind speed shall be specified.

The active power, reactive power, active current, reactive current and voltage shall be given for each line period (50 or 60 Hz), and shall be measured as positive sequence fundamentals – see Annex C.

The test shall be carried out for the wind turbine operating at a) between $0,1 P_n$ and $0,3 P_n$ and b) above $0,9 P_n$.

The test can be carried out using for instance a set-up such as the one outlined in Figure 5. The voltage drops are created by a short-circuit emulator that connects the three or two

phases to ground via an impedance, or connecting the three or two phases together through an impedance.



IEC 1299/08

Figure 5 – System with short circuit emulator for testing wind turbine response to temporary voltage drop


The impedance Z_1 is for limiting the effect of the short-circuit on the up-stream grid. The size of the impedance should be selected so that the voltage drop testing is not causing an unacceptable situation at the upstream grid, and at the same time not significantly affecting the transient response of the wind turbine. A by-pass connection of Z_1 may be applied prior and after the drop.

The voltage drop is created by connecting the impedance Z_2 by the switch S. The size of Z_2 shall be adjusted to give the voltage magnitudes specified in Table 1 when the wind turbine is not connected.

The values of the impedances Z_1 and Z_2 used in the tests shall be stated in the description of the test equipment.

The switch S shall be able to accurately control the time between connection and disconnection of Z_2 , and for all three or two phases. The switch can be for example a mechanical circuit breaker or a power electronic device.

The voltage magnitudes specified in Table 1 may be affected by the wind turbine operation, but are defined for the wind turbine not connected to the setup outlined in Figure 5. Without the wind turbine connected, the voltage drop shall be within the shape indicated in Figure 6. The duration of the drop shall be measured from closing to opening of the switch S. The time-tolerance is included as to account for tolerance in operation of the switch S and that the positive sequence voltage will not drop or rise instantly, but with a slope.



IEC 1300/08

Figure 6 – Tolerance of voltage drop

NOTE The test should be carried out at a) between $0,1 P_n$ and $0,3 P_n$ to get response at the most probable operational mode (depending on the wind conditions), and at b) above $0,9 P_n$ to get the response at tougher conditions.

7.6 Active power

7.6.1 Maximum measured power

The maximum measured power shall be measured so that it can be specified in accordance with 6.6.1 as a 600 s average value, P_{600} , a 60 s average value, P_{60} and as a 0,2 s average value, $P_{0,2}$ applying the following procedure:

- Measurements shall be sampled during continuous operation only.
- The active power shall be measured at the WT terminals.
- Measurements shall be taken so that at least five 10 min time-series of power are collected for each 1 m/s wind speed bin between cut-in wind speed and 15 m/s.
- The wind speed is measured as 10 min average values and according to 7.1.3.
- The measured power shall be transferred to 0,2 s average data and 60 s average data by block averaging.
- $P_{0,2}$ shall be determined as the highest valid 0,2 s average value recorded during the measurement period.
- P_{60} shall be determined as the highest valid 60 s average value recorded during the measurement period.
- P_{600} shall be determined as the highest valid 600 s average value recorded during the measurement period.

The measurements shall be taken with a measurement set-up as specified in Figure 3, and by applying voltage and current transformers, and an anemometer with specifications according to Table 2.

As a guidance, the full-scale range for measuring the current may be two times the rated current of the wind turbine.

7.6.2 Ramp rate limitation

The ramp rate limitation shall be tested so that it can be characterized according to 6.6.2. The following procedure shall be applied:

- The wind turbine shall be started from stand still.
- The ramp rate shall be set to 10 % of rated power per minute.
- The test shall be carried out until 10 min after the wind turbine has connected to the grid.
- The available active power output shall during the whole test be at least 50 % of rated power.
- The active power shall be measured at the WT terminals.
- The test results shall be reported as 0,2 s average data.

The measurements shall be taken with a measurement set-up as specified in Figure 3 and by applying anemometer, voltage and current transformers with specifications according to Table 2. The wind speed shall be stated as a time-series plot with 1 Hz data over the test period.

The available active power output shall be read from the control system of the wind turbine, or if the wind turbine control system does not facilitate this, an approximate value can be used based on measured wind speed combined with the power curve of the wind turbine.

7.6.3 Set point control

The active power set point control shall be tested so that it can be characterized according to 6.6.3. The following procedure shall be applied:

- The test shall be carried out during a test period of 10 min.
- Ramp rate limitation shall be deactivated during the test to ensure fastest possible response.
- The set point signal shall be reduced from 100 % to 20 % in steps of 20 % with 2 min operation at each set point value, i.e. according to Figure 1.
- The available active power output shall during the whole test be at least 90 % of rated power.
- The active power shall be measured at the WT terminals.
- The test results shall be reported as 0,2 s average data.

The measurements shall be taken with a measurement set-up as specified in Figure 3 and by applying anemometer, voltage and current transformers with specifications according to Table 2. The wind speed shall be stated as a time-series plot with 1 Hz data over the test period.

The available active power output shall be read from the control system of the wind turbine, or if the wind turbine control system does not facilitate this, an approximate value can be used based on measured wind speed combined with the power curve of the wind turbine.

7.7 Reactive power

7.7.1 Reactive power capability

The maximum inductive reactive power and the maximum capacitive reactive power shall be measured so that it can be stated according to 6.7.1.

- For the measurement of the maximum inductive reactive power the wind turbine shall be set to the operation mode, which gives the maximum inductive reactive power in the whole power range.

- For the measurement of the maximum capacitive reactive power the wind turbine shall be set to the operation mode, which gives the maximum capacitive reactive power in the whole power range.

For each of the two setting modes the following procedure shall be applied:

- Measurements shall be sampled during continuous operation only.
- The active and reactive power shall be measured at the WT terminals.
- Measurements shall be taken so that at least thirty 1 min time-series of active and reactive power are collected at each 10 % power bin.
- The sampled data shall be transferred to 1 min average data by applying block averaging for each 1 min period.
- The 1 min average data shall be sorted according to the method of bins so that the reactive power can be specified as average bin values in a Table for 0, 10, ...90, 100 % of rated power. Here 0, 10, ...90, 100 % are the midpoints of active power bins.

The measurements shall be taken with a measurement set-up as specified in Figure 3 and by applying voltage and current transformers with the specifications according to Table 2.

7.7.2 Set point control

The reactive power control by set point value shall be measured so that it can be stated according to 6.7.2.

For the measurement at a set point of reactive power = 0, the following procedure shall be applied:

- Measurements shall be sampled during continuous operation only.
- The active and reactive power shall be measured at the WT terminals.
- Measurements shall be taken so that at least thirty 1 min time-series of active and reactive power are collected at each 10 % power bin.
- The sampled data shall be transferred to 1 min average data by applying block averaging for each 1 min period.
- The 1 min average data shall be sorted according to the method of bins so that the reactive power can be specified in a table for 0, 10, ...90, 100 % of rated power. Here 0, 10, ...90, 100 % are the midpoints of active power bins.

For the measurement during the step change of reactive power the following procedure shall be applied:

- Measurements shall be sampled during continuous operation only.
- The active and reactive power shall be measured at the WT terminals.
- The active power output shall be at approximately 50 % of rated power.
- The sampled data for reactive power shall be 0,2 s. average data.
- The set point of reactive power shall be varied according to Figure 2.
- The measured reactive power shall be shown in a graph as 0,2 s. data together with the set point value of reactive power.

The measurements shall be taken with a measurement set-up as specified in Figure 3 and by applying voltage and current transformers with the specifications according to Table 2.

7.8 Grid protection

The protection levels and the disconnection times of the WT shall be determined concerning over- and under-voltage and over- and under-frequency. This shall be done using a separate 3 phase voltage supply, which is variable in voltage and frequency, and fed into the control of

the WT. The set-point protection levels and disconnection times of the WT controller shall also be specified. Due to safety reasons these measurements concerning the grid protection are performed while the generator of the wind turbine is not in operation.

The following procedure shall be applied for the determination of the protection levels:

- Under-voltage protection level, U_{under} :
The voltage of the separate 3 phase voltage supply shall be decreased in all three phases from 100 % of nominal voltage at nominal frequency in steps of 1 % of nominal voltage until the WT disconnects. Each step shall take at least 20 s.
- Over-voltage protection level, U_{over} :
The voltage of the separate 3 phase voltage supply shall be increased in all three phases from 100 % of nominal voltage at nominal frequency in steps of 1 % of nominal voltage until the WT disconnects. Each step shall take at least 20 s.
- Under-frequency protection level, f_{under} :
The frequency of the separate 3 phase voltage supply shall be decreased from 100 % of nominal frequency at nominal voltage in steps of 0,1 Hz until the WT disconnects. Each step shall take at least 20 s.
- Over-frequency protection level, f_{over} :
The frequency of the separate 3 phase voltage supply shall be increased from 100 % of nominal frequency at nominal voltage in steps of 0,1 Hz until the WT disconnects. Each step shall take at least 20 s.

For the determination of the disconnection times the following procedure shall be applied:

- The disconnection time of the wind turbine shall be determined from the data sheet of the wind turbine or by a measurement of the disconnection time.
- The disconnection time is the time duration from the beginning of the voltage step until the wind turbine has disconnected.
- Under-voltage:
A voltage step from nominal voltage to $U_{\text{under}} - 5\%$ of nominal voltage shall be given to the circuit breaker of the WT by the separate voltage supply.
- Over-voltage:
A voltage step from nominal voltage to $U_{\text{over}} + 5\%$ of nominal voltage shall be given to the circuit breaker of the WT by the separate voltage supply.
- Over-frequency:
A frequency step from nominal frequency to $f_{\text{over}} + 1\text{ Hz}$ shall be given to the circuit breaker of the WT by the separate voltage supply.
- Under-frequency:
A frequency step from nominal frequency to $f_{\text{under}} - 1\text{ Hz}$ shall be given to the circuit breaker of the WT by the separate voltage supply.

7.9 Reconnection time

The reconnection time shall be tested so that it can be characterized according to 6.9. The following procedure shall be applied:

- The test shall be carried out once for each of the 3 grid failure times specified in 6.9.
- The average wind speed shall be greater than 10 m/s during the reconnection time.
- The grid should be made unavailable to the wind turbine by opening a breaker in the grid. This breaker will typically be the MV breaker connecting the wind turbine to the power collection system. The opening of the breaker shall be done while the wind turbine is in operation. The grid should be made available again to the wind turbine by closing the breaker.

- The failure time is the time between opening and closing the breaker. The breaker would normally have to be operated manually, and the tester should ensure that the grid failure time is as specified within a tolerance of ± 1 s.
- The active power shall be measured at the WT terminals.
- The voltage shall be measured at the WT terminals.
- The test results shall be reported based on 0,2 s average data of the power and voltage. Based on the measured power and voltage, the reconnection time is determined from the time when the voltage returns to its normal level (between 0,9 and 1,1 pu) to the time where wind turbine starts producing power again ($P > 0$).

The measurements shall be taken with a measurement set-up as specified in Figure 3 and by applying voltage and current transformers with the specifications according to Table 2.

8 Assessment of power quality

8.1 General

This clause gives methods for estimating the power quality expected from a wind turbine or a group of wind turbines when deployed at a specific site, and to allow the results to be compared to requirements in other IEC publications.

If electricity network operators and regulatory authorities apply their own requirements in place of or in addition to IEC standards, the principles of this clause may still be used as a guidance.

The methods for assessing compliance with power quality requirements are valid for wind turbines with PCC at MV or HV in power systems with fixed frequency within ± 1 Hz, and sufficient active and reactive power regulation capabilities. In other cases, the principles for assessing compliance with power quality requirements may still be used as a guidance.

8.2 Voltage fluctuations

8.2.1 General

The flicker emissions from a wind turbine installation shall be limited to comply with the flicker emission limits as specified in equation (15) and equation (16) below.

$$P_{st} \leq E_{Psti} \quad (15)$$

$$P_{lt} \leq E_{Plti} \quad (16)$$

where

P_{st} and P_{lt} are the short and long-term flicker emissions from the wind turbine installation;
 E_{Psti} and E_{Plti} are the short and long-term flicker emission limits for the relevant PCC.

Furthermore, the relative voltage change due to a wind turbine installation shall be limited in accordance with equation (17) below.

$$d \leq \frac{\Delta U_{dyn}}{U_n} \quad (17)$$

where

d is the relative voltage change due to a switching operation of a wind turbine installation;

$\frac{\Delta U_{\text{dyn}}}{U_n}$ is the maximum permitted voltage change.

Recommended methods for assessing the flicker emission limits and the maximum permitted voltage change for installations at medium and high voltage levels are given in IEC 61000-3-7.

The procedure given in the subsequent subclauses is recommended for assessing the flicker emission and the relative voltage change due to a wind turbine installation.

8.2.2 Continuous operation

The 99th percentile flicker emission from a single wind turbine during continuous operation shall be estimated applying equation (18) below.

$$P_{\text{st}} = P_{\text{lt}} = c(\psi_k, v_a) \times \frac{S_n}{S_k} \quad (18)$$

where

$c(\psi_k, v_a)$ is the flicker coefficient of the wind turbine for the given network impedance phase angle, ψ_k at the PCC, and for the given annual average wind speed, v_a at hub-height of the wind turbine at the site;

S_n is the rated apparent power of the wind turbine;

S_k is the short-circuit apparent power at the PCC.

The flicker coefficient of the wind turbine for the actual ψ_k and v_a at the site, may be found from the Table of data produced as a result of the measurements described in 7.3.3 by applying linear interpolation.

In case more wind turbines are connected to the PCC, the flicker emission from the sum of them can be estimated from equation (19) below.

$$P_{\text{st}\Sigma} = P_{\text{lt}\Sigma} = \frac{1}{S_k} \times \sqrt{\sum_{i=1}^{N_{\text{wt}}} (c_i(\psi_k, v_a) \times S_{n,i})^2} \quad (19)$$

where

$c_i(\psi_k, v_a)$ is the flicker coefficient of the individual wind turbine;

$S_{n,i}$ is the rated apparent power of the individual wind turbine;

N_{wt} is the number of wind turbines connected to the PCC.

8.2.3 Switching operations

The flicker emission due to switching operations of a single wind turbine shall be estimated applying equation (20) and equation (21) below.

$$P_{\text{st}} = 18 \times N_{10m}^{0,31} \times k_f(\psi_k) \times \frac{S_n}{S_k} \quad (20)$$

$$P_{\text{lt}} = 8 \times N_{120m}^{0,31} \times k_f(\psi_k) \times \frac{S_n}{S_k} \quad (21)$$

where $k_f(\psi_k)$ is the flicker step factor of the wind turbine for the given ψ_k at the PCC. See also Note 1.

The flicker step factor of the wind turbine for the actual ψ_k at the site may be found from the table of data produced as a result of the measurements described in 7.3.4 by applying linear interpolation.

In case more wind turbines are connected to the PCC, the flicker emission from the sum of them can be estimated from equation (22) and equation (23) below.

$$P_{st\Sigma} = \frac{18}{S_k} \times \left(\sum_{i=1}^{N_{wt}} N_{10m,i} \times (k_{f,i}(\psi_k) \times S_{n,i})^{3,2} \right)^{0,31} \quad (22)$$

$$P_{lt\Sigma} = \frac{8}{S_k} \times \left(\sum_{i=1}^{N_{wt}} N_{120m,i} \times (k_{f,i}(\psi_k) \times S_{n,i})^{3,2} \right)^{0,31} \quad (23)$$

where

$N_{10m,i}$ and $N_{120m,i}$ are the number of switching operations of the individual wind turbine within a 10 min and 2 h period respectively;

$k_{f,i}(\psi_k)$ is the flicker step factor of the individual wind turbine;

$S_{n,i}$ is the rated apparent power of the individual wind turbine. See also Note 2.

If there is an overall control system associated with the wind turbine installation that limits the total number of switching operations, adequate measures should be taken to include the effect of this.

The relative voltage change due to a switching operation of a single wind turbine shall be estimated applying equation (24) below:

$$d = 100 \times k_u(\psi_k) \times \frac{S_n}{S_k} \quad (24)$$

where

d is the relative voltage change in %;

$k_u(\psi_k)$ is the voltage change factor of the wind turbine for the given ψ_k at the PCC.

The voltage change factor of the wind turbine for the actual ψ_k at the site may be found from the table of data produced as a result of the measurements described in 7.3.4 by applying linear interpolation.

In case more wind turbines are connected to the PCC, it is still not likely that even two of them will perform a switching operation at the same time. Hence, no summation effects need to be taken into account to assess the relative voltage change of a wind turbine installation consisting of multiple wind turbines.

NOTE 1 Equation (20) and equation (21) may be deduced from B.4.2 applying an observation period of 600 s and 7 200 s respectively.

NOTE 2 Equation (22) and equation (23) may be deduced as equation (20) and equation (21), though including in the summation the number of wind turbines connected to the PCC. The summation is justified because the transient part of a switching operation, i.e. the part that significantly contributes to the flicker emission, is normally of a short duration.

8.3 Current harmonics, interharmonics and higher frequency components

The harmonic currents shall be limited to the degree needed to avoid unacceptable harmonic voltages at the PCC.

The applicable limits for emission of harmonics may be found by applying the guidance given in IEC 61000-3-6.

IEC 61000-3-6 gives guidance for summation of harmonic current distortion from loads. Applying this, the harmonic current at the PCC due to a wind turbine installation with a number of wind turbines may be estimated applying equation (25) below:

$$I_{h\Sigma} = \sqrt[\beta]{\sum_{i=1}^{N_{wt}} \left(\frac{I_{h,i}}{n_i} \right)^\beta} \quad (25)$$

where

N_{wt} is the number of wind turbines connected to the PCC;

$I_{h\Sigma}$ is the h 'th order harmonic current distortion at the PCC;

n_i is the ratio of the transformer at the i 'th wind turbine;

$I_{h,i}$ is the h 'th order harmonic current distortion of the i 'th wind turbine;

β is an exponent with a numerical value to be selected according to Table 3 and the points below.

Table 3 – Specification of exponents according to IEC 61000-3-6

Harmonic order	β
$h < 5$	1,0
$5 \leq h \leq 10$	1,4
$h > 10$	2,0

If the wind turbines are equal and their converters' line commutated, the harmonics are likely to be in phase and $\beta = 1$ shall be used for all harmonic orders.

Equation (25) does not take into account the use of transformers with different vector groups that may cancel out particular harmonics. If this is the case, adequate measures should be taken to include the effect of this.

Equation (25) can also be applied for current interharmonics and higher frequency components. As current interharmonics and higher frequency components are assumed to be uncorrelated, it is recommended to use $\beta = 2$ in equation (25) for summation of these.

Annex A (informative)

Sample report format

This sample report format gives a suggested format for reporting the results of tests for characterizing the power quality parameters of a wind turbine. The assessor should fill in the empty tables and insert graphics at the Figure captions.

REPORT ON RESULTS OF WIND TURBINE POWER QUALITY TESTS

The reported characteristics are valid for the specific configuration of the assessed wind turbine type only. Other configurations, including altered control parameters, that cause the wind turbine to behave differently with respect to power quality, require separate assessment.

Name of test organization	
Report number	
Wind turbine type designation	
Wind turbine manufacturer	
Serial number of wind turbine tested	

The wind turbine identified above has been tested in accordance with IEC 61400-21. General wind turbine data are given below:

Wind turbine type (horizontal/vertical axis)	
Number of blades	
Rotor diameter (m)	
Hub height (m)	
Blade control (pitch/stall)	
Speed control (fixed/two-speed/variable)	
Generator type and rating(s) (kW)	
Frequency converter type and rating (kVA)	
Reactive compensation type and rating (kvar)	
Transformer ratio and rating (kVA)	
Identification of wind turbine terminals	

This test report is accompanied by the documents specified below.

Type of information	Document name and date
Description of the tested wind turbine, including settings of the relevant control parameters	
Description of test site and grid connection	
Description of test equipment	
Description of test conditions	
Note of exceptions to IEC 61400-21	

Author	
Checked	
Approved	
Date of issue	

Characteristic parameters that are determined otherwise than outlined in IEC 61400-21 are marked. This includes parameters that are calculated instead of measured. The document(s) with exceptions to IEC 61400-21 describes the alternative procedure(s) that has been applied.

The resulting characteristic parameters are stated below.

A.1 Wind turbine rated data at terminals

Rated power, P_n (kW)	
Rated wind speed, v_n (m/s)	
Rated apparent power, S_n (kVA)	
Rated current, I_n (A)	
Rated voltage, U_n (V)	
Rated frequency, f_n (Hz)	

A.2 Voltage fluctuations

A.2.1 Continuous operation

The operational mode of the wind turbine during the test was:

Reactive set-point control, $Q = 0$
Other mode:

Network impedance phase angle, ψ_k (°)	30	50	70	85
Annual average wind speed, v_a (m/s)	Flicker coefficient, $c(\psi_k, v_a)$			
6,0				
7,5				
8,5				
10,0				

A.2.2 Switching operations

The operational mode of the wind turbine during the test was:

Reactive set-point control, $Q = 0$
Other mode:

Case of switching operation	Start-up at cut-in wind speed			
Max number of switching operations, N_{10m}				
Max number of switching operations, N_{120m}				
Network impedance phase angle, ψ_k (°)	30	50	70	85
Flicker step factor, $k_f(\psi_k)$				
Voltage change factor, $k_u(\psi_k)$				

Case of switching operation	Start-up at rated wind speed or higher			
Max number of switching operations, N_{10m}				
Max number of switching operations, N_{120m}				
Network impedance phase angle, ψ_k (°)	30	50	70	85
Flicker step factor, $k_f(\psi_k)$				
Voltage change factor, $k_u(\psi_k)$				

Case of switching operation	Worst case switching between generators			
Max number of switching operations, N_{10m}				
Max number of switching operations, N_{120m}				
Network impedance phase angle, ψ_k (°)	30	50	70	85
Flicker step factor, $k_f(\psi_k)$				
Voltage change factor, $k_u(\psi_k)$				

A.3 Current harmonics, interharmonics and higher frequency components

The emission of current harmonics, interharmonics and higher frequency components from the wind turbine is specified for in percent of I_n for operation of the wind turbine within the power bins 10, 20, ... , 100 % of P_n .

The operational mode of the wind turbine during the test was:

Reactive set-point control, Q = 0
Other mode:

A.4 Response to voltage drops

Wind turbine operational mode:

Test conditions:

Figure A.1 Time-series of measured voltage drop when the wind turbine under test is not connected. Case VD1-VD6.

Test results for operation at between $0,1P_n$ and $0,3P_n$:

Figure A.2a Time-series of measured positive sequence fundamental active power. Case VD1-VD6.

Figure A.2b Time-series of measured positive sequence fundamental reactive power. Case VD1-VD6.

Figure A.3a Time-series of measured positive sequence fundamental active current. Case VD1-VD6.

Figure A.3b Time-series of measured positive sequence fundamental reactive current. Case VD1-VD6.

Figure A.4 Time-series of measured positive sequence fundamental voltage at wind turbine terminals. Case VD1-VD6.

Test results for operation at above $0,9P_n$:

Figure A.5a Time-series of measured positive sequence fundamental active power. Case VD1-VD6.

Figure A.5b Time-series of measured positive sequence fundamental reactive power. Case VD1-VD6.

Figure A.6a Time-series of measured positive sequence fundamental active current. Case VD1-VD6.

Figure A.6b Time-series of measured positive sequence fundamental reactive current. Case VD1-VD6.

Figure A.7 Time-series of measured positive sequence fundamental voltage at wind turbine terminals. Case VD1-VD6.

A.5 Active power

A.5.1 Maximum measured power

600 s average value

Measured value, P_{600} (kW)	
Normalized value, $p_{600} = P_{600} / P_n$	

Reactive power set point step change:

Figure A.9 Time-series of reactive power set-point values and measured reactive power.

Figure A.10 Time-series of active power during test (shall be approximately 50 % of rated).

A.7 Grid protection

	Protection level		Disconnection time (s)	
	Set point	Measured	Set point	Measured
Over-voltage				
Under-voltage				
Over-frequency				
Under-frequency				

A.8 Reconnection time

Duration of grid failure	10 s	1 min	10 min
Actual measured duration of grid failure (s)			
Reconnection time (s)			

Annex B (informative)

Voltage fluctuations and flicker

B.1 Continuous operation

The measurement and assessment procedures for flicker during continuous operation are shown in Figure B.1. It is illustrated in Figure B.1 that the measurement procedure is rather comprehensive, whereas the assessment procedure is fairly simple.




Figure B.1 – Measurement and assessment procedures for flicker during continuous operation of the wind turbine

The illustration of the measurement procedure in Figure B.1 is as follows:

- 1) a number of voltage and current time-series $u_m(t)$ and $i_m(t)$ are measured, distributed over the wind speed interval from cut-in wind speed to 15 m/s;
- 2) each set of measured time-series is used as input to simulate the voltage fluctuations, $u_{fic}(t)$ on a fictitious grid with an appropriate short-circuit apparent power $S_{k, fic}$ and for four different network impedance phase angles, ψ_k ;
- 3) each simulated instantaneous voltage time-series $u_{fic}(t)$ is then used as input to the voltage flicker algorithm described in IEC 61000-4-15 to generate the flicker emission value $P_{st, fic}$;
- 4) each $P_{st, fic}$ value is normalized to a flicker coefficient $c(\psi_k)$, which is in principle independent of the selected short-circuit apparent power $S_{k, fic}$;
- 5) for each network impedance phase angle ψ_k , the weighting procedure then calculates the weighted accumulated distribution functions of the flicker coefficients, $Pr(c < x)$, assuming four different wind speed distributions. $Pr(c < x)$ represents the distribution of flicker coefficients that would have been obtained if the measurements had been performed on a site with Rayleigh distributed wind speeds of mean v_a ;
- 6) for each accumulated distribution, the 99 % percentile $c(\psi_k, v_a)$ of the flicker coefficient is then reported.

The assessment procedure specifies how the reported flicker coefficients can be used to estimate the flicker emission from a single wind turbine or a group of wind turbines operating continuously on any specified site.

B.2 Switching operations

The measurement and assessment procedures for switching operations are shown in Figure B.2. These procedures specify how to measure and assess voltage changes as well as flicker. It is seen that the measurement procedure is rather comprehensive, and that the assessment procedure is fairly simple.




Figure B.2 – Measurement and assessment procedures for voltage changes and flicker during switching operations of the wind turbine

The measurement procedure for switching operations is as follows:

- 1) a number of voltage and current time-series $u_m(t)$ and $i_m(t)$ are measured for each of the specified types of switching;
- 2) each set of measured time-series is used as input to simulate the voltage fluctuations, $u_{fic}(t)$ on a fictitious grid with an appropriate short-circuit apparent power $S_{k, fic}$ and for four different network impedance phase angles, ψ_k ;
- 3) each simulated instantaneous voltage time-series $u_{fic}(t)$ is then used as input to the voltage flicker algorithm described in IEC 61000-4-15 to generate the flicker emission value $P_{st, fic}$ and as input to an RMS calculation algorithm to identify the maximum one period RMS value $U_{fic, max}$ and the minimum one period r.m.s. value $U_{fic, min}$;
- 4) each $P_{st, fic}$ value is normalized to a flicker step factor $k_f(\psi_k)$, and each voltage change $U_{fic, max} - U_{fic, min}$ is normalized to a voltage change factor $k_u(\psi_k)$;
- 5) for each network impedance phase angle ψ_k , the measured flicker step factors and voltage change factors are then averaged;
- 6) the averaged flicker step factors and voltage change factors are then reported together with the maximum number N_{10m} of the switching operation within a 10 min period and the maximum number N_{120m} of the switching operation within a 120 min period, for each type of switching operation.

The assessment procedure for switching operations specifies how to estimate the flicker emission and voltage changes from switching operations on any specified site, using the reported flicker step factors and voltage change factors. Methods are given for a single wind turbine as well as a group of wind turbines

B.3 Weighting of flicker coefficients

The following example illustrates the weighting procedure, which is used in this part of IEC 61400 to derive the flicker coefficients $c(\psi_k, v_a)$ for four different wind speed distributions. The determination of the flicker coefficient is only shown for the network impedance phase

angle $\psi_k = 50^\circ$. The same procedure shall be performed for the other network impedance phase angles 30° , 70° and 85° .

Figure B.3 shows a set of measured flicker coefficients $c(\psi_k)$ as a function of wind speed for the network impedance phase angle $\psi_k = 50^\circ$.




Figure B.3 – Flicker coefficient as a function of wind speed

Using these flicker coefficients to obtain a resulting flicker coefficient $c(\psi_k, v_a)$ for each wind speed distribution, the following steps are performed:

- classification of the flicker coefficients $c(\psi_k)$ in 1 m/s bins of the wind speed;
- determination of the number of measurements in each wind speed bin;
- determination of the weighting factor w_i for each wind speed bin;
- determination of the weighted accumulated distribution $Pr(c < x)$;
- determination of the 99th percentile, which gives the flicker coefficient $c(\psi_k, v_a)$.

The cut-in wind speed of the WT is, in this example, $v_{\text{cut-in}} = 3$ m/s. Few measurements were performed at wind speeds below cut-in wind speed and at wind speeds above 15 m/s. These measurements are not taken into account. Only the measurements above cut-in wind speed and below 15 m/s are used for the determination of the flicker coefficient $c(\psi_k, v_a)$.

Table B.1 shows the wind speed bins, the number of measurements of each bin, the relative frequency of occurrence of measured flicker coefficients $f_{m,i}$ for each wind speed bin and the Rayleigh distribution, $f_{y,i}$ for annual average wind speed $v_a = 6$ m/s, 7,5 m/s, 8,5 m/s and 10 m/s.

Table B.1 – Number of measurements $N_{m,i}$ and frequency of occurrence of $f_{m,i}$ and $f_{y,i}$ for each wind speed bin in the range from cut-in wind speed to 15 m/s

Wind speed bin range m/s	Number of measurements $N_{m,i}$	$f_{m,i}$ %	$f_{y,i}$ %	$f_{y,i}$ %	$f_{y,i}$ %	$f_{y,i}$ %
			6 m/s	7,5 m/s	8,5 m/s	10 m/s
3 – <4	30	5,38	11,64	8,21	6,64	4,98
4 – <5	36	6,45	12,57	9,44	7,83	6,02
5 – <6	45	8,06	12,37	10,04	8,59	6,80
6 – <7	33	5,91	11,26	10,04	8,91	7,32
7 – <8	42	7,53	9,58	9,53	8,83	7,56
8 – <9	33	5,91	7,67	8,65	8,41	7,56
9 – <10	33	5,91	5,80	7,52	7,74	7,34
10 – <11	69	12,37	4,15	6,29	6,88	6,93
11 – <12	87	15,59	2,82	5,07	5,94	6,39
12 – <13	60	10,75	1,82	3,95	4,97	5,75
13 – <14	45	8,06	1,11	2,97	4,05	5,07
14 – <15	45	8,06	0,65	2,16	3,21	4,37
Total N_m	558					

The weighting factor, w_i , is the ratio between the frequency of occurrence of the wind speeds $f_{y,i}$ and the relative frequency of occurrence of measured flicker coefficients $f_{m,i}$. Table B.2 gives the weighting factor, w_i , for each wind speed bin.

Table B.2 – Weighting factor w_i for each wind speed bin

Wind speed bin range (m/s)	w_i 6 m/s	w_i 7,5 m/s	w_i 8,5 m/s	w_i 10 m/s
3 – <4	2,165	1,527	1,236	0,927
4 – <5	1,949	1,464	1,214	0,933
5 – <6	1,533	1,245	1,065	0,843
6 – <7	1,904	1,698	1,507	1,237
7 – <8	1,273	1,267	1,173	1,005
8 – <9	1,297	1,462	1,423	1,278
9 – <10	0,980	1,272	1,308	1,241
10 – <11	0,335	0,509	0,557	0,561
11 – <12	0,181	0,325	0,381	0,410
12 – <13	0,169	0,367	0,463	0,535
13 – <14	0,138	0,368	0,502	0,628
14 – <15	0,081	0,267	0,398	0,542

The total sum of the weighting factor for each bin multiplied by the number of measurements for that is given in Table B.3.

Table B.3 – Total sum of weighting factor multiplied by number of measurements for all wind speed bins

v_a (m/s)	6,0	7,5	8,5	10,0
$\sum_{i=1}^{Nbin} w_i \times N_{m,i}$	454,40	467,99	457,64	424,60

In the next step, the measurements are sorted according to the flicker coefficients $c(\psi_k)$. This is illustrated in Table B.4 where the upper row gives the maximum value of all of the flicker coefficients $c(\psi_k)$ in the wind speed range 3 m/s to 15 m/s. The maximum of the flicker coefficients $c(\psi_k)$ is the 100 percentile, that means the weighted accumulated distribution factor $Pr(c < 11,495) = 1,0$. Subsequent rows of Table B.4 are completed by subtracting the weighting factor for the relevant measurement (from Table B.2) divided by the total sum of weighting factors (from Table B.3), from the Figure in the previous row.

Table B.4 – Weighted accumulated distribution of the flicker coefficients $Pr(c < x)$ for each wind speed distribution

Sorted flicker coefficients	Corresponding wind speed m/s	$Pr(c < x)$ 6 m/s	$Pr(c < x)$ 7,5 m/s	$Pr(c < x)$ 8,5 m/s	$Pr(c < x)$ 10 m/s
11,495	13,4	1,0000	1,0000	1,0000	1,0000
11,379	13,4	0,9997	0,9992	0,9989	0,9985
11,298	13,4	0,9994	0,9984	0,9978	0,9970
10,584	14,6	0,9991	0,9976	0,9967	0,9956
10,472	11,9	0,9989	0,9971	0,9958	0,9943
10,444	14,6	0,9985	0,9964	0,9950	0,9933
10,418	11,9	0,9983	0,9958	0,9941	0,9920
10,418	10,3	0,9979	0,9951	0,9933	0,9911
10,364	14,6	0,9972	0,9940	0,9921	0,9898
10,308	14,6	0,9970	0,9935	0,9912	0,9885
10,286	10,3	0,9968	0,9929	0,9903	0,9872
10,280	11,9	0,9961	0,9918	0,9891	0,9859
10,104	10,3	0,9957	0,9911	0,9883	0,9849
10,059	14,2	0,9950	0,9900	0,9871	0,9836
9,931	14,2	0,9948	0,9894	0,9862	0,9823
:		:	:	:	:
8,882	12,9	0,9906	0,9788	0,9713	0,9620
8,858	12,9	0,9902	0,9780	0,9703	0,9608
8,846	12,1	0,9898	0,9772	0,9693	0,9595
8,836	11,3	0,9895	0,9765	0,9683	0,9582
8,831	12,1	0,9891	0,9758	0,9674	0,9573

The relevant 99th percentiles are marked by bold types in Table B.4. These 99th percentiles give the flicker coefficients $c(\psi_k, v_a)$ for the network impedance phase angle of 50° for the measurement report, as shown in Table B.5.

Table B.5 – Resulting flicker coefficient in continuous operation

ψ_k (°)	30	50	70	85
v_a (m/s)	Flicker coefficient			
6,0		8,9		
7,5		10,1		
8,5		10,3		
10,0		10,4		

The reported flicker coefficients are the 99th percentile of the values in the wind speed interval from cut-in wind speed to 15 m/s, though not necessarily for the complete wind speed interval from zero to infinity.

The uncertainty introduced by the limited measurement interval is illustrated in Table B.6. Using the accumulated distribution functions for the Rayleigh distributions, the first three rows show the probabilities that wind speed is below, within or above the specified measurement interval from 3 m/s to 15 m/s. In the best case, all flicker coefficients outside the measurement interval are below the 99th percentile inside the measurement interval. In that case, the reported percentile actually corresponds to the best case percentile in Table B.6. In the worst case, all the flicker coefficients in the wind speed interval above 15 m/s are greater than the 99th percentile inside the measurement interval. In that case, the reported percentile corresponds to the worst case percentile in Table B.6. As can be seen, the actual percentage of the reported percentile is quite uncertain for the wind speed distributions with high values of the annual mean wind speeds. The uncertainty can be reduced to any desired level by increasing the upper limit of the measurement interval above 15 m/s. This will, however, often dramatically increase the required testing period and thereby the cost of the measurements.

Table B.6 – Probabilities and percentiles for different wind speeds

v_a (m/s)	6,0	7,5	8,5	10,0
$Pr(v < 3 \text{ m/s})$ (%)	17,8	11,8	9,3	6,8
$Pr(3 \text{ m/s} < v < 15 \text{ m/s})$ (%)	81,4	83,9	82,0	76,1
$Pr(v > 15 \text{ m/s})$ (%)	0,7	4,3	8,7	17,1
Best case percentile (%)	99,2	99,2	99,2	99,2
Worst case percentile (%)	98,4	94,8	90,5	82,2

NOTE The first three rows show the probabilities that wind speed is below, within or above the specified measurement interval from 3 m/s to 15 m/s. From these probabilities, the possible intervals of the actually measured percentiles are given by the last two rows.

B.4 Deduction of definitions

B.4.1 Flicker coefficient

The simulated flicker $P_{st, fic}$ value will depend on the short-circuit power of the grid, $S_{k, fic}$, and the angle of the grid impedance, ψ_k . $P_{st, fic}$ is approximately inversely proportional to $S_{k, fic}$, whereas the relation between $P_{st, fic}$ and ψ_k depends on the wind turbine type. Therefore, the flicker coefficient, $c(\psi_k)$, is defined so that:

$$P_{st, fic} = c(\psi_k) \times \frac{S_n}{S_{k, fic}} \quad (\text{B.1})$$

where S_n is the rated apparent power of the wind turbine.

Hence, the flicker coefficient $c(\psi_k)$ becomes:

$$c(\psi_k) = P_{st, fic} \times \frac{S_{k, fic}}{S_n} \quad (B.2)$$

B.4.2 Flicker step factor

IEC 61000-3-3 defines an analytical method to assess flicker, based on a voltage change and a form factor. The form factor, $F = 1$, corresponds to a stepwise voltage change. That method is used to define the flicker step factor, $k_f(\psi_k)$, in the present standard. The flicker step factor is defined so that it can be used to calculate an equivalent voltage step, which has the same flicker severity as the switching operation. The formal definition is

$$d_{max} = k_f(\psi_k) \times \frac{S_n}{S_{k, fic}} \times 100 \quad (B.3)$$

where d_{max} is the equivalent voltage step in percentage of rated voltage.

Applying the IEC 61000-3-3 analytical method, a voltage step, d_{max} , gives the flicker impression time, t_f , according to

$$t_f = 2,3 \times d_{max}^{3,2} \quad (B.4)$$

and this flicker impression time gives the flicker severity, $P_{st, fic}$, according to

$$P_{st, fic} = \left(\frac{\sum t_f}{T_p} \right)^{1/3,2} \quad (B.5)$$

in an observation period, T_p . With a single flicker impression time, t_f , as above,

$$P_{st, fic} = 100 \times k_f(\psi_k) \times \frac{S_n}{S_{k, fic}} \times \left(\frac{2,3}{T_p} \right)^{1/3,2} \quad (B.6)$$

Using this result, the flicker step factor, $k_f(\psi_k)$, can be defined as

$$k_f(\psi_k) = \frac{S_{k, fic}}{100 \times S_n} \times \left(\frac{T_p}{2,3} \right)^{1/3,2} \times P_{st, fic} \quad (B.7)$$

The observation time, T_p , in equation (B.7) is the length of the simulated voltage time-series in seconds.

B.4.3 Voltage change factor

The relative voltage change, Δu , due to switching operations will depend on the short-circuit power of the grid, $S_{k, fic}$, and the angle of the network impedance ψ_k . Δu is approximately inversely proportional to $S_{k, fic}$, whereas the relation between Δu and ψ_k depends on the technology of the wind turbine. Therefore, the voltage change factor, $k_u(\psi_k)$, is defined according to

$$\Delta u = k_u(\psi_k) \times \frac{S_n}{S_{k, fic}} \quad (B.8)$$

Inserting the simulated voltage change on the grid with the short-circuit power of the grid, $S_{k, fic}$, the voltage change factor can then be determined by

$$k_u(\psi_k) = \sqrt{3} \times \frac{U_{\text{fic,max}} - U_{\text{fic,min}}}{U_n} \times \frac{S_{k,\text{fic}}}{S_n} \quad (\text{B.9})$$

where

$U_{\text{fic,max}}$ and $U_{\text{fic,min}}$ are the maximum and minimum values respectively of the simulated phase-to-neutral voltage, $u_{\text{fic}}(t)$, on the fictitious grid.

Annex C (informative)

Measurement of active power, reactive power and voltage

This Annex gives the recommended procedure to calculate active power, reactive power, active current, reactive current and voltage as positive sequence fundamentals based on measurement of instantaneous voltages and currents.

The reasoning for presenting power, current and voltage by their positive sequence fundamentals is that this provides for clear definitions of the quantities, and of particular significance for the case of an unbalanced power system. Further reasons are that:

- a) The positive sequence of the fundamental is the one that produces torque in the rotating machines. The negative sequence and the harmonics only cause losses.
- b) In many cases, reactive current is specified instead of the reactive power. Using a positive sequence of the fundamental, the reactive current component can be calculated explicitly. The same applies to the power factor.
- c) Many power system simulators use only the positive sequence of the fundamental. Thus, for easy verification of the simulations, the measurements should be presented in a similar way.

In order to measure the positive sequence of the fundamental of the voltages and currents a multichannel datalogger with high sampling rate is needed (typically at least 2 kHz per channel). The analogue anti-aliasing filter (low pass filter) should have the same frequency response in all voltage and current inputs in order to prevent phase errors. Moreover, the amplitude error due to the anti-aliasing filter should be negligible at the fundamental frequency.

When phase voltages and currents are measured, the fundamental's Fourier coefficients are first calculated over one fundamental cycle T (equation shown here only for phase a voltage u_a ; other phase voltages and currents are calculated similarly)

$$u_{a,\cos} = \frac{2}{T} \int_{t-T}^t u_a(t) \cos(2\pi f_1 t) dt \quad (\text{C.5})$$

$$u_{a,\sin} = \frac{2}{T} \int_{t-T}^t u_a(t) \sin(2\pi f_1 t) dt \quad (\text{C.6})$$

where f_1 is the frequency of the fundamental.

The effective value of this fundamental phase voltage is

$$U_{a1} = \sqrt{\frac{u_{a,\cos}^2 + u_{a,\sin}^2}{2}} \quad (\text{C.7})$$

The voltage and current vector components of the fundamental positive sequence are calculated using:

$$u_{1+,\cos} = \frac{1}{6} \left[2u_{a,\cos} - u_{b,\cos} - u_{c,\cos} - \sqrt{3}(u_{c,\sin} - u_{b,\sin}) \right] \quad (\text{C.8})$$

$$u_{1+,sin} = \frac{1}{6} \left[2u_{a,sin} - u_{b,sin} - u_{c,sin} - \sqrt{3}(u_{b,cos} - u_{c,cos}) \right] \quad (C.9)$$

$$i_{1+,cos} = \frac{1}{6} \left[2i_{a,cos} - i_{b,cos} - i_{c,cos} - \sqrt{3}(i_{c,sin} - i_{b,sin}) \right] \quad (C.10)$$

$$i_{1+,sin} = \frac{1}{6} \left[2i_{a,sin} - i_{b,sin} - i_{c,sin} - \sqrt{3}(i_{b,cos} - i_{c,cos}) \right] \quad (C.11)$$

The active and reactive powers of the fundamental positive sequence are then

$$P_{1+} = \frac{3}{2} (u_{1+,cos} i_{1+,cos} + u_{1+,sin} i_{1+,sin}) \quad (C.12)$$

$$Q_{1+} = \frac{3}{2} (u_{1+,cos} i_{1+,sin} - u_{1+,sin} i_{1+,cos}) \quad (C.13)$$

and the effective phase-to-phase voltage of the fundamental positive sequence is

$$U_{1+} = \sqrt{\frac{3}{2} (u_{1+,sin}^2 + u_{1+,cos}^2)} \quad (C.14)$$

The effective active and reactive currents of the fundamental positive sequence are

$$I_{P1+} = \frac{P_{1+}}{\sqrt{3}U_{1+}} \quad (C.15)$$

$$I_{Q1+} = \frac{Q_{1+}}{\sqrt{3}U_{1+}} \quad (C.16)$$

The power factor of the fundamental positive sequence is

$$\cos \varphi_{1+} = \frac{P_{1+}}{\sqrt{P_{1+}^2 + Q_{1+}^2}} \quad (C.17)$$

These calculations can be performed in a spreadsheet program or using a special computer program. A new value of the reactive and active power should be calculated at least once in every fundamental period using the latest data.

Bibliography

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*

IEC/TR 61000-3-6, *Electromagnetic compatibility (EMC) – Part 3-6: Limits – Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*

IEC/TR 61000-3-7, *Electromagnetic compatibility (EMC) – Part 3-7: Limits – Assessment of emission limits for the connection of fluctuating installations to MV, HV and EHV power systems – Basic EMC publication*

IEC 61000-4-30, *Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods*

IEC 61400-1, *Wind turbines – Part 1: Design requirements*

Thomas Ackerman (editor), *Wind power in power systems*, January 2005, John Wiley and Sons Ltd, ISBN 0470855088, 690 pages.

British Standards Institution (BSI)

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level.

It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.

Tel: +44 (0)20 8996 9000 Fax: +44 (0)20 8996 7400

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to BSI Customer Services.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001
Email: orders@bsigroup.com

You may also buy directly using a debit/credit card from the BSI Shop on the website www.bsigroup.com/shop

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library.

Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.

Tel: +44 (0)20 8996 7111

Fax: +44 (0)20 8996 7048 Email: info@bsigroup.com

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.

Tel: +44 (0)20 8996 7002 Fax: +44 (0)20 8996 7001

Email: membership@bsigroup.com

Information regarding online access to British Standards via British Standards Online can be found at www.bsigroup.com/BSOL

Further information about BSI is available on the BSI website at www.bsigroup.com

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained. Details and advice can be obtained from the Copyright & Licensing Manager.

Tel: +44 (0)20 8996 7070 Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Tel +44 (0)20 8996 9001

Fax +44 (0)20 8996 7001

www.bsigroup.com/standards

raising standards worldwide™

BSI
British Standards