



BSI Standards Publication

Superconductivity

Part 4: Residual resistance ratio
measurement — Residual resistance
ratio of Nb-Ti and Nb₃Sn composite
superconductors

National foreword

This British Standard is the UK implementation of EN 61788-4:2016. It is identical to IEC 61788-4:2016. It supersedes BS EN 61788-4:2011 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee L/-/90, Super Conductivity.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016.

Published by BSI Standards Limited 2016

ISBN 978 0 580 86604 3

ICS 17.200.20; 29.050

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 April 2016.

Amendments/corrigenda issued since publication

Date	Text affected
-------------	----------------------

EUROPEAN STANDARD

EN 61788-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2016

ICS 17.200.20; 29.050

Supersedes EN 61788-4:2011

English Version

**Superconductivity - Part 4: Residual resistance ratio
measurement - Residual resistance ratio of Nb-Ti and Nb₃Sn
composite superconductors
(IEC 61788-4:2016)**

Supraconductivité - Partie 4: Mesurage du rapport de
résistance résiduelle - Rapport de résistance résiduelle des
composites supraconducteurs de Nb-Ti et de Nb₃Sn
(IEC 61788-4:2016)

Supraleitfähigkeit - Teil 4: Messung des
Restwiderstandsverhältnisses - Restwiderstandsverhältnis
von Nb-Ti und Nb₃Sn Verbundsupraleitern
(IEC 61788-4:2016)

This European Standard was approved by CENELEC on 2016-02-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 90/359/FDIS, future edition 4 of IEC 61788-4, prepared by IEC/TC 90 "Superconductivity" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61788-4:2016.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-11-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2019-02-23

This document supersedes EN 61788-4:2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61788-4:2016 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-815	-	International Electrotechnical Vocabulary- (IEV) -- Part 815: Superconductivity		-

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Principle	8
5 Apparatus	8
5.1 Material of measurement mandrel or of measurement base plate	8
5.2 Diameter of the measurement mandrel and length of the measurement base plate	8
5.3 Cryostat for the resistance (R_2) measurement	9
6 Specimen preparation	9
7 Data acquisition and analysis	9
7.1 Resistance (R_1) at room temperature	9
7.2 Resistance (R_2 or R_2^*) just above the superconducting transition	9
7.2.1 Correction of strain effect	9
7.2.2 Data acquisition of cryogenic resistance	10
7.2.3 Optional acquisition methods	12
7.3 Correction on measured R_2^* of Nb-Ti composite superconductor for bending strain	12
7.4 Residual resistance ratio (RRR)	12
8 Uncertainty and stability of the test method	12
8.1 Temperature	12
8.2 Voltage measurement	12
8.3 Current	13
8.4 Dimension	13
9 Test report	13
9.1 RRR value	13
9.2 Specimen	13
9.3 Test conditions	14
9.3.1 Measurements of R_1 and R_2	14
9.3.2 Measurement of R_1	14
9.3.3 Measurement of R_2	14
Annex A (informative) Additional information relating to the measurement of RRR	15
A.1 Recommendation on specimen mounting orientation	15
A.2 Alternative methods for increasing temperature of specimen above superconducting transition temperature	15
A.3 Alternative measurement methods of R_2 or R_2^*	15
A.4 Bending strain dependency of RRR for Nb-Ti composite superconductor	18
A.5 Procedure of correction of bending strain effect	21
Annex B (informative) Uncertainty considerations	23
B.1 Overview	23
B.2 Definitions	23
B.3 Consideration of the uncertainty concept	23

B.4	Uncertainty evaluation example for TC 90 standards.....	25
Annex C (informative) Uncertainty evaluation in test method of RRR for Nb-Ti and Nb ₃ Sn composite superconductors		27
C.1	Evaluation of uncertainty.....	27
C.2	Summary of round robin test of RRR of a Nb-Ti composite superconductor.....	30
C.3	Reason for large COV value in the intercomparison test on Nb ₃ Sn composite superconductor	31
Bibliography.....		32
Figure 1 – Relationship between temperature and resistance.....		8
Figure 2 – Voltage versus temperature curves and definitions of each voltage		10
Figure A.1 – Definition of voltages		17
Figure A.2 – Bending strain dependency of RRR value for pure Cu matrix of Nb-Ti composite superconductors (comparison between measured values and calculated values).....		19
Figure A.3 – Bending strain dependency of RRR value for round Cu wires.....		19
Figure A.4 – Bending strain dependency of normalized RRR value for round Cu wires.....		20
Figure A.5 – Bending strain dependency of RRR value for rectangular Cu wires		20
Figure A.6 – Bending strain dependency of normalized RRR value for rectangular Cu wires.....		21
Figure C.1 – Distribution of observed r_{RRR} of Cu/Nb-Ti composite superconductor		31
Table A.1 – Minimum diameter of the measurement mandrel for round wires		21
Table A.2 – Minimum diameter of the measurement mandrel for rectangular wires.....		21
Table B.1 – Output signals from two nominally identical extensometers		24
Table B.2 – Mean values of two output signals		24
Table B.3 – Experimental standard deviations of two output signals.....		24
Table B.4 – Standard uncertainties of two output signals		25
Table B.5 – COV values of two output signals.....		25
Table C.1 – Uncertainty of each measurement.....		30
Table C.2 – Obtained values of R_1 , R_2 and r_{RRR} for three Nb ₃ Sn samples		31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SUPERCONDUCTIVITY –**Part 4: Residual resistance ratio measurement –
Residual resistance ratio of Nb-Ti and Nb₃Sn
composite superconductors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61788-4 has been prepared by IEC technical committee 90: Superconductivity.

This fourth edition cancels and replaces the third edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the unification of similar test methods for residual resistance ratio (RRR) of Nb-Ti and Nb₃Sn composite superconductors, the latter of which is described in IEC 61788-11.

The text of this standard is based on the following documents:

FDIS	Report on voting
90/359/FDIS	90/360/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61788 series, published under the general title *Superconductivity*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Copper, Cu/Cu-Ni or aluminium is used as matrix material in Nb-Ti and Nb₃Sn composite superconductors and works as an electrical shunt when the superconductivity is interrupted. It also contributes to recovery of the superconductivity by conducting heat generated in the superconductor to the surrounding coolant. The cryogenic-temperature resistivity of copper is an important quantity, which influences the stability and AC losses of the superconductor. The residual resistance ratio is defined as a ratio of the resistance of the superconductor at room temperature to that just above the superconducting transition.

This part of IEC 61788 specifies the test method for residual resistance ratio of Nb-Ti and Nb₃Sn composite superconductors. The curve method is employed for the measurement of the resistance just above the superconducting transition. Other methods are described in A.3.

SUPERCONDUCTIVITY –

Part 4: Residual resistance ratio measurement – Residual resistance ratio of Nb-Ti and Nb₃Sn composite superconductors

1 Scope

This part of IEC 61788 specifies a test method for the determination of the residual resistance ratio (RRR) of Nb-Ti and Nb₃Sn composite superconductors with Cu, Cu-Ni, Cu/Cu-Ni and Al matrix. This method is intended for use with superconductor specimens that have a monolithic structure with rectangular or round cross-section, RRR value less than 350, and cross-sectional area less than 3 mm². In the case of Nb₃Sn, the specimens have received a reaction heat-treatment.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-815, *International Electrotechnical Vocabulary – Part 815: Superconductivity* (available at: www.electropedia.org)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-815 and the following apply.

3.1 residual resistance ratio RRR

ratio of resistance at room temperature to the resistance just above the superconducting transition


Note 1 to entry: This note applies to the French language only.

Note 2 to entry: In this part of IEC 61788 for Nb-Ti and Nb₃Sn composite superconductors, the room temperature is defined as 293 K (20 °C), and the residual resistance ratio is obtained in Formula (1), where the resistance (R_1) at 293 K is divided by the resistance (R_2) just above the superconducting transition.

$$r_{\text{RRR}} = \frac{R_1}{R_2} \quad (1)$$

Here r_{RRR} is a value of the residual resistance ratio, R_2 is a value of the resistance measured in a strain-free condition and zero external magnetic field.

Figure 1 shows schematically a resistance versus temperature curve acquired on a specimen while measuring the cryogenic resistance.



The cryogenic resistance, R_2 , is determined by the intersection, A, of two straight lines (a) and (b) at temperature T_c^* .

Figure 1 – Relationship between temperature and resistance

4 Principle

The resistance measurement both at room and cryogenic temperatures shall be performed with the four-terminal technique. All measurements are done without an applied magnetic field.

The target relative combined standard uncertainty of this method is defined as an expanded uncertainty ($k = 2$) not to exceed 5 %.

The maximum bending strain induced during mounting and cooling the Nb-Ti specimen shall not exceed 2 %. The measurement shall be conducted in a strain-free condition or in a condition with allowable thermal strain for the Nb₃Sn specimen.

5 Apparatus

5.1 Material of measurement mandrel or of measurement base plate

Material of the measurement mandrel for a coiled Nb-Ti specimen or of the measurement base plate for a straight Nb-Ti or Nb₃Sn specimen shall be copper, aluminium, silver, or the like whose thermal conductivity is equal to or better than 100 W/(m·K) at liquid helium temperature (4,2 K). The surface of the material shall be covered with an insulating layer (tape or a layer made of polyethylene terephthalate, polyester, polytetrafluoroethylene, etc.) whose thickness is 0,1 mm or less.

5.2 Diameter of the measurement mandrel and length of the measurement base plate

The diameter of the measurement mandrel shall be large enough to keep the bending strain of the specimen less than or equal to 2 % for the Nb-Ti specimen. The Nb₃Sn specimen on a base plate shall be measured in a strain-free condition or a condition with allowable thermal strain.

The measurement base plate shall be at least 30 mm long in one dimension.

5.3 Cryostat for the resistance (R_2) measurement

The cryostat shall include a specimen support structure and a liquid helium reservoir for measurement of the resistance R_2 . The specimen support structure shall allow the specimen, which is mounted on a measurement mandrel or a measurement base plate, to be lowered into and raised out of a liquid helium bath. In addition, the specimen support structure shall be made so that a current can flow through the specimen and the resulting voltage generated along the specimen can be measured.

6 Specimen preparation

The test specimen shall have no joints or splices with a length of 30 mm or longer. The specimen shall be instrumented with current contacts near each of its ends and a pair of voltage contacts over its central portion. The distance between two voltage taps (L) shall be 25 mm or longer. A thermometer for measuring cryogenic temperature shall be attached near the specimen.

Some mechanical method shall be used to hold the specimen against the insulated layer of the measurement mandrel or base plate. Special care should be taken during instrumentation and installation of the specimen on the measurement mandrel or base plate so that no excessive force, which may cause undesired bending strain or tensile strain, would be applied to the specimen. Ideally, it is intended that the Nb₃Sn specimen be as straight as possible; however, this is not always the case, thus care should be taken to measure the specimen in its as received condition.

The specimen shall be mounted on a measurement mandrel or on a measurement base plate for these measurements. Both resistance measurements, R_1 and R_2 , shall be made on the same specimen and the same mounting.

7 Data acquisition and analysis

7.1 Resistance (R_1) at room temperature

The mounted specimen shall be measured at room temperature (T_m (K)), where T_m satisfies the following condition: $273 \text{ K} \leq T_m \leq 308 \text{ K}$. A specimen current (I_1 (A)) shall be applied so that the current density is in the range of 0,1 A/mm² to 1 A/mm² based on the total wire cross-sectional area, and the resulting voltage (U_1 (V)), I_1 and T_m shall be recorded. Formula (2) below shall be used to calculate the resistance (R_m) at room temperature. The resistance (R_1) at 293 K (20 °C) shall be calculated using Formula (3) for a wire with Cu matrix. The value of R_1 shall be set equal to R_m , without any temperature correction, for wires that do not contain a pure Cu component.

$$R_m = \frac{U_1}{I_1} \quad (2)$$

$$R_1 = \frac{R_m}{[1 + 0,00393 \times (T_m - 293)]} \quad (3)$$

7.2 Resistance (R_2 or R_2^*) just above the superconducting transition


7.2.1 Correction of strain effect

Under a strained condition of the Nb-Ti specimen, the measured cryogenic resistance, R_2^* , is not a correct value for R_2 . The corresponding correction of the strain effect is described in 7.3.

7.2.2 Data acquisition of cryogenic resistance

The specimen, which is still mounted as it was for the room temperature measurement, shall be placed in the cryostat for electrical measurement specified in 5.3. Horizontal mounting of the specimen is recommended in A.1. Alternate cryostats that employ a heating element to sweep the specimen temperature are described in A.2. The specimen shall be slowly lowered into the liquid helium bath and cooled to liquid helium temperature over a time period of at least 5 min.

During the acquisition phases of the low-temperature R_2^* measurements, a specimen current (I_2) shall be applied so that the current density is in the range 0,1 A/mm² to 10 A/mm² based on the total wire cross-sectional area, and the resulting voltage (U (V)), I_2 (A), and specimen temperature (T (K)) shall be recorded. In order to keep the ratio of signal to noise high enough, the measurement shall be carried out under the condition that the absolute value of the resulting voltage above the superconducting transition exceeds 10 μ V. An illustration of the data to be acquired and its analysis is shown in Figure 2.



IEC

NOTE Voltages with subscripts + and – are those obtained in the first and second measurements under positive and negative currents, respectively, and U_{20+} and U_{20-} are those obtained at zero current. For clarity, U_{0rev} measured at zero current is not shown coincident with U_{0-} . Straight line (a) is drawn in the transition region with a sharp increase in the voltage with temperature and straight line (b) is drawn in the region with a nearly constant voltage.

Figure 2 – Voltage versus temperature curves and definitions of each voltage

When the specimen is in the superconducting state and the test current (I_2) is applied, two voltages shall be measured nearly simultaneously: U_{0+} (the initial voltage recorded with a positive current polarity) and U_{0rev} (the voltage recorded during a brief change in applied current polarity). A valid R_2^* measurement requires that excessive interfering voltages are not present and that the specimen is initially in the superconducting state. Thus, the following condition shall be met for a valid measurement:

$$\frac{|U_{0+} - U_{0rev}|}{\bar{U}_2} < 1 \% \quad (4)$$

where \bar{U}_2 is the average voltage for the specimen in the normal state at cryogenic temperature, which is defined by Formula (5).

The specimen shall be gradually warmed so that it changes to the normal state completely. When the cryostat for the resistance measurement specified in 5.3 is used, this can be achieved simply by raising the specimen to an appropriate position above the liquid helium level. The specimen voltage versus temperature curve shall be acquired with the rate of temperature increase maintained between 0,1 K/min and 10 K/min. The voltage versus temperature curve shall continue to be recorded during the transition into the normal state, up to a temperature somewhat less than 15 K for the Nb-Ti specimen and less than 25 K for the Nb₃Sn specimen. Then, the specimen current shall be decreased to zero and the corresponding voltage, U_{20+} , shall be recorded at a temperature below 15 K for the Nb-Ti specimen and below 25 K for the Nb₃Sn specimen.

The specimen shall then be slowly lowered into the liquid helium bath and cooled to within ± 1 K from the temperature at which the initial voltage signal U_{0+} was recorded. A specimen current, I_2 , with the same magnitude but negative polarity (polarity opposite that used for the initial curve) shall be applied and the voltage U_{0-} shall be recorded at this temperature. The procedural steps shall be repeated to record the voltage versus temperature curve with this negative current. In addition, when the measurement current, I_2 , decreases to 0, the recording of U_{20-} shall be made at within ± 1 K from the temperature at which U_{20+} was recorded.

Each of the two voltage versus temperature curves shall be analysed by drawing a line (a) through the data where the absolute value of voltage sharply increases with temperature (see Figure 2) and drawing a second line (b) through the data above the transition where the voltage is nearly constant for Nb-Ti or raised gradually and almost linearly for Nb₃Sn with temperature increase. U_{2+}^* and U_{2-}^* in Figure 2 shall be determined at the intersection of these two lines for the positive and negative polarity curves, respectively.

The corrected voltages, U_{2+} and U_{2-} , shall be calculated using the following equations: $U_{2+} = U_{2+}^* - U_{0+}$ and $U_{2-} = U_{2-}^* - U_{0-}$. The average voltage, \bar{U}_2 , shall be defined as

$$\bar{U}_2 = \frac{|U_{2+} - U_{2-}|}{2} \quad (5)$$

A valid R_2^* measurement requires that the shift of thermoelectric voltage be within acceptable limits during the measurements of U_{2+} and U_{2-} . Thus, the following condition shall be met for a valid measurement:

$$\frac{|\Delta_+ - \Delta_-|}{\bar{U}_2} < 3 \% \quad (6)$$

where Δ_+ and Δ_- are defined as $\Delta_+ = U_{20+} - U_{0+}$ and $\Delta_- = U_{20-} - U_{0-}$. If the R_2^* measurement does not meet the validity requirements in 7.2.2, specifically either in Formula (4) or (6), then improvement steps either in hardware or experimental operation shall be taken to meet these requirements before results are reported.

Formula (7) shall be used to calculate the measured resistance (R_2^*) just above the superconducting transition.

$$R_2^* = \frac{\overline{U_2}}{I_2} \quad (7)$$

7.2.3 Optional acquisition methods

The method described in the body of this part of IEC 61788 is the “reference” method and optional acquisition methods are outlined in A.3.

7.3 Correction on measured R_2^* of Nb-Ti composite superconductor for bending strain

If there is no pure Cu component in the superconductor, then R_2 shall be set equal to R_2^* .

For a specimen with a pure Cu component, the bending strain shall be defined by $\varepsilon_b = 100 \times (h/r)$ (%), where h is a half of the specimen thickness and r is the bending radius. If the bending strain is less than 0,3 %, then no correction is necessary, and R_2 shall be set equal to R_2^* .

If neither of the above two situations applies, then the resistance R_2 just above the superconducting transition under the strain-free condition shall be estimated by

$$R_2 = R_2^* - \Delta\rho \times \frac{L}{S_{Cu}} \quad (8)$$

where $\Delta\rho$ is defined below and S_{Cu} and L are defined in 8.4. The increase in the resistivity of pure copper at 4,2 K due to tensile strain, ε (%), is expressed by

$$\Delta\rho (\Omega m) = 6,24 \times 10^{-12} \varepsilon - 5,11 \times 10^{-14} \varepsilon^2; \varepsilon \leq 2 \% \quad (9)$$

The calculation of Formula (9) shall be carried out assuming that the equivalent tensile strain ε is $(1/2)\varepsilon_b$ and $(4/3 \pi)\varepsilon_b$ for rectangular and round wires, respectively. The bending strain dependency of residual resistance ratio for pure copper is described in A.4.

7.4 Residual resistance ratio (RRR)

The RRR value shall be calculated using Formula (1).

8 Uncertainty and stability of the test method

8.1 Temperature

The room temperature shall be determined with a standard uncertainty not exceeding 0,6 K, while holding the specimen, which is mounted on the measurement mandrel or on the measurement base plate, at room temperature.

8.2 Voltage measurement

For the resistance measurement, the voltage signal shall be measured with a relative standard uncertainty not exceeding 0,3 %.

8.3 Current

When the current is directly applied to the specimen with a programmable DC current source, the specimen test current shall be determined with a relative standard uncertainty not exceeding 0,3 %.

When the specimen test current is determined from a voltage-current characteristic of a standard resistor by the four-terminal technique, the standard resistor, with a relative combined standard uncertainty not exceeding 0,3 %, shall be used.

The fluctuation of DC specimen test current, provided by a DC power supply, shall be less than 0,5 % during every resistance measurement.

8.4 Dimension

The distance along the specimen between the two voltage taps (L) shall be determined with a relative combined standard uncertainty not exceeding 5 %.

For correction of the bending strain effect in the case of the wire with pure Cu matrix, the cross-sectional area of Cu matrix (S_{Cu}) shall be determined using a nominal value of copper to non-copper ratio and nominal dimensions of the specimen. The wire diameter (d) and mandrel radius (R_d) shall be determined with relative standard uncertainty not exceeding 1 % and 3 %, respectively.

9 Test report

9.1 RRR value

The obtained RRR value (r_{RRR}) shall be reported as

$$r_{RRR}(1 \pm U_{re}) \quad (n = \dots), \quad (10)$$

where

U_{re} is the expanded relative uncertainty:

$$U_{re} = 2u_r \quad (k = 2)$$

where

u_r denotes the relative combined standard uncertainty,

k is a coverage factor, and

n is the sampling number.

It is desired that n be larger than 4 so that the normal distribution can be assumed for observed results to estimate the standard deviation. If n is not sufficiently large, a rectangular distribution shall be assumed.

9.2 Specimen

The test report for the result of the measurements shall also include the following items, if known:

- a) Manufacturer;
- b) Classification and/or symbol;
- c) Shape and area of the cross-section;

- d) Dimensions of the cross-sectional area;
- e) Number of filaments or subelements;
- f) Diameter of the filaments or subelements;
- g) Cu to Nb-Ti volume ratio, Cu-Ni to Nb-Ti volume ratio, or Cu, Cu-Ni to Nb-Ti volume ratio, or Al, Cu to Nb-Ti volume ratio or volume ratio among Cu-Ni, Cu, and Nb-Ti or among Al, Cu, and Nb-Ti for Nb-Ti specimen;
- h) Cu to non-Cu volume ratio for Nb₃Sn specimen;
- i) Cross-sectional area of the Cu matrix (S_{Cu}).

9.3 Test conditions

9.3.1 Measurements of R_1 and R_2

The following test conditions shall be reported for the measurements of R_1 and R_2 :

- a) Total length of the specimen;
- b) Distance between the voltage measurement taps (L);
- c) Length of each current contact;
- d) Transport currents (I_1 and I_2);
- e) Current densities (I_1 and I_2 divided by the nominal total wire cross-sectional area);
- f) Voltages (U_1 , U_{0+} , U_{0rev} , U_{2+}^* , U_{20+} , U_{0-} , U_{2-}^* , U_{20-} and \bar{U}_2);
- g) Resistances (R_m , R_1 , R_2^* and R_2);
- h) Resistivities ($\rho_1 = (R_1 \times S_{Cu})/L$ and $\rho_2 = (R_2 \times S_{Cu})/L$);
- i) Material, shape, and dimensions of the mandrel or the base plate;
- j) Installation method of the specimen in the mandrel or the base plate;
- k) Insulating material of the mandrel or the base plate.

9.3.2 Measurement of R_1

The following test conditions shall be reported for the measurement of R_1 :

- a) Temperature setting and holding method of the specimen;
- b) T_m : Temperature for measurement of R_m .

9.3.3 Measurement of R_2

The following test conditions shall be reported for the measurement of R_2 :

- a) Rate of increasing temperature;
- b) Method of cooling down and heating up.

Additional information relating to the measurement of RRR is given in Annex A. Annex B describes definitions and an example of uncertainty in measurement. Uncertainty evaluation in the reference test method of RRR for composite superconductors is given in Annex C.

Annex A (informative)

Additional information relating to the measurement of RRR

A.1 Recommendation on specimen mounting orientation

When a specimen is in the form of straight wire, horizontal mounting of the wire on the base plate is recommended since this mounting orientation can reduce possible thermal gradient along the wire compared to the vertical mounting orientation. Here the horizontal mounting orientation means that the wire axis is parallel to the surface of liquid helium.

A.2 Alternative methods for increasing temperature of specimen above superconducting transition temperature

The following methods are also recommended for increasing temperature above the superconducting transition of the specimen. The rate of increasing temperature of the whole specimen within a range between 0,1 K/min and 10 K/min should be applied for these methods. In order to dampen the rate of increasing temperature and to avoid a large temperature gradient, special care should be taken in selecting heater power, heat capacity (the specimen with the measurement mandrel or the measurement base plate) and the distance between the heater and the specimen.

a) Heater method

The specimen can be heated above the superconducting transition by a heater installed in the measurement mandrel or in the measurement base plate after taking the specimen out of the liquid helium bath in the cryostat.

b) Adiabatic methods

1) Adiabatic method

In this method, the cryostat holds a chamber in which the specimen, a sample holder, a heater and so on are contained. Before the chamber is immersed in the liquid helium bath, air inside the chamber is pumped out and helium gas is filled. Then, the chamber is immersed in the liquid helium bath and the specimen is cooled to a temperature of 5 K or lower. After the helium gas is pumped out, the specimen can be heated above the superconducting transition by the heater under adiabatic condition.

2) Quasi-adiabatic method

In this method, the cryostat holds the specimen a certain distance above the liquid helium bath for the entire cryogenic measurement. A thermal anchor from the measurement mandrel or the measurement base plate to the liquid helium bath allows the specimen to be cooled to a temperature of 5 K or lower. The specimen can be heated above the superconducting transition by a heater located in the measurement mandrel or the measurement base plate under quasi-adiabatic condition.

c) Refrigerator method

In this method, an electromechanical apparatus (a refrigerator) is used to cool the specimen, which is mounted on a measurement mandrel or a measurement base plate, to a temperature of 6 K or lower. The specimen can be heated above the superconducting transition by a heater or by controlling the refrigerator power.

A.3 Alternative measurement methods of R_2 or R_2^*

The following methods can optionally be used for acquisition of R_2 or R_2^* .

a) Modified reference method

This is a simplified method with acquisition of only one voltage-temperature curve and is used only for Nb-Ti composite superconductors. The voltage of the specimen is measured in the superconducting state under a desired direction of current (I_2) and then with current in the opposite direction. These values are U_{0+} and U_{0rev} as shown in Figure A.1. The current is then changed back to the initial direction. After the transition to the normal state, the voltage is measured as U'_{2+} in a plateau region of the curve within about 4 K above the transition. Then the voltage is read under a zero current (U_{20}). The current direction is then reversed and the voltage is measured again (U'_{2-}). The cryogenic resistance is obtained from

$$R_2^* = \frac{\bar{U}_2}{I_2} \quad (\text{A.1})$$

with


$$\bar{U}_2 = \frac{|U'_{2+} - U'_{2-}|}{2} \quad (\text{A.2})$$

This approximately compensates for the effect of thermoelectric voltage. The following conditions should be fulfilled to ensure that the influence of the interfering voltage and the thermoelectric voltage shift on R_2^* measurement is not appreciably large:

$$\frac{|U_{0+} - U_{0rev}|}{\bar{U}_2} < 1 \% \quad (\text{A.3})$$

$$\frac{\Delta_{2+} - \Delta_{2-}}{\bar{U}_2} < 3 \% \quad (\text{A.4})$$

where Δ_{2+} and Δ_{2-} are defined by $\Delta_{2+} = |U'_{2+} - U_{20}|$ and $\Delta_{2-} = |U'_{2-} - U_{20}|$, respectively.



IEC

Figure A.1 – Definition of voltages

b) Fixed temperature method

In this method R_2 or R_2^* is directly determined at a fixed temperature in a plateau region within about 4 K above the transition for Nb-Ti composite superconductors, and R_2 is directly determined at 20 K for Nb₃Sn composite superconductors, instead of using the method described in 7.2. In this case it is desirable to check that the whole specimen is at a uniform and fixed temperature. In the measurement of Nb₃Sn composite superconductor the fixed temperature of 20 K should be determined with a combined standard uncertainty not exceeding 0,6 K. The fixed temperature and the combined standard uncertainty should be noted in the test report. Also the U_{0+} and U_{0-} , which are defined in 7.2.2, should be recorded as the zero voltage level in the fixed method. In order to eliminate the influence of thermoelectric voltage, two voltage signals of the specimen, say U_{2+} and U_{2-} , should be acquired nearly simultaneously by reversal of the test current. For the fixed method the effect of thermoelectric voltage on determination of cryogenic resistance can be eliminated.

c) Computer-based method

A computer can be used to control the current direction and warming of the specimen and to measure the voltage-temperature curve. Changes in current direction by periodic current reversals or periodic current on and off cycles are used to correct for offset voltages in order that the measurements can be made during one cycle of changing the specimen temperature. The effect of thermoelectric voltage should also be checked.

d) Other simplified methods with periodic checks

Simplified methods without temperature measurement might also be accepted, if an operator with sufficient experience performs the measurement using a given apparatus and if the following condition is satisfied. If a simplified laboratory practice can be shown, through periodic checks, to achieve the same result as the method in this part of IEC 61788, within its stated uncertainty, then the simplified practice may be used in place of this reference method. These periodic checks could be accomplished by doing one of the following:

- 1) an interlaboratory comparison where one laboratory uses the reference method and another laboratory uses their simplified method;
- 2) a single laboratory comparison where one laboratory "checks" their simplified method against the reference method;

- 3) periodic measurement of a small set of reference samples with well-known RRR values using the simplified method;
- 4) regular/frequent measurements with multiple specimens, one of which is a reference sample that would not be mounted/dismounted and would be measured every time as a calibrator.

A.4 Bending strain dependency of RRR for Nb-Ti composite superconductor

In general, the resistivity (ρ) of a pure metal such as copper at a very-low temperature increases as its applied strain increases. In general, a lower ρ wire has a larger percentage change in ρ than a higher ρ wire. There is almost no effect of strain on the room temperature resistivity of a metal. This means that the change in r_{RRR} with strain is more significant for a material whose r_{RRR} is high. According to the result of the intercomparison tests [1]¹, the dependency on bending strain was low for a specimen of low r_{RRR} . Bending strain is applied when the specimen is mounted on the measurement mandrel. Since the bending strain is inversely proportional to a radius of bent curvature, the smaller the diameter of the measurement mandrel the larger is the bending strain being applied to the specimen.

The increase in resistivity, $\Delta\rho$, at 4 K as a function of cold working ratio, r_{CW} [%], for pure copper is shown in Chapter 8 of reference [2]. Since the value of r_{CW} is approximately equal to the value of tensile strain, ε , when ε is small, the result is expressed as in Formula (9). The dependency of the copper resistivity increase on bending strain can be obtained by replacing the bending strain by an equivalent tensile strain.

Figure A.2 shows the relationship between r_{RRR} and bending strain for Nb-Ti composite superconductors with pure Cu matrix, obtained from the measured values of the intercomparison test performed in 1993 and 1994. The lines in the figure are the relationships calculated according to Formula (9) for each specimen. The measured values basically agree with the calculated values, and high r_{RRR} materials are sensitive to bending strain. Using Formula (9), Figure A.3 shows the dependency of round Cu wires where r_{RRR} with zero strain ($r_{RRR}(0)$) varies from 50 to 350. Figure A.4 shows bending strain dependency of r_{RRR} normalized by the value at zero strain. A similar dependency of rectangular Cu wires is shown in Figures A.5 and A.6. For copper with r_{RRR} of 350, which is the highest limit of r_{RRR} in this part of IEC 61788, the r_{RRR} decreases by about 10 % for a bending strain of 2 %, with respect to the zero strain value.

¹ Numbers in square brackets refer to the Bibliography.




Figure A.2 – Bending strain dependency of RRR value for pure Cu matrix of Nb-Ti composite superconductors (comparison between measured values and calculated values)




Figure A.3 – Bending strain dependency of RRR value for round Cu wires




Figure A.4 – Bending strain dependency of normalized RRR value for round Cu wires




Figure A.5 – Bending strain dependency of RRR value for rectangular Cu wires




Figure A.6 – Bending strain dependency of normalized RRR value for rectangular Cu wires

To evaluate a high- r_{RRR} material, it is therefore desirable to use a straight base plate or a mandrel with a large coil diameter so that the evaluation can be performed with the least possible bending strain being applied. In addition to this, special care should be taken with the specimen so that there is no significant strain applied to it during handling.

The minimum diameters, d_{min} , of the measurement mandrel for round and rectangular wires are listed in Table A.1 and Table A.2, respectively.

Table A.1 – Minimum diameter of the measurement mandrel for round wires

Wire diameter d [mm]	0,50	0,75	1,00	1,25	1,50
Minimum diameter d_{min} [mm]	10,6	15,9	21,2	26,5	31,8

Table A.2 – Minimum diameter of the measurement mandrel for rectangular wires

Thickness t [mm]	0,25	0,50	0,75	1,00
Minimum diameter d_{min} [mm]	6,3	12,5	18,8	25,0

A.5 Procedure of correction of bending strain effect

Clause A.5 describes the procedure of correction of bending strain effect on the resistance at low temperature given in 7.3. For a specimen of thickness $2h$ mounted on a mandrel of radius R_d , the bending strain is given by

$$\varepsilon_b = 100 \times (h/R_d) \% \quad (\text{A.5})$$

Then, the equivalent tensile strain is

$$\varepsilon = (1/2)\varepsilon_b \quad (\text{A.6})$$

for a rectangular wire and

$$\varepsilon = [4/(3\pi)]\varepsilon_b \quad (\text{A.7})$$

for a round wire. The increase in the resistivity of pure copper at 4,2 K is calculated by substituting this ε value into Formula (9). Then, the corrected resistance at low temperature is calculated using Formula (8).

Annex B (informative)

Uncertainty considerations

B.1 Overview

In 1995, a number of international standards organizations, including IEC, decided to unify the use of statistical terms in their standards. It was decided to use the word “uncertainty” for all quantitative (associated with a number) statistical expressions and eliminate the quantitative use of “precision” and “accuracy”. The words “accuracy” and “precision” could still be used qualitatively. The terminology and methods of uncertainty evaluation are standardized in ISO/IEC Guide 98-3:2008 [3].

It was left to each Technical Committee to decide if they were going to change existing and future standards to be consistent with the new unified approach. Such change is not easy and creates additional confusion, especially for those who are not familiar with statistics and the term uncertainty. At the June 2006 TC 90 meeting in Kyoto, it was decided to implement these changes in future standards.

Converting “accuracy” and “precision” numbers to the equivalent “uncertainty” numbers requires knowledge about the origins of the numbers. The coverage factor of the original number may have been 1, 2, 3, or some other number. A manufacturer’s specification that can sometimes be described by a rectangular distribution will lead to a conversion number of $1/\sqrt{3}$. The appropriate coverage factor was used when converting the original number to the equivalent standard uncertainty. The conversion process is not something that the user of the standard needs to address for compliance to TC 90 standards, it is only explained here to inform the user about how the numbers were changed in this process. The process of converting to uncertainty terminology does not alter the user’s need to evaluate their measurement uncertainty to determine if the criteria of the standard are met.

The procedures outlined in TC 90 measurement standards were designed to limit the uncertainty of any quantity that could influence the measurement, based on TC 90 experts’ engineering judgment and propagation of error analysis. Where possible, the standards have simple limits for the influence of some quantities so that the user is not required to evaluate the uncertainty of such quantities. The overall uncertainty of a standard was then confirmed by an interlaboratory comparison.

B.2 Definitions

Statistical definitions can be found in three sources: ISO/IEC Guide 98-3:2008, ISO/IEC Guide 99:2007 [4], and the NIST Guidelines for Evaluating and Expressing the Uncertainty of NIST Measurement Results (NIST) [5]. Not all statistical terms used in this part of IEC 61788 are explicitly defined in ISO/IEC Guide 98-3:2008. For example, the terms “relative standard uncertainty” and “relative combined standard uncertainty” are used in ISO/IEC Guide 98-3:2008 (5.1.6, Annex J), but they are not formally defined in ISO/IEC Guide 98-3:2008 (see [5]).

B.3 Consideration of the uncertainty concept

Statistical evaluations in the past frequently used the coefficient of variation (COV), which is the ratio of the standard deviation and the mean (N.B. the COV is often called the relative standard deviation). Such evaluations have been used to assess the precision of the measurements and give the closeness of repeated tests. The standard uncertainty (SU) depends more on the number of repeated tests and less on the mean than the COV and

therefore in some cases gives a more realistic picture of the data scatter and test judgment. The example in Table B.1 shows a set of electronic drift and creep voltage measurements from two nominally identical extensometers using the same signal conditioner and data acquisition system. The $n = 10$ data pairs are taken randomly from the spreadsheet of 32 000 cells. Here, extensometer number one (E_1) is at zero offset position whilst extensometer number two (E_2) is deflected to 1 mm. The output signals are in volts. Tables B.2, B.3, B.4 and B.5 are the mean values, experimental standard deviations, standard uncertainties and COV values of two output signals, respectively.

Table B.1 – Output signals from two nominally identical extensometers

Output signal [V]	
E_1	E_2
0,001 220 70	2,334 594 73
0,000 610 35	2,334 289 55
0,001 525 88	2,334 289 55
0,001 220 70	2,334 594 73
0,001 525 88	2,334 594 73
0,001 220 70	2,333 984 38
0,001 525 88	2,334 289 55
0,000 915 53	2,334 289 55
0,000 915 53	2,334 594 73
0,001 220 70	2,334 594 73

Table B.2 – Mean values of two output signals

Mean (\bar{X}) [V]	
E_1	E_2
0,001 190 19	2,334 411 62

$$\bar{X} = \frac{\sum_{i=1}^n X_i}{n} \quad [\text{V}] \quad (\text{B.1})$$

Table B.3 – Experimental standard deviations of two output signals

Experimental standard deviation (σ) [V]	
E_1	E_2
0,000 303 48	0,000 213 381

$$\sigma = \sqrt{\frac{1}{n-1} \cdot \sum_{i=1}^n (X_i - \bar{X})^2} \quad [\text{V}] \quad (\text{B.2})$$

Table B.4 – Standard uncertainties of two output signals

Standard uncertainty (u) [V]	
E_1	E_2
0,000 095 97	0,000 067 48

$$u = \frac{\sigma}{\sqrt{n}} \text{ [V]} \quad (\text{B.3})$$

Table B.5 – COV values of two output signals

COV value [%]	
E_1	E_2
25,498 2	0,009 1

$$X_{\text{COV}} = \frac{\sigma}{X} \quad (\text{B.4})$$

The standard uncertainty is very similar for the two extensometer deflections. In contrast, the COV value (X_{COV}) is nearly a factor of 2 800 different between the two data sets. This shows the advantage of using the standard uncertainty, which is independent of the mean value.

B.4 Uncertainty evaluation example for TC 90 standards

The observed value of a measurement does not usually coincide with the true value of the measurand. The observed value may be considered as an estimate of the true value. The uncertainty is part of the "measurement error" which is an intrinsic part of any measurement. The magnitude of the uncertainty is both a measure of the metrological quality of the measurements and improves the knowledge about the measurement procedure. The result of any physical measurement consists of two parts: an estimate of the true value of the measurand and the uncertainty of this "best" estimate. ISO/IEC Guide 98-3:2008, within this context, is a guide for a transparent, standardized documentation of the measurement procedure. One can attempt to measure the true value by measuring "the best estimate" and using uncertainty evaluations which can be considered as two types: Type A uncertainties (repeated measurements in the laboratory in general expressed in the form of Gaussian distributions) and Type B uncertainties (previous experiments, literature data, manufacturer's information, etc. often provided in the form of rectangular distributions).

The calculation of uncertainty using the ISO/IEC Guide 98-3:2008 procedure is illustrated in the following example:

- a) The user derives in the first step a mathematical measurement model in the form of identified measurand as a function of all input quantities. A simple example of such model is given for the uncertainty of a force, F_{LC} measurement using a load cell:

$$F_{\text{LC}} = F_m + d_W + d_R + d_{\text{Re}},$$

where F_m , d_W , d_R , and d_{Re} represent the force expected due to an applied standard mass, the manufacturer's data, repeated checks of standard mass/day and the reproducibility of checks on different days, respectively.

Here the input quantities are: the measured force of standard mass using different balances (Type A), manufacturer's data deviation (Type B), repeated test results using the digital electronic system (Type B), and reproducibility of the final values measured on different days (Type B).

- b) The user should identify the type of distribution for each input quantity (e.g. Gaussian distributions for Type A measurements and rectangular distributions for Type B measurements).
- c) Evaluate the standard uncertainty of the Type A measurements:

$$u_A = \frac{\sigma}{\sqrt{n}}$$

where σ is the experimental standard deviation and n is the total number of measured data points.

- d) Evaluate the standard uncertainties of the Type B measurements:

$$u_B = \sqrt{\frac{1}{3} \cdot d_w^2 + \dots\dots}$$

where d_w is the range of rectangular distributed values.

- e) Calculate the combined standard uncertainty for the measurand by combining all the standard uncertainties using the expression

$$u_C = \sqrt{u_A^2 + u_B^2}$$

In this case, it has been assumed that there is no correlation between input quantities. If the model equation has terms with products or quotients, the combined standard uncertainty is evaluated using partial derivatives and the relationship becomes more complex due to the sensitivity coefficients [6], [7].

- f) Optional – the combined standard uncertainty of the estimate of the referred measurand can be multiplied by a coverage factor (e.g. 1 for 68 % or 2 for 95 % or 3 for 99 %) to increase the probability that the measurand can be expected to lie within the interval.
- g) Report the result as the estimate of the measurand \pm the expanded uncertainty, together with the unit of measurement, and, at a minimum, state the coverage factor used to compute the expanded uncertainty and the estimated coverage probability.

To facilitate the computation and standardize the procedure, use of appropriate certified commercial software is a straightforward method that reduces the amount of routine work [8], [9]². In particular, the indicated partial derivatives can be easily obtained when such a software tool is used. Further references for the guidelines of measurement uncertainties are given in [5], [10], and [11].

² References [8] and [9] give example(s) of suitable products available commercially. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of these products.

Annex C (informative)

Uncertainty evaluation in test method of RRR for Nb-Ti and Nb₃Sn composite superconductors

C.1 Evaluation of uncertainty

Uncertainty in the residual resistance ratio is composed of the standard uncertainty in the room temperature resistance (u_{R1}) and that in the cryogenic resistance (u_{R2}). In the following the coverage factor k is assumed to be 1 for simplicity.

The residual resistance ratio of the superconducting wire is given by $r_{RRR} = R_1/R_2$. If the deviations of R_1 and R_2 from their statistical averages are ΔR_1 and ΔR_2 , the deviation of the residual resistance ratio, Δr_{RRR} , is

$$\frac{\Delta r_{RRR}}{r_{RRR}} = \frac{\Delta R_1}{R_1} - \frac{\Delta R_2}{R_2}. \quad (\text{C.1})$$

Hence, the relative standard uncertainty of r_{RRR} is

$$u_r = \left[\left(\frac{u_{R1}}{R_1} \right)^2 + \left(\frac{u_{R2}}{R_2} \right)^2 \right]^{1/2}. \quad (\text{C.2})$$

Since the room temperature resistance is given by

$$R_1 = \frac{U_1}{[1 + 0,00393(T_m - 293)]I_1} [\Omega], \quad (\text{C.3})$$

the deviation of R_1 is

$$\begin{aligned} \Delta R_1 &= \frac{\partial R_1}{\partial U_1} \Delta U_1 + \frac{\partial R_1}{\partial T_m} \Delta T_m + \frac{\partial R_1}{\partial I_1} \Delta I_1 \\ &= \frac{1}{1 + 0,00393(T_m - 293)} \left(\frac{\Delta U_1}{I_1} - 0,00393 R_1 \Delta T_m - \frac{U_1}{I_1^2} \Delta I_1 \right) \\ &\cong \frac{\Delta U_1}{I_1} - 0,00393 R_1 \Delta T_m - \frac{U_1}{I_1^2} \Delta I_1 [\Omega], \end{aligned} \quad (\text{C.4})$$

where ΔU_1 , ΔT_m and ΔI_1 are the deviations of the voltage, temperature and applied current, respectively. The approximation in Formula (C.4) is based on the fact that the effect of difference of temperature from 293 K (20 °C) on sensitivity coefficients is small. Its effect on the final target uncertainty is 0,2 % at most (for measurement at 273 K (0 °C)). The corresponding deviation of the room temperature can be divided as

$$\Delta T_m = \Delta T_{m1} + \Delta T_{m2} \quad [\text{K}] \quad (\text{C.5})$$

where ΔT_{m1} is a difference between the measured room temperature and the specimen temperature, and ΔT_{m2} is the deviation caused by the bolometer. Thus, the standard uncertainty in the room temperature resistance is given by

$$u_{R1} = \left[\left(\frac{u_{U1}}{I_1} \right)^2 + u_{RTm1}^2 + (0,00393R_1)^2 u_{Tm2}^2 + \left(\frac{U_1}{I_1^2} \right)^2 u_{I1}^2 \right]^{1/2} \quad [\Omega] \quad (C.6)$$

where

u_{U1} [V] is the type B uncertainty in the room temperature voltage ($u_{U1}/U_1 = 0,005/\sqrt{3}$),

u_{I1} [A] is the type B uncertainty in the room temperature current ($u_{I1}/I_1 = 0,005/\sqrt{3}$),

u_{Tm2} [K] is the type B uncertainty in the room temperature measurement using a bolometer ($u_{Tm2} = 1/\sqrt{3}$ [K]).

The u_{RTm1} [Ω] is the type B uncertainty in R_1 due to the difference of the room temperature from the specimen temperature and is formally expressed as $u_{RTm1} = -0,00393I_1u_{Tm1}$. However, u_{Tm1} is not obtained from a mathematical model but u_{Tm1} is directly estimated as $\pm 17\%$ of R_1 from the results of round robin testing on RRR of Nb-Ti [12]. Assuming a similar situation, it can also be assumed as $u_{RTm1}/R_1 = 0,017/\sqrt{3}$.

In the cryogenic resistance measurement, the specimen voltage is measured twice with a change in the current direction. It should be noted that the voltage at the transition is determined by drawing two straight lines and an appreciable uncertainty may appear in these analyses. This uncertainty is denoted by b . Then, the standard uncertainty in the cryogenic temperature resistance is similarly given by

$$u_{R2} = \left[2 \left(\frac{u_{U2}}{I_2} \right)^2 + 2b^2 + \left(\frac{U_2}{I_2^2} \right)^2 u_{I2}^2 \right]^{1/2} \quad [\Omega] \quad (C.7)$$

where u_{U2} [V] is the type B uncertainty due to the voltmeter, and u_{I2} [A] is the type B uncertainty in the current. In the above, $u_{U2}/U_2 = 0,005/\sqrt{3}$ and $u_{I2}/I_2 = 0,005/\sqrt{3}$. The first and second terms are doubled because the measurements are done twice. Hence, when the sample is measured in a bending-free condition, the relative combined standard uncertainty is given by

$$u_r = \left[1,43 \times 10^{-4} + 2 \left(\frac{b}{R_2} \right)^2 \right]^{1/2} \quad (C.8)$$

When the sample current is measured using a voltmeter and a standard resistor, the uncertainties of the voltage and resistance affect the uncertainty of measurement. If the value of the voltage and its standard uncertainty are U and u_U , and if the value of the resistance and its standard uncertainty are R and u_R , $(U_1/I_1^2)^2 u_{I1}^2$ in Formula (C.6) and $(U_2/I_2^2)^2 u_{I2}^2$ in Formula (C.7) are respectively replaced by

$$\left(\frac{U_1}{I_1} \right)^2 \left(\frac{u_U^2}{U^2} + \frac{u_R^2}{R^2} \right), \quad \left(\frac{U_2}{I_2} \right)^2 \left(\frac{u_U^2}{U^2} + \frac{u_R^2}{R^2} \right) \quad (C.9)$$

When the cryogenic resistance is measured in a bent condition, the result needs to be compensated for the strain effect using the given equation with the distance between the two voltage taps (L), the diameter (d), copper ratio (r_{Cu}) and the radius of a mandrel (R_d) used for the measurement. We assume that a round wire of diameter d is wound on a measurement mandrel of radius R_d . With the aid of Formulae (8) and (9) the value of the compensated cryogenic resistance is given by

$$\begin{aligned} R_2 &= R_2^* - 6,24 \times 10^{-12} \frac{8}{3\pi^2} \frac{L}{dr_{Cu}R_d} \\ &= R_2^* - 1,69 \times 10^{-12} \frac{L}{dr_{Cu}R_d} \quad [\Omega] \end{aligned} \quad (C.10)$$

where we have used $\varepsilon = (4/3 \pi)(d/2R_d)$ and $S_{Cu} = \pi(d/2)^2 r_{Cu}$, and the small second term in Formula (9) was neglected. The quantity r_{Cu} is a ratio that copper occupies in a cross-sectional area of the wire and can be given by $r_{Cu} = c/(1 + c)$ using the copper ratio, c . If the second term in Formula (C.10) is denoted by δR_2 , the contribution to the combined standard uncertainty of u_{R2} from the uncertainties of L , d , r_{Cu} and R_d is estimated as

$$u_{R2}^* = |\delta R_2| \left[\left(\frac{u_L}{L} \right)^2 + \left(\frac{u_d}{d} \right)^2 + \left(\frac{u_{rCu}}{r_{Cu}} \right)^2 + \left(\frac{u_{Rd}}{R_d} \right)^2 \right]^{1/2} \quad [\Omega] \quad (C.11)$$

where u_L [m], u_d [m], u_{rCu} and u_{Rd} [m] are the type B standard uncertainties of distance between voltage taps, diameter, copper ratio and radius of mandrel, respectively. L is required to be measured within the uncertainty $u_L/L = 0,05/\sqrt{3}$. It is assumed that the uncertainty of d is $u_d/d = 0,02/\sqrt{3}$. The relative uncertainties of r_{Cu} and R_d are required to be smaller than $0,05/\sqrt{3}$. The maximum compensation is about $\delta R_2/R_2 = 0,10$ when the bending strain is 2 % for $r_{RRR} = 350$. Hence, the relative combined standard uncertainty of cryogenic resistance due to the bending strain correction is estimated at most to be

$$\frac{u_{R2}^*}{R_2} = 0,513 \times 10^{-2}. \quad (C.12)$$

From the above analysis the relative combined standard uncertainty in the residual resistance ratio is given by

$$u_r = \frac{u}{(R_1/R_2)} = \left[\left(\frac{u_{R1}}{R_1} \right)^2 + \left(\frac{u_{R2}}{R_2} \right)^2 + \left(\frac{u_{R2}^*}{R_2} \right)^2 \right]^{1/2} = \left[1,69 \times 10^{-4} + 2 \left(\frac{b}{R_2} \right)^2 \right]^{1/2}. \quad (C.13)$$

According to the round robin test shown in C.2, u_r was estimated as $2,44 \times 10^{-2}$. Thus, b/R_2 is estimated as

$$\frac{b}{R_2} = 1,46 \times 10^{-2}. \quad (C.14)$$

The type and target value of uncertainty of each measurement are listed in Table C.1.

Table C.1 – Uncertainty of each measurement

Uncertainty	Type	Value	Remarks
u_{U1}/U_1	B	$0,005/\sqrt{3}$	$ \Delta U_1 /U_1 < 0,005$
u_{I1}/I_1	B	$0,005/\sqrt{3}$	$ \Delta I_1 /I_1 < 0,005$
u_{Tm2}	B	$1/\sqrt{3}$ K	$ \Delta T_m < 1$ K
u_{U2}/U_2	B	$0,005/\sqrt{3}$	$ \Delta U_2 /U_2 < 0,005$
u_{I2}/I_2	B	$0,005/\sqrt{3}$	$ \Delta I_2 /I_2 < 0,005$
u_L/L	B	$0,05/\sqrt{3}$	$ \Delta L /L < 0,05$
u_d/d	B	$0,02/\sqrt{3}$	$ \Delta d /d < 0,02$
u_{rCu}/r_{Cu}	B	$0,05/\sqrt{3}$	$ \Delta r_{Cu} /r_{Cu} < 0,05$
u_{Rd}/R_d	B	$0,05/\sqrt{3}$	$ \Delta R_d /R_d < 0,05$

C.2 Summary of round robin test of RRR of a Nb-Ti composite superconductor

The round robin test of RRR was carried out on a Cu/Nb-Ti composite superconductor. The specifications of the test superconductor are:

- diameter: 0,80 mm, 0,86 mm including insulating layer;
- Cu/Nb-Ti ratio: 6,5;
- mean filament diameter: about 70 μ m;
- number of filaments: 16;
- twist pitch: 30 mm;
- critical current: more than 185 A (3 T, 4,2 K);
- r_{RRR} : more than 150.

Participating institutes were provided with specimens that were nearly straight. Some specimens were measured in the as-received condition and some were measured wound on a bobbin under a strained condition. The number of participating institutes was 13 from five countries and the number of determinations was 77. R_2 was measured following the method defined in 7.2 and 7.3, and those in A.3. The details of the measurements are described in reference [12]. The effect of the strain was corrected using Formulae (8) and (9). The distribution of the measured r_{RRR} is shown in Figure C.1. Almost all of the data, except for three, were concentrated fairly sharply. The average was 178,5, the standard deviation was 4,4 and the COV value was 2,44 %. If the three extraordinary data are omitted, the average was 178,2, the standard deviation was 3,1 and the COV value was 1,73 %.

Hence, it is reasonable to define the target relative combined standard uncertainty of this method not to exceed 2,5 % based on the COV value in the round robin test.




Figure C.1 – Distribution of observed r_{RRR} of Cu/Nb-Ti composite superconductor

C.3 Reason for large COV value in the intercomparison test on Nb₃Sn composite superconductor

The COV value of the intercomparison test for Nb₃Sn samples was 6,07 % [13]. This value is much larger than that for Nb-Ti (2,44 %), although there is no contribution from additional uncertainty in correction of the strain effect. For clarification of this reason an intercomparison test was performed between two laboratories for three Nb₃Sn samples, two of which were cut from the same batch of heat treatment. The r_{RRR} obtained using the reference method agreed within 1 % between the two laboratories for the three samples as shown in Table C.2, while the r_{RRR} values were different between the two samples obtained from the same batch [14]. This indicates that the large COV value in the former intercomparison test originated from inhomogeneity of samples, while the test method itself was fairly accurate. This inhomogeneity may be due to the high sensitivity to heat treatment conditions or due to defects of the diffusion barrier. Since a r_{RRR} value is commonly required to be greater than a minimum value in order to pass, the existence of inhomogeneities may require that several specimens of a given wire be measured and reported.

Table C.2 – Obtained values of R_1 , R_2 and r_{RRR} for three Nb₃Sn samples

Sample	Laboratory 1			Laboratory 2		
	$R_1(293\text{ K}) [\Omega]$	$R_2(T_c^*) [\Omega]$	r_{RRR}	$R_1(293\text{ K}) [\Omega]$	$R_2(T_c^*) [\Omega]$	r_{RRR}
B	$1,593 \times 10^{-3}$	$1,49 \times 10^{-5}$	107	$1,61 \times 10^{-3}$	$1,49 \times 10^{-5}$	108
C	$1,719 \times 10^{-3}$	$1,66 \times 10^{-5}$	104	$1,74 \times 10^{-3}$	$1,66 \times 10^{-5}$	105
D	$1,619 \times 10^{-3}$	$1,61 \times 10^{-5}$	100	$1,65 \times 10^{-3}$	$1,62 \times 10^{-5}$	101

For this reason the uncertainty in the test method of RRR for Nb₃Sn is expected to be as low as that for Nb-Ti. Therefore, the value of $b/R_2 = 1,46 \times 10^{-2}$ obtained in the intercomparison test for RRR measurement in Nb-Ti can also be used to estimate the uncertainty of r_{RRR} in Nb₃Sn with Formula (C.8). In addition, the result shown in Table C.2 indicates that the main difference between the measurements in the two laboratories comes from the observed values of R_1 . This is considered to be caused by the uncertainty in the room temperature.

Bibliography

- [1] MURASE S., SAITOH T., MATSUSHITA T. and OSAMURA K. Standardization of the method for the determination of the residual resistance ratio (RRR) of Cu/Nb-Ti composite superconductors. *Proc. of ICEC16/ICMC*, Kitakyushu, May 1996, p.1795
 - [2] SIMON N.J., DREXLER E.S., REED R.P. *Properties of Copper and Copper Alloys at Cryogenic Temperatures*. NIST Monograph, 177 (1992)
 - [3] ISO/IEC Guide 98-3:2008, *Uncertainty of measurement – Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*
 - [4] ISO/IEC Guide 99:2007, *International vocabulary of metrology – Basic and general concepts and associated terms (VIM)*
 - [5] TAYLOR, B.N. and KUYATT, C.E. Guidelines for Evaluating and Expressing the Uncertainty of NIST Measurement Results. NIST Technical Note 1297, 1994 (Available at <<http://physics.nist.gov/Pubs/guidelines/TN1297/tn1297s.pdf>>)
 - [6] KRAGTEN, J. Calculating standard deviations and confidence intervals with a universally applicable spreadsheet technique, *Analyst*, Vol. 119, 2161 (1994)
 - [7] EURACHEM / CITAC Guide CG 4 Second edition:2000, Quantifying Uncertainty in Analytical Measurement
 - [8] Available at <<http://www.metrodata.de/>>
 - [9] Available at <<http://www.isgmax.com/>>
 - [10] CHURCHILL, E., HARRY, H.K. and COLLE, R. Expression of the Uncertainties of Final Measurement Results. NBS Special Publication 644 (1983)
 - [11] JAB NOTE Edition 1:2003, Estimation of Measurement Uncertainty (Electrical Testing / High Power Testing). (Available at <<http://www.jab.or.jp>>)
 - [12] MATSUSHITA T., OTABE E.S., MURASE S., OSAMURA K. and HUA CY. *Adv. in Supercond.* XI, Tokyo, Springer, 1507 (1999)
 - [13] MURASE S., SAITOH T., MORIAI H., MATSUSHITA T and OSAMURA K., *Advances in Superconductivity.* XI, Tokyo, Springer, 1511 (1999)
-

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK