



BSI Standards Publication

Industrial-process measurement and control — Data structures and elements in process equipment catalogues

Part 12: Lists of properties (LOPs) for flow
measuring equipment for electronic data
exchange

National foreword

This British Standard is the UK implementation of EN 61987-12:2016. It is identical to IEC 61987-12:2016.

The UK participation in its preparation was entrusted to Technical Committee AMT/7, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016.

Published by BSI Standards Limited 2016

ISBN 978 0 580 75075 5

ICS 25.040.40; 35.100.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2016.

Amendments/corrigenda issued since publication

Date	Text affected
-------------	----------------------

EUROPEAN STANDARD

EN 61987-12

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2016

ICS 25.040.40; 35.100.20

English Version

**Industrial- Process Measurement and Control - Data Structures
and Elements in Process Equipment Catalogues - Part 12: Lists
of properties (LOPs) for flow measuring equipment for electronic
data exchange
(IEC 61987-12:2016)**

Mesure et commande dans les processus industriels -
Éléments et structures de données dans les catalogues
d'équipements de processus - Partie 12: Listes de
propriétés (LDP) pour les équipements de mesure de débit
pour l'échange électronique de données
(IEC 61987-12:2016)

Industrielle Leittechnik - Datenstrukturen und -elemente in
Katalogen der Prozessleittechnik - Teil 12: Merkmalleisten
(ML) für Durchflussmessgeräte für den elektronischen
Datenaustausch
(IEC 61987-12:2016)

This European Standard was approved by CENELEC on 2016-04-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 65E/490/FDIS, future edition 1 of IEC 61987-12, prepared by SC 65E "Devices and integration in enterprise systems" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61987-12:2016.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2017-01-27
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2019-04-27

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61987-12:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60079-0:2011	NOTE	Harmonized as EN 60079-0:2012.
IEC 60947-5-6:1999	NOTE	Harmonized as EN 60947-5-6:2000.
IEC 61298-1:2008	NOTE	Harmonized as EN 61298-1:2008.
IEC 61298-2:2008	NOTE	Harmonized as EN 61298-2:2008.
IEC 61298-3:2008	NOTE	Harmonized as EN 61298-3:2008.
IEC 61360-1	NOTE	Harmonized as EN 61360-1.
IEC 61360-2	NOTE	Harmonized as EN 61360-2.
IEC 61360-5	NOTE	Harmonized as EN 61360-5.
IEC 61784-1:2003	NOTE	Harmonized as EN 61784-1:2004.
IEC 61987-1	NOTE	Harmonized as EN 61987-1.
ISO 5167-2:2003	NOTE	Harmonized as EN ISO 5167-2:2003.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u> series	<u>Title</u>	<u>EN/HD</u>	<u>Year</u> series
IEC 61360		Standard data elements types with associated classification scheme for electric items - Part 1: Definitions - Principles and methods	EN 61360	
IEC 61987-10	2009	Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 10: Lists of Properties (LOPs) for Industrial-Process Measurement and Control for Electronic Data Exchange - Fundamentals	EN 61987-10	2009
-	-		+ AC	2011
IEC 61987-11	2012	Industrial-process measurement and control - Data structures and elements in process equipment catalogues -- Part 11: List of Properties (LOP) of measuring equipment for electronic data exchange - Generic structures	EN 61987-11	2012

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	6
4 General	7
4.1 Overview.....	7
4.2 Depiction of OLOPs and DLOPs	7
4.2.1 General	7
4.2.2 Structural roles	7
4.2.3 Marking of polymorphic areas.....	8
4.3 Examples of DLOP block usage.....	11
4.3.1 Block “Input”	11
4.3.2 Block “Output”.....	13
Annex A (normative) Operating list of properties for flow measuring equipment.....	17
Annex B (normative) Device lists of properties for flow measuring equipment.....	18
B.1 Flow transmitter	18
B.2 Coriolis mass flow transmitter.....	18
B.3 Thermal mass flow transmitter.....	18
B.4 Orifice/differential pressure flow transmitter	18
B.5 Variable area flow transmitter/gauge.....	19
B.6 (Oval) gear flow transmitter/gauge.....	19
B.7 Helix flow transmitter/gauge	19
B.8 Piston flow transmitter/gauge	19
B.9 Electromagnetic flow transmitter	20
B.10 Electromagnetic insertion flow transmitter.....	20
B.11 Turbine/propeller/Woltmann flow transmitter/gauge.....	20
B.12 Swirl flow transmitter	20
B.13 Ultrasonic flow transmitter	21
B.14 Vortex flow transmitter	21
B.15 Positive displacement flow transmitter/gauge.....	21
B.16 Remote/separate transmitter	21
Annex C (normative) Property library.....	22
Annex D (normative) Block library for considered device types.....	23
Bibliography	24
Figure 1 – Structure of a polymorphic area	8
Table 1 – Example of structure of polymorphic areas.....	10
Table 2 – Example for the “Input” block	11
Table 3 – Example for the “Output” block.....	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL-PROCESS MEASUREMENT AND CONTROL –
DATA STRUCTURES AND ELEMENTS
IN PROCESS EQUIPMENT CATALOGUES –**

**Part 12: Lists of properties (LOPs) for flow measuring
equipment for electronic data exchange**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61987-12 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this standard is based on the following documents:

FDIS	Report on voting
65E/490/FDIS	65E/494/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61987 series, published under the general title *Industrial-process measurement and control – Data structures and elements in process equipment catalogues*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The exchange of product data between companies, business systems, engineering tools, data systems within companies and, in the future, control systems (electrical, measuring and control technology) can run smoothly only when both the information to be exchanged and the use of this information has been clearly defined.

Prior to this standard, requirements on process control devices and systems were specified by customers in various ways when suppliers or manufacturers were asked to quote for suitable equipment. The suppliers in their turn described the devices according to their own documentation schemes, often using different terms, structures and media (paper, databases, CDs, e-catalogues, etc.). The situation was similar in the planning and development process, with device information frequently being duplicated in a number of different information technology (IT) systems.

Any method that is capable of recording all existing information only once during the planning and ordering process and making it available for further processing, gives all parties involved an opportunity to concentrate on the essentials. A precondition for this is the standardization of both the descriptions of the objects and the exchange of information.

This standard series proposes a method for standardization which will help both suppliers and users of measuring equipment to optimize workflows both within their own companies and in their exchanges with other companies. Depending on their role in the process, engineering firms may be considered here to be either users or suppliers.

The method specifies measuring equipment by means of blocks of properties. These blocks are compiled into lists of properties (LOPs), each of which describes a specific equipment (device) type. This standard series covers both properties that may be used in an inquiry or a proposal and detailed properties required for integration of the equipment in computer systems for other tasks.

IEC 61987-10 defines structure elements for constructing lists of properties for electrical and process control equipment in order to facilitate automatic data exchange between any two computer systems in any possible workflow, for example engineering, maintenance or purchasing workflow and to allow both the customers and the suppliers of the equipment to optimize their processes and workflows. IEC 61987-10 also provides the data model for assembling the LOPs.

IEC 61987-11 specifies the generic structure for operating and device lists of properties (OLOPs and DLOPs). It lays down the framework for further parts of IEC 61987 in which complete LOPs for device types measuring a given physical quantity and using a particular measuring principle will be specified. The generic structure may also serve as a basis for the specification of LOPs for other industrial-process control instrument types such as control valves and signal processing equipment.

IEC 61987-12 concerns flow measuring equipment. It provides one operating LOP for all types of flow transmitter which can be used, for example, as a request for various sorts of quotation. The DLOPs provided in this standard for a range of flow transmitter types can be used in very different ways: in the computer systems of equipment manufacturers and suppliers; in CAE and similar systems of EPC contractors and other engineering companies; and especially in the various plant maintenance systems used by plant owners. The OLOP and the DLOPs provided correspond to the guidelines specified in IEC 61987-10 and IEC 61987-11.

INDUSTRIAL-PROCESS MEASUREMENT AND CONTROL – DATA STRUCTURES AND ELEMENTS IN PROCESS EQUIPMENT CATALOGUES –

Part 12: Lists of properties (LOPs) for flow measuring equipment for electronic data exchange

1 Scope

This part of IEC 61987 provides an

- operating list of properties (OLOP) for the description of the operating parameters and the collection of requirements for a flow measuring equipment and
- device lists of properties (DLOP) for the description of a number of flow measuring equipment types.

The structures of the OLOP and the DLOP correspond to the general structures defined in IEC 61987-11 and agree with the fundamentals for the construction of LOPs defined in IEC 61987-10.

Aspects other than the OLOP, needed in different electronic data exchange processes described in IEC 61987-10, will be published in IEC 61987-92¹.

Libraries of properties and of blocks used in the LOPs in this standard are listed in Annex C and Annex D.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61360 (all parts), *Standard data elements types with associated classification scheme for electric components*

IEC 61987-10:2009, *Industrial-process measurement and control – Data structures and elements in process equipment catalogues – Part 10: List of Properties (LOPs) for Industrial-Process Measurement and Control for Electronic Data Exchange – Fundamentals*

IEC 61987-11:2012, *Industrial-process measurement and control – Data structures and elements in process equipment catalogues – Part 11: Lists of Properties (LOP) of measuring equipment for electronic data exchange – Generic structures*

3 Terms and definitions

For the purpose of this document, the terms and definitions given in IEC 61987-10 and IEC 61987-11 apply.

¹ Under consideration

4 General

4.1 Overview

The LOPs provided by this document are intended for use in electronic data exchange processes performed between any two computer systems. The computer systems can both belong to the same company or they can belong to different companies as described in Annex C of IEC 61987-10:2009.

The OLOP for the family of flow measuring equipment is to be found in Annex A while the DLOPs of the individual flow device types are to be found in Annex B.

Structural elements such as LOP type, block and property defined in this standard are available in electronic form in the “Automation equipment” domain of the IEC Common Data Dictionary (CDD).

4.2 Depiction of OLOPs and DLOPs

4.2.1 General

The properties of the OLOPs and DLOPs used in this part of IEC 61987 have been created in conformance to the requirements of the IEC 61360 series. As such, the structural elements, properties and attributes to be found in the IEC Common Data Dictionary are normative.

4.2.2 Structural roles

The entities within a list of properties can have one of a number of structural roles.

a) Property

A property exists as a property only.

b) Ref. property + Block

A reference property connects a block to the superordinate block or LOP in which it is embedded.

Properties and sub-blocks listed below a block name and placed one position to the right are elements of the block. A block ends when another block name appears in the same column as the block name or in any other column to its left.

The reference property has the same preferred name as the block to which it refers. All attributes of these properties are available in the IEC Common Data Dictionary (CDD).

c) Cardinality property

A cardinality property is connected to the block which immediately follows it. The value of the property (0 ... n) in a transaction file determines the number of times the associated block shall be repeated. It is identified by the identifier in the column “Property identifier”.

The preferred name of a cardinality property is “Number of <xxxx>“, where <xxxx> is derived from name of the block with which it is associated.

In the transaction file (see examples in 4.3), it can be seen that a block has been repeated twice:

- the cardinality property directly before the block has a value greater than 1,
- the name of the repeated block is extended by “_” followed by the repetition number.

Example:

If the block “Signal function” is repeated 3 times, the following construction occurs in the transaction file:

“number of signal function” has the value “3”	- cardinality property
“ Signal function_1 ”	- first repeated block
...	
“ Signal function_2 ”	- second repeated block
...	

“Signal function_3”

- third repeated block

...

d) **Ref. property + Block**

This role is similar to b) but the block concerned can be repeated according to value of the cardinality property which precedes it.

e) **Polymorphic control property**

A polymorphic control property provides the means of introducing complete blocks of properties describing different realizations of a particular device function, for instance inputs and outputs. The property has a value list containing the designations of the blocks that may be introduced. When in a transaction file a polymorphic control property is assigned a value, the corresponding block follows (see examples in Tables 2 and 3).

A polymorphic control property is identified in the IEC Common Data Dictionary by the identifier in the column “Property identifier”. The preferred name of a polymorphic property is “<xxxx> type“, where <xxxx> is normally the derived from name of the block with which it is associated.

f) **Ref. property + Polymorphic block**

This role is similar to b) but the block concerned is created by polymorphism.

g) **Polymorphic control property with the fixed value: “<Block name from value list>”**

This property appears directly behind the polymorphic block property. It is the same property as the polymorphic control property for the block, but with the fixed value used to create the block (see IEC 61987-10).

4.2.3 Marking of polymorphic areas

To help identify the possible polymorphic blocks in a list of properties in a printable version of this standard, a number with grey background has been added to the rightmost column of the DLOP to indicate the properties associated with the block. It should be noted that in transaction file, only the polymorphic block selected from value list of the polymorphic control property would appear in the superordinate block.

Block Name (*containing a polymorphic area*)

Properties and sub-blocks
(*of the common part, valid for all alternative cases*)

Name of the polymorphic control property (*which has a value list consisting of exactly n values*)

Block Name (*for alternative case 1*)

Properties and sub-blocks
(*for alternative case 1*)

Block Name (*for alternative case 2*)

Properties and sub-blocks
(*for alternative case 2*)

...

Block Name (*for alternative case n*)

Properties and sub-blocks
(*for alternative case n*)

IEC

Figure 1 – Structure of a polymorphic area

Every polymorphic area corresponds to a block, the structure of which is shown in Figure 1. A polymorphic area begins with the name of this block containing this area.

The block name can be optionally followed by any number of additional properties or sub-blocks, provided that they are valid for all alternative sub-blocks that can be generated by the polymorphism.

The polymorphic control property follows, by means of which one of the alternative blocks can be selected. The alternative sub-blocks with their properties and sub-blocks are now listed one after the other.

The polymorphic area ends with the last property of the last sub-block that can be selected using the value list of the polymorphic control property.

In order to facilitate the analysis of the LOPs the following non-normative numerical marking system has been used. A polymorphic area can have one or more subordinate, polymorphic areas embedded in it. Table 1 shows the structure of the polymorphic areas implemented in the DLOPs of Annex B. In Table 1, each individual polymorphic area has been assigned a unique number. The areas have been numbered in the sequence which they occur in the LOP, not according to their level in the structure. The number of an embedded area has therefore a marking number greater than the marking number of area in which it is embedded.

For example, the majority of the content of the “Output” block is generated from the polymorphic area marked with the number 8, which starts at “Type of output” and can include any of the specializations which also are marked with the number 8. Each specialization also includes in this case a further polymorphic area, “Assigned variable” which is marked by its own number (>8).

Table 1 – Example of structure of polymorphic areas

Block name	Marking number of 1 st level polymorphic area	Marking number of nested polymorphic area (2 nd level)
Input		
Measured variable		
Type of measured variable	1	
Auxiliary input		
Type of auxiliary input	2	
Analog current input	2	
Assigned variable	2	3
Analog voltage input	2	
Assigned variable	2	4
Frequency input	2	
Assigned variable	2	5
Pulse input	2	
Assigned variable	2	6
Manufacturer-specific input	2	
Assigned variable	2	7
Output		
Type of output	8	
Analog current output	8	
Assigned variable	8	9
Analog voltage output	8	
Assigned variable	8	10
Frequency output	8	
Assigned variable	8	11
Pulse output	8	
Assigned variable	8	12
Manufacturer-specific	8	
Assigned variable	8	13
Pneumatic/hydraulic output	8	
Assigned variable	8	14
Performance		
Performance variable		
Type of performance variable	15	
Mechanical and electrical construction		
Structural design		
Structural design of a thermal mass flow transmitter	16	

In the OLOP for flow measuring equipment, there is only one polymorphic area. It appears in the block “Phase”.

In order to make clear how the structural elements such as block, cardinality and polymorphism can be implemented using the LOPs of this standard some examples are provided in 4.3.

4.3 Examples of DLOP block usage

4.3.1 Block “Input”

A Coriolis mass flowmeter with DN25 process connections has three input variables: mass flow, density and temperature. An additional binary voltage input can be configured to operate a totalizer reset or to start/stop batching. The Input block in the DLOP is configured as shown in Table 2 (... indicates a property or properties that have not been used; grey shading indicates polymorphism).

Table 2 – Example for the “Input” block

Name of LOP type, block or property ²		Assigned value	Unit
...			
Input			
	Number of measured variables	3	
Measured variable_1			
	...		
	Type of measured variable		
	measured variable type	Mass flow measurement	
Mass flow measurement			
	measured variable type	Mass flow measurement	
	measuring principle	Coriolis mass flow for liquids	
Measuring range for mass flow			
	lower range-limit of mass flow	0	kg/h
	upper range-limit of mass flow	18 000	kg/h
	base density	1 000	kg/m ³
	...		
Measured variable_2			
	...		
	measured variable type	Density measurement	
Density measurement			
	measured variable type	Density measurement	
	measuring principle		
Measuring range for density			
	lower range-limit of density	310	kg/m ³
	upper range-limit of density	8 000	kg/m ³
	...		
Measured variable_3			
	...		

² In the CDD, block names start with a capital letter, property names with a lower case letter

Name of LOP type, block or property ²		Assigned value	Unit
	measured variable type	Temperature measurement	
	Temperature measurement		
	measured variable type	Temperature measurement	
	type of temperature measurement	Temperature	
	measuring principle		
	Measuring range for temperature		
	lower range-limit of temperature	0	°C
	upper range-limit of temperature	150	°C
	number of auxiliary inputs	1	
	Auxiliary input		
	...		
	connected variable	Status input	
	function of input/output	Switch	
	Type of auxiliary input		
	auxiliary input type	Binary input	
	Binary input		
	auxiliary input type	Binary input	
	reference standard		
	number of signal functions	2	
	Signal function _1		
	purpose of signal	Totalizer reset	
	state for "low" signal	None	
	state for " high" signal	Reset totalizer	
	...		
	Signal function_2		
	purpose of signal	Batching start/stop	
	state for "low" signal	Stop batching	
	state for " high" signal	Start batching	
	...		
	...		
	minimum signal level for signal "0"	0	V
	maximum signal level for signal "0"	0	V
	minimum signal level for signal "1"	3	V
	maximum signal level for signal "1"	30	V
	...		
	electrical data for passive behaviour		
	...		
	number of galvanic isolations	1	
	Galvanic isolation		
	galvanic isolation from inputs	5 000	V
	...		

4.3.2 Block “Output”

A Coriolis mass flowmeter has three outputs: a current output, a pulse/frequency output and a relay output, comprising an NC and an NO relay. The process variable assigned to the outputs at the factory is mass flow, the default flow mass range being the measuring range. The Output block in the DLOP is configured as shown in Table 3 (only the parameters used are shown; grey shading indicates polymorphism).

Table 3 – Example for the “Output” block

Name of LOP type, block or property ³		Assigned value	Unit
...			
number of outputs		3	
Output_1			
...			
displayed variable		Mass flow	
function of input/output		Representation of measured value	
Type of output			
output type		Analog current output	
Analog current output			
output type		Analog current output	
Assigned variable			
assigned variable type		Assigned mass flow range	
Assigned mass flow range			
assigned variable type		Assigned mass flow range	
lower range-value of mass flow		0	kg/h
upper range-value of mass flow		18 000	kg/h
Analog current output parameters			
type of current output		Configurable 0/4...20 mA	
power source behaviour		Active, passive	
set power source behaviour		Passive	
lower range end-value of current output		4	mA
upper range end-value of current output		20	mA
lower current limit of the proportional range		3,8	mA
upper current limit of the proportional range		20,5	
Current signal on alarm			
current for lower signal on alarm		3,5	mA
current for upper signal on alarm		22	mA
configurability of signal on alarm		MIN, MAX, HOLD, User value	
set signal on alarm		MIN	
superimposed digital communication		HART	
current signal resolution		0,5	µA
Electrical data for passive behaviour			
rated voltage		24	V
minimum voltage		18	VDC

³ In the CDD, block names start with a capital letter, property names with a lower case letter

Name of LOP type, block or property ³				Assigned value	Unit
			maximum voltage	30	VDC
			...		
			minimum current	3,5	mA
			maximum current	22	mA
			...		
			minimum load at voltage input	150	Ω
			...		
			number of galvanic isolations	1	
			Galvanic isolation_1		
			galvanic isolation from inputs	1 000	V
			galvanic isolation from outputs	1 000	V
			..		
			galvanic isolation from external power supplies	1 000	V
			...		
			number of explosion protection parameters for intrinsic safety	1	
			Explosion protection parameters for intrinsic safety		
			...		
			explosion protection concept	N/A	
			type of intrinsically safe protection	la	
			...		
			Safety related properties for passive behaviour		
			maximum input power (P_i)	1,25	W
			maximum input voltage (U_i)	30	VDC
			maximum input current (I_i)	100	mA
			maximum internal capacitance (C_i)	6	nF
			maximum internal inductance (L_i)	0	mH
			...		
			Output_2		
			...		
			displayed variable	Mass flow	
			function of input/output	Representation of measured value	
			Type of output		
			output type	Pulse output	
			Pulse output		
			output type	Pulse output	
			Assigned variable		
			assigned variable type	Assigned mass flow value	
			Assigned mass flow value		
			assigned variable type	Assigned mass flow value	
			pulse value of mass	10	kg
			...		
			Pulse/frequency output parameters		

Name of LOP type, block or property ³		Assigned value	Unit
Pulse input/output parameters			
	minimum adjustable pulse width	0,5	ms
	maximum adjustable pulse width	2 000	ms
	set pulse width	2	ms
	...		
Pulse signal on alarm			
	...		
	configurability of signal on alarm	MIN, MAX, HOLD, User value, Ignore	
	set signal on alarm	User value	
	...		
	power source behaviour	Active, passive	
	set power source behaviour	Passive	
	switching element for passive behaviour	Open collector	
	...		
Electrical data for passive behaviour			
	...		
	maximum voltage	30	VDC
	...		
	maximum current	250	mA
	...		
	number of galvanic isolations for passive behaviour	1	
Galvanic isolation			
	galvanic isolation of electrical circuits	galvanically isolated from all inputs, outputs and power circuits	
	...		
Output_3			
	...		
	displayed variable	Mass flow	
	function of input/output	Status indication	
Type of output			
	output type	Binary isolated output	
Binary isolated output			
	output type	Binary isolated output	
	...		
	number of signal functions	2	
Signal function_1			
	purpose of signal	Limit detection	
	state for "low" signal	Measurement within limit	
	state for " high" signal	Measurement out of limits	
	...		
Signal function_2			
	purpose of signal	Empty pipe detection	
	state for "low" signal	Pipe full	
	state for " high" signal	Pipe empty	

Name of LOP type, block or property ³			Assigned value	Unit
		...		
		...		
		type of contact	Normally open	
		Electromechanical contact parameters		
		...		
		AC rating		
		maximum voltage at inductive load (AC)	30	VAC
		maximum current at inductive load (AC)	0,5	mA
		cos (phi)	0,7	
		power VA	15	VA
		DC rating		
		maximum voltage at ohmic load (DC)	60	VDC
		maximum current at ohmic load (DC)	0,1	mA
		power Watt	6	W
		switching delay	5	ms
		...		
		number of galvanic isolations	1	
		Galvanic isolation		
		galvanic isolation of electrical circuits	Galvanically isolated from all inputs, outputs and power circuits	
		...		

Annex A (normative)

Operating list of properties for flow measuring equipment

The considered OLOP has been created for for all types of flow measuring equipment. It is assigned to three areas of flow measuring equipment in the classification scheme for process measuring equipment (see Table A.1 in IEC 61987-11:2012):

- flow gauge IEC-ABA644
- flow switch IEC-ABA698
- flow transmitter IEC-ABA761

NOTE The OLOP is also to be found in the Properties Tree field and has the ID IEC-ABA003 .

The OLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>⁴

⁴ Website checked 2014.11.01

Annex B (normative)

Device lists of properties for flow measuring equipment

B.1 Flow transmitter

The DLOPs of Annex B correspond to the classification scheme for measuring equipment placed in Annex A of IEC 61987-11:2012.

The DLOP for a generic flow transmitter is assigned to the node of the classification:

- generic flow transmitter IEC-ABV010

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA005.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁵

B.2 Coriolis mass flow transmitter

The DLOP for a Coriolis mass flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- coriolis mass flow transmitter IEC-ABA763

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA006.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁵

B.3 Thermal mass flow transmitter

The DLOP for a thermal mass flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- thermal mass flow transmitter IEC-ABA764

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA016.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁵

B.4 Orifice/differential pressure flow transmitter

The DLOP for an orifice/differential pressure flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- Orifice plate flow meter IEC-ABA767

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA010.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁵

⁵ Website checked 2014.11.01

B.5 Variable area flow transmitter/gauge

The DLOP for a variable area flow transmitter/gauge is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- variable area flow transmitter/gauge IEC-ABA771

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA020.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁶

B.6 (Oval) gear flow transmitter/gauge

The DLOP for an (oval) gear flow transmitter/gauge is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- oval gear flow transmitter IEC-ABA785

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA013.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁶

B.7 Helix flow transmitter/gauge

The DLOP for a helix flow transmitter/gauge is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- helix flow transmitter IEC-ABA786

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA024.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁶

B.8 Piston flow transmitter/gauge

The DLOP for a piston flow transmitter/gauge is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- piston flow transmitter IEC-ABA788

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA014.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁶

⁶ Website checked 2014.11.01

B.9 Electromagnetic flow transmitter

The DLOP for an electromagnetic flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- electromagnetic flow transmitter IEC-ABA792

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA008.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁷

B.10 Electromagnetic insertion flow transmitter

The DLOP for an electromagnetic insertion flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- electromagnetic insertion flow transmitter IEC-ABA793

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA009.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁷

B.11 Turbine/propeller/Woltmann flow transmitter/gauge

The DLOP for a turbine/propeller/Woltmann flow transmitter/gauge is assigned to the following nodes of the classification (Table A.1 of IEC 61987-11:2012):

- turbine flow transmitter IEC-ABA799
- propeller flow transmitter IEC-ABA797

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA018.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁷

B.12 Swirl flow transmitter

The DLOP for a swirl flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- swirl flow transmitter IEC-ABA800

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA007.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁷

⁷ Website checked 2014.11.01

B.13 Ultrasonic flow transmitter

The DLOP for an ultrasonic flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- ultrasonic flow transmitter IEC-ABA801

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA019.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁸

B.14 Vortex flow transmitter

The DLOP for a vortex flow transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- vortex flow transmitter IEC-ABA802

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA022.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁸

B.15 Positive displacement flow transmitter/gauge

The DLOP for a positive displacement flow transmitter/gauge is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- positive displacement flow gauge IEC-ABA645

NOTE The DLOP is also to be found in the Properties Tree field and has the ID IEC-ABA023.

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁸

B.16 Remote/separate transmitter

The DLOP for a remote/separate transmitter is assigned to the following node of the classification (Table A.1 of IEC 61987-11:2012):

- remote/separate transmitter IEC-ABA882

The DLOP is available with all blocks and properties in the IEC CDD at:
<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁸

⁸ Website checked 2014.11.01

Annex C (normative)

Property library

The properties used in the OLOP in Annex A and DLOPs in Annex B are available with all attributes in the IEC CDD at:

<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.⁹

⁹ Website checked 2014.11.01

Annex D
(normative)

Block library for considered device types

The blocks used in the OLOPs in Annex A and DLOPs in Annex B are available with all attributes in the IEC CDD at:

<http://std.iec.ch/cdd/iec61987/cdddev.nsf/TreeFrameset?OpenFrameSet>.¹⁰

¹⁰ Website checked 2014.11.01

Bibliography

IEC 60050 (all parts), *International Electrotechnical Vocabulary* (available at <http://www.electropedia.org/>)

IEC 60079-0:2011, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60947-5-6:1999, *Low-voltage switchgear and controlgear – Part 5-6: Control circuit devices and switching elements – DC interface for proximity sensors and switching amplifiers (NAMUR)*

IEC 61298-1:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 1: General considerations*

IEC 61298-2:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 2: Tests under reference conditions*

IEC 61298-3:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 3: Tests for the effects of influence quantities*

IEC 61360-1, *Standard data element types with associated classification scheme for electric components – Part 1: Definitions – Principles and methods*

IEC 61360-2, *Standard data element types with associated classification scheme for electric components – Part 2: EXPRESS dictionary schema*

IEC 61360-5, *Standard data element types with associated classification scheme for electric components – Part 5: Extensions to the EXPRESS dictionary schema*

IEC 61784-1:2003, *Digital data communications for measurement and control – Part 1: Profile sets for continuous and discrete manufacturing relative to fieldbus use in industrial control systems*

IEC 61987-1, *Industrial-process measurement and control – Data structures and elements in process equipment catalogues – Part 1: Measuring equipment with analogue and digital output*

IEC 61987-92, *Industrial-process measurement and control – Data structures and elements in process equipment catalogues – Part 92: Lists of properties (LOP) of measuring equipment for electronic data exchange – aspect LOPs¹¹*

EN 10204:2004, *Metallic products. Types of inspection document*

ISO 5167-2:2003, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full -- Part 2: Orifice plates*

ISO 13584-25, *Industrial automation systems and integration – Parts library – Part 25: Logical resource: Logical model of supplier library with aggregate values and explicit content*

ISO 13584-42, *Industrial automation systems and integration – Parts library – Part 42: Description methodology: Methodology for structuring part families*

¹¹ In consideration.

ISO 15926-2, *Industrial automation systems and integration – Integration of life-cycle data for process plants including oil and gas production facilities – Part 2: Data model*

ISO/TS 15926-4, *Industrial automation systems and integration – Integration of life-cycle data for process plants including oil and gas production facilities – Part 4: Initial reference data*

CWA 15295: 2005-08, *Description of References and Data Models for Classification*

ISA–TR20.00.01: 2001, *Specification Forms for Process Measurement and Control Instruments. Part 1: General Considerations*

NE 100 Version 3.2: 2010, *Use of Lists of Properties in Process Control Engineering Workflows*

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Copyright in BSI publications

All the content in BSI publications, including British Standards, is the property of and copyrighted by BSI or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use.

Save for the provisions below, you may not transfer, share or disseminate any portion of the standard to any other person. You may not adapt, distribute, commercially exploit, or publicly display the standard or any portion thereof in any manner whatsoever without BSI's prior written consent.

Storing and using standards

Standards purchased in soft copy format:

- A British Standard purchased in soft copy format is licensed to a sole named user for personal or internal company use only.
- The standard may be stored on more than 1 device provided that it is accessible by the sole named user only and that only 1 copy is accessed at any one time.
- A single paper copy may be printed for personal or internal company use only.

Standards purchased in hard copy format:

- A British Standard purchased in hard copy format is for personal or internal company use only.
- It may not be further reproduced – in any format – to create an additional copy. This includes scanning of the document.

If you need more than 1 copy of the document, or if you wish to share the document on an internal network, you can save money by choosing a subscription product (see 'Subscriptions').

Reproducing extracts

For permission to reproduce content from BSI publications contact the BSI Copyright & Licensing team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email subscriptions@bsigroup.com.

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Useful Contacts

Customer Services

Tel: +44 345 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 345 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK