

# Compressed air —

## Part 9: Test methods for liquid water content

ICS 71.100.20

## National foreword

This British Standard reproduces verbatim ISO 8573-9:2004 and implements it as the UK national standard.

The UK participation in its preparation was entrusted to Technical Committee MCE/8, Compressors, pneumatic tools, pneumatic machines and vacuum technology, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this committee can be obtained on request to its secretary.

### Cross-references

The British Standards which implement international publications referred to in this document may be found in the *BSI Catalogue* under the section entitled “International Standards Correspondence Index”, or by using the “Search” facility of the *BSI Electronic Catalogue* or of British Standards Online.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a British Standard does not of itself confer immunity from legal obligations.**

### Summary of pages

This document comprises a front cover, an inside front cover, the ISO title page, pages ii to v, a blank page, pages 1 to 11 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

### Amendments issued since publication

Amd. No.	Date	Comments

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 17 June 2004

© BSI 17 June 2004

ISBN 0 580 43961 5

# INTERNATIONAL STANDARD

# ISO 8573-9

First edition  
2004-02-01

---

---

## Compressed air —

Part 9:

## Test methods for liquid water content

*Air comprimé —*

*Partie 9: Méthodes d'essai pour la détermination de la teneur en eau liquide*



Reference number  
ISO 8573-9:2004(E)



## Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Units and symbols</b> .....	<b>2</b>
<b>5 Selection of methods</b> .....	<b>2</b>
<b>6 Sampling techniques</b> .....	<b>2</b>
<b>7 Measurement methods</b> .....	<b>2</b>
<b>8 Evaluation of test results</b> .....	<b>8</b>
<b>9 Uncertainty</b> .....	<b>9</b>
<b>10 Test report</b> .....	<b>9</b>
<b>Annex A (informative) Sample test report</b> .....	<b>11</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 8573-9 was prepared by Technical Committee ISO/TC 118, *Compressors, pneumatic tools and pneumatic machines*, Subcommittee SC 4, *Quality of compressed air*.

ISO 8573 consists of the following parts, under the general title *Compressed air*:

- *Part 1: Contaminants and purity classes*
- *Part 2: Test methods for aerosol oil content*
- *Part 3: Test methods for measurement of humidity*
- *Part 4: Test methods for solid particle content*
- *Part 5: Test methods for oil vapour and organic solvent content*
- *Part 6: Test methods for gaseous contaminant content*
- *Part 7: Test methods for viable microbiological contaminant content*
- *Part 8: Test methods for solid particle content by mass concentration*
- *Part 9: Test methods for liquid water content*

Part 2 is under revision.

## Introduction

Water can be present in compressed air systems in two states: liquid and vapour. Liquid water usually consists of liquid aerosol and wall flow.

This part of ISO 8573 deals with liquid water content. Water vapour content is dealt with in ISO 8573-3.





# Compressed air —

## Part 9: Test methods for liquid water content

### 1 Scope

This part of ISO 8573 specifies test methods for determining the liquid water content in compressed air, expressed as the liquid water mass concentration. The limitations of the methods are also given. One of a series of standards aimed at harmonizing air contamination measurements, it identifies sampling techniques and also gives requirements for evaluation, uncertainty considerations and reporting for the air purity parameter liquid water. The test methods are suitable for determining the purity classes in accordance with ISO 8573-1.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1219-1, *Fluid power systems and components — Graphic symbols and circuit diagrams — Part 1: Graphic symbols*

ISO 3857-1, *Compressors, pneumatic tools and machines — Vocabulary — Part 1: General*

ISO 5598, *Fluid power systems and components — Vocabulary*

ISO 8573-1, *Compressed air — Part 1: Contaminants and purity classes*

ISO 8573-2, *Compressed air — Part 2: Test methods for aerosol oil content*

ISO 8573-3, *Compressed air — Part 3: Test methods for measurement of humidity*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 3857-1, ISO 5598, ISO 8573-1, ISO 8573-2 and the following apply.

#### 3.1

##### **water aerosol**

liquid water particles in compressed air that have negligible fall velocity/settling velocity

#### 3.2

##### **liquid water**

water aerosol and wall flow in compressed air

## 4 Units and symbols

For the purposes of this part of ISO 8573, the following, including non-SI-preferred, units are used:

- 1 bar = 100 000 Pa;
- 1 l (litre) = 0,001 m<sup>3</sup>;
- bar(a) is used for expressing absolute pressure;
- bar(e) is used for expressing effective pressure.

For the graphic symbols used in Figure 1, diagrams are in accordance with ISO 1219-1.

## 5 Selection of methods

The method to be selected is dependent on the mass concentration range of liquid water in compressed air. The most suitable method for the range of liquid water content estimated to be present in the sample may be selected from Table 1.

**Table 1 — Liquid water mass concentration measurement methods**

Type of method	Liquid water concentration ( $c_w$ ) g/m <sup>3</sup>
Gravimetric method	$c_w \geq 0,1$
Vapourization method	$c_w \leq 5$

## 6 Sampling techniques

The sampling shall be made at or near actual pressure and at a constant compressed air flow rate.

The choice of sampling method will depend upon the actual level of contamination and the compressed air flow in the compressed air system. For sampling methods, see ISO 8573-2.

Compressed air samples may be routed back into main pipe or vent to the atmosphere after measurement. The value of air sample parameters (pressure, temperature, air velocity, etc.) shall be within the ranges specified by the test equipment manufacturer.

## 7 Measurement methods

### 7.1 General

The test equipment and instruments shall be in good working order. Consideration shall be given to the calibration requirements of the measurement equipment used as given in the applicable instructions.

Pressure and temperature may also affect liquid water content measurement results. Therefore, the temperature and the pressure at the measuring point should be maintained at steady state conditions.

Reference should be made to the measurement equipment manufacturer as to applicability of the equipment.

## 7.2 Determination of liquid water content by gravimetric method

### 7.2.1 General

This method identifies the collection of condensate from the sampling point, the separation of water from that condensate and the weight of liquid water present in the compressed air sample. The volume of compressed air from which the liquid water is separated shall be measured.

### 7.2.2 Test equipment

#### 7.2.2.1 General description

The general arrangement of the test equipment for the gravimetric method shall be in accordance with Figure 1. In the case of partial flow sampling, the water separator (3) with the attendant components (12 and 13) in the drain line should be excluded.

NOTE The numbers given between parentheses refer to the numbering of the elements in Figure 1.

For symbols, see ISO 1219-1.

#### 7.2.2.2 Water separator (3)

The main function of the separator is partial removal of liquid water from air flow and protection of the high-efficiency filter (4) from overflow. The separator efficiency of water removal from the compressed air flow shall be not less than 80 %.

#### 7.2.2.3 High-efficiency filter (4)

The high-efficiency coalescing filter for liquid water removal shall have an efficiency of  $\geq 99,9$  %, rated for oil particles  $\leq 3$   $\mu\text{m}$ .

#### 7.2.2.4 Collecting vessels (13)

Vessels with a volume of not less than 0,5 l that enable the liquid water collection to be observed during testing shall be used.

#### 7.2.2.5 Oil/water separator (14)


The liquid collected in the collecting vessels (13) shall be transferred to the oil/water separator (14). A detailed explanation of the procedure of water separation is identified in ISO 8573-2.

#### 7.2.2.6 Drain valves (12)

Drain valves are used to drain the liquid water collected in the water separator (3), high-efficiency filter (4) and collecting vessels (13). A drain valve between the filter (4) and the collecting vessel is normally left in the open position; a drain valve between the collecting vessel and the oil/water separator (14) is normally left in the closed position.

#### 7.2.2.7 Measuring columns (15)

The amount of separated liquid water is measured in the measuring column graduated in millilitres or weighted in grams. The accuracy of measurement of mass shall be better than  $\pm 2$  % of the reading.



**Key**

- |                               |                      |                        |
|-------------------------------|----------------------|------------------------|
| 1 sampling point              | 6 pressure gauge     | 11 discharge outlet    |
| 2 shut-off valve              | 7 thermometer        | 12 drain valve         |
| 3 water separator             | 8 flow control valve | 13 collecting vessel   |
| 4 high-efficiency filter      | 9 air flowmeter      | 14 oil/water separator |
| 5 differential pressure gauge | 10 shut-off valve    | 15 measuring column    |

**Figure 1 — Circuit diagram of test equipment for weighing method**

**7.2.2.8 Differential pressure gauge (5)**

This gauge determines the pressure drop across the high-efficiency filter (4). The accuracy of measurement of the pressure drop shall be better than  $\pm 2\%$ .

**7.2.2.9 Pressure gauge (6)**

In order to determine the air sample volume, the values of pressure shall be recorded during the entire period of the test. The accuracy of measurement of pressure shall be better than  $\pm 2\%$  of full scale.

**7.2.2.10 Thermometer (7)**

In order to determine the air sample volume, the values of temperature shall be recorded during the entire period of the test. The accuracy of measurement of temperature shall be better than  $\pm 1\text{ }^\circ\text{C}$ .

**7.2.2.11 Air flowmeter (9)**

In order to determine the air sample volume, the values of flow rate shall be recorded during the entire period of the test. The accuracy of measurement of flow rate shall be better than  $\pm 5\%$ .

**7.2.2.12 Flow control valve (8)**

In order to adjust the flow accurately, a flow control valve with fine adjustment shall be used.

**7.2.2.13 Pipes, connectors, shut-off valves (2,10 and 12)**

Pipes, connectors and shut-off valves shall be according to ISO 8573-2.

**7.2.3 Test procedure**

The procedures for preparation for measuring the high-efficiency filter (4) stabilization and the liquid water measurement shall be carried out in accordance with ISO 8573-2.

In order to obtain good test uncertainty, the air sampling shall be carried on until the appearance in the collecting vessels (13) of not less than 100 ml of total liquid water as a sum of both vessels.

**7.2.4 Determination of test results**

It is necessary to ensure that result are stable, repeatable and presented in a form which shows that they are so.

When the volume of liquid water is measured, the liquid water content in the compressed air flow,  $c_w$ , in  $\text{g}/\text{m}^3$ , is calculated using the following formula:

$$c_w = \frac{V\rho}{qt} \times \frac{1}{60} = 0,016\ 67 \frac{V\rho}{qt} \quad (1)$$

where

$V$  is the volume of liquid water collected, in millilitres;

$\rho$  is the specific density of water, in kilograms per cubic metre;

$q$  is the sampling air flow rate, in litres per second (ANR);

$t$  is the duration of the test, in minutes.

When the mass of liquid water is measured, the formula becomes:

$$c_w = \frac{m}{qt} \times \frac{1000}{60} = 16,667 \frac{m}{qt} \quad (2)$$

where

$m$  is the mass of water, in grams.

### 7.3 Determination of liquid water content by vapourization method

#### 7.3.1 General

The vapourization method consists of the following consecutive operations:

- a) determination of the water vapour quantity in the compressed air sample under actual conditions (for the full saturation state);
- b) changing the compressed air sample parameters to transform the liquid water to vapour;
- c) determination of the water vapour quantity in the compressed air sample after changing its parameters;
- d) determination of the difference between water vapour content values in the compressed air sample in actual conditions and after the transformation of liquid water to vapour.


The vapourization method may be used in conjunction with either the full or partial flow sampling method.

#### 7.3.2 Test equipment

##### 7.3.2.1 General description

The general arrangement of the test equipment for vapourization shall be in accordance with Figure 2.

NOTE The numbers between parentheses in the subclause titles refer to the numbering of the elements in Figure 2.



#### Key

1	sampling point	8	pressure sensor
2	shut-off valve	9	temperature sensor
3	pressure sensor	10	humidity sensor
4	temperature sensor	11	flowmeter or flow indicator
5	humidity sensor	12	flow control valve
6	heater	13	discharge outlet
7	pressure regulator valve		

**Figure 2 — Set-up for vapourization method**

#### 7.3.2.2 Pressure sensor (3 and 8)

These instruments are required for the measurement of the compressed air pressure under actual conditions and after the vapourization of the liquid water during the entire test period. The accuracy of measurement of the pressure shall be better than  $\pm 2\%$  of reading.

#### 7.3.2.3 Temperature sensor (4 and 9)

These instruments are required for the measurement of the compressed air temperature under actual conditions and after the vapourization of the liquid water during the entire test period. The accuracy of measurement of the temperature shall be better than  $\pm 1\text{ }^{\circ}\text{C}$  of reading.

#### 7.3.2.4 Humidity sensor (5 and 10)

These instruments are required for the measurement of the compressed air humidity under actual conditions and after the vapourization of the liquid water during the entire test period. The accuracy of measurement of the humidity shall be better than  $\pm 5\%$  RH.

#### 7.3.2.5 Heater (6)

The heater shall be powerful enough to transform all liquid water to vapour.

#### 7.3.2.6 Pressure regulator valve (7)

The pressure regulator valve shall reduce the compressed air pressure to intensify the liquid water vapourization.

In order to obtain good test uncertainty, the heater (6) and the flow control valve (12) shall guarantee the downstream level of compressed air relative humidity at not more than 80 %.

#### 7.3.2.7 Flowmeter or flow indicator (11)

In order to determine the availability of the air sample flow, a flowmeter or flow indicator shall be used.

#### 7.3.2.8 Pipes, connectors, shut-off valve (2) and flow control valve (12)

Pipes, connectors and shut-off valve and flow control valve shall be according to ISO 8573-2.

### 7.3.3 Calculation of test results

The value of the liquid water content,  $c_w$  in  $\text{g/m}^3$ , is determined using the formula:

$$c_w = d_2 - d_1 \quad (3)$$

where

$d_1$  is the water vapour content in the air sample under actual conditions, in grams per cubic metre;

$d_2$  is the water vapour content in the air sample after the transformation of liquid water to vapour, in grams per cubic metre.

The measurement of the water vapour content  $d_1$  and  $d_2$  shall be made in accordance with ISO 8573-3.

Taking into consideration the fact that the compressed air sample is fully saturated under actual conditions (i.e. relative humidity is 100 %), water vapour content  $d_1$  can also be determined using the table of limited content of water vapour in air or the "i-d" diagram of wet air state.

## 8 Evaluation of test results

### 8.1 Reference conditions

The measured liquid water content shall be recalculated to refer to the dry air volume as given by the partial pressure of the air at the sampling point.

Reference conditions for liquid water content volume statements are as follows.

- Air temperature: 20 °C;
- Air pressure: 1 bar(a);
- Relative water vapour pressure: 0 %.



## 8.2 Average value

Depending on the reproducibility of the method, the measurement facility and the experience of the parties involved in the provision of the measurement facility, the average of consecutive measurements at the sample point shall be used.

## 9 Uncertainty

The uncertainty of the method depends on the equipment used and accuracy of the result calculation. The total uncertainty of the authorized results of the test shall be  $\pm 10\%$ .

NOTE The uncertainty of the vapourization method for liquid water content measurement depends on the hygrometer used and the accuracy of calculation.

## 10 Test report

### 10.1 Statements

Statements of the liquid water content in the compressed air shall be made such that the values can be verified according to the procedures given in this part of ISO 8573.

The influence of any factors — e.g. oil contaminants or sample pipe — present in the sample that may affect the result of liquid water measurement shall be recorded.

### 10.2 Statement format

The report used to declare liquid water content according to this part of ISO 8573 shall contain the following.

- a) A description of the compressed air system and its working conditions, with sufficient detail for determining the validity of the declared concentration value:
  - 1) volume flow rate;
  - 2) sampling time;
  - 3) pressure;
  - 4) temperature;
  - 5) other contaminants.
- b) A description of the sampling point where the samples were taken.
- c) A description of the sampling and measurement system used, in particular, the materials and equipment used, and details of its calibration record.
- d) The phrase “Declared liquid water content in accordance with ISO 8573-9”, followed by:
  - 1) the figure for the actual, average measured value evaluated in accordance with Clause 8, and calculated to refer to the *reference* conditions;
  - 2) the figure for the actual, average measured value evaluated in accordance with Clause 8 above, referring to the *actual* conditions;
  - 3) the liquid water content, expressed in grams per cubic metre at actual and reference conditions;

- 4) the pressure and temperature (humidity) to which the measurement refers;
  - 5) the figure followed by a statement regarding the applicable uncertainty; and
  - 6) the date of the calibration record.
- e) The date of the sampling and measurements.

A sample test report is presented in Annex A.

## Annex A (informative)

### Sample test report

#### Liquid water content in compressed air

General description of compressed air system, test condition, sample point: \_\_\_\_\_

\_\_\_\_\_

Test method applied: \_\_\_\_\_

Sampling method applied: \_\_\_\_\_

List of test equipment used and respective calibration dates: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

#### Test results of liquid water content in accordance with ISO 8573-9

Test No.	Test date and time	Compressed air parameters			Total water volume collected ml	Liquid water concentration g/m <sup>3</sup>	
		Temperature °C	Pressure bar	Total sample volume m <sup>3</sup>		Actual condition	Reference condition
1							
2							
3							
...							
...							
...							
...							
Average value:							
Reported by:				Date:			
Authorized by:				Date:			
If the measurement is outside a particular range then identify as being "not measured".							

---

---

# BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

## Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.  
Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

## Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.  
Fax: +44 (0)20 8996 7001. Email: [orders@bsi-global.com](mailto:orders@bsi-global.com). Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

## Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.  
Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: [info@bsi-global.com](mailto:info@bsi-global.com).

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.  
Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.  
Email: [membership@bsi-global.com](mailto:membership@bsi-global.com).

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

## Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager.  
Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553.  
Email: [copyright@bsi-global.com](mailto:copyright@bsi-global.com).