

BS ISO 13374-4:2015



BSI Standards Publication

# Condition monitoring and diagnostics of machine systems — Data processing, communication and presentation

Part 4: Presentation

**bsi.**

...making excellence a habit.™

**National foreword**

This British Standard is the UK implementation of ISO 13374-4:2015.

The UK participation in its preparation was entrusted to Technical Committee GME/21/7, Mechanical vibration, shock and condition monitoring - Condition monitoring.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.

Published by BSI Standards Limited 2015

ISBN 978 0 580 86175 8

ICS 17.160; 35.240.99

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 December 2015.

**Amendments/corrigenda issued since publication**

Date	Text affected
------	---------------

---

INTERNATIONAL  
STANDARD

**ISO**  
**13374-4**

First edition  
2015-12-01

---

---

**Condition monitoring and diagnostics  
of machine systems — Data  
processing, communication and  
presentation —**

Part 4:  
**Presentation**

*Surveillance et diagnostic d'état des machines — Traitement, échange  
et présentation des données —*

*Partie 4: Présentation*



Reference number  
ISO 13374-4:2015(E)

© ISO 2015



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
copyright@iso.org  
www.iso.org

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Open CM&amp;D information architecture presentation requirements</b> .....	<b>1</b>
4.1 Overview .....	1
4.2 Basic requirements .....	2
4.3 Authentication and authorization requirements .....	2
4.4 Internationalization and localization requirements .....	2
4.5 User tracking requirements.....	2
4.6 User configuration requirements .....	2
<b>5 Open CM&amp;D processing architecture presentation requirements</b> .....	<b>3</b>
5.1 Overview .....	3
5.2 Technical display (TD) module requirements .....	4
5.3 Information presentation (IP) module requirements.....	4
<b>Bibliography</b> .....	<b>5</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 5, *Condition monitoring and diagnostics of machine systems*.

ISO 13374 consists of the following parts, under the general title *Condition monitoring and diagnostics of machine systems — Data processing, communication and presentation*:

- *Part 1: General guidelines*
- *Part 2: Data processing*
- *Part 3: Communication*
- *Part 4: Presentation*

## Introduction

The various computer software systems written for condition monitoring and diagnostics (CM&D) of machines that are currently in use cannot easily exchange data or operate in a plug-and-play fashion without an extensive communication infrastructure. The lack of an all-purpose communication system makes it difficult to integrate various CM&D sub-systems and provide a unified view of the condition of machinery to users. The intent of ISO 13374 is to provide the basic requirements for open CM&D software architecture in order to allow CM&D information to be processed, communicated, and displayed by various software packages independent of platform-specific or hardware-specific protocols.

ISO 13374-1 gives a general overview of data processing, communication, and presentation. ISO 13374-2 provides greater details into data processing methodology and requirements that should be present in today's software-enhanced systems. ISO 13374-3 provides the requirements of the data communication architecture for open CM&D systems. This part of ISO 13374 provides the requirements for the presentation of CM&D information for diagnostic analysis and decision support.





# Condition monitoring and diagnostics of machine systems — Data processing, communication and presentation —

## Part 4: Presentation

### 1 Scope

This part of ISO 13374 details the requirements for presentation of information for technical analysis and decision support in an open architecture for condition monitoring and diagnostics. Software design professionals need to present diagnostic/prognostic data, health information, advisories, and recommendations on computer displays and in written report formats to end-users. This part of ISO 13374 provides standards for the display of this information in CM&D systems.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 13372, *Condition monitoring and diagnostics of machines — Vocabulary*

ISO 13374-1, *Condition monitoring and diagnostics of machines — Data processing, communication and presentation — Part 1: General guidelines*

ISO 13374-2, *Condition monitoring and diagnostics of machines — Data processing, communication and presentation — Part 2: Data processing*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13372 apply.

## 4 Open CM&D information architecture presentation requirements

### 4.1 Overview

An information architecture describes all the data objects and their properties (or attributes), data types, data object relationships, reference data, and data documents for a given system or application. As specified in ISO 13374-2, an open CM&D information architecture describes the content for each of the five layers shown in [Figure 1](#).




Figure 1 — CM&D information architecture layers (from ISO 13374-2:2007)

## 4.2 Basic requirements

To support the continuous improvement of end-user interfaces, including graphical user interfaces (GUIs), displays, and reports, an open CM&D information architecture shall separate presentation and display functionality from the information content and logic. Presentation interface functionality is often described using templates which specify the method of formatting end-user displays and reports and allow customization. The presentation interfaces in an open CM&D information architecture shall communicate with a layer 5 data document definition and comply with a defined layer 4 reference data library. Implementations will vary according to application requirements.

## 4.3 Authentication and authorization requirements

In computing, authentication is the mechanism by which a software system may securely identify who is using the system. Authorization, by contrast, is the mechanism by which a system determines what level of access and functionality a particular authenticated user should have to secure resources controlled by the system. An open CM&D information architecture shall support user authentication and should support user authorization. The architecture shall also specify the supported methods utilized for authentication and authorization, if authorization is supported.

## 4.4 Internationalization and localization requirements

In computing, internationalization and localization are the mechanisms by which a software system can readily adapt to different languages, time zones, regional differences, and technical requirements of an end-user population. Internationalization is the process of designing a software application so that it can be adapted to various languages and regions without engineering changes. Localization is the process of adapting internationalized software for a specific region or language by adding locale-specific components and translating text. An open CM&D information architecture shall specify the supported methods for end-user internationalization and localization.

## 4.5 User tracking requirements

The tracking of user interactions with a software system is often necessary to meet regulatory requirements. An open CM&D information architecture should specify the supported user tracking methodology and the methods of reporting on this information.


## 4.6 User configuration requirements

Software systems often permit users to configure a system to meet their specific needs. This configuration information should then be captured and utilized during each subsequent user session. An open CM&D information architecture should specify the supported user configuration options.

## 5 Open CM&D processing architecture presentation requirements

### 5.1 Overview

A processing architecture describes the interactions or transactions between modules internal to the software system itself, external from end-user interactions, or external from other software system interactions. As specified in ISO 13374-1, an open CM&D processing architecture specification shall utilize the processing architecture shown in [Figure 2](#).



**Figure 2 — Data processing block diagram (from ISO 13374-1:2003)**

This architecture is defined as blocks of data processing functionality. After each block in the system has been properly configured, the basic data are converted into digital form in data acquisition (DA) and are processed in various ways as they are transformed into actionable information, resulting in advisory generation (AG). As the processing progresses from DA to AG, data from preceding blocks need to be transferred to subsequent blocks and additional information acquired from or sent to external systems. Similarly, as the data evolve into information, both standard technical displays and graphical presentation formats are required. This part of ISO 13374 defines the technical displays (TD)

and information presentation (IP) requirements for any open CM&D processing architecture. With such an approach, the data processing blocks from various suppliers can be integrated into a complete, functional system.

Systems often start with data acquisition in embedded environments with real time constraints. Information is then processed and refined in subsequent system blocks and made available for health assessment, prognostics, and advisory generation. These requirements currently lead to disparate technology choices. The presentation software displaying outputs from the “information-oriented” presentation blocks (HA, PA, and AG) are often different than those used in the “data-oriented” presentation blocks (DA, DM, and SD).

## 5.2 Technical display (TD) module requirements

The TD modules in an open CM&D processing architecture provide the diagnostic displays and reports required for an end-user to analyse the data coming from the monitoring technologies the system is required to support. Each TD module shall document and optionally display their refresh method(s), normal refresh rates, and time of last update. Modules should also include rate of change information, e.g. graphically through the use of trend plotting.

## 5.3 Information presentation (IP) module requirements

The IP modules in an open CM&D processing architecture provide an end-user with intelligent, actionable information about the current and future health of a machine with recommended advisories for subsequent actions. Both human and automated agents may be utilized and each agent’s output may differ from analysing equivalent inputs. To provide unambiguous context, each IP module shall have a mechanism to identify the source intelligent agent “analyst”, the source condition monitoring technologies utilized for the analysis, and the time of analysis. Each IP module shall document and optionally display their refresh method(s), normal refresh rates, and time of last update.

In presentations of the overall health status of a machine to a non-technical audience, an open CM&D processing architecture should utilize the following standard terminology:

**Undetermined** – Condition indicators have not been reviewed.

**Good** – All condition indicators monitored are within normal limits.

**Fair** – Certain condition indicators are abnormal and warrant continued monitoring, but do not appear to significantly increase the likelihood of operational failure.

**Serious but stable** – Certain condition indicators are abnormal with an increased likelihood of operational failure. These abnormal indicators, however, are currently stable.

**Serious** – Certain condition indicators are abnormal and worsening with an increased likelihood of operational failure.

**Critical but stable** – Certain condition indicators are abnormal with a significantly increased likelihood of operational failure. These abnormal indicators, however, are currently stable.

**Critical** – Certain condition indicators are abnormal and worsening with a significantly increased likelihood of operational failure.

## Bibliography

- [1] ISO 8601, *Data elements and interchange formats — Information interchange — Representation of dates and times*
- [2] ISO/IEC 19501, *Information technology — Open Distributed Processing — Unified Modeling Language (UML) Version 1.4.2*





# British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

## About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

## Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at [bsigroup.com/standards](http://bsigroup.com/standards) or contacting our Customer Services team or Knowledge Centre.

## Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at [bsigroup.com/shop](http://bsigroup.com/shop), where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

## Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to [bsigroup.com/subscriptions](http://bsigroup.com/subscriptions).

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

**PLUS** is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit [bsigroup.com/shop](http://bsigroup.com/shop).

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email [bsmusales@bsigroup.com](mailto:bsmusales@bsigroup.com).

## BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

## Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

## Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

## Useful Contacts:

### Customer Services

**Tel:** +44 845 086 9001

**Email (orders):** [orders@bsigroup.com](mailto:orders@bsigroup.com)

**Email (enquiries):** [cservices@bsigroup.com](mailto:cservices@bsigroup.com)

### Subscriptions

**Tel:** +44 845 086 9001

**Email:** [subscriptions@bsigroup.com](mailto:subscriptions@bsigroup.com)

### Knowledge Centre

**Tel:** +44 20 8996 7004

**Email:** [knowledgecentre@bsigroup.com](mailto:knowledgecentre@bsigroup.com)

### Copyright & Licensing

**Tel:** +44 20 8996 7070

**Email:** [copyright@bsigroup.com](mailto:copyright@bsigroup.com)



...making excellence a habit.™