

BS ISO 16358-3:2013



BSI Standards Publication

**Air-cooled air conditioners and  
air-to-air heat pumps — Testing  
and calculating methods for  
seasonal performance factors**  
Part 3: Annual performance factor

**bsi.**

...making excellence a habit.™

**National foreword**

This British Standard is the UK implementation of ISO 16358-3:2013.

The UK participation in its preparation was entrusted to Technical Committee RHE/17, Testing of air conditioning units.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013. Published by BSI Standards Limited 2013

ISBN 978 0 580 72754 2

ICS 23.120; 27.080

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 April 2013.

**Amendments issued since publication**

Date	Text affected
------	---------------

---

---

---

**Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —**

Part 3:  
**Annual performance factor**

*Climatiseurs à condenseur à air et pompes à chaleur air/air — Essais et méthodes de calcul des coefficients de performance saisonniers —  
Partie 3: Coefficient de performance annuel (COPA)*





**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

	Page
Foreword .....	iv
<b>1 Scope .....</b>	<b>1</b>
<b>2 Normative references .....</b>	<b>1</b>
<b>3 Terms and definitions .....</b>	<b>1</b>
<b>4 Symbols .....</b>	<b>3</b>
<b>5 Calculation of annual performance factor (APF) and total annual performance factor (TAPF) .....</b>	<b>3</b>
<b>6 Test report .....</b>	<b>3</b>
<b>Annex A (informative) Calculation of total annual performance factor (TAPF) .....</b>	<b>4</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. [www.iso.org/directives](http://www.iso.org/directives)

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. [www.iso.org/patents](http://www.iso.org/patents)

Any trade name used in this document is information given for the convenience of users of this document and does not constitute an endorsement. Equivalent products can be used if they can be shown to lead to the same results.

The committee responsible for this document is ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 6, *Testing and rating of air-conditioners and heat pumps*.

The parts of ISO 16358 are given below:

- *Part 1: Cooling seasonal performance factor*
- *Part 2: Heating seasonal performance factor*
- *Part 3: Annual performance factor*

# Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —

## Part 3: Annual performance factor

### 1 Scope

**1.1** This part of ISO 16358 specifies the testing and calculating methods for seasonal performance factor of equipment covered by ISO 5151, ISO 13253 and ISO 15042.

**1.2** This part of ISO 16358 also specifies the seasonal performance test conditions and the corresponding test procedures for determining the seasonal performance factor of equipment, as specified in [1.1](#), under mandatory test conditions and is intended for use only in marking, comparison, and certification purposes.

**1.3** This part of ISO 16358 does not apply to the testing and rating of:

- a) water-source heat pumps or water-cooled air conditioners;
- b) portable units having a condenser exhaust duct;
- c) individual assemblies not constituting a complete refrigeration system; or
- d) equipment using the absorption refrigeration cycle.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5151, *Non-ducted air conditioners and heat pumps — Testing and rating for performance*

ISO 13253, *Ducted air-conditioners and air-to-air heat pumps — Testing and rating for performance*

ISO 15042, *Multiple split-system air-conditioners and air-to-air heat pumps — Testing and rating for performance*

ISO 16358-1, *Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors — Part 1: Cooling seasonal performance factor*

ISO 16358-2, *Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors — Part 2: Heating seasonal performance factor*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5151, ISO 13253, ISO 15042 and the following apply.

**3.1**  
**cooling seasonal total load**  
**CSTL**

total annual amount of heat that is removed from the indoor air when the equipment is operated for cooling in active mode

**3.2**  
**cooling seasonal energy consumption**  
**CSEC**

total annual amount of energy consumed by the equipment when it is operated for cooling in active mode

**3.3**  
**cooling seasonal performance factor**  
**CSPF**

ratio of the total annual amount of heat that the equipment can remove from the indoor air when operated for cooling in active mode to the total annual amount of energy consumed by the equipment during the same period

**3.4**  
**heating seasonal total load**  
**HSTL**

total annual amount of heat, including make-up heat, which is added to the indoor air when the equipment is operated for heating in active mode

**3.5**  
**heating seasonal energy consumption**  
**HSEC**

total annual amount of energy consumed by the equipment, including make-up heat, when it is operated for heating in active mode

**3.6**  
**annual performance factor**  
**APF**

ratio of the total annual amount of heat that the equipment can remove from and add to the indoor air when operated for cooling and heating, respectively, in active mode to the total annual amount of energy consumed by the equipment during the same period

**3.7**  
**total annual performance factor**  
**TAPF**

ratio of the total annual amount of heat that the equipment can remove from and add to the indoor air to the total annual amount of energy consumed by the equipment, including the active, inactive and disconnected modes

**3.8**  
**active mode**

mode corresponding to the hours with cooling and heating demand of the building and whereby the cooling or heating function of the unit is switched on

**3.9**  
**inactive mode**

mode corresponding to the hours when the unit is not operating to meet cooling or heating demand

Note 1 to entry: This mode may include the operation of a crankcase heater.

**3.10**  
**disconnected mode**

mode corresponding to the hours when the unit is electrically disconnected from the main power supply

Note 1 to entry: Power consumption is zero.



## 4 Symbols

Symbol	Description	Unit
$C_{CSE}$	cooling seasonal energy consumption (CSEC)	Wh
$C_{HSE}$	heating seasonal energy consumption (HSEC)	Wh
$F_{AP}$	annual performance factor (APF)	—
$F_{CSP}$	cooling seasonal performance factor (CSPF)	—
$F_{TAP}$	total annual performance factor (TAPF)	—
$L_{CST}$	cooling seasonal total load (CSTL)	Wh
$L_{HST}$	heating seasonal total load (HSTL)	Wh

## 5 Calculation of annual performance factor (APF) and total annual performance factor (TAPF)

Annual performance factor (APF),  $F_{AP}$ , shall be calculated by Formula (1).

$$F_{AP} = \frac{L_{CST} + L_{HST}}{C_{CSE} + C_{HSE}} \quad (1)$$

Calculation of  $L_{CST}$  and  $C_{CSE}$  is according to ISO 16358-1, and calculation of  $L_{HST}$  and  $C_{HSE}$  is according to ISO 16358-2.

For the cooling-only equipment, the annual performance factor (APF) shall be equal to the cooling seasonal performance factor (CSPF).

In case of calculating the total annual performance factor (TAPF), refer to [Annex A](#).

## 6 Test report

The test report for this part of ISO 16358 shall include the calculation of APF (and TAPF if applicable) and test reports from ISO 16358-1 for cooling and ISO 16358-2 for heating.

## Annex A (informative)

### Calculation of total annual performance factor (TAPF)

#### A.1 General

This annex applies only to the reverse cycle units.

#### A.2 Measurement of the electric power consumption during the inactive mode

The unit shall be electrically connected to the main power source after shut-down for 6 h. Indoor and outdoor temperature of 20 °C condition shall be reached. The power consumption shall be measured for one hour after the temperature conditions are stabilized. The same test is repeated with the temperature condition of 5 °C, 10 °C and then 15 °C with the stabilization period of 2 h between each test. As a reference case, each power consumption value shall be weighted by weighting factors in [Table A.1](#) and then integrated to obtain a weighted average inactive power consumption,  $P_{ia}$ . The calculation of inactive power may also be undertaken for other climate conditions and operating schedules.

NOTE If the results of the tests at 20 °C and 5 °C are within 5 % or 1 W, then the tests at 15 °C and 10 °C are not mandatory. The average value of these results is used for the four considered temperature conditions.

**Table A.1 — Default weighting factors for determination of reference inactive energy consumption**

Temperature condition	5 °C	10 °C	15 °C	20 °C
Weighting factor	0,05	0,13	0,27	0,55

Inactive energy consumption (IAEC) shall be calculated by Formula (A.1).

$$C_{IAE} = H_{ia} \times P_{ia} \quad (A.1)$$

where

$C_{IAE}$  is the inactive energy consumption;

$H_{ia}$  is the number of hours of inactive mode as given in [Table A.2](#);

$P_{ia}$  is the weighted average power consumption.

#### A.3 Calculation of total annual performance factor (TAPF)

Total annual performance factor (TAPF),  $F_{TAP}$ , shall be calculated by Formula (A.2).

$$F_{TAP} = (L_{CST} + L_{HST}) / (C_{CSE} + C_{HSE} + C_{IAE}) \quad (A.2)$$

Calculation of  $L_{CST}$  and  $C_{CSE}$  is according to ISO 16358-1, and calculation of  $L_{HST}$  and  $C_{HSE}$  is according to ISO 16358-2.

Inactive energy consumption (IAEC),  $C_{IAE}$ , shall be calculated by Formula (A.1).

The default mode hours for the calculation of reference total annual performance factor are shown in [Table A.2](#). The calculation of total annual performance factor may also be undertaken for other distributions of mode hours.

**Table A.2 — Default hours by mode for the calculation of reference total annual performance factor**

	<b>Active mode</b> h	<b>Inactive mode, <math>H_{ia}</math></b> h	<b>Disconnected mode</b> h
Cooling season	1 817	—	—
Heating season	2 866	—	—
Annual total hours	4 683	4 077	0





# British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

## About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

## Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at [bsigroup.com/standards](http://bsigroup.com/standards) or contacting our Customer Services team or Knowledge Centre.

## Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at [bsigroup.com/shop](http://bsigroup.com/shop), where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

## Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to [bsigroup.com/subscriptions](http://bsigroup.com/subscriptions).

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

**PLUS** is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit [bsigroup.com/shop](http://bsigroup.com/shop).

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email [bsmusales@bsigroup.com](mailto:bsmusales@bsigroup.com).

## BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

## Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

## Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

## Useful Contacts:

### Customer Services

**Tel:** +44 845 086 9001

**Email (orders):** [orders@bsigroup.com](mailto:orders@bsigroup.com)

**Email (enquiries):** [cservices@bsigroup.com](mailto:cservices@bsigroup.com)

### Subscriptions

**Tel:** +44 845 086 9001

**Email:** [subscriptions@bsigroup.com](mailto:subscriptions@bsigroup.com)

### Knowledge Centre

**Tel:** +44 20 8996 7004

**Email:** [knowledgecentre@bsigroup.com](mailto:knowledgecentre@bsigroup.com)

### Copyright & Licensing

**Tel:** +44 20 8996 7070

**Email:** [copyright@bsigroup.com](mailto:copyright@bsigroup.com)



...making excellence a habit.™