

BS ISO 19892:2011



BSI Standards Publication

Plastics piping systems — Thermoplastics pipes and fittings for hot and cold water — Test method for the resistance of joints to pressure cycling

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of ISO 19892:2011.

The UK participation in its preparation was entrusted to Technical Committee PRI/88/4, Test Methods - Plastic Piping.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 64382 8

ICS 23.040.60; 83.080.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2011.

Amendments issued since publication

Date	Text affected
------	---------------

**Plastics piping systems —
Thermoplastics pipes and fittings for hot
and cold water — Test method for the
resistance of joints to pressure cycling**

*Systèmes de canalisations en plastiques — Tubes en matières
thermoplastiques et raccords pour l'eau chaude et froide — Méthode
d'essai de la résistance des assemblages aux cycles de pression*





COPYRIGHT PROTECTED DOCUMENT

© ISO 2011

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 19892 was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 5, *General properties of pipes, fittings and valves of plastic materials and their accessories — Test methods and basic specifications*.

Plastics piping systems — Thermoplastics pipes and fittings for hot and cold water — Test method for the resistance of joints to pressure cycling

1 Scope

This International Standard specifies a method for testing the resistance of joints to pressure cycling. It is applicable to piping systems based on thermoplastics pipes intended to be used in hot and cold water applications.

2 Principle

An assembly of pipes and fittings is subjected to water pressure cycling between two positive pressure limits, while being maintained at a specified temperature and inspected for leakage.

NOTE It is assumed that the following test parameters are set by the reference standard (i.e. the standard making reference to this International Standard), as applicable (see Clause 4):

- a) the test temperature;
- b) the number of test pieces;
- c) the test pressure limits;
- d) the duration of one cycle;
- e) the number of cycles.

3 Apparatus

3.1 Pressurizing device, capable of applying and regulating the water pressure in the test piece in a sinusoidal or trapezoidal form between pressure limits as specified in the reference standard.


3.2 Pressure measurement device, capable of measuring the water pressure in the test piece to an accuracy of $\pm 5\%$. The device measurement shall be capable of producing a record of the sinusoidal or trapezoidal wave form.

3.3 Test chamber, capable of maintaining the specified test temperature (see Clause 4) to an accuracy of $\pm 2\text{ }^{\circ}\text{C}$.

3.4 Thermometer(s), capable of checking conformity to the specified test temperature (see 3.3).

3.5 End-sealing device, of appropriate size and sealing method for sealing the non-joined end of the test piece. The device shall be restrained in a manner which does not exert longitudinal forces on the joints.

A typical test arrangement is shown in Figure 1.



Key

- 1 temperature controlled test chamber
- 2 test assemblies
- 3 water
- 4 air
- 5 pressure converter
- 6 compressed air cylinder
- 7 valve
- 8 electric control

Figure 1 — Schematic test arrangement

4 Test parameters

Unless specified otherwise in the reference standard, the test parameters given in Table 1 shall apply.

Table 1 — Test parameters

Parameter	Value
Number of test pieces	3
Conditioning and test temperature	$(23 \pm 2) \text{ }^\circ\text{C}$
Test pressure limits	Shall conform to Table 3
Cycle frequency	(30 ± 5) cycles per minute
Number of cycles	10 000

5 Test pieces

5.1 Number

The number of test pieces shall conform to Clause 4.

5.2 Preparation

The test piece shall comprise an assembly of pipes and at least one fitting joined in accordance with the manufacturer's recommended practice.

The free length on each side of the fitting under test shall be not less than either $1,5d_n$ or 300 mm, whichever is the greater, where d_n is the nominal outside diameter of the pipe.

In order to include the required number of pipes and fitting(s), several test pieces may be tested simultaneously, provided the failure of one test piece does not affect the others under test.

6 Conditioning

6.1 Fill each test piece with water so that all the air is expelled.

6.2 Bring the test piece and water therein to the specified temperature (see Clause 4).

6.3 Condition the test piece at the applicable temperature (see Clause 4) in accordance with Table 2 before or after connecting the test piece(s) to the pressurizing device. If subsequent connection is necessary, ensure that all air is again expelled and that the conditioning has been completed immediately before connection to the pressurizing device.

Table 2 — Conditioning periods

Pipe wall thickness e mm	Minimum conditioning period h
$e < 3$	1
$3 \leq e < 8$	3
$8 \leq e < 16$	6
$16 \leq e < 32$	10

7 Procedure

7.1 Unless specified otherwise in the reference standard, subject the test piece to the applicable pressure limits conforming to Table 3 and for the number of cycles and cycle frequency conforming to Clause 4, while, for the duration of the test and on completion

- a) maintaining the test temperature,
- b) monitoring the test piece for any signs of leaks, and
- c) checking wave form at the start, at regular intervals and at the end of the test and recording them.

Table 3 — Test pressure limits

Design pressure <i>p</i> _D bar	Test pressure limits	
	Upper limit bar	Lower limit bar
4	6	0,5
6	9	0,5
8	12	0,5
10	15	0,5

NOTE 1 bar = 0,1 MPa = 10⁵ Pa; 1 MPa = 1 N/mm².

7.2 If leakage occurs prior to completion of the number of cycles, record the number of elapsed cycles and the position and nature of the leak.

7.3 On completion of the number of cycles, inspect all joints for any sign of leakage.

8 Test report

The test report shall include the following information:

- a) a reference to this International Standard, i.e. ISO 19892:2011, and to the reference standard;
- b) the material and other identification and the number of the components under test, including their operating pressure;
- c) the test temperature;
- d) the test pressures comprising the lowest and the highest of the cycle;
- e) the cycle frequency;
- f) the number of cycles;
- g) a record of the wave form at the start, at regular intervals and at the end of each test;
- h) the signs of leakage, if any, and where and when they occurred;
- i) any factors which can have affected the results, such as any incident or any operating detail not specified in this International Standard;
- j) the date of test.

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™