

Condition monitoring and diagnostics of machines — Acoustic emission

ICS 17.140.20; 17.160

National foreword

This British Standard is the UK implementation of ISO 22096:2007.

The UK participation in its preparation was entrusted by Technical Committee GME/21, Mechanical vibration, shock and condition monitoring, to Subcommittee GME/21/7, Condition monitoring.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 October 2007

© BSI 2007

ISBN 978 0 580 56839 8

Amendments issued since publication

Amd. No.	Date	Comments

INTERNATIONAL
STANDARD

ISO
22096

First edition
2007-07-15

**Condition monitoring and diagnostics of
machines — Acoustic emission**

Surveillance et diagnostic d'état des machines — Émission acoustique



Reference number
ISO 22096:2007(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 22096 was prepared by Technical Committee ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 5, *Condition monitoring and diagnostics of machines*.

Introduction

Acoustic emission (AE) technology can be used as a stand-alone condition monitoring technique that may also be employed to complement other condition monitoring techniques based on other technologies (e.g. vibration, infrared, etc.) used for machine condition analysis and diagnosis/prognosis. Due to the nature of AE, an understanding of the operating mechanics of the monitored machine is not essential, but such an understanding allows the maximum amount of data to be extracted from the results of the AE phenomena. As a diagnostic tool for machine condition monitoring, AE can be employed as a permanently installed, semi-permanent or portable system, depending on the criticality of the machine. Typically, an AE system would contain transducers, amplifiers, filters and data acquisition systems. Depending on the particular application, a range of AE characteristics can be extracted from the captured AE to provide indicators for machine condition monitoring.

Condition monitoring and diagnostics of machines — Acoustic emission

1 Scope

This International Standard specifies the general principles required for the application of acoustic emission (AE) to condition monitoring and diagnostics of machinery operating under a range of conditions and environments. It is applicable to all machinery and associated components and covers structure-borne measurements only.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2041, *Vibration and shock — Vocabulary*

ISO 12718, *Non-destructive testing — Eddy current testing — Vocabulary*

ISO 13372, *Condition monitoring and diagnostics of machines — Vocabulary*

ISO 18436-6, *Condition monitoring and diagnostics of machines — Requirements for training and certification of personnel — Part 6: Acoustic emission*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 2041, ISO 12718, ISO 13372 and the following apply.

3.1

acoustic emission

⟨machine monitoring⟩ range of phenomena that results in the generation of structure-borne and fluid-borne (liquid, gas) propagating waves due to the rapid release of energy from localized sources within and/or on the surface of a material

NOTE 1 Such a release may be a result of a process such as crack propagation, friction, impact, and leakage.

NOTE 2 The definition of acoustic emission in this document conveys its broad application in machine monitoring.

3.2

acoustic emission monitoring

⟨machine monitoring⟩ detection and collection of information and acoustic emission data that indicate the state of a machine

NOTE The definition of acoustic emission monitoring in this document relates to the application in machine monitoring.

3.3

acoustic emission sensor/receiver

device containing a transducing element that converts elastic wave motion into an electrical signal

3.4

acoustic emission signal

electrical signal from an acoustic emission sensor resulting from acoustic emission

3.5

acoustic emission characteristics

set of specific characteristics describing acoustic emission associated with a machine or an acoustic emission source

NOTE The signature can be of a burst type, i.e. emission events which can be separated in time; or a continuous type, i.e. emissions which cannot be separated in time.

3.6

acoustic emission waveguide

device which allows the transfer of elastic waves from the machine to an acoustic emission sensor

3.7

background noise

false signals produced by causes other than acoustic emission, or by acoustic emission sources that are not relevant to the machine component being monitored

NOTE This can include signals of electrical, thermal and mechanical origins.

3.8

couplant

coupling media between an AE sensor and the object from which measurement is to be acquired

EXAMPLES Oil, grease, adhesive bond, water-soluble paste, wax.

3.9

Hsu-Nielsen source

pencil lead break device to simulate an acoustic emission event using the fracture of a brittle graphite lead in a suitable fitting

NOTE Changes in signal can be due to variations in the lead. Typically, lead 2H of diameter 0,5 mm (alternatively 0,3 mm) and length $(3,0 \pm 0,5)$ mm is used.

3.10

machine

mechanical system designed expressly to perform a specific task, such as the forming of material or the transference and transformation of motion, force or energy

NOTE This is also sometimes referred to as equipment.

3.11

machine system

machine train (deprecated)

mechanical system in which the principal subsystem is a specific machine (3.10) and whose other subsystems are components and auxiliaries whose individual functions are integrated to support the actions and work of the machine

4 Principle of the acoustic emission technology

4.1 Acoustic emission (AE) phenomenon

Acoustic emission is a physical phenomenon occurring within and/or on the surface of materials. The term "acoustic emission" is used to describe the spontaneous elastic energy released by a process in the form of transient elastic waves. Acoustic emissions generated within a material manifest as elastic waves on the surface of the material and cover a broad frequency range. Typically, the frequency content of detected acoustic emission signals falls within the range of 20 kHz to 1 MHz.

The waves associated with AE are detected by the use of a suitable sensor that converts the surface displacement of the material into an electrical signal. These electrical signals are processed by appropriate instrumentation and/or data processing techniques to characterize the system condition and to aid in detection of the early stages of loss of mechanical and structural integrity. The signal waveform from the sensor is affected by multiple path propagation and several wave modes that are generated in and/or on the material. As such, the sensor response for identical input sources that propagate through varying transmissions paths will be different.

4.2 Advantages and limitations of acoustic emission

AE offers the following advantages:

- a) it is non-invasive;
- b) it provides real-time process information;
- c) due to its higher sensitivity, it may offer earlier fault detection than vibration analysis;
- d) it offers monitoring of dynamic performance;
- e) it may be applied to a wide range of rotational speeds with significant advantages at slow rotational speeds [of the order of less than 1 Hz (60 r/min)];
- f) it allows for detection of the friction/wear process, for instance, rubbing between loose mating components or deterioration in lubricating condition.

Limitations of AE include

- susceptibility to attenuation,
- susceptibility to high operational background noise, and
- the inability to relate the resultant defect AE characteristics to the exact fault mechanism.

5 Applications of the acoustic emission technique

5.1 Machinery monitored by acoustic emission

Acoustic emission technology may be applied to a wide range of machinery, provided a transmission path from the position of the sensor to the region of interest exists. This is particularly important for structure-borne AE monitoring; some examples are detailed in Table 1. The method does not rely on absolute quantities of measured AE parameters but on trends of AE parameters that are measured during a specified operational condition. For instance, an increasing trend in the detected AE signal level under steady operating conditions is indicative of machine deterioration; AE signal amplitude modulated at a bearing defect frequency is indicative of early stages of bearing element defect, which may not be detectable with vibration or shock pulse

monitoring. It should be noted that AE activity will vary for differing machines, operating conditions and machine loading.

Table 1 — Examples of applications of AE to machine condition monitoring

Machine type	Fault						
	Bearing deterioration	Mechanical seal rubbing	Wear	Lubricant contamination and loss of lubricant	Severe mis-alignment	Mounting faults	Process monitoring, including leakage, performance, etc.
Pump	•	•	•	•	•	•	•
Gear box	•		•	•	•	•	•
Electric motor	•			•	•	•	
Steam turbine	•	•		•	•	•	•
Industrial gas turbine	•	•		•	•	•	•
Electric generator	•			•	•	•	
Diesel engine			•				•
Machining processes	•		•	•			
Fan or blower	•			•	•		•
Slow-speed rotating machine (typically < 60 r/min)	•			•	•	•	•
Machine components, e.g. valves, heat exchangers			•	•		•	•
Compressors (air, gas, etc.)	•	•	•	•	•	•	•

5.2 Interference factors

Prior to performing an AE measurement, it is very important to be aware of potential noise sources, such as electronic noise (electromagnetic and radio frequency interference), airborne noise (such as gas leaks or the impact of sand particles on the machine in windy environments), operational background noise (flow of fluids in pipes) and mechanical background noise, whose presence might affect the AE measurement.

6 Data acquisition

6.1 Installing a system

A schematic diagram of a typical structure-borne AE data acquisition system is illustrated in Figure 1. Typically the sensor is coupled to the machine under observation. This in turn is usually connected to a pre-amplifier, which is connected to an acquisition system. Some AE sensors have built-in pre-amplifiers. The data shall be acquired while the machine is operational and the amount of data acquired and extent of analysis depends upon the particular application. The system can be permanent, semi-permanent or portable.




Figure 1 – Schematic diagram of an acquisition system

6.2 AE instrumentation and sensors

Detection is the most important part of an AE chain and every attempt should be undertaken to overcome poor installation and acoustical coupling. Furthermore, the effects of incorrect frequency selection for filters, sensors, acquisition rates, etc. should be considered. Instruments and sensors may be characterized and calibrated to EN 13477-1, EN 13477-2, ASTM E 1106-86 and ASTM E976-05. In addition, sensor parameters that shall be considered include size, sensitivity, frequency response and environment. In circumstances where appropriate, for instance large circular bearings, an array of transducers may be necessary for source location. Location could be achieved by a number of methods; AE wave arrival time is one such method.

6.3 Sensor installation and coupling media for structure-borne monitoring

For structure-borne monitoring, the purpose of the mounting arrangement is to ensure the sensor is fixed onto a structure with an adequate coupling media (couplant). Mounting methods will be either a mechanical arrangement (compression force applied with a magnet, mechanical clamp, etc.) or the use of an adhesive. In the latter instance, the adhesive also serves as the couplant.

The location of the AE sensor should ensure a transmission path to the machine component under observation. This path can include surface discontinuities (a discontinuity is defined as an interface, for instance, the interface between a bolt head and the clamped component). However, these surfaces should be in contact either directly or across a couplant (e.g. a transmission path across a plain journal bearing where the lubricating and cooling oil serves as the couplant for transmission). In addition, the surface onto which the sensor is placed shall be clean. The signal transmission path can be improved by removing any surface paint to expose the metal substrate; however removal of any coat should not degrade the machine integrity or performance. Every attempt shall be made to ensure that the face of the sensor is fixed flat onto the surface, avoiding surface curvature, contaminating particles or surface discontinuities. The primary purpose of this procedure is to improve transmission paths and to ensure repeatability.

Under certain conditions, the AE sensor may be installed on a waveguide. Usually the waveguide is constructed to ensure a more direct transmission path between the sensor and machine component under observation and/or to effect a reduction in the temperature experienced by the AE sensor. The waveguide can affect the acquired AE wave, for instance, attenuation, waveform shape, etc.

The couplant may be applied by placing a small amount in the centre of the intended position of the sensor, which is then carefully pressed onto the surface, spreading the couplant uniformly. The thickness of the couplant can alter the sensitivity of the sensor.

In conditions where the use of a couplant is impractical, a dry contact may be used. In this case, the necessary contact pressure shall be determined experimentally, for instance, with the Hsu-Nielsen source.

Attempts should be made to ensure air or voids are not present between the sensor front face and the surface of the machine.

When an adhesive couplant is used, ensure that the bond employed to fix the AE sensors to a structure does not break or peel off as a direct result of surface deformation, thermal expansion or mechanical loading. Also ensure that the characteristics of the adhesive with respect to the operating conditions and environment are known.

NOTE Bond cracking can be a source of acoustic emission.

It is important to isolate the sensor electrically to prevent background noise encroaching through the electrical ground.

7 Preliminary information

The preparation and execution of the examination, as well as interpretation of the results, necessitate prior knowledge of the following:

- identification name and number of the machine;
- detail of current operating conditions (load, speed, temperature, etc.);
- history of service and maintenance actions;
- mechanical design details;
- history of faults or failures;
- any previous AE data.

Interpretation of results will require reference to a relevant experimental database or operational condition of known mechanical integrity: a baseline. A baseline is data or sets of data as measured or observed when the equipment operation is known to be acceptable and stable. Subsequent measurements can be compared to these baseline values to detect changes. Baseline data should accurately define the initial stable condition of the machine, preferably operating in its normal operating state.

For machines with several operational states, it may be necessary to establish baselines for each of these states. For new and overhauled equipment, there may be a wear-in period. As a result, it is common to see a change in measured values during the first few days or weeks of operation. Therefore, time should be allotted for wear-in before acquiring baseline data. For equipment which has been operating for a significant period, and monitored for the first time, a baseline can still be established as a trending reference point.

8 Data analysis and presentation of results

The primary purpose of data analysis is to relate AE activity to the operating condition, measuring or monitoring any deviation from baseline conditions to assist in identifying the condition of the machine.

Examples of criteria adopted for AE evaluation of machinery condition are as follows:

- a) AE activity that consistently increases with increasing time;
- b) the magnitude of AE activity during periods of steady state operation;
- c) appearance of signal features not present when running the machine in good condition;

- d) instrument-specific methods based on proprietary signal characterization built into a manufacturer's instrument;
- e) the presence of signal amplitude modulations at defect repetition frequencies.

9 Establishing procedures

It should be emphasized that obtaining successful AE measurements is based on repetitive accurate monitoring within set parameters. This requires AE personnel to be competent at establishing, verifying and/or implementing documented procedures for the application of specific types of tests, with an understanding of their limitations. These competency requirements are specified in ISO 18436-6.

Bibliography

- [1] ISO 17359, *Condition monitoring and diagnostics of machines — General guidelines*
- [2] EN 13477-1, *Non-destructive testing — Acoustic emission — Equipment characterisation — Part 1: Equipment description*
- [3] EN 13477-2, *Non-destructive testing — Acoustic emission — Equipment characterisation — Part 2: Verification of operating characteristic*
- [4] EN 13554, *Non-destructive testing — Acoustic emission — General principles*
- [5] ASTM E976-05, *Standard Guide for Determining the Reproducibility of Acoustic Emission Sensor Response*
- [6] ASTM E1106-86, *Standard Method for Primary Calibration of Acoustic Emission Sensors*
- [7] DSTU 4227, *Guidelines on acoustic-emission diagnostics of critical objects*

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.
Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.
Fax: +44 (0)20 8996 7001. Email: orders@bsi-global.com. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.
Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: info@bsi-global.com.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.
Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.
Email: membership@bsi-global.com.

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager.
Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553.
Email: copyright@bsi-global.com.