

Structural use of steelwork in building —

Part 8: Code of practice for fire resistant design

ICS 13.220.50; 91.080.10

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by Technical Committee B/525, Building and civil engineering structures, to Subcommittee B/525/31, Structural use of steel, upon which the following bodies were represented.

British Constructional Steelwork Association Ltd.
 Cold Rolled Sections Association
 Confederation of British Metalforming
 Department of the Environment, Transport and the Regions
 Health and Safety Executive
 Institution of Civil Engineers
 Institution of Structural Engineers
 Office of the Deputy Prime Minister — Building Regulations Division
 Office of the Deputy Prime Minister — Represented by Building Research Establishment
 Steel Construction Institute
 UK Steel Association
 Welding Institute
 Co-opted members

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 28 November 2003

© BSI 28 November 2003

First published 1990

Amendments issued since publication

| Amd. No. | Date | Comments |
|----------|------|----------|
| | | |
| | | |
| | | |
| | | |

The following BSI references relate to the work on this standard
 Committee reference B/525/31
 Draft for comment 02/10268 DC

Contents

| | Page |
|--|--------------------|
| Committees responsible | Inside front cover |
| Foreword | iii |
| <hr/> | |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 2 |
| 4 Major symbols | 3 |
| 5 General principles | 3 |
| 6 Structural members in fire | 4 |
| 7 Fire limit states | 14 |
| 8 Evaluation of fire performance | 15 |
| <hr/> | |
| Annex A (normative) Strength retention factors for cold formed steels complying with BS EN 10143 | 31 |
| Annex B (normative) Re-use of steel after a fire | 31 |
| Annex C (normative) Simplified method of calculation for beams with shelf angles | 33 |
| <hr/> | |
| Bibliography | 37 |
| <hr/> | |
| Figure 1 — Thermal elongation of steel | 5 |
| Figure 2 — Variation of specific heat with temperature for steel | 6 |
| Figure 3 — Variation of thermal conductivity with temperature for steel | 7 |
| Figure 4 — Variation of thermal elongation with temperature for normal weight and lightweight concrete | 9 |
| Figure 5 — Variation of specific heat with temperature for normal weight and lightweight concrete | 10 |
| Figure 6 — Variation of thermal conductivity with temperature for normal weight and lightweight concrete | 11 |
| Figure 7 — Measurement of depth into concrete slab | 27 |
| Figure 8 — Insulation thickness for trapezoidal profiled steel sheets | 27 |
| Figure 9 — Insulation thickness for re-entrant profiled steel sheets | 28 |
| Figure 10 — Effect of beam deflection on a fire-resisting wall | 28 |
| Figure C.1 — Temperature blocks for beams with shelf angles | 34 |
| Figure C.2 — Definition of dimension x | 35 |
| Figure C.3 — Definition of blocks 4, 5 and 6 | 36 |
| <hr/> | |
| Table 1 — Strength retention factors for steel complying with grades S275 to S355 of BS EN 10025 and BS EN 10210-1 | 12 |
| Table 2 — Strength retention factors for concrete complying with BS 8110 | 12 |
| Table 3 — Strength retention factors for cold worked reinforcing steel complying with DD ENV 10080 | 13 |
| Table 4 — Strength retention factors for grade 4.6 and 8.8 bolt assemblies and welds complying with BS 5950-2 | 13 |
| Table 5 — Load factors for fire limit state | 14 |
| Table 6 — Calculation of A_m/V values | 17 |
| Table 7 — Maximum section factor for unprotected members | 18 |
| Table 8 — Limiting temperatures for the design of protected and unprotected hot finished members | 21 |
| Table 9 — Design temperatures for columns and tension members. (Temperatures apply to I and H sections heated on three and four sides and angle and channel sections heated on four sides) | 22 |
| Table 10 — Design temperature for members in bending. (Temperatures apply to I and H sections heated on three and four sides and channel sections heated on three sides) | 23 |

| | Page |
|--|------|
| Table 11 — Fire protection thickness modification factor | 25 |
| Table 12 — Temperature distribution through a composite floor with profiled steel sheeting | 27 |
| Table 13 — Minimum thickness of concrete for trapezoidal profiled steel sheets | 28 |
| Table 14 — Minimum thickness of concrete for re-entrant profiled steel sheets | 28 |
| Table A.1 — Strength retention factors for cold formed steels complying with BS EN 10143 | 31 |
| Table C.1 — Block temperature | 35 |
| Table C.2 — Temperature gradient | 35 |

Foreword

This part of BS 5950 has been prepared by Subcommittee B/525/31, Structural use of steel. It supersedes BS 5950-8:1990, which is withdrawn.

This new edition has been prepared following the developments in fire engineering and the issue of a number of new and related standards adopting European and international standards for materials. The principal change in this edition is the introduction of a more comprehensive set of elevated temperature properties for hot finished steel, normal weight concrete, lightweight concrete and hot rolled and cold worked reinforcing bars. These properties are in agreement with those given in the Eurocodes and have been introduced to enable the fire engineering design of steel structures.

Other changes include the renaming of “Strength reduction factors” to “Strength retention factors” and the inclusion of strength retention factors for normal and lightweight concretes, bolts and welds.

The load factor for non-permanent imposed loads in offices for general use at the fire limit state has also been changed from 0.8 to 0.5. Furthermore, the load factor of 0.0 for wind loads used in the design for boundary conditions to control external fire spread has been added.

The material strength factor of concrete has been reduced from 1.30 to 1.10 and a material strength factor of 1.0 has been added for cold-worked reinforcing steel.

The section factor was defined as H_p/A in the 1990 edition of BS 5950-8. In this edition, European terminology has been used and the section factor is now defined as A_m/V . However, the numerical values are unaltered.

The subclause on castellated sections has been edited to clarify its scope of application.

BS 5950 is a document combining codes of practice to cover the design, construction and fire resistance of steel structures and specifications for materials, workmanship and erection. It comprises the following parts:

- *Part 1: Code of practice for design — Rolled and welded sections;*
- *Part 2: Specification for materials, fabrication and erection — Rolled and welded sections;*
- *Part 3: Design in composite construction: Section 3.1: Code of practice for design of simple and continuous composite beams;*
- *Part 4: Code of practice for design of composite slabs with profiled steel sheeting;*
- *Part 5: Code of practice for design of cold formed thin gauge sections;*
- *Part 6: Code of practice for design of light gauge profiled steel sheeting;*
- *Part 7: Specification for materials, fabrication and erection: cold formed sections and sheeting;*
- *Part 8: Code of practice for fire resistant design;*
- *Part 9: Code of practice for stressed skin design.*

This part of BS 5950 gives recommendations for evaluating the fire resistance of steel and steel/concrete composite structures. Methods are given for determining the thermal response of the structure and evaluating the protection required, if any, to achieve the specified performance, although it is recognized that there are situations where other proven methods may be appropriate.

It has been assumed in the drafting of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people; also that construction, the application of any fire protection and supervision will be carried out by capable and experienced organizations.

As a code of practice, this British Standard takes the form of guidance and recommendations. It should not be quoted as if it were a specification and particular care should be taken to ensure that claims of compliance are not misleading.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages ii to iv, pages 1 to 37 and a back cover.

The copyright notice displayed in this document indicates when the document was last issued.

1 Scope

This part of BS 5950 gives recommendations for:

- steel beams, columns and tension members designed to BS 5950-1;
- steel/concrete composite beams designed to BS 5950-3;
- concrete-filled steel hollow sections designed to BS 5400-5;
- composite floors designed to BS 5950-4.

For each type of member, recommendations are given for the load carrying capacity and, where appropriate insulation performance, for a given fire exposure assuming they act in isolation and restraint to thermal expansion is ignored.

These recommendations are based on:

- a) fire resistance derived from standard fire tests;
- b) fire resistance derived from calculations.

NOTE These recommendations may also be applied to members for which the fire exposure has been determined from natural fires.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

BS 476-20, *Fire tests on building materials and structures — Part 20: Method for determination of the fire resistance of elements of construction (general principles)*.

BS 4482, *Specification for cold reduced steel wire for the reinforcement of concrete*.

BS 5400-5, *Steel, concrete and composite bridges — Part 5: Code of practice for design of composite bridges*.

BS 5950-1, *Structural use of steelwork in building — Part 1: Code of practice for design — Rolled and welded sections*.

BS 5950-2, *Structural use of steelwork in building — Part 2: Specification for materials, fabrication and erection — Rolled and welded sections*.

BS 5950-3.1, *Structural use of steelwork in building — Part 3: Design in composite construction: Section 3.1: Code of practice for design of simple and continuous composite beams*.

BS 5950-4, *Structural use of steelwork in building — Part 4: Code of practice for design of composite slabs with profiled steel sheeting*.

BS 7974, *Application of fire safety engineering principles to the design of buildings — Code of practice*.

BS 8110 (all parts), *Structural use of concrete*.

BS 8290-1, *Suspended ceilings — Part 1: Code of practice for design*.

BS EN 1363-1, *Fire resistance tests — Part 1: General requirements*.

BS EN 1991-1-2, *Eurocode 1: Actions on structures — Part 1-2: General actions — Actions on structures exposed to fire*.

BS EN 10025, *Hot rolled products of non-alloy structural steels — Technical delivery conditions*.

BS EN 10143, *Continuously hot-dip metal coated steel sheet and strip — Tolerances on dimensions and shape*.

BS EN 10210-1, *Hot finished structural hollow sections of non-alloy and fine grain structural steels — Part 1: Technical delivery requirements*.

DD ENV 10080, *Steel for the reinforcement of concrete — Weldable ribbed reinforcing steel B500 — Technical delivery conditions for bars, coils and welded fabric*.

3 Terms and definitions

For the purpose of this part of BS 5950, the following terms and definitions apply.

3.1

critical element

element of a section that is fundamental to the structural response

3.2

design temperature

temperature that the critical element will reach at the end of the specified period of fire resistance in a test in accordance with the standard fire test

3.3

element

one of the following:

- a) the flange of a rolled or built-up I, H or channel section;
- b) the web of a rolled or built-up I, H or channel section;
- c) the leg of an angle and channel;
- d) the flange or the stalk of an I section;
- e) the side of a hollow section.

3.4

fire exposure

time–temperature response based on either the standard fire (fire resistance) or natural fires

3.5

fire protection material

material that has been shown by a standard fire test to be capable of remaining in position and providing adequate thermal insulation for the fire resistance period under consideration

3.6

fire resistance

length of time for which the member or other component is required to withstand exposure to the fire regime given in the standard fire without the load capacity falling below the fire limit state factored load or loss of integrity and/or insulation

3.7

insulation

ability of a separating component to restrict the temperature rise of its unexposed face to below specified levels

3.8

integrity

ability of a separating component to contain a fire to specified criteria for collapse, freedom from holes, cracks and fissures and sustained flaming on its unexposed face

3.9

limiting temperature

temperature of the critical element of a member at failure under fire conditions

3.10

load capacity

limit of force or moment that may be applied without causing failure due to yielding or rupture

3.11

natural fires

fire consisting of a growth and decay phase based on the type and size of the compartment, available combustible material and air supply, including parametric fires and characteristic fires as defined in BS 7974 and BS EN 1991-1-2

3.12**standard fire**

fire represented by a time–temperature relationship given in BS 476-20 and BS EN 1363-1

3.13**standard fire test**

test where the standard fire is used to determine the fire resistance of the member

3.14**structural member**

part of a structure designed to resist force or moment, such as a steel section formed by hot rolling, cold forming or welding sections and/or plates together

3.15**thermal expansion**

increase in length, cross-sectional area or volume of a material per degree increase in temperature

4 Major symbols

The major symbols used in this standard are as follows:

- A_m Exposed surface area of a member per unit length;
- F_f Applied axial load at the fire limit state, using the factored loads given in 7.1;
- M Applied moment at the fire limit state, using the factored loads given in 7.1;
- M_c Moment capacity at 20 °C;
- M_{cf} Moment capacity at the required period of fire resistance;
- V Volume of the member per unit length;
- γ_f Load factor;
- γ_m Material strength factor.

5 General principles**5.1 Aims of fire precautions**

The aims of fire precautions are to safeguard life and to minimize fire damage to property and financial loss. These aims are principally achieved by:

- a) minimizing the risk of ignition;
- b) providing a safe exit for occupants;
- c) restricting the spread of fire;
- d) minimizing the risk of structural collapse to ensure safe exit for occupants and safety of fire-fighters.

This part of BS 5950 is principally concerned with items c) and d).

The designer responsible for the fire strategy of the building as a whole should ensure the compatibility of the structural performance requirements with the aims of fire precautions.

5.2 Structural performance requirements

The structure should be designed and constructed such that its stability will be maintained for an appropriate period by following either a prescriptive or performance based approach to fire safety.

The deformation of the structure for a given fire exposure should be considered in the design criteria of any separating elements.

The designer responsible for the overall stability of the structure during a fire should be clearly identified. This designer should ensure the compatibility of the structural design and detailing between all those structural parts and components that are required for overall stability, even if some or all the structural design and detailing of those structural parts and components is carried out by another designer.

5.3 Methods of design

The structural performance may be assessed using results from standard fire tests or calculation models that consider the fire exposure, thermal response and structural response.

5.4 Fire exposure

The fire exposure may be determined in terms of:

- the time temperature relationship defined by the standard fire (which forms the basis of fire resistance); or
- natural fire, where the geometry and linings of the compartment, the combustible material and the possible ventilation are considered. This includes parametric fires and characteristic fires as defined in BS 7974.

5.5 Thermal response

The temperature of a structural component for a given fire exposure may be determined from:

- tabulated data given in this code for structural steel elements and composite floor slabs, based on fire resistance (time–temperature response from the standard fire); or
- any calculation model for thermal response based on acknowledged principles and assumptions of the theory of heat transfer.

5.6 Structural response

The response of the structure to a given fire exposure may be determined by considering either:

- individual structural members, where the effects of restraint to thermal expansion may be ignored;
- structural analysis of sub-frames where thermal expansion and geometric non-linearity is considered;
- global structural analysis where thermal expansion and geometric non-linearity are considered.

6 Structural members in fire

6.1 Properties at elevated temperature

6.1.1 Hot finished steel

6.1.1.1 General

The following properties apply to hot finished structural steels, which are not subsequently heat treated, complying with BS EN 10025 and BS EN 10210-1 at elevated temperatures and are for use in fire calculations. Properties at ambient temperature are given in BS 5950-1.

6.1.1.2 Thermal elongation

The thermal elongation of steel $\Delta l/l$ may be determined from the following:

for $20\text{ °C} \leq \theta_a < 750\text{ °C}$:

$$\Delta l/l = 1.2 \times 10^{-5} \theta_a + 0.4 \times 10^{-8} \theta_a^2 - 2.416 \times 10^{-4}$$

for $750\text{ °C} \leq \theta_a \leq 860\text{ °C}$:

$$\Delta l/l = 1.1 \times 10^{-2}$$

for $860\text{ °C} < \theta_a \leq 1\,200\text{ °C}$:

$$\Delta l/l = 2 \times 10^{-5} \theta_a - 6.2 \times 10^{-3}$$

where

- l is the length at 20 °C ;
- Δl is the temperature induced expansion;
- θ_a is the steel temperature (°C).

The relation of thermal elongation with temperature is shown in Figure 1.




Figure 1 — Thermal elongation of steel

For simple calculation models, the thermal elongation of steel $\Delta l/l$ may be determined from:

$$\Delta l/l = 14 \times 10^{-6} (\theta_a - 20)$$

6.1.1.3 Specific heat

The specific heat of steel c_a may be determined from the following:

for $20\text{ }^\circ\text{C} \leq \theta_a < 600\text{ }^\circ\text{C}$:

$$c_a = 425 + 7.73 \times 10^{-1} \theta_a - 1.69 \times 10^{-3} \theta_a^2 + 2.22 \times 10^{-6} \theta_a^3 \text{ J/kg}\cdot\text{K}$$

for $600\text{ }^\circ\text{C} \leq \theta_a < 735\text{ }^\circ\text{C}$:

$$c_a = 721 + \frac{5\,371}{738 - \theta_a} \text{ J/kg}\cdot\text{K}$$

for $735\text{ }^\circ\text{C} \leq \theta_a < 900\text{ }^\circ\text{C}$:

$$c_a = 605 + \frac{7\,624}{\theta_a - 731} \text{ J/kg}\cdot\text{K}$$

for $900\text{ }^\circ\text{C} \leq \theta_a \leq 1\,200\text{ }^\circ\text{C}$:

$$c_a = 650 \text{ J/kg}\cdot\text{K}$$

where

θ_a is the steel temperature ($^\circ\text{C}$).

The variation of specific heat with temperature is shown in Figure 2.




Figure 2 — Variation of specific heat with temperature for steel

6.1.1.4 Thermal conductivity

The thermal conductivity λ_a of steel may be determined from the following:

for $20\text{ °C} \leq \theta_a < 800\text{ °C}$:

$$\lambda_a = 54 - 3.33 \times 10^{-2} \theta_a \text{ W/m}\cdot\text{K}$$


for $800\text{ °C} \leq \theta_a \leq 1\,200\text{ °C}$:

$$\lambda_a = 27.3 \text{ W/m}\cdot\text{K}$$

where

θ_a is the steel temperature (°C).

The variation of thermal conductivity with temperature is shown in Figure 3.



6.1.2 Normal weight concrete

6.1.2.1 General

The following properties can be used for normal weight concrete with a cube strength less than or equal to 60 N/mm², composed of either siliceous aggregate or calcareous aggregate.

6.1.2.2 Thermal elongation

The thermal elongation Δ/l of normal weight concrete may be determined from the following:
for 20 °C $\leq \theta_c < 700$ °C:

$$\Delta/l = -1.8 \times 10^{-4} + 9 \times 10^{-6} \theta_c + 2.3 \times 10^{-11} \theta_c^3$$

for 700 °C $\leq \theta_c \leq 1\,200$ °C:

$$\Delta/l = 14 \times 10^{-3}$$

where

l is the length of the concrete member at 20 °C;

Δ/l is the temperature induced expansion;

θ_c is the concrete temperature (°C).

For simple calculation models, the thermal elongation of normal weight concrete Δ/l may be determined from:

$$\Delta/l = 18 \times 10^{-6} (\theta_a - 20)$$

The variation of thermal elongation with temperature is shown in Figure 4.

6.1.2.3 Specific heat

The specific heat of normal weight concrete c_c may be determined from:

for $20\text{ °C} \leq \theta_c < 1\ 200\text{ °C}$:

$$c_c = 900 + 80(\theta_c/120) - 4(\theta_c/120)^2 \text{ J/kg}\cdot\text{K}$$

where

θ_c is the concrete temperature (°C).

The variation of specific heat with temperature is shown in Figure 5.

6.1.2.4 Thermal conductivity

The thermal conductivity λ_c of normal weight concrete may be determined from the following:

for $20\text{ °C} \leq \theta_c < 1\ 200\text{ °C}$:

$$\lambda_c = 2 - 0.24(\theta_c/120) + 0.012(\theta_c/120)^2 \text{ W/m}\cdot\text{K}$$

The variation of thermal conductivity with temperature is shown in Figure 6.

6.1.2.5 Moisture content

In the absence of specific data, the moisture content should be assumed to be 4 % of the concrete weight.

6.1.3 Lightweight concrete**6.1.3.1 General**

The following properties can be used for lightweight concrete with a cube strength less than or equal to 60 N/mm^2 .

6.1.3.2 Thermal elongation

The thermal elongation $\Delta l/l$ of lightweight concrete may be determined from:

$$\Delta l/l = 8 \times 10^{-6}(\theta_c - 20)$$

where

l is the length of the concrete member at 20 °C ;

Δl is the temperature induced expansion;

θ_c is the concrete temperature (°C).

The variation of thermal elongation with temperature is shown in Figure 4.

6.1.3.3 Specific heat

The specific heat of lightweight concrete c_a may be considered to be independent of temperature and a value of $840\text{ J/kg}\cdot\text{K}$ may be taken.

The variation of specific heat with temperature is shown in Figure 5.

6.1.3.4 Thermal conductivity

The thermal conductivity λ_c of lightweight concrete may be determined from the following:

for $20\text{ °C} \leq \theta_c \leq 800\text{ °C}$:

$$\lambda_c = 1.0 - (\theta_c/1\ 600) \text{ W/m}\cdot\text{K}$$


for $\theta_c > 800\text{ °C}$:


$$\lambda_c = 0.5 \text{ W/m}\cdot\text{K}$$

The variation of thermal conductivity with temperature is shown in Figure 6.

6.1.3.5 Moisture content

In the absence of specific data, the moisture content should be assumed to be 5 % of the concrete weight.




**Key**

1 Normal weight concrete

2 Lightweight concrete

Figure 5 — Variation of specific heat with temperature for normal weight and lightweight concrete



6.1.4 Hot rolled and cold worked reinforcing bars

The properties for thermal expansion, specific heat and thermal conductivity used for hot rolled steels can be used for hot rolled and cold worked reinforcing bars.

6.2 Strength retention factors

The strength retention factors for grade S275 and S355 steels complying with BS EN 10025 and BS EN 10210-1 are given in Table 1. The appropriate value of strain should be determined from 6.3.

The strength retention factors for normal weight and lightweight concrete are given in Table 2.

The strength retention factors for cold worked reinforcing steel are given in Table 3. The retention factors for hot rolled reinforcing steel may be taken from Table 1 corresponding to 2 % strain.

The strength retention factors for bolts and welds are given in Table 4.

The factors in Table 1, Table 2, Table 3 and Table 4 are expressed as fractions of the room temperature design strength.

Strength retention factors for cold finished steels complying with BS EN 10143 are given in Annex A.

Strength retention factors for other grades of steel should be established on the basis of elevated temperature tensile tests.

Table 1 — Strength retention factors for steel complying with grades S275 to S355 of BS EN 10025 and BS EN 10210-1

| Temperature °C | Strength retention factors at a strain (in %) of: | | |
|-------------------|---|-------|-------|
| | 0.5 | 1.5 | 2.0 |
| 100 | 0.97 | 1.000 | 1.000 |
| 150 | 0.959 | 1.000 | 1.000 |
| 200 | 0.946 | 1.000 | 1.000 |
| 250 | 0.884 | 1.000 | 1.000 |
| 300 | 0.854 | 1.000 | 1.000 |
| 350 | 0.826 | 0.968 | 1.000 |
| 400 | 0.798 | 0.956 | 0.971 |
| 450 | 0.721 | 0.898 | 0.934 |
| 500 | 0.622 | 0.756 | 0.776 |
| 550 | 0.492 | 0.612 | 0.627 |
| 600 | 0.378 | 0.460 | 0.474 |
| 650 | 0.269 | 0.326 | 0.337 |
| 700 | 0.186 | 0.223 | 0.232 |
| 750 | 0.127 | 0.152 | 0.158 |
| 800 | 0.071 | 0.108 | 0.115 |
| 850 | 0.045 | 0.073 | 0.079 |
| 900 | 0.030 | 0.059 | 0.062 |
| 950 | 0.024 | 0.046 | 0.052 |

NOTE 1 Intermediate values may be obtained by linear interpolation.

NOTE 2 For temperatures higher than the values given, a linear reduction in strength to zero at 1 300 °C may be assumed.

Table 2 — Strength retention factors for concrete complying with BS 8110

| Temperature °C | Strength retention factors | |
|-------------------|----------------------------|----------------------|
| | Normal weight concrete | Lightweight concrete |
| 20 | 1.00 | 1.00 |
| 100 | 0.95 | 1.00 |
| 200 | 0.90 | 1.00 |
| 300 | 0.85 | 1.00 |
| 400 | 0.75 | 0.88 |
| 500 | 0.60 | 0.76 |
| 600 | 0.45 | 0.64 |
| 700 | 0.30 | 0.52 |
| 800 | 0.15 | 0.40 |
| 900 | 0.08 | 0.28 |
| 1 000 | 0.04 | 0.16 |
| 1 100 | 0.01 | 0.04 |
| 1 200 | 0.00 | 0.00 |

Table 3 — Strength retention factors for cold worked reinforcing steel complying with DD ENV 10080

| Temperature °C | Strength retention factor |
|-------------------|---------------------------|
| 20 | 1.00 |
| 100 | 1.00 |
| 200 | 1.00 |
| 300 | 1.00 |
| 400 | 0.94 |
| 500 | 0.67 |
| 600 | 0.40 |
| 700 | 0.12 |
| 800 | 0.11 |
| 900 | 0.08 |
| 1 000 | 0.05 |
| 1 100 | 0.03 |
| 1 200 | 0.00 |

Table 4 — Strength retention factors for grade 4.6 and 8.8 bolt assemblies and welds complying with BS 5950-2

| Temperature °C | Strength retention factor for bolts (Tension and shear) | Strength retention factor for welds |
|-------------------|--|-------------------------------------|
| 20 | 1.00 | 1.00 |
| 100 | 0.97 | 1.00 |
| 150 | 0.95 | 1.00 |
| 200 | 0.94 | 1.00 |
| 300 | 0.90 | 1.00 |
| 400 | 0.78 | 0.88 |
| 500 | 0.55 | 0.63 |
| 600 | 0.22 | 0.38 |
| 700 | 0.10 | 0.13 |
| 800 | 0.07 | 0.07 |
| 900 | 0.03 | 0.02 |
| 1 000 | 0.00 | 0.00 |

6.3 Strain levels

When calculating the structural performance in fire, consideration should be given to both the limiting strain in the steel and the corresponding strain in any fire protection material. The following strains should not be exceeded, unless it has been demonstrated in fire resistance tests that a higher level of strain may be satisfactorily developed in the steel and that the fire protection material has the ability to remain intact:

- composite members in bending which are unprotected or protected with fire protection materials which have demonstrated their ability to remain intact at this level of strain: 2.0 %;
- non-composite members in bending which are unprotected or protected with fire protection materials which have demonstrated their ability to remain intact at this level of strain: 1.5 %;
- members not covered in a) or b): 0.5 %.

7 Fire limit states

7.1 General

The structural effects of a fire in a building, or part of a building, should be considered as a fire limit state. A fire limit state should be treated as an accidental limit state.

At the fire limit state members or sub-assemblies should be assumed to be subject to the heating conditions specified in the standard fire test for the required period of fire resistance, except when analysis is based on the consideration of natural fires.

In checking the strength and stability of the structure at the fire limit state, the loads should be multiplied by the relevant load factor γ_f given in Table 5.

Wind loads should only be applied to buildings where the height to eaves is greater than eight metres and only considered when checking the design of the primary elements of the framework. The effect of wind loads can be ignored when designing for boundary conditions to control external fire spread.

Table 5 — Load factors for fire limit state

| Load | γ_f |
|--|------------|
| Dead load | 1.00 |
| Imposed loads: | |
| a) permanent: | |
| 1) those specifically allowed for in design, e.g. plant, machinery and fixed partitions | 1.00 |
| 2) in storage buildings or areas used for storage in other buildings (including libraries and designated filing areas) | 1.00 |
| b) non-permanent: | |
| 1) in escape stairs and lobbies | 1.00 |
| 2) in offices for general use | 0.50 |
| 3) all other areas (imposed snow loads on roofs may be ignored) | 0.80 |
| Wind loads: | |
| a) design for boundary conditions to control external fire spread | 0.00 |
| b) all other cases | 0.33 |

7.2 Material strength factors

At the fire limit state, the capacities of the members may be calculated using the following material strength factors (γ_m):

- a) steel 1.00;
- b) concrete 1.10;
- c) cold worked reinforcing steel 1.00.

7.3 Performance criteria

In the case of a fire, the mechanical resistance of the entire structure or individual structural members should be designed and constructed in such a way that their load bearing function is maintained under the factored loads derived from 7.1 during the relevant fire exposure.

Any specified requirements for the insulation and integrity of compartment walls and floors, including any incorporated members, should also be satisfied.

7.4 Bracing members

Steel bracing members required to provide stability to the structure at the fire limit state should have adequate fire resistance, unless alternative load paths can be identified.

Where fire protection to bracing members is necessary, the protection thickness should be based on the section factor of the member or a value of 200 m^{-1} , whichever is the smaller value.

In some cases, it might not be necessary to apply fire protection to bracing members and consideration should be given to:

- shielding bracing members from fire by placing them in vertical shafts or within walls;
- the use of infill masonry walls which, although they are typically ignored in terms of overall stability at ambient temperature, can provide the sufficient shear capacity during a fire instead of relying on the steel bracing systems;
- the possibility that only bracing systems within a fire compartment might be subjected to elevated temperatures and the other unaffected bracing systems might be sufficient to provide the required stability at the fire limit state;
- the possibility that the steel beam to column connections might have sufficient stiffness to ensure stability at the fire limit state.

7.5 Re-use of steel after a fire

It might be possible to re-use steel after a fire. Guidance is given in Annex B.

8 Evaluation of fire performance

8.1 General

Fire resistance may be determined by either of the following methods:

- a) standard fire tests for all types of members (see 8.3);
- b) calculation using the design methods given in this Code.

8.2 Section factor

8.2.1 General

The rate of temperature increase of a steel member in a fire may be assumed to be proportional to its section factor A_m/V (in m^{-1}):

where

A_m is the exposed surface area (in m) per unit length of member, as given in Table 6;

V is the volume of the member per unit length;

NOTE The section factor was defined as H_p/A in the 1990 edition. The symbols have been changed in line with European terminology. Numerical values are unaltered.

8.2.2 Rolled, fabricated and hollow sections excluding castellated sections

When calculating the section factor for rolled, fabricated and hollow sections, the gross cross-sectional area should be used. The effect of small holes may be ignored.

8.2.3 Castellated sections

For castellated sections, the section factor should be taken as that of the uncut parent section.

8.2.4 Tapered sections

For tapered sections, the maximum section factor should be used.

8.3 Fire performance derived from testing

8.3.1 General

Members designed in accordance with the appropriate part of BS 5950 may be given the required fire resistance by applying, when necessary, a fire protection material at a thickness that has been derived from the standard fire test.

Data for determining the required thickness of a given fire protection material for a member with a given section factor A_m/V for a given period of fire resistance should be derived from appraisal of a series of such tests.









































Where the factored loads for the fire limit state differ from those applied in the tests, the test results should be adjusted, either by using Table 8 or else by means of fire engineering calculation, as appropriate.

These tests should be carried out at an approved testing station and the recommendations derived from them should be prepared by a suitably qualified person.

8.3.2 Unprotected members

A hot finished rolled or hollow section member which has a load ratio $R \leq 0.6$ (see 8.4.2.2 and 8.4.2.3) may be assumed to have an inherent fire resistance of 30 min without any fire protection, provided that it has a section factor A_m/V not exceeding the appropriate maximum value given in Table 7.

Table 6 — Calculation of A_m/V values

| Steel section | Profile protection | | | | | Box and solid protection | | | | |
|---|---|--|---|---|--|--|---|---|--|--|
| | 4 sides | 3 sides | 3 sides | 2 sides | 1 side | 4 sides | 3 sides | 3 sides | 2 sides | 1 side |
| Universal beams, universal columns and joists (plain and castellated)  A_m |  $4B + 2D - 2t$ |  $3B + 2D - 2t$ |  $2B + 2d - t$ |  $3B + D - t$ |  B |  $2B + 2D$ |  $B + 2D$ |  $B + 2d$ |  $B + D$ |  B |
|  A_m |  $2B + 2D$ |  $B + 2D$ |  $2B + 2D - t$ | | |  $2B + 2D$ |  $B + 2D$ |  $B + 2D$ | | |
| Angles  A_m |  $2B + 2D$ |  $B + 2D$ |  $2B + 2D - t$ | | |  $2B + 2D$ |  $B + 2D$ |  $B + 2D$ | | |
| Channels  A_m |  $4B + 2D - 2t$ |  $4B + D - 2t$ |  $3B + 2D - 2t$ | | |  $2B + 2D$ |  $2B + D$ |  $B + 2D$ | | |
| Hollow sections, square or rectangular  A_m |  $2B + 2D$ |  $B + 2D$ | | | |  $2B + 2D$ |  $B + 2D$ | | | |
| Hollow sections, circular  A_m |  πD | | | | |  πD | | | | See note 2 |

NOTE 1 The general principle applied in calculating A_m/V for unprotected or profile-protected sections is to use the actual profile of the steel section; fillet radii may be taken into account and are normally included in published tables. For box protection, the smallest enclosing rectangle of the steel section is used.

NOTE 2 The air space created in boxing a section improves the insulation and a value of A_m/V , and therefore A_m higher than that for profile protection would be anomalous. Hence A_m is taken as the circumference of the tube and not $4D$.

Table 7 — Maximum section factor for unprotected members

| Description | A_m/V m ⁻¹ |
|--|----------------------------|
| Members in bending, directly supporting concrete slabs or composite slabs | 90 |
| Columns in simple construction (as described in BS 5950-1) | 50 |
| Columns comprising rolled sections filled with aerated concrete blockwork between the flanges in accordance with [3] | 69 |

8.3.3 Protected members

8.3.3.1 Required thickness

The required thickness of fire protection materials for the required period of fire resistance should be determined from standard fire tests.

NOTE Further information on the appraisal of fire test data may be obtained from [1] and [2].

8.3.3.2 Junctions between fire protection materials

Full continuity of fire protection should be maintained at junctions between different methods of fire protection.

8.3.3.3 Castellated sections

For castellated sections complying with 4.15.5 of BS 5950-1:2000, the thickness of passive fire protection material should be 1.2 times the thickness determined from the section factor A_m/V of the original (uncastellated) section.

8.3.3.4 Hollow sections

The required thickness of fire protection for a hollow section should be determined using the values of the section factor A_m/V given in 8.2.

For spray-applied lightweight cementitious based fire protection materials, the thickness required for a hollow section may be derived from the thickness t required for an I or H section with the same section factor A_m/V as follows:

for $A_m/V < 250$

$$\text{thickness} = t \{1 + (A_m/V)/1\,000\}$$

for $A_m/V \geq 250$

$$\text{thickness} = 1.25t$$

In the following cases, these equations should not be used and a separate appraisal of protection thickness should be made instead:

- where intumescent fire protection materials are used;
- where the test data has been derived from I or H sections filled between the flanges.

8.3.3.5 Structural connections

Provided the load ratio of the connection defined as the load carried during the fire to the load capacity at 20 °C is lower or equal to the load ratio (see 8.4.2.2 and 8.4.2.3) of the connecting members the thickness of protection applied to various parts of the connection should be the same as the thickness of the protection applied to the connected members.

If the load ratio of the connection is higher than the load ratio of the connecting members the protection to the connection should be increased from that applied to the connecting members to ensure that the connection does not fail first. This can be achieved by calculating the required protection thickness assuming the connecting members have a load ratio equal to the connection and applying this thickness over the connection area.

Where test evidence is available, it might be possible to reduce the protection to the bolts of the connection.

8.3.3.6 Tension members

Where thermal expansion can cause gaps in the fire protection materials, consideration should be given to the penetration of heat.

8.4 Fire performance derived from calculation

8.4.1 General

The fire behaviour of hot finished steel members may be determined using either:

- the limiting temperature method (see 8.4.2);
- the moment capacity method (see 8.4.4).

8.4.2 Limiting temperature method

8.4.2.1 General

The limiting temperature method may be used to determine the behaviour in fire of columns, tension members and beams with low shear load, designed in accordance with BS 5950-1.

Where the limiting temperature, as given in Table 8 for the applicable load ratio, is not less than the design temperature given by 8.4.3 for the required period of fire resistance, the member may be considered to have adequate fire resistance without protection.

When the limiting temperature is less than the design temperature given in 8.4.3, the protection thickness necessary to provide adequate fire resistance may be derived either from 8.3 or else from validated calculation methods.

The limiting temperature, which should not be exceeded during the required period, depends upon the following:

- the ratio of the load carried during the fire to the load capacity at 20 °C given in 8.4.2.2, 8.4.2.3 or 8.4.2.4, as applicable;
- the temperature gradient within the member;
- the stress profile through the cross-section;
- the dimensions of the section.

8.4.2.2 Load ratio for beams

For beams designed in accordance with BS 5950-1 and having three or four sides fully exposed, the load ratio R should be taken as the greater of:

$$R = \frac{M_f}{M_c} \quad \text{or} \quad R = \frac{mM_f}{M_b}$$

where

M_f is the applied moment at the fire limit state;

M_b is the buckling resistance moment (lateral torsional);

M_c is M_{cx} or M_{cy} as appropriate to the axis of bending, where they are the moment capacity of the section about the major and minor axes in the absence of axial load;

m is the equivalent uniform moment factor.

8.4.2.3 Load ratio for columns

The load ratio for columns exposed on up to four sides should be determined from the following:

- a) for columns in simple construction designed in accordance with the recommendations of BS 5950-1:

$$R = \frac{F_f}{A_g p_c} + \frac{M_{fx}}{M_b} + \frac{M_{fy}}{p_y Z_y}$$

where

- A_g is the gross area;
- p_c is the compressive strength;
- p_y is the design strength of steel;
- Z_y is the elastic modulus about the minor axis;
- M_b is as defined in 8.4.2.2;
- F_f is the axial load at the fire limit state;
- M_{fx} is the maximum moment about the major axis at the fire limit state;
- M_{fy} is the maximum moment about the minor axis at the fire limit state.

- b) for columns in continuous construction designed in accordance with BS 5950-1.

For sway or non-sway frames a load ratio of 0.67 may be used or, alternatively, the load ratio R may be taken as the greater of:

$$R = \frac{F}{A_g p_y} + \frac{M_{fx}}{M_{cx}} + \frac{M_{fy}}{M_{cy}} \quad \text{or}$$

$$R = \frac{F}{A_g p_c} + \frac{m M_{fx}}{M_b} + \frac{m M_{fy}}{p_y Z_y}$$

where

- $A_g, p_c, p_y, Z_y, F_f, M_{fx}$ and M_{fy} are as defined in 8.4.2.3a);
- M_b, M_{cx}, M_{cy} and m are as defined in 8.4.2.2.

F_f, M_{fx}, M_{fy} should be determined taking account of any notional horizontal forces.

8.4.2.4 Load ratio for tension members

For tension members exposed on up to four sides, the load ratio R should be determined from:

$$R = \frac{F_f}{A_g p_y} + \frac{M_{fx}}{M_{cx}} + \frac{M_{fy}}{M_{cy}}$$

where

- $A_g, p_y, F_f, M_{fx}, M_{fy}$ are as defined in 8.4.2.3a);
- M_{cx} and M_{cy} are as defined in 8.4.2.2.

8.4.3 Design temperature**8.4.3.1 General**

The design temperature depends on the section configuration and dimensions. For unprotected rolled I or H sections, it may be determined from tests or, for common periods of fire resistance, from Table 9 for columns and tension members or Table 10 for beams.

Table 8 — Limiting temperatures for the design of protected and unprotected hot finished members

| Description of member | Limiting temperature at a load ratio of: | | | | | | |
|---|--|-----|-----|-----|-----|-----|-----|
| | 0.7 | 0.6 | 0.5 | 0.4 | 0.3 | 0.2 | 0.1 |
| | °C | °C | °C | °C | °C | °C | °C |
| Members in compression, for a slenderness λ^a : | | | | | | | |
| ≤ 70 | 510 | 540 | 580 | 615 | 655 | 710 | 800 |
| > 70 but ≤ 180 | 460 | 510 | 545 | 590 | 635 | 635 | 635 |
| Non-composite members in bending supporting concrete slabs or composite slabs: | | | | | | | |
| unprotected members, or protected members complying with item a) or b) of 6.3 | 590 | 620 | 650 | 680 | 725 | 780 | 880 |
| other protected members | 540 | 585 | 625 | 655 | 700 | 745 | 800 |
| Composite members in bending supporting concrete slabs or composite slabs: | | | | | | | |
| unprotected members, or protected members complying with item a) or b) of 6.3 | | | | | | | |
| i) 100 % degree of shear connection | 550 | 580 | 610 | 645 | 685 | 740 | 840 |
| ii) 40 % degree of shear connection | 575 | 600 | 635 | 665 | 700 | 760 | 865 |
| other protected members | | | | | | | |
| i) 100 % degree of shear connection | 495 | 530 | 570 | 610 | 650 | 705 | 785 |
| ii) 40 % degree of shear connection | 530 | 560 | 595 | 630 | 675 | 725 | 795 |
| Members in bending not supporting concrete slabs: | | | | | | | |
| unprotected members, or protected members complying with item a) or b) of 6.3 | 520 | 555 | 585 | 620 | 660 | 715 | 810 |
| other protected members | 460 | 510 | 545 | 590 | 635 | 690 | 770 |
| Members in tension: all cases | 460 | 510 | 545 | 590 | 635 | 690 | 770 |
| NOTE For beams supporting a composite slab the limiting temperatures only apply when the voids between the top of the beam and underside of the steel deck are filled with non-combustible void fillers. For guidance on limiting temperatures when void fillers are not used, see [2]. | | | | | | | |
| ^a λ is the slenderness, i.e. the effective length divided by the radius of gyration. | | | | | | | |

Table 9 — Design temperatures for columns and tension members. (Temperatures apply to I and H sections heated on three and four sides and angle and channel sections heated on four sides)

| Flange thickness mm | Design temperature for fire resistance period of: | | | |
|------------------------|---|--------------|--------------|--------------|
| | 15 min °C | 30 min °C | 45 min °C | 60 min °C |
| 6 | 672 | 821 | 895 | 941 |
| 7 | 654 | 811 | 894 | 940 |
| 8 | 635 | 799 | 893 | 939 |
| 9 | 615 | 786 | 891 | 938 |
| 10 | 596 | 772 | 889 | 938 |
| 11 | 577 | 760 | 886 | 937 |
| 12 | 558 | 750 | 883 | 936 |
| 13 | 540 | 743 | 879 | 935 |
| 14 | 523 | 738 | 874 | 934 |
| 15 | 507 | 735 | 868 | 933 |
| 16 | 491 | 732 | 861 | 931 |
| 17 | 476 | 728 | 853 | 930 |
| 18 | 462 | 722 | 844 | 928 |
| 19 | 449 | 716 | 835 | 926 |
| 20 | 436 | 708 | 825 | 923 |
| 22 | 413 | 692 | 804 | 917 |
| 24 | 391 | 674 | 784 | 909 |
| 26 | 372 | 657 | 766 | 899 |
| 28 | 355 | 639 | 752 | 887 |
| 30 | 339 | 622 | 743 | 874 |
| 32 | 325 | 605 | 737 | 859 |
| 34 | 312 | 589 | 734 | 844 |
| 36 | 300 | 574 | 729 | 828 |
| 38 | 289 | 559 | 723 | 812 |
| 40 | 279 | 545 | 714 | 797 |
| 45 | 256 | 512 | 690 | 764 |
| 50 | 237 | 482 | 663 | 744 |
| 55 | 221 | 456 | 637 | 735 |
| 60 | 208 | 432 | 612 | 728 |
| 65 | 196 | 410 | 589 | 714 |
| 70 | 185 | 390 | 567 | 697 |
| 75 | 176 | 373 | 547 | 679 |
| 80 | 168 | 356 | 527 | 661 |

NOTE 1 For fire resistance periods greater than 60 min, the steel temperature can conservatively be assumed to be the same as the furnace temperature used in the standard fire test.

NOTE 2 For square, round and rectangular steel hollow sections used in bending, compression or tension the above temperatures corresponding to a flange thickness 2.05 times the section wall thickness may be taken.

NOTE 3 The values in this table can be used to conservatively determine the web temperature of a steel section by replacing the flange thickness by the web thickness.

Table 10 — Design temperature for members in bending. (Temperatures apply to I and H sections heated on three and four sides and channel sections heated on three sides)

| Flange thickness mm | Design temperature for fire resistance period of: | | | |
|------------------------|---|--------|--------|--------|
| | 15 min | 30 min | 45 min | 60 min |
| | °C | °C | °C | °C |
| 6 | 672 | 820 | 895 | 940 |
| 7 | 654 | 810 | 894 | 940 |
| 8 | 634 | 798 | 887 | 939 |
| 9 | 615 | 785 | 892 | 938 |
| 10 | 596 | 772 | 891 | 938 |
| 11 | 577 | 760 | 889 | 937 |
| 12 | 560 | 750 | 887 | 936 |
| 13 | 542 | 743 | 884 | 935 |
| 14 | 526 | 739 | 879 | 934 |
| 15 | 511 | 736 | 875 | 933 |
| 16 | 496 | 733 | 869 | 932 |
| 17 | 482 | 730 | 863 | 930 |
| 18 | 468 | 725 | 856 | 928 |
| 19 | 457 | 720 | 847 | 927 |
| 20 | 445 | 714 | 840 | 925 |
| 22 | 423 | 699 | 831 | 920 |
| 24 | 401 | 683 | 812 | 913 |
| 26 | 385 | 668 | 793 | 905 |
| 28 | 370 | 654 | 778 | 897 |
| 30 | 354 | 638 | 764 | 886 |
| 32 | 342 | 624 | 752 | 875 |
| 34 | 328 | 609 | 744 | 862 |
| 36 | 318 | 596 | 738 | 850 |
| 38 | 307 | 583 | 736 | 837 |
| 40 | 300 | 574 | 730 | 827 |

NOTE 1 For fire resistance periods greater than 60 min, the steel temperature can conservatively be assumed to be the same as the furnace temperature used in the standard fire test.

NOTE 2 For hollow sections, refer to Table 9.

NOTE 3 The values in this table can be used to conservatively determine the web temperature of a steel section by replacing the flange thickness by the web thickness.

8.4.4 Moment capacity method

8.4.4.1 Non-composite beams

This method is applicable only to laterally restrained beams which have webs which satisfy the requirements for a Class 1 plastic or Class 2 compact section as defined in BS 5950-1.

A beam whose temperature profile can be defined, for a given fire exposure, may be assessed by calculating its moment capacity M_{cf} using the elevated temperature profile for the required fire exposure and the appropriate values of the strength retention factor, given in 6.2. Provided that the applied moment M_f at the fire limit state does not exceed M_{cf} , the member may be considered to have adequate load carrying capacity for the defined fire exposure without protection.

For a cross-section that is uniformly heated to a temperature θ_D the moment capacity M_{cf} can be determined from:

$$M_{cf} = k_r M_c$$

where

- k_r is the strength retention factor from Table 1 for 2 % strain relating to the steel temperature θ_D ;
- M_c is M_{cx} or M_{cy} as appropriate to the axis of bending, where they are the moment capacity of the section about the major and minor axes in the absence of axial load.

For a cross-section that is non-uniformly heated the moment capacity M_{cf} can be determined from:

$$M_{cf} = \sum_{i=1}^n A_i z_i k_r p_y$$

where

- A_i is the area of an element of the cross-section with a uniform temperature θ_i ;
- z_i is the distance from the plastic neutral axis to the centroid of element area A_i ;
- k_r is the strength retention factor for a temperature θ_i from Table 1 for 2 % strain;
- p_y is the design strength of steel.

When the applied moment M_f at the fire limit state exceeds M_{cf} , the protection thickness necessary to provide adequate load carrying capacity may be derived either from 8.3 or else from validated calculation methods.

A simplified calculation method for beams with shelf angles is given in Annex C.

8.4.4.2 Composite beams

This method is applicable only to beams which act compositely with the supporting concrete slab and have webs which satisfy the requirements for a Class 1 plastic or Class 2 compact section as defined in BS 5950-1.

The following equation can be used to determine the load-carrying capacity of the composite beam provided:

- any gaps between the underside of a steel trapezoidal or re-entrant deck of the composite floor and the top flange of the steel beam are filled with insulation;
- only the sagging moment capacity is considered;
- the depth of the steel section is less than 500 mm and the overall depth of the composite slab or concrete slab is greater than 120 mm.

The moment capacity M_{cf} for a composite beam can be determined from:

$$M_{cf} = \frac{M_c k_r}{0.7 + 0.2(N/N_f)}$$

where

- M_c is the moment capacity at the ultimate limit state (using partial material factors given in BS 5950-3.1 for the ultimate limit state);
- k_r is the strength retention factor from Table 1 for 2 % strain based on the steel temperature of the bottom flange;
- N/N_f is the degree of shear connection in the cold design.

Guidance on the design of composite beams with no insulation between the underside of the composite slab and top of the steel beam can be obtained from [2].

8.5 Portal frames

In buildings with fire resistant external walls that rely for their stability on the columns of portal frames that have rafters with no fire protection, the portal frames should be so constructed that the fire resistance of the external walls will be maintained in the event of rafter collapse in a fire.

This may be achieved by designing the bases and foundations of the portal frame columns supporting the external walls, to resist the forces and moments generated by the collapse of the portal frame rafter, taking account of the amount of roof cladding in place at the time of rafter collapse.

The columns supporting the wall should have the same fire resistance as the wall. Any fire protection to the column should extend at least to the top of the fire-resistant part of the wall, although the method of analysis used may require such protection to extend beyond that point.

NOTE For further information and design methods, see [4].

8.6 Concrete-filled hollow section columns

8.6.1 General

Square, rectangular and circular hollow sections, filled with unreinforced or reinforced concrete can obtain a good level of fire resistance when used as columns, without the need to apply external fire protection to the steel shell.

For greatest efficiency at the fire limit state, the section should be designed such that the load bearing capacity of the steel shell is low compared to the load carrying capacity of the concrete core.

Guidance on the design of concrete-filled hollow sections can be obtained from references [5] and [6].

8.6.2 Externally applied fire protection to concrete-filled circular or rectangular hollow sections

Concrete-filled structural hollow sections may be protected against fire with externally applied insulating materials. The thickness of fire protection material required for a concrete-filled structural hollow section may be determined by multiplying the thickness of the same fire protection material required for a hollow structural section of the same section factor A_m/V without concrete filling, by the modification factor c obtained from Table 11.

This method should only be used for passive insulating materials and is not applicable to active materials such as intumescent coatings.

Table 11 — Fire protection thickness modification factor

| A_m/V | c |
|------------|------|
| 50 to 75 | 1.00 |
| 75 | 1.00 |
| 100 | 0.92 |
| 125 | 0.88 |
| 150 | 0.81 |
| 175 | 0.75 |
| 200 | 0.69 |
| 260 to 300 | 0.55 |

NOTE The minimum practical thickness of a protective system might be limited by the fixing system used or by the stability of the fire protection material.

8.7 Water-filled structures

Where the columns and/or beams of a structure are filled with water (or any other liquid and additive mixture suitable for use as a cooling agent), the rate at which they will heat up in a fire may be sufficiently low for any other form of fire protection to be unnecessary. If it can be shown that, in the event of a fire, any such steelwork would not be heated to a temperature that would render it unable to maintain its function, then the water-filling may be considered to give adequate fire resistance.

Methods of assessment are beyond the scope of this document and specialist literature should be consulted. The engineer should, however, be satisfied that the procedure and the assumptions made are applicable to the structure in question.

NOTE For further information, see [7].

8.8 External bare steel

Steelwork positioned outside the envelope of a building may, in certain circumstances, be adequately safe in a fire without the need for protection. If it can be shown that, in the event of a fire, any external steelwork will not be heated to such a temperature as to render it unable to maintain its function, then it may be left without any protection. Use may be made of heat shields and wired glass in adjacent windows.

In assessing the effects of fire on an external steel member, the possibility of flames being deflected by the wind and causing forced ventilation should be considered.

Methods of assessment are beyond the scope of this document and specialist literature should be consulted. The engineer should, however, be satisfied that the procedure and assumptions made are applicable to the structure in question.

NOTE For further information, see [8].

8.9 Floor and roof slabs

8.9.1 General

The fire resistance of a concrete floor or roof slab may be determined as follows:

- a) a composite slab in accordance with BS 5950-4 should comply with 8.9.2 or 8.9.3;
- b) all other concrete slabs should comply with BS 8110-2.

8.9.2 Unprotected composite slabs with profiled steel sheeting

8.9.2.1 Simplified design method

Where a slab is designed in accordance with BS 5950-4, it may be considered to have at least a fire resistance of 30 min in its simply-supported form. Where such a slab is continuous over a number of supports, account may be taken of the enhanced fire resistance produced by such continuity.

NOTE Design data for continuous composite slabs with mesh reinforcement may be obtained from [9] and [10].

8.9.2.2 Analytical design method

The capacity of the composite floor for a given fire exposure can be determined subject to the following provisions.

- a) The temperature within the concrete slab should be determined from Table 12, or from test results corrected for the effects of moisture.
- b) The strength of any reinforcement within the slab for a given temperature should be determined using the strength retention factors given in Table 3.
- c) The strength of the steel deck should be ignored at the fire limit state.
- d) At the fire limit state, the plastic moment capacity of the slab based on the concrete and embedded reinforcement may be used.
- e) At the fire limit state unlimited redistribution of moments may be assumed.
- f) It may be assumed that, provided the slab is designed in accordance with BS 5950-4, shear failure need not be considered at the fire limit state.

NOTE For further information, see [10].

Wherever account is taken of continuity over a support, to ensure adequate ductility, the steel fabric or reinforcing bars used as support reinforcement should satisfy the minimum elongation requirement specified in BS 4482 and DD ENV 10080.

8.9.2.3 Thermal insulation requirement

The minimum slab depth for thermal insulation (see Figure 8 and Figure 9) in fire is met if:

- a) for open trapezoidal profiles the depth of concrete above the deck is not less than that given in Table 13; or
- b) for re-entrant profiles (in which the opening in the soffit does not exceed 10 % of the soffit area, and the re-entrant gap does not exceed 20 mm), the overall slab depth is not less than that given in Table 14.

NOTE BS 5950-4 recommends that the minimum depth of structural concrete over the profiled steel sheet should be 50 mm.

8.9.2.4 Integrity

The integrity of a composite slab with profiled steel sheeting should be maintained by forming a continuous membrane with the side seams being locked into and sealed by the concrete.

8.9.3 Protected composite slabs with profiled steel sheeting

The fire resistance of protected composite slabs with profiled steel sheeting may be assessed by the standard fire test.

Table 12 — Temperature distribution through a composite floor with profiled steel sheeting


| Depth into slab ^a mm | Temperature distribution for a fire resistance period of: | | | | | | | | | | | |
|------------------------------------|---|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| | 30 min | | 60 min | | 90 min | | 120 min | | 180 min | | 240 min | |
| | NW °C | LW °C | NW °C | LW °C | NW °C | LW °C | NW °C | LW °C | NW °C | LW °C | NW °C | LW °C |
| 10 | 470 | 460 | 650 | 620 | 790 | 720 | * | 770 | * | * | * | * |
| 20 | 340 | 330 | 530 | 480 | 650 | 580 | 720 | 640 | * | 740 | * | * |
| 30 | 250 | 260 | 420 | 380 | 540 | 460 | 610 | 530 | 700 | 630 | 770 | 700 |
| 40 | 180 | 200 | 330 | 290 | 430 | 360 | 510 | 430 | 600 | 520 | 670 | 600 |
| 50 | 140 | 160 | 250 | 220 | 370 | 280 | 440 | 340 | 520 | 430 | 600 | 510 |
| 60 | 110 | 130 | 200 | 170 | 310 | 230 | 370 | 280 | 460 | 380 | 540 | 440 |
| 70 | 90 | 80 | 170 | 130 | 260 | 170 | 320 | 220 | 410 | 320 | 480 | 380 |
| 80 | 80 | 60 | 140 | 80 | 220 | 130 | 270 | 180 | 360 | 270 | 430 | 320 |
| 90 | 70 | 40 | 120 | 70 | 180 | 100 | 240 | 150 | 320 | 230 | 380 | 280 |
| 100 | 60 | 40 | 100 | 60 | 160 | 80 | 210 | 140 | 280 | 190 | 360 | 270 |

Key
 NW is ordinary dense structural concrete
 LW is lightweight concrete
 * indicates a temperature greater than 800 °C

^a For any profile shape, the depth into the concrete is measured normal to the surface of the profiled steel sheet (see Figure 7).



Figure 7 — Measurement of depth into concrete slab



Key

1 Insulation thickness (includes screed)

Figure 8 — Insulation thickness for trapezoidal profiled steel sheets

**Key**


1 Insulation thickness (includes screed)

Figure 9 — Insulation thickness for re-entrant profiled steel sheets**Table 13 — Minimum thickness of concrete for trapezoidal profiled steel sheets (see Figure 8)**

| Concrete type | Minimum thickness of concrete for a fire resistance period of: | | | | | |
|------------------------------------|--|--------|--------|---------|---------|---------|
| | 30 min | 60 min | 90 min | 120 min | 180 min | 240 min |
| | mm | mm | mm | mm | mm | mm |
| Ordinary dense structural concrete | 60 | 70 | 80 | 90 | 115 | 130 |
| Lightweight concrete | 50 | 60 | 70 | 80 | 100 | 115 |

Table 14 — Minimum thickness of concrete for re-entrant profiled steel sheets (see Figure 9)

| Concrete type | Minimum thickness of concrete for a fire resistance period of: | | | | | |
|------------------------------------|--|--------|--------|---------|---------|---------|
| | 30 min | 60 min | 90 min | 120 min | 180 min | 240 min |
| | mm | mm | mm | mm | mm | mm |
| Ordinary dense structural concrete | 90 | 90 | 110 | 125 | 150 | 170 |
| Lightweight concrete | 90 | 90 | 105 | 115 | 135 | 150 |

**Key**

1 Internal fire wall

2 $L/100$ (at mid-span)**Figure 10 — Effect of beam deflection on a fire-resisting wall**

8.10 Walls

8.10.1 General

The appropriate thickness of fire protection to be applied to steel members incorporated into fire-resisting walls should be determined in accordance with 8.3 or by using validated calculation methods. If the wall itself provides protection to the steel member, this may be taken into account in assessing the section factor for the member.

NOTE To comply with statutory requirements, walls very close to a site boundary may also need to be checked for resistance to an external fire.

8.10.2 Walls connected to steel members

Properly designed fire-resisting walls may be assumed to have sufficient inherent robustness to accommodate thermally induced differential movements between the wall and steel members incorporated into it or directly connected to it, except for walls directly under beams which support significant vertical loads, see 8.10.3.

8.10.3 Walls under beams

Where a fire-resisting wall is liable to be subjected to significant additional vertical load due to the increased vertical deflection of a steel beam in a fire, see Figure 10, either:

- a) provision should be made to accommodate the anticipated vertical movement of the beam; or
- b) the wall should be designed to resist the additional vertical load in fire conditions.

For the purpose of this clause, the anticipated vertical movement at midspan of a vertically loaded steel beam in a fire should be taken as 1/100 of its span, unless a smaller value can be justified by an analytical assessment.

8.10.4 Independent fire-resisting walls

Where a steel member is very close to, or touching, a fire-resisting wall which obtains its resistance to horizontal forces independently of that steel member, the effects of horizontal thermal bowing of the wall and the steel member on the stability and integrity of the fire-resisting wall should be directly assessed. Any fire protection applied to the steel member may be taken into account when determining its thermal bowing.

NOTE Further guidance is given in [11].

8.11 Roofs

Where a roof spans across a fire resisting compartment wall and it is required that strips of the roof should be fire protected on the underside either side of the compartment wall, care should be taken to fire stop any gaps between the top of the wall and the underside of the roof cladding to allow for differential thermal movement in fire.

Where practicable, combustible insulation should also be fire stopped along the line of the wall.

8.12 Ceilings

8.12.1 General

The contribution of the protection provided by a ceiling may be considered as supplying all or part of the fire protection required by a floor or roof, subject to the requirements of 8.12.2.

8.12.2 Dry suspended ceiling systems

8.12.2.1 General

For structural fire protection, the complete ceiling and floor or roof construction should be considered. Ceilings should be constructed in accordance with BS 8290-1.

8.12.2.2 Suspension systems

The grid with its appropriate expansion cut-outs should be supported and restrained so as to ensure that the tiles or boards will remain in place and will not be dislodged in fire conditions.

8.12.2.3 Fittings

All fittings which penetrate the ceiling should have the same fire resistance as the ceiling, or be enclosed in a recess in the ceiling which is designed to provide the same level of fire protection as the ceiling.

Ventilation ducts and similar openings should be given special consideration to ensure that the integrity of the ceiling is not broken.

8.12.2.4 Junctions

Junctions with other elements of the building should be checked to ensure that there will be no breakdown in the integrity of the fire resistant barrier. Care should be exercised, in particular, with the connection of internal partitions to ensure that they will not disrupt the ceiling in the event of a fire. Fire barriers in the ceiling void should be so detailed and constructed as to ensure full continuity of protection.

8.12.2.5 Installation and maintenance

Particular care should be taken over the installation and maintenance of suspended ceilings to ensure that long-term protection is given.

Annex A (normative)

Strength retention factors for cold formed steels complying with BS EN 10143

The strength retention factors for cold formed members made from steels complying with BS EN 10143 may be taken from Table A.1. The appropriate value of strain should be determined from 6.3.

Table A.1 — Strength retention factors for cold formed steels complying with BS EN 10143

| Strain % | Strength retention factors at a temperature (in °C) of: | | | | | | | | |
|-------------|---|-------|-------|-------|-------|-------|-------|-------|-------|
| | 200 | 250 | 300 | 350 | 400 | 450 | 500 | 550 | 600 |
| 0.5 | 0.945 | 0.890 | 0.834 | 0.758 | 0.680 | 0.575 | 0.471 | 0.370 | 0.269 |
| 1.5 | 1.000 | 0.985 | 0.949 | 0.883 | 0.815 | 0.685 | 0.556 | 0.453 | 0.349 |
| 2.0 | 1.000 | 1.000 | 1.000 | 0.935 | 0.867 | 0.730 | 0.590 | 0.490 | 0.390 |

NOTE Intermediate values may be obtained by linear interpolation.

Further guidance on the fire protection of cold formed steel members used as primary structural members is given in [12].

Annex B (normative)

Re-use of steel after a fire

B.1 General

Structural steel may be reused after a fire provided that its mechanical properties have not been severely impaired and that the members have not been distorted or damaged beyond acceptable engineering criteria. It is important to recognize that structural steels are produced by different manufacturing routes and these will affect the extent of distortion and deterioration in mechanical properties. Reference should be made to BS 5950-2 on the acceptability of dimensional changes that might have occurred.

In practice, for the vast majority of cases distortion of steel members due to thermal effects e.g. restriction on expansion, relaxation of locked in residual stresses generated in manufacturing cold formed shapes, will usually render a steel member unsuitable for re-use before the material properties have been unduly permanently affected. However it is important that members outside the fire affected zone should be checked for distortion or damage particularly at the main connections.

B.2 Temperature effects on strength

B.2.1 Hot finished mild and micro-alloyed steels

Structural steels are generally produced with mechanical properties in excess of the minimum required to satisfy the relevant standard and therefore some deterioration in properties can usually be tolerated whilst still maintaining compliance with the design strengths.

The mechanical properties of hot finished structural steels to BS EN 10025 and BS EN 10210-1 are not significantly affected until they have achieved temperatures well in excess of 600 °C. Without any confirmatory testing for mild steels (S235 and S275), it may be assumed that at least 90 % of the mechanical properties are regained irrespective of the temperatures attained (even after heating to above 1 000 °C). For micro-alloyed steels (S355), it can be assumed that at least 75 % of the strength is regained on cooling from temperatures above 600 °C.

Non-destructive test methods can be employed to ascertain whether the mechanical strength of members have been unduly affected. However, this should be carried out under the advice of a competent metallurgist with an understanding of the effect of temperature on micro-structural properties. In cases where the strength properties have deteriorated, it may be assumed for notch tough grades C and above the Charpy impact transition temperature may have also been adversely affected.

B.2.2 "Old" hot finished structural steels to BS 15

Hot finished structural steels produced to BS 15 are the forerunner to present day mild steels. The guidance presented for Grades S235 and S275 in B.2.1 may be adopted.

B.2.3 Cold finished steel

Cold finished steel will distort at low temperatures (less than 600 °C) due to relieving of residual stresses locked in from the manufacturing processes and will render a member unsuitable for re-use. It may be assumed that for Grades up to Z35 (BS EN 10143) 90 % of the original design strength may be retained. After a fire, the surface condition (corrosion protection system) must be checked for integrity. Most paint systems will be damaged by hot smoke and galvanized coatings will be affected by a temperature rise of only 200 °C. For light steel sections such as purlins and rails, replacement rather than reinstatement is usually the most economic proposition.

B.2.4 Reinforcing and prestressing steels

The strength properties of reinforcing and prestressing steels are affected by fire to a greater extent than hot rolled structural steels although for hot and cold formed reinforcing steels in particular, the temperatures they would have to be subjected to would in any event result in a permanent serious loss in strength of the surrounding concrete.

Hot finished reinforcing steels regain all their strength after being heated up to 500 °C and at least 90 % after being heated to 600 °C.

Cold worked reinforcing steels regain all their strength after being heated to 350 °C and at least 90 % after being heated to 550 °C.

The strength properties of prestressing wires are permanently affected when they are heated to temperatures above 250 °C. In addition, pretension can be permanently affected by a rise in temperature of only 100 °C.

B.2.5 Cast steel

The strength properties of cast steels may be treated in a similar manner to hot rolled structural steels of similar grade. Members may be re-used providing they remain within specified tolerances for straightness shape and area.

B.3 Connections

B.3.1 General

Connections in the fire affected zone and adjoining areas should be examined to ensure that there has been no distortion or damage due to heat or thermal expansion. During heating and cooling high stress levels may be generated at the connections with the result that deformation and failure of bolts and welds may occur in either shear or tension. For bolts in particular, this might sometimes not be obvious until they are removed for inspection, in which case it is recommended new bolts are inserted.

B.3.2 Bolts

Where structural members have been heated to the extent that paintwork has been burnt off (not just covered in smoke residues), it is recommended bolts be replaced at the main connections as a matter of course.

The properties of Grade 4.6 bolts behave in a similar manner to hot rolled structural mild steels and may adopt the same guidance given in **B.2.1**.

The strength properties of high strength heat treated bolts, Grades 8.8, 10.9 and above are significantly reduced after heating to temperatures in excess of 500 °C and should be replaced.

Friction grip fasteners may also lose their friction grip when heated at only moderate temperatures and should be replaced.

B.3.3 Welds

Welded connections should be examined for visible cracks.

In general, the effect of fire on the mechanical properties of welds may be assumed to be the same as the parent steel member.

B.4 Fire protection materials

Many fire protection materials are rendered unsuitable for future use by fire. All fire-protection materials should be examined and replaced as necessary.

B.5 On-site checks

Inspection (and, where necessary, tests) should be carried out on site to verify the continued suitability of the structural members. Members should be assessed on the basis of their compliance with the appropriate British Standard. See [13].

Annex C (normative)

Simplified method of calculation for beams with shelf angles

C.1 General

The moment capacity of a beam with shelf angles supporting in situ or precast concrete slabs may be calculated using the method described in C.2 from the temperature profile in C.3, subject to the following conditions.

- a) Precast concrete slabs should be made of normal weight concrete and should not have any deliberately designed voids in the end 75 mm of their length.
- b) The void between the precast slab and the beam should be filled with grout.
- c) Precast floor slabs should have at least 75 mm of bearing on the angles.
- d) The steel angles should be of grade S355 steel, not less than 125 mm × 75 mm × 12 mm, fixed with the longer legs supporting the concrete slabs, and the vertical leg upwards, as shown in Figure C.1, Figure C.2 and Figure C.3.
- e) The connections at either end of the beam should either be contained wholly within the depth of the floor slab or else fire protected to the same degree as the supporting member.
- f) The moments due to the loads transmitted via the slab at the fire limit state, should not exceed the transverse moment capacity of the angles at the required period of fire resistance (M_{cf}) given by:

$$M_{cf} = 1.2 p_y Z k_R$$

where

- p_y is the design strength of steel;
 - Z is the elastic modulus of angle leg, equal to $t^2/6$ per unit length;
 - t is the thickness of angle leg;
 - k_R is the strength retention factor from Table 1 for 1.5 % strain, for the temperature of the angle at the fire limit state.
- g) The angles may be welded or bolted to the beam. In addition to resisting the applied vertical loads at the fire limit state, the connection of the angles to the beam should be capable of transmitting the longitudinal shear force necessary to develop the required axial forces in the angles at the point of maximum moment. Any weld below the angle should be ignored. In these calculations the strengths of welds and bolts should be taken as 80 % of the relevant design strength at elevated temperature derived using the appropriate strength retention factor from Table 1 for 0.5 % strain.

C.2 Calculation method

In the calculations, a constant strain across the section as given in 6.3 should be assumed. The deflection may be ignored. The following procedure may be used.

- a) Determine the temperature distribution across the section, at the fire limit state. For beams with shelf angles the temperature distribution may be assumed to be as given in C.3.
- b) Divide the section into an appropriate number of blocks of constant width.
- c) Calculate the elevated temperature load capacity of each block, assuming it to be entirely in tension or entirely in compression, as appropriate.
- d) Determine the position of the horizontal plastic neutral axis of the section, which divides the total cross-section into tension and compression zones subject to equal and opposite forces.
- e) Take the moment capacity of the section at the fire limit state as the algebraic sum of the positive or negative moment contribution of each block, about any convenient horizontal axis.

C.3 Temperature profile

C.3.1 General

The dimensions and temperature blocks shown in Figure C.1 should be used to determine the moment capacity of a beam with shelf angles.

The temperature for each block should be taken at its mid-height position.

C.3.2 Exposed steelwork

The temperature θ_1 of the lower flange (block 1) should be determined from 8.4.3. The temperatures of blocks 2 and 3, and of the angle root (θ_2 , θ_3 and θ_R respectively) should be determined from Table C.1, in which D_e/B_e is the aspect ratio (Figure C.1):

where

D_e is the overall exposed depth of the steel section; and

B_e is the width of the exposed bottom flange.

C.3.3 Embedded steelwork

The full design strength of steel is maintained at temperatures below 300 °C. Thus the temperatures of blocks 4, 5 and 6 should be calculated using:


$$\theta_x = \theta_R - Gx \quad \text{but } \theta_x \geq 300 \text{ }^\circ\text{C}$$

where

θ_x is the temperature (in °C) at location x ;

x is the distance (in mm) from angle root, measured as shown in Figure C.2;

G is the temperature gradient (in °C/mm), given in Table C.2.



Key

1 Concrete slab


Figure C.1 — Temperature blocks for beams with shelf angles

Table C.1 — Block temperature

| Aspect ratio | Block temperature for a fire resistance period of: | | | | | | | | |
|------------------------|--|------------|------------|-----------------|------------|------------|-----------------|------------|------------|
| | 30 min | | | 60 min | | | 90 min | | |
| | θ_2 | θ_3 | θ_R | θ_2 | θ_3 | θ_R | θ_2 | θ_3 | θ_R |
| | °C | °C | °C | °C | °C | °C | °C | °C | °C |
| $D_e/B \leq 0.6$ | $\theta_1 - 140$ | 475 | 350 | $\theta_1 - 90$ | 725 | 600 | $\theta_1 - 60$ | 900 | 775 |
| $0.6 < D_e/B \leq 0.8$ | $\theta_1 - 90$ | 510 | 385 | $\theta_1 - 60$ | 745 | 620 | $\theta_1 - 30$ | 910 | 785 |
| $0.8 < D_e/B \leq 1.1$ | $\theta_1 - 45$ | 550 | 425 | $\theta_1 - 30$ | 765 | 640 | θ_1 | 925 | 800 |
| $1.1 < D_e/B \leq 1.5$ | $\theta_1 - 25$ | 550 | 425 | θ_1 | 765 | 640 | θ_1 | 925 | 800 |
| $1.5 < D_e/B$ | θ_1 | 550 | 425 | θ_1 | 765 | 640 | θ_1 | 925 | 800 |

Table C.2 — Temperature gradient

| Period of fire resistance min | G °C/mm |
|----------------------------------|--------------|
| 30 | 2.3 |
| 60 | 3.8 |
| 90 | 4.3 |




NOTE 1 The definitions of blocks 4, 5 and 6 vary depending on whether or not the 300 °C line lies within the depth of the shelf angles. See Figure C.3.

NOTE 2 The location of x_{300} is given by the following expression:

$$x_{300} = (\theta_R - 300)/G$$

Figure C.2 — Definition of dimension x



Bibliography

Standards publications

BS 15:1961, *Specification for mild steel for general structural purposes.*

BS 5400-5:1979, *Steel, concrete and composite bridges — Part 5: Code of practice for design of composite bridges.*

BS 5950-1:2000, *Structural use of steelwork in building — Part 1: Code of practice for design — Rolled and welded sections.*

Other publications

[1] MORRIS, W.A., READ, R.E.H. and COOKE, G.M.E. *Guidelines for the construction of fire resisting structural elements.* Building Research Establishment. The Stationery Office, 1988.

[2] ASSOCIATION OF SPECIALIST FIRE PROTECTION. *Fire protection for structural steel in buildings (3rd edition – revised).* The Steel Construction Institute and ASFP.

[3] BUILDING RESEARCH ESTABLISHMENT. BRE Digest 317. *Fire resistant steel structures: Free standing blockwork-filled columns and stanchions.* The Stationery Office, December 1986.

[4] NEWMAN, G.M. *Fire and steel construction: The behaviour of steel portal frames in boundary conditions.* Steel Construction Institute, 1990.

[5] NEWMAN, G.M and SIMMS, W.I. *Technical report: The fire resistance of concrete filled tubes to Eurocode 4.* The Steel Construction Institute P259. Ascot, 2001.

[6] TWILT, L, HASS, R, KLINGSCH W., EDWARDS, M. and DUTTA D., *Design guide for structural hollow section columns exposed to fire.* CIDECT, 1994.

[7] BOND, G.V.L. *Fire and steel construction: Water cooled hollow columns.* Steel Construction Institute, 1975.

[8] LAW, M. and O'BRIEN, T. *Fire and steel construction: Fire safety of bare external structural steel.* Steel Construction Institute, 1981.

[9] CONSTRUCTION INDUSTRY RESEARCH AND INFORMATION ASSOCIATION. *Fire resistance of composite slabs with steel decking.* CIRIA special publication 42. London, 1986.

[10] NEWMAN, G.M. *Fire resistance of composite floors with steel decking.* Steel Construction Institute, 1989.

[11] COOKE, G.M.E. *Thermal bowing in fire and how it affects building design.* Building Research Establishment Information Paper 21/88. The Stationery Office, December 1988.

[12] LAWSON, R.M. *Building design using cold formed steel sections: Fire protection.* Steel Construction Institute, 1993.

[13] KIRBY, B.R., LAPWOOD, D.G. and THOMSON, G. *The reinstatement of fire damaged steel and iron framed structures.* British Steel, Swinden Laboratories, 1986.

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001. Fax: +44 (0)20 8996 7001. Email: orders@bsi-global.com. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: info@bsi-global.com.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001. Email: membership@bsi-global.com.

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager. Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553. Email: copyright@bsi-global.com.