

CONFIRMED
DECEMBER 2007

Operating tables —

Part 1: Specification for mobile general operating tables

UDC 615.478.62

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Health Care Standards Committee (HCC/-) to Technical Committee HCC/33, upon which the following bodies were represented:

Association of Anaesthetists of Great Britain and Ireland
 Association of Clinical Pathologists
 British Medical Association
 British Surgical Trades Association Incorporated
 Castor Manufacturers' (UK) Association
 Department of Health and Social Security
 Department of the Environment (Property Services Agency)
 Malaysian Rubber Producers' Research Association
 National Association of Theatre Nurses
 Royal College of Midwives
 Royal College of Nursing and National Council for Nurses of the United Kingdom
 Royal College of Surgeons of England

This British Standard, having been prepared under the direction of the Health Care Standards Committee, was published under the authority of the Board of BSI and comes into effect on 30 November 1987

© BSI 11-1999

The following BSI references relate to the work on this standard:
 Committee reference HCC/33
 Draft for comment 80/62157 DC

ISBN 0 580 15902 7

Amendments issued since publication

Amd. No.	Date of issue	Comments

Contents

	Page
Committees responsible	Inside front cover
Foreword	ii
<hr/>	
1 Scope	1
2 Dimensions and height	1
3 General requirements	1
4 Table side bars	2
5 Dimensions of side bar accessory clamps	2
6 Radiographic requirements	2
7 Finishes of exposed surfaces of table	2
8 Mattress	2
9 Marking	3
10 Information to be supplied by the manufacturer	3
<hr/>	
Appendix A Recommendations for design of mobile general operating tables	4
Appendix B Recommendations for radio-translucency of the table top	4
<hr/>	
Figure 1 — Typical mobile general operating table	5
Figure 2 — Some table top positions	6
<hr/>	
Table 1 — Tests and requirements for paint and plastics coating finishes	3
<hr/>	
Publications referred to	Inside back cover
<hr/>	

Foreword

This Part of BS 6859 has been prepared under the direction of the Health Care Standards Committee at the request of the Department of Health and Social Security.

BS 6859 is published in two Parts, Part 2 specifying requirements for fixed-pedestal general operating tables. Attention is drawn to BS 5724-2.22 which specifies requirements for safety of general operating tables. BS 2891 which specifies requirements for operating table covers and pads is currently being revised. When the revision is published, clause 8 of this Part of BS 6859 will be amended to refer to it.

Design recommendations for mobile general operating tables are given in Appendix A.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, pages 1 to 6, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

1 Scope

This Part of BS 6859 specifies requirements for mobile general operating tables with non-transferable tops of four or more sections. Mobile operating tables intended for use with specialist procedures and accessories to tables are outside the scope of this Part of BS 6859, except that dimensions for accessory clamps have been specified to ensure interchangeability of accessories between tables.

NOTE The titles of the publications referred to in this standard are listed on the inside back cover.

2 Dimensions and height

NOTE Figure 1 shows schematic representations of a typical mobile general operating table.

2.1 Table top

The length of the table top shall be not less than 1 850 mm, and the width, including the side bars, shall be not more than 620 mm.

2.2 Trunk section(s)

The length of the trunk section(s), i.e. excluding head and leg sections, shall be not less than 840 mm and the width of the trunk sections excluding side bars shall be not less than 470 mm.

2.3 Height

With the table top horizontal, the height of the table, excluding the mattress, shall be not less than 650 mm. The height of the table shall be adjustable upwards by not less than 200 mm.

2.4 Floor clearance

The minimum clearance between the floor and table base shall be 12 mm.

3 General requirements

NOTE 1 Except for movements of the leg section, all movements of the table should be controllable from or near the usual head end of the table.

NOTE 2 When assessing compliance with 3.1 and 3.2, the table should be lowered by an operator experienced in the use of operating tables.

3.1 Trendelenburg position [see Figure 2(a)]

It shall be possible to lower the table top to a position where the angle between the head end and the horizontal is at least 35° but it shall not be possible to lower the table top so that the angle exceeds 45°. The time taken to lower the table top to an angle of 35° from the horizontal shall not exceed 8 s from engagement of the lowering mechanism.

3.2 Reverse Trendelenburg position

[see Figure 2(b)]

It shall be possible to lower the table top to a position where the angle between the foot end and the horizontal is at least 35° but it shall not be possible to lower the table top so that the angle exceeds 45°. The time taken to lower the table top to an angle of 35° from the horizontal shall not exceed 8 s from engagement of the lowering mechanism.

3.3 Lateral tilt [see Figure 2(c)]

It shall be possible to tilt the table top laterally to either side to a position where the angle between the table top and the horizontal is at least 15° but does not exceed 20°.

3.4 Break-back point [see Figure 2(d) and Figure 2(e)]

At the break-back point, the table top shall be capable of flexion to 130° in any position where all sections are above the horizontal. The table top shall be capable of extension to an angle of not less than 220° between the upper surfaces when all sections are below the horizontal.

3.5 Chair or sitting position

It shall be possible to adjust the sections of the table top to form a chair or sitting position.

3.6 Rotation of table top [see Figure 1(c)]

If the table top can be rotated in the horizontal plane with respect to the base, a mechanism shall be provided to lock it in any position.

3.7 Mobility

The table shall move in a forward or backward direction without lateral drift, and it shall be possible to steer the table without lateral drift.

It shall be possible to immobilize the table by means of a single control.

3.8 Head section

The head section shall be capable of adjustment through any angle between $45 \pm 1^\circ$ downwards and 10° upwards. A quick-release mechanism shall be fitted incorporating a self-locking device and capable of overriding the adjustment control.

3.9 Single leg section

The leg section on tables with a single leg section shall be adjustable downwards through a minimum angle of 100°.

3.10 Divided leg section

The two leg sections on tables with a divided leg section shall be capable of rotation outwards in a horizontal plane to subtend an angle of not less than 100° and each shall also be independently adjustable downwards through a minimum angle of 100°.

3.11 Detachable sections

3.11.1 In the case of tables with a single leg section, if both head and leg sections are detachable, they shall be interchangeable.

3.11.2 Detachable sections shall not be removable without the release of a locating or locking device.

4 Table side bars

4.1 Materials

Side bars shall be manufactured either from stainless steel of grade 304S15 or 431S29 as specified in BS 970-1 or from a material of equivalent loadbearing capacity, wear resistance and corrosion resistance.

4.2 Dimensions

The cross section of side bars shall be $31.5^{+0.25}_{-0.5}$ mm × 6.2 ± 0.15 mm.

4.3 Distance of bar from side of table top

The gap between side bars and the side of the table top shall be not less than 10 mm.

5 Dimensions of side bar accessory clamps

5.1 Accessory clamp sockets

5.1.1 Side bar socket. The dimensions of the socket shall be $32.5^{+0.5}_{-0}$ mm × $7.0^{+0}_{-0.5}$ mm.

5.1.2 Circular accessory socket. The socket shall be a circle of diameter $16.5^{+0}_{-0.5}$ mm.

5.1.3 Rectangular accessory socket. The dimensions of the socket shall be $32.5^{+0.5}_{-0}$ mm × $7.0^{+0}_{-0.5}$ mm.

5.1.4 Square accessory socket. The socket shall be a square with edge length $16.5^{+0.5}_{-0}$ mm.

5.2 Accessory rods

5.2.1 Circular section. The diameter of the cross section of the rod shall be $16.0^{+0}_{-0.5}$ mm.

5.2.2 Rectangular section. The dimensions of the cross section of the rod shall be $31.5^{+0.25}_{-0.5}$ mm × 6.2 ± 0.15 mm.

5.2.3 Square section. The edge length of the cross section of the rod shall be $16.0^{+0}_{-0.5}$ mm.

6 Radiographic requirements

NOTE The design of the operating table should allow the use of a mobile X-ray image intensifier.

6.1 Space shall be provided immediately below the table top to accommodate an X-ray film cassette with dimensions of 383.5 mm × 459.5 mm, so that it can be placed under any part of the patient.

6.2 It shall be possible to load an X-ray film cassette from both the head and foot ends of the table.

6.3 A device shall be provided to enable the X-ray film cassette to be placed in position.

7 Finishes of exposed surfaces of table

7.1 Stainless steel

The stainless steel, including welds, shall be polished in accordance with finishes 3A, 3B, 4 or 8 of Table 1 of BS 1449-2:1983.

7.2 Coated steel

Applied coatings such as stoving paint or plastics coating shall comply with the requirements given in Table 1 when tested by the appropriate method.

7.3 Chromium and nickel plated steel

Chromium and nickel plated steel components shall be plated in accordance with service condition number 3 of BS 1224.

7.4 Aluminium alloy

Aluminium alloy components, if anodized, shall comply with grade AA5 of BS 1615, or shall be straight grained to a minimum of 36 grit aluminium oxide, satin finished or bright polished.

7.5 Other materials

If exposed surfaces of the table are made from other materials, they shall have a corrosion resistance equal to or better than the materials referred to in 7.1 to 7.4.

8 Mattress

The table top shall be covered by a removable, washable, antistatic mattress segmented or hinged to conform to the size and different configurations of the table top. The mattress shall be attached to the table top and shall not impede adjustments of the table top or the fitting of accessories.

9 Marking

The operating table shall be marked with the following:

- a) the name or trademark of the manufacturer;
- b) the number and date of this British Standard, i.e. BS 6859-1:1987¹⁾.

10 Information to be supplied by the manufacturer

The manufacturer shall provide a statement of the attenuation of the table top.

NOTE Recommendations for radio-translucency of the table top are given in Appendix B.

Table 1 — Tests and requirements for paint and plastics coating finishes

Test	Method	Requirements
1. Bend test	BS 3900-E1 using the type 2 apparatus and a 6 mm mandrel and burnished steel	No cracks or loss of adhesion when examined with normal corrected vision
2. Scratch resistance	BS 3900-E2. Loaded with 2 000 g	No bare metal visible
3. Impact resistance	BS 3900-E3. Indent to 3 mm	No loss of adhesion
4. Cupping test	BS 3900-E4. Indent to 3 mm on paint and reverse side	No loss of adhesion or cracks when examined with normal corrected vision

¹⁾ Marking BS 6859-1:1987 on or in relation to a product represents a manufacturer's declaration of conformity, i.e. a claim by or on behalf of the manufacturer that the product meets the requirements of the standard. The accuracy of the claim is therefore solely the responsibility of the person making the claim. Such a declaration is not to be confused with third party certification of conformity, which may also be desirable.

Appendix A Recommendations for design of mobile general operating tables

A.1 Table base

The base of the table should be designed to minimize obstruction to the feet and legs of the theatre staff.

A.2 Floor loading

Operating tables can impose heavy loads on floors, particularly when used to transport patients within the operating department.

To minimize wear to the floor, the wheels and/or castors should be of such numbers, dimensions and materials that will result in low static and dynamic pressure on floor surfaces commensurate with ease of mobility. Suspension arrangements of wheels and/or castors should ensure that all wheels and/or castors make full contact with floor surfaces whilst the table is being moved.


A.3 Brake

The release of the braking mechanism should not result in a significant uncontrolled drop in the height of the table top.

Appendix B Recommendations for radio-translucency of the table top

The table top, excluding the mattress, should have an attenuation equivalent to no greater than 1 mm thickness of aluminium, determined from measurements of air Kerma under narrow beam conditions.

The measurements should be made with X-radiation from an X-ray source assembly operated at an X-ray tube voltage of 100 kV with a total filtration of 2.5 mm aluminium. The percentage ripple of the X-ray tube voltage should be less than 10 %.






Figure 2 — Some table top positions

Publications referred to

- BS 970, *Specification for wrought steels for mechanical and allied engineering purposes.*
- BS 970-1, *General inspection and testing procedures and specific requirements for carbon, carbon manganese, alloy and stainless steels.*
- BS 1224, *Specification for electroplated coatings of nickel and chromium.*
- BS 1449, *Steel plate, sheet and strip.*
- BS 1449-2, *Specification for stainless and heat-resisting steel plate, sheet and strip.*
- BS 1615, *Specification for anodic oxidation coatings on aluminium.*
- BS 2891, *Specification for operating table covers or pads of cellular rubber²⁾.*
- BS 3900, *Methods of test for paints.*
- BS 3900:Group E, *Mechanical tests on paint films.*
- BS 3900-E1, *Bend test (cylindrical mandrel).*
- BS 3900-E2, *Scratch test.*
- BS 3900-E3, *Impact (falling weight) resistance.*
- BS 3900-E4, *Cupping test.*
- BS 5724, *Medical electrical equipment²⁾.*
- BS 5724-2.22, *Specification for general operating tables.*
- BS 6859, *Operating tables²⁾.*
- BS 6859-2, *Specification for fixed-pedestal general operating tables.*

²⁾ Referred to in the foreword only.

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: 020 8996 7002. Fax: 020 8996 7001.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.