



BSI Standards Publication

**Plastics piping systems for
soil and waste discharge
(low and high temperature)
within the building structure
— Thermoplastics —
Recommended practice for
installation**

National foreword

This Published Document is the UK implementation of CEN/TR 13801:2014. It supersedes DD ENV 13801:2001 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PRI/88/1, Plastics piping for non-pressure applications.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014. Published by BSI Standards Limited 2014

ISBN 978 0 580 82484 5

ICS 83.140.30; 91.140.80

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 April 2014.

Amendments issued since publication

Date	Text affected
------	---------------

English Version

Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Thermoplastics - Recommended practice for installation

Systèmes de canalisations en plastique pour l'évacuation des eaux-vannes et des eaux usées (à basse et à haute température) à l'intérieur de la structure des bâtiments - Thermoplastiques - Pratiques recommandées pour la pose

Kunststoff-Rohrleitungssysteme zum Ableiten von Abwasser (niedriger und hoher Temperatur) innerhalb der Gebäudestruktur - Thermoplastische Werkstoffe - Empfehlungen für die Verlegung

This Technical Report was approved by CEN on 1 October 2013. It has been drawn up by the Technical Committee CEN/TC 155.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 General terminology, terms, definitions, symbols and abbreviations	7
3.1 General terminology.....	7
3.2 Terms and definitions	8
3.3 Symbols	8
3.4 Abbreviations	10
4 Design limits of the system	10
5 Storage, transport and handling	11
5.1 General.....	11
5.2 Transport	11
5.3 Storage.....	12
5.4 Handling on site	13
6 Installation	14
6.1 General recommendations for installation	14
6.1.1 Cutting of pipe.....	14
6.1.2 Chamfering of pipe	15
6.1.3 Fabricating.....	15
6.2 Recommendations for above-ground installation.....	15
6.2.1 General.....	15
6.2.2 Installation of PE and PP pipeworks with non-removable rigid joints	15
6.2.3 Installation with joint design taking account of thermal movement	16
6.2.4 Supports	20
6.3 Recommendations for installation in buried conditions	26
6.3.1 General.....	26
6.3.2 Installation for BD application.....	26
6.3.3 Differential movement - Flexible joints.....	27
6.4 Jointing procedure	28
6.4.1 Jointing with adhesives	28
6.4.2 Jointing with ring seal joints	30
6.4.3 Jointing with butt fusion	32
6.4.4 Jointing with electrofusion couplings.....	34
6.4.5 Jointing with flanges and backing rings	35
6.4.6 Jointing with compression joints.....	35
7 Special precautions	36
7.1 Concreting of thermoplastics systems within the building structure.....	36
7.1.1 General.....	36
7.1.2 Inserting systems in concrete setting at ambient temperature	38
7.1.3 Inserting systems into post-heated concrete	42
7.2 Foaming of thermoplastics systems	42
7.3 Prevention of additional stresses in pipework.....	42
8 Jointing to other materials or other constructions	43
8.1 General.....	43
8.2 Adhesive joints	43
8.3 Ring seal joints	43

8.4	Jointing to non-thermoplastics components	43
8.5	Adaptors	45
9	Fire resistance of pipework	46
10	Testing and inspection of installations	46
10.1	Testing	46
10.2	General inspection	46
11	Maintenance and cleaning of installations	46
11.1	General	46
11.2	Cleaning and descaling techniques	47
12	Chemical resistance of thermoplastics systems	47
13	Recycling of thermoplastics components of the system.....	47
	Bibliography.....	48

Foreword

This document (CEN/TR 13801:2014) has been prepared by Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems", the secretariat of which is held by NEN.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes ENV 13801:2000.

The revision mainly consists in changing the status from ENV to CEN/TR and the following minor changes:

- a) other materials than PP homopolymer mentioned in 5.1;
- b) update of symbols in Clause 3;
- c) mention of possible local regulations on fire and acoustics in Clause 4;
- d) reference of adhesives standards in 6.4.

This Technical Report is only a guidance document to be used mainly as a basis for preparing more specific manufacturer's instructions. It is associated with standards for piping systems covering a particular thermoplastic material for a specified application. There are a number of such standards.

It is based on the results of the work undertaken in ISO/TC 138 "Plastics pipes, fittings and valves for the transport of fluids", which is a Technical Committee of the International Organization for Standardization (ISO).

This Technical Report is consistent with general standards on functional requirements and on recommended practice for installation.

Introduction

This Technical Report covers the recommended practice for installation of the thermoplastics piping systems for soil and waste discharge. The most important recommendations are expressed by the use of the imperative. These are strongly recommended.

Guidance for installation is presented, e.g. by the use of “may” or “is recommended”, for consideration as a matter of judgement in each case.

1 Scope

This Technical Report gives the recommended practice for installation of thermoplastics piping systems in the field of soil and waste discharge (low and high temperature) inside buildings (marked with “B”) and of soil and waste discharge systems for both inside buildings and buried in ground within the building structure (marked with “BD”).

This Technical Report provides material dependent installation techniques but it is important that the general installation practice as given in the relevant parts of EN 12056 for B application are taken into account in manufacturer's instructions, subject to any applicable national and/or local regulations.

This Technical Report is applicable to thermoplastics pipes and fittings as specified in the associated standards EN 1329-1 [1] (PVC-U), EN 1451-1 [2] (PP), EN 1453-1 [3] (PVC-U with structured-wall pipes), EN 1455-1 [4] (ABS), EN 1519-1 [5] (PE), EN 1565-1 [6] (SAN+PVC) and EN 1566-1 [7] (PVC-C), their joints and to joints with components of other plastics and non-plastics materials intended to be used for the following purposes:

- a) soil and waste discharge pipework for the conveyance of domestic waste waters (low and high temperature);

NOTE 1 See Clause 4 for waste discharge temperature limits.

- b) ventilating pipework associated with a);
- c) rainwater pipework within the building structure (see Figure 1, key 16).

It is applicable to pipes and fittings, marked with “B”, which are intended to be used above ground only, and to pipes and fittings, marked “BD”, which are intended to be used above and buried in ground within the building structure.

NOTE 2 Only those components as specified in the relevant associated standard with nominal outside diameters equal to or greater than 75 mm (marked with “BD”) are intended for use buried in ground within the building structure. The term “within building structure” covers all gravity discharge pipework within a building, including the elements installed below the slab and buried in the ground.

If specified in the relevant associated standard, this Technical Report also covers soil and waste discharge pipework fixed externally onto the building (see Figure 1, key 17). It is not applicable to pipework that passes under the building without any connection from the discharge system.

NOTE 3 According to the associated standards, for external above ground soil and waste discharge, additional requirements depending on the climate, will be agreed between the manufacturer and the user.

According to the associated standards, components conforming to other standards on plastic piping systems may be used with pipes and fittings conforming to a given associated standard, if they conform to the requirements for joint dimensions and functional requirements of the given associated standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12056-1:2000, *Gravity drainage systems inside buildings - Part 1: General and performance requirements*

EN 12056-2:2000, *Gravity drainage systems inside buildings - Part 2: Sanitary pipework, layout and calculation*

EN 12056-3:2000, *Gravity drainage systems inside buildings - Part 3: Roof drainage, layout and calculation*

EN 12056-5, *Gravity drainage systems inside buildings - Part 5: Installation and testing, instructions for operation, maintenance and use*


3 General terminology, terms, definitions, symbols and abbreviations

3.1 General terminology

For the general terminology, refer to EN 12056-1:2000, EN 12056-2:2000 or EN 12056-3:2000, where applicable, and see Figure 1 (the figure is schematic only).

Local and/or national regulations may require separate drainpipe systems for foul and rainwater.

Dimensions in metres



Key

1	sewer	7	rainwater downpipe	13	floor gully/trap
2	manhole	8	branch discharge pipe	14	gutter
3	inspection chamber	9	wash basin	15	pipework from other buildings
4	drain	10	sink	16	internal rainwater downpipe
5	discharge stack	11	water closet	17	external discharge stack
6	stack vent	12	bath		

NOTE Key 1, 2, 7 and 14 are not covered by this Technical Report. Key 3 is covered if the distance to the building wall is smaller than or equal to 1 m.

Figure 1 — Terminology for a soil and waste discharge system

3.2 Terms and definitions

For the purposes of this document, the terms and definitions given in the relevant associated standard and the following apply.

3.2.1

associated standard

standard which specifies all requirements applicable to pipes, fittings and joints made of a particular material to be installed according to the recommendations of this Technical Report

3.2.2

ring seal socket length

type S, type N or M, or type L

length of a ring seal socket, which is designated as short (type S), normal or medium (type N or type M), or long (type L) in the relevant associated standards

Note 1 to entry: In EN 1329-1, EN 1453-1 and in ISO 8283-4 [13], type N sockets are designated by type M (medium).

3.2.3

flexible leg

L_1 and L_2

free length between two fixed points either sides of a bend of a solvent cement system

Note 1 to entry: The two lengths are designated L_1 and L_2 .

3.2.4

bedding zone

c

thickness of the compacted zone below the pipe when buried within the building structure

3.2.5

expansion gap

E , E_1 , E_2

distance left during installation between the bottom of a socket and the spigot of the inserted component, allowing expansion of the system

3.3 Symbols

For the purposes of this document, the following symbols apply.

3.3.1 Symbols for installation

c bedding zone (see 6.3.2)

D_{\max} recommended maximum distance between support centres in above-ground installation (see 6.2.4.2)

$L_{c,\max}$ maximum recommended distance between anchored brackets in concreted-in installation (see 7.1.2.7)

L_F free length between fixed points in above-ground installation (see 6.2.3.1)

Y effective sealing length (see 6.2.3.2)

3.3.2 Symbol for sockets for solvent cement jointing

The design symbol (square-shaped) given in Figure 2 signifies a rigid, non-removable connection of two pipes and/or fittings made by means of a solvent cement socket.



Figure 2 — Design symbol for solvent cement joint

3.3.3 Symbols for sockets for ring seal jointing

The design symbols (cup-shaped) given in Figure 3 signify a non-rigid, removable connection of two pipes and/or fittings made by means of a rubber seal in a type S, type N, type M or type L socket, respectively.




Figure 3 — Design symbols for ring seal joint

3.3.4 Symbol for butt-fusion joint

The design symbol given in Figure 4 signifies a rigid, non-removable connection of two pipes and or/fittings made after fusion by means of a heating plate.




Figure 4 — Design symbol for butt-fusion joint

3.3.5 Symbol for electrofusion coupling

The design symbol given in Figure 5 signifies a rigid, non-removable connection of two pipes and/or fittings made by means of integral electrically powered fusion.




Figure 5 — Design symbol for electrofusion coupling

3.3.6 Symbol for flange and backing ring joint

The design symbol given in Figure 6 signifies a rigid connection of two pipes and/or fittings made by means of bolts and nuts.



Figure 6 — Design symbol for flange and backing ring joint

3.3.7 Symbol for compression joint

The design symbol given in Figure 7 signifies a rigid connection of two pipes and/or fittings made by means of thread, rubber ring and screw.





Figure 7 — Design symbol for compression joint

3.3.8 Symbols for brackets

The design symbols for brackets given in Figure 8 signify an anchor bracket or a guide bracket, respectively.



a) Anchor bracket (for fixed point)



b) Guide bracket (for free movement of pipe)

Figure 8 — Design symbols for brackets

3.4 Abbreviations

For the thermoplastics materials, the following abbreviations apply:

ABS	acrylonitrile-butadiene-styrene
PE	polyethylene
PP	polypropylene
PP-H	polypropylene homopolymer
PVC-C	chlorinated poly(vinyl chloride)
PVC-U	unplasticised poly(vinyl chloride)
SAN+PVC	styrene copolymer blend

4 Design limits of the system

Discharge systems of thermoplastics are primarily designed for intermittent waste discharges from domestic origin including from washing and dishwashing machines. Discharge systems of PE, PP, and PVC-C are also designed for discharges from public laundries, launderettes or other installations where long periods of high

temperature discharge occur. For the design of systems for other discharges than domestic waste, see Clause 12 and manufacturer's recommendations.

Apply the requirements for the calculation of the flow capacity of plumbing installations, as specified in relevant European Standards, subject to any applicable national and/or local regulations.

Design of the systems should take into account applicable national regulations with regard to reaction to fire and fire resistance.

Design of the systems should take into account applicable national regulations on acoustic of the building, including provision on mounting and fixing, acoustic properties of the products and noise protection.

NOTE Among European Standards, EN 12056-2 and EN 12056-3 are primarily applicable for flow capacity calculation.

5 Storage, transport and handling

5.1 General

Attention is drawn to any relevant local and/or national safety regulations.

Avoid damage to the surfaces and ends of pipe and fittings.

Loading and handling of components made of PP-homopolymers (marked PP-H) for which performance impact testing is carried out at 23 °C (see EN 1451-1) is not recommended at ambient temperatures lower than +5 °C. For components made of other materials (e.g. PVC, PP-copolymers), follow the manufacturer's instructions regarding installation at low temperature.

Support pipes with sockets and with pre-assembled fittings, in such a way that they are protected from damage and that the ends are free from loading, e.g. by alternating the socket and non-socket ends in given or adjacent layers.

5.2 Transport

Load pipes and fittings in such a way that no damage occurs during transport (see Figure 9).

Stack the pipes at a maximum stacking height of 1,5 m unless otherwise specified in the manufacturer's instructions, for example when transporting caged bundles.




Figure 9 — Loading for transport

5.3 Storage

Do not carelessly unload pipes and fittings (see Figure 10).

Provide a storage area free from substances harmful to the relevant thermoplastics (see Clause 12), comprising smooth and level ground or a flat timber base to avoid the risk of bent or damaged pipes. Where PE pipes are supplied in coils, store them either stacked flat one on top of the other, or (chiefly for sizes greater than DN 90) vertically in purpose-built racks or cradles.

Avoid storage in direct sunlight over a period longer than one year. Where long-term storage and/or strong sunlight is expected, screening from the direct rays of the sun is recommended, except for black-coloured PE components.

Recommended maximum stacking height is 1,5 m [see Figure 10, detail a)] unless otherwise stated in the manufacturer's instructions, for example when stacking caged bundles [see Figure 10, detail b)].

Dimensions in metres




Figure 10 — Storage on site

5.4 Handling on site

To avoid risk of damage, carry, not drag, pipes and fittings to the work place (see Figure 11).

NOTE Careless handling might lead to damaged materials and faulty installations.




Figure 11 — Handling on site

6 Installation

6.1 General recommendations for installation

6.1.1 Cutting of pipe

Cut pipe square to length with a fine tooth saw, or special purpose equipment (see Figure 12). Remove all burrs at the inside and outside edges of the cut surfaces.

Prior to fusion jointing, if necessary, e.g. if the pipe ends were slightly tapered during their production cut 10 mm to 15 mm from the factory-made pipes.




Figure 12 — Cutting of pipe

To obtain a square guide line, a piece of paper may be wrapped around the pipe and the edges brought together (see Figure 13).




Figure 13 — Optional method for square cutting

6.1.2 Chamfering of pipe

6.1.2.1 Do not chamfer components made of PE or PP which are designed for butt-fusion jointing (see 6.4.3.2.2).

6.1.2.2 For components to be jointed by other techniques, the pipes may be chamfered if necessary according to the manufacturer's instructions. Chamfer the pipes with a medium file or special purpose equipment. Provide approximately matching chamfers on the pipe and the socket; with an angle α between 15° and 45° . Keep a remaining wall thickness of at least $e/3$ (see Figure 14).




Figure 14 — Chamfering of pipe end

6.1.3 Fabricating

Do not fabricate on site thermoplastics components by any other means (fusion, socket forming, bending, etc.) than described in 6.1.1 and 6.1.2.

6.2 Recommendations for above-ground installation

6.2.1 General


When thermoplastics are subject to changes in temperature, thermal movement or forces occur. The actual forces or movement are a function of variation in temperature and cannot be calculated directly from the coefficient of thermal expansion formula and the water temperature because hot discharges are intermittent, resulting in a difference in temperature between the internal and the external surface of the pipe due to the low coefficient of conductivity through the wall.

6.2.2 Installation of PE and PP pipeworks with non-removable rigid joints

PE and PP pipeworks with non-removable rigid joints (e.g. PE or PP butt-fused joints or joints with electrofusion couplings, see 6.4.3 or 6.4.4 respectively) may be installed preventing any thermal movement. In this case the pipework components and the supports are intended to withstand the forces which occur due to changes in temperature and result in stress in the pipework.

Fix all pipes rigidly to the building structure and fasten each branch to the building structure by anchor brackets (e.g. with an arrangement of fixed points as shown in Figure 15). This Figure is given for example and does not apply for support centres (see Table 3).

For fixed point design, refer to the Note in 6.2.4.1, and carefully follow the manufacturer's instructions.



Key

1 anchor bracket (also all other brackets)

Figure 15 — Typical arrangement of fixed points for PE and PP pipework with rigid joints

6.2.3 Installation with joint design taking account of thermal movement

6.2.3.1 Expansion gap and length between fixed points

In all the other cases which are not covered by 6.2.2, the thermal movement is not prevented and it is relieved by the joint design.

The effective maximum temperature has been used for designing the socket depth and the maximum recommended free length of pipe permitted by each joint, when the installation is operated at temperatures ranging between 0 °C and 30 °C.

NOTE 1 The coefficients of thermal expansion for thermoplastics are given in Table 1.

Table 1 — Coefficients of thermal expansion

Material	Coefficient of thermal expansion [°C] ⁻¹
ABS	8×10^{-5} to 9×10^{-5}
PE	17×10^{-5} to 20×10^{-5} ^a
PP	11×10^{-5} to 18×10^{-5}
PVC-C	6×10^{-5} to 8×10^{-5}
PVC-U	6×10^{-5} to 8×10^{-5}
PVC-U with structured-wall pipes	6×10^{-5} to 8×10^{-5}
SAN+PVC	6×10^{-5} to 8×10^{-5}
^a This is the conventional range of coefficients; other values may be used, with reference to manufacturer's instructions.	

In above-ground installations, such systems require fixed points (secured with anchor brackets or built into the building structure) and intermediate supports provided by guide brackets. Branches are always considered as fixed points.

Hence, when the length between fixed points, L_F , in above ground horizontal installation exceeds 1 m, use non-rigid joints for expansion: a relevant ring seal socket (type S, type N or M, or type L) as specified in the relevant associated standard may be suitable. Therefore, conform to Table 2 for the maximum recommended lengths, L_F , permitted by each type of expansion socket. During installation keep also an expansion gap, E , according to Table 2 at each socket bottom.

NOTE 2 For PE systems, the ring seal sockets type L have been specially designed to allow thermal movement; refer to ISO 8283-2 [12] for the selection of the appropriate design.


Table 2 — Recommended length between fixed points, and recommended expansion gap at each socket, for above ground horizontal installation

Material	Type S socket		Type N or M socket		Type L socket	
	L_F ^a	E	L_F ^a	E	L_F ^a	E
	m	mm	m	mm	M	mm
ABS	$1 \leq L_F \leq 4$ ^b	≥ 10	$1 \leq L_F \leq 4$	≥ 10	$1 \leq L_F \leq 8$	≥ 20
PE	(no type S for PE)		$1 \leq L_F \leq 4$ ^b	≥ 20	$1 \leq L_F \leq 8$	≥ 50
PP	(no type S for PP)		$1 \leq L_F \leq 4$	≥ 15 ^c	$1 \leq L_F \leq 8$	≥ 20
PVC-C	$1 \leq L_F \leq 4$ ^b	≥ 10	$1 \leq L_F \leq 4$	≥ 10	$1 \leq L_F \leq 8$	≥ 20
PVC-U	$1 \leq L_F \leq 4$ ^b	≥ 10	$1 \leq L_F \leq 4$	≥ 10	$1 \leq L_F \leq 8$	≥ 20
PVC-U with structured-wall pipes	$1 \leq L_F \leq 4$ ^b	≥ 10	$1 \leq L_F \leq 4$	≥ 10	$1 \leq L_F \leq 8$	≥ 20
SAN+PVC	(no type S for SAN+PVC)		$1 \leq L_F \leq 4$	≥ 10	$1 \leq L_F \leq 8$	≥ 20
NOTE These recommendations apply for ambient installation temperatures between 0 °C and + 30 °C.						
^a Where $L_F \leq 1$ m, then E is not specified.						
^b For nominal outside diameter $d_n \leq 50$ mm, reduce L_F to ≤ 2 m, and prefer type N or M sockets.						
^c Reduce E to ≥ 10 mm where $L_F \leq 2$ m.						

For expansion of soil and waste vertical pipes, install a ring seal joint at least at each storey height. Typical above-ground installations with solvent-cement and ring seal joints are given in Figure 16 and Figure 17 respectively. Both figures are given as examples and do not apply for support centres.

For expansion of rainwater vertical pipes, install a ring seal joint at least every second storey height.


Dimensions in millimetres



Key

- 1 socket type N or M

Figure 16 — Example of installation with solvent cement joints and expansion sockets



Key

- 1 socket type N or M
- 2 pipe of any diameter

Figure 17 — Example of installation with ring seal joints

6.2.3.2 Effective sealing length

When jointing spigots of pipes or fittings into ring seal sockets, including into expansion sockets combined with other jointing techniques, e.g. fusion or solvent-cement joints, take care to ensure that the cylindrical part of the spigot is sufficiently inserted in the seal in the socket. The recommended minimum effective sealing length, Y (see Figure 18), for such joint is 10 mm for $d_n \leq 50$ mm and $0,2d_n$ for $d_n > 50$ mm.



Figure 18 — Effective sealing length

6.2.4 Supports

6.2.4.1 Bearing capacity, fit and fixing of brackets

Brackets are made of metals or plastics.


As applicable, check the brackets for marking and/or associated information to confirm that the bracket is intended to carry the size and weight of the system components to be supported thereby.

For brackets to be used as fixed points [see detail a) of Figure 19], ensure that the bracket can grip the pipe or fitting firmly but not clamp it hard, taking account of the thickness of any coatings and/or sleeves involved.

NOTE For PE systems, if the ring seal socket type L has no special anchoring device such as factory-made collar, the construction of anchor bracket can be made using an electrofusion tape [see detail b) of Figure 19].

For brackets to be used as guide brackets (see Figure 20), ensure that the guide is smooth and allows the pipe to move linearly, taking account of the thickness of any coating and/or sleeves involved.

If any sleeves are to be used, locate them in position.



Key

1 electrofusion tape for fixed point constructions

Figure 19 — Typical anchor brackets



Key

- 1 sleeve of soft material

Figure 20 — Typical guide brackets

6.2.4.2 Distance between support centres

For simple installations, unless otherwise specified in the manufacturer's instructions, do not exceed the recommended value for D_{max} given in Table 3 as the distance between two following support centres, either fixed or guide centres.

When the design of brackets does not allow to sustain the distances of Table 3, then use shorter distances according to the manufacturer's instructions.

Continuous support may be used for horizontal pipes.

Table 3 — Recommended maximum distance, D_{max} , between support centres

Nominal outside diameter d_n mm	Distance between support centres	
	Horizontal pipework D_{max} m	Vertical pipework D_{max} m
32	0,5	1,2
40	0,5	1,2
50	0,5	1,5
63	0,8	1,5
75	0,8	2,0
80	0,8	2,0
82	0,8	2,0
90	0,9	2,0
100	1,0	2,0
110	1,1	2,0
125	1,25	2,0
140	1,4	2,0
160	1,6	2,0
180	1,7	2,0
200	1,7	2,0
250	2,0	3,0
315	3,0	3,0

For more demanding applications, see manufacturer's instructions.

Attention is drawn to specific requirements that may be needed for instance for solvent cement jointed systems presenting a bend. In such a case a flexible leg may be installed (see Figure 21) in which the total length $L_1 + L_2$ does not exceed the recommended value D_{max} of Table 2: $L_1 + L_2 \leq D_{max}$. It is recommended for each length L_1 or L_2 not to exceed the value given in Table 4.

Table 4 — Recommended maximum distance between support centres for bends of solvent cement jointed pipework systems

Nominal outside diameter d_n mm	Distance between support centres and bend L_1 or L_2 mm
≤ 40	≤ 200
> 0 and ≤ 50	≤ 250
> 50 and ≤ 75	≤ 375
> 75 and ≤ 110	≤ 550
> 110 and ≤ 125	≤ 625
> 125 and ≤ 160	≤ 800




Figure 21 — Flexible leg

6.2.4.3 Installation of brackets

6.2.4.3.1 General


Make fixed points at the pipe sockets or at the sockets of fittings (see Figure 22 and Figure 23).

NOTE For PE systems an electrofusion tape can be used, see Figure 24 as an example. If no electrofusion tape is available, two electrofusion couplings can be used instead.

Install for each pipe only one anchor bracket for a fixed point.

Install guide brackets in such a way that the distance between the centres of the brackets (support centres) never exceeds the maximum recommended distance, D_{max} , given in Table 3.


Dimensions in millimetres



Key

- 1 guide bracket for pipe length $\geq 1,5$ m
- 2 wide guide bracket for pipe length ≥ 2 m

Figure 22 — Typical above-ground installation with d_n 40 mm, 63 mm, 90 mm and 110 mm pipes and fittings




Key

L_F recommended length between fixed points (see Table 2)

1 ring seal socket type L or type N or type M, according to L_F value (see Table 2)

Figure 23 — Typical general sketch for above-ground installation



Key

- 1 anchor bracket
- 2 electrofusion tape

Figure 24 — Fixing with an electrofusion tape

6.2.4.3.2 Supports for jointing with double sockets

Always use an anchor bracket to fix the double socket.

For horizontal pipes arrange the sum of the expansion gaps, $E_1 + E_2$ (see Figure 25), to be equal to, or greater than, the value of E , as recommended in 6.2.3.1.

Keep the distance between support centres smaller than, or equal to D_{max} as recommended in Table 3.




Figure 25 — Expansion gaps with double sockets

6.3 Recommendations for installation in buried conditions

6.3.1 General

This subclause covers the application area BD for pipework buried in ground within the building structure, where the existence of hot water discharge temperature in addition to the external forces from surroundings is usual.

As specified in the relevant associated system standard, pipes and fittings used in the application area BD shall be those of nominal outside diameter equal to or greater than 75 mm which are designed for this application and marked accordingly.

Attention is drawn to local and/or national regulations concerning the foundation stability and the embedment construction, for example when the trench is built in close proximity to foundation. Subclauses 6.3.2 and 6.3.3 give examples of possible installations.

Adopt effective means to prevent the entry of gravel, rodents or gas. When designing the pipework, take due note of the proximity of underground gas services.

For the pipe length permitted for each expansion socket, L_F , do not exceed the values given in Table 5, and keep at the bottom of each expansion socket an expansion gap, E , as recommended in Table 5.

Table 5 — Recommended length between fixed points, and recommended expansion gap at each socket, for buried installation


Material	Type S socket		Type N or M socket		Type L socket	
	L_F m	E mm	L_F m	E mm	L_F M	E mm
ABS	≤ 6	≥ 10	≤ 9	≥ 10	a	a
PE	(no type S for PE)		≤ 6	≥ 15	≤ 15	≥ 40
PP	(no type S for PP)		≤ 9	≥ 10	a	a
PVC-C	≤ 6	≥ 10	≤ 9	≥ 10	a	a
PVC-U	≤ 6	≥ 10	≤ 9	≥ 10	a	a
SAN+PVC	(no type S for SAN+PVC)		≤ 9	≥ 10	a	a
a Type L sockets are used for BD application area with PE systems only.						

6.3.2 Installation for BD application

Install the pipework on a bedding zone keeping below the pipework a layer of gravel or compacted sand with a thickness, c , in the range of 100 mm up to 150 mm. It is recommended not to use heavy compaction equipment when back-filling the zone over the pipe, but to use light compaction equipment only (see zone X in Figure 26).

If presence of ground water may be expected, the use of gravel is preferable.

Attention is drawn to any relevant local and/or national regulations.



Key

- 1 zone X
- 2 gravel or compacted sand
- 3 native soil
- 4 bedding c , where $100 \text{ mm} \leq c \leq 150 \text{ mm}$

Figure 26 — Typical example for installation in sand or gravel

6.3.3 Differential movement - Flexible joints


Differential movement in a drain will occur when there is a change in either loading conditions or in the mode of support between successive pipes. Inspection chambers, manholes and other structures generally will be subject to settlement different from that of the pipes associated with them.

For PE systems, follow the manufacturer's instructions, and see Figure 27 as an example.

For systems made of other thermoplastics, arrange to accommodate subsequent differential settlement by means of flexible joints. To considerably reduce the risk of shear fracture provide a flexible joint located in or as close as practicable to the face of the structure. If a “rocker” pipe is used, it is recommended that the length between the two flexible joints (see Figure 28) does not exceed 0,6 m. Where considerable differential settlement is anticipated, several “rocker” pipes may be laid, and if necessary the gradient may be increased locally to reduce the likelihood of a back fall developing. In each case the maximum deviation at each joint should not exceed that recommended by the manufacturer.

Attention is drawn to any relevant local and/or national regulations.

Dimensions in millimetres




Key

- 1 inside of structure
- 2 sleeve of soft material

Figure 27 — Typical example for installation of PE system through a rigid structure

Dimensions in millimetres



Key

- 1 inside of structure
- 2 flexible joint
- 3 sleeve of soft material
- 4 rocker pipe

Figure 28 — Typical example for installation with flexible joints

NOTE A rubber or bitumen wrap at the concrete interface can provide stress relief from expansion, shear, and/or bending loads. This is particularly important for limiting radial shear and discontinuity stress in pressure pipe.

6.4 Jointing procedure


6.4.1 Jointing with adhesives

This technique is applicable to above-ground or below-ground installations with ABS, PVC-C, PVC-U, PVC-U with structured-wall pipes and SAN+PVC systems and provides rigidly jointed pipework.

Unless otherwise specified by the manufacturer, the adhesive should comply with EN 14680 [9]. Adhesives complying with EN 14814 [10] are deemed to be suitable for soil and waste applications.

Adhesive jointing is recommended to be made only at ambient temperatures ranging between $-5\text{ }^{\circ}\text{C}$ and $+30\text{ }^{\circ}\text{C}$, unless otherwise specified by the adhesive manufacturer.

Cut and chamfer pipe as required. Use only those adhesives which are specified by the manufacturer and in accordance with the relevant associated system standard. To avoid evaporation, use small cans or tubes; reseal immediately after use (see Figure 29). Attention is drawn to any relevant local and/or national health and safety regulations; seek manufacturer's advice.




Key

1 can with adhesive

Figure 29 — Sealing the can

If not specified by the manufacturer's instructions, the pipes may be prepared by abrading the mating surfaces with abrasive paper, then cleaning the surfaces with a cleaning fluid (see Figure 30).




Key

1 can with cleaning fluid

Figure 30 — Abrading and cleaning the pipe end

Do not thin or dilute adhesives, except for ABS systems where adhesive may be thinned with thinners recommended by the adhesive manufacturer only.

Apply an even coat of adhesive to the socket and the pipe. It is preferable to use axial strokes of the brush so as to avoid a build-up of adhesive on the pipe and in the socket, or the formation of large bubbles in the film layer (see Figure 31).



Key
1 can with adhesive

Figure 31 — Brushing with axial strokes

Immediately after applying adhesive, insert the pipe in the socket to its full depth without excessive twisting and ensure correct alignment (see Figure 32). Remove excess adhesive. Leave joint undisturbed for the time recommended by the pipe manufacturer.

It is recommended to clean the brushes immediately after use with a suitable thinner or cleaning fluid, and to get them dry before being used again.




Figure 32 — Full insertion of the spigot end

NOTE Attention is drawn to 8.2 for the adhesive jointing of components made of different plastics.

6.4.2 Jointing with ring seal joints

This technique is applicable to above-ground or below-ground installations of components made of all the materials covered by the associated system standards and provides non-rigidly jointed pipework.


When the sealing ring is not placed into the socket by the manufacturer, use only the sealing rings specified by the manufacturer. Clean the groove of the ring seal socket, wipe the sealing ring clean and dry. Insert the ring in the groove, ensuring that the ring is not distorted or misaligned.

Cut and chamfer the pipe as required. Clean the end of the pipe. Apply the lubricant to the spigot end and insert the spigot into the socket, keeping an expansion gap, E , equal to the recommended value given in Table 2 or Table 5, whichever is applicable. Use only the lubricant recommended by the manufacturer.

Inserting the spigot (ensuring that the expansion gap left is the relevant length) can be done by using one of the following techniques:

- inserting to the full depth, marking the pipe around the mouth of the socket [see Detail a) of Figure 33] and then withdrawing it by the relevant amount [see Detail b) of Figure 33];
- marking the spigot end to the relevant depth, as specified by the manufacturer, then inserting the spigot to the mark (see Figure 34).


Expansion units are ready for use according to the second technique as shown in Figure 34 because these are premarked and preassembled.



Key

- 1 insertion mark
- 2 lubricant

Figure 33 — Expansion gap with a ring seal joint




Key

- 1 insertion mark

Figure 34 — Expansion gap with an expansion unit

In horizontal pipework, double socketed fittings may also be installed with an expansion gap on the upstream end of the fitting. In this case, anchor the fitting with a bracket (see Figure 35), and anchor the pipe upstream with a bracket approximately in the middle of the pipe (see 6.2.4.3.2).



Key

- 1 anchor bracket
- 2 plain end pipe inserted to the bottom of fitting socket
- a direction of flow

Figure 35 — Normal positioning of expansion gaps in double socketed fittings

6.4.3 Jointing with butt fusion

6.4.3.1 General

The butt fusion technique is applicable to above-ground or below-ground installation with PP and PE components and provides rigidly jointed pipework. The pipe or fitting ends to be fused are heated by means of a heating element, then pressed together with a given pressure.

NOTE 1 The fused joints have physical and mechanical properties similar to those of the pipe material since an interlacing of the material molecule chains occurs.

For components made of PP, joint together by butt fusion only those which are made of materials with melt mass-flow rate (MFR) of the same class or of immediate adjacent classes, and which are MFR class marked on the component itself (for example: MFR B).

NOTE 2 As an example, MFR B can be fused with a product marked MFR A, MFR B and/or MFR C, but is not allowed with MFR D.

In all cases, follow the manufacturer's instructions to ensure a leak- and trouble-free joint.

6.4.3.2 Jointing recommendations

6.4.3.2.1 General

Carry out the fusion operation in a clean place, protected from frost and high humidity.

Depending on the dimension of the pipes and fittings to be fused, use the equipment and techniques as shown in Figure 36.




Figure 36 — Butt fusion techniques


The method of butt welding comprises three stages as follow.

6.4.3.2.2 Surface preparation

Check that the matching surfaces for assembly are cut square, without chamfer, and are free from defects.

6.4.3.2.3 Heating of surfaces

Before starting the fusion process, check the operation of the fusion machine. Raise the temperature of the heater according to the manufacturer's instructions, normally between 200 °C and 230 °C for PE, and between 190 °C and 220 °C for PP. Align the joint surfaces of the jointing components to be fused and insert the hot heating plate between them. Press the two components together with the heating plate at a pressure in the fusion surface between 0,12 MPa and 0,22 MPa for PE, and between 0,10 MPa and 0,20 MPa for PP. Maintain the heating-up pressure until a bead of melt material is formed around the whole circumference of the components to be fused. Manufacturer's instructions may include recommendation for parameters of the fusion operation as shown in Figure 37 including time intervals and related pressures together with the preferred ranges of temperature.



Key

P_{a1}, P_{a2}	(MPa)	heating pressures, high and low
P_{f1}	(MPa)	fusion pressure
t_{a1}, t_{a2}	(s)	heating times with high and low pressures
t_a	(s)	total heating time
t_{f1}	(s)	pressure build-up time
t_{f2}	(s)	cooling time
t_f	(s)	total cooling time
t_u	(s)	change-over time

Figure 37 — Parameters for fusion operation

6.4.3.2.4 Fusion

Remove the hot plate and press the heated surfaces together. Maintain the pressure according to the manufacturer's instructions and a correct alignment of the two components until the fusion zone has cooled. Parameters for fusing the parts together and for the cooling operation may be given in the manufacturer's instruction, see Figure 37.

WARNING — Do not accelerate the cooling process by means of cold water or any other cooling equipment since this may impair the quality of the joint.

6.4.4 Jointing with electrofusion couplings

6.4.4.1 General

Electrofusion couplings are applicable to above-ground and below-ground installations with PE components and provide rigidly jointed pipework.

The parts (pipe or fitting ends) to be fused are inserted, after cleaning, into the coupling and brought to the fusion temperature produced by a built-in heating coil.

6.4.4.2 Additional preparation of pipe ends

The pipe ends may be chamfered. Mark the pipe at the insert length required by the coupling. If a repair coupling without a butt ring is to be used, the insert lengths correspond to half the length of the coupling. If recommended by the manufacturer's instructions, scrap the marked area with a knife or special equipment (see Figure 38).




Figure 38 — Preparation of pipe end

6.4.4.3 Jointing recommendations

Ensure that the electrofusion coupling is clean and free from grease and dust.

If necessary, clean the coupling by abrading, but without using soap or any other cleaning agents.

Insert the prepared pipe or fitting ends into the coupling, until the inserted ends reach the butt rings, if any, or, if a repair coupling without butt ring is used, until the marked length has been inserted (see 6.4.4.2).

Prior to the welding procedure, check the pipe and/or fitting for correct alignment. Alignment should be maintained during the complete procedure until cooling is completed.

NOTE 1 Incorrect alignment might cause stress and leakage.

Connect the terminals to an electrical power source and operate the power input according to the manufacturer's instructions.

A fully automatic electrofusion machine is recommended.

Once the fusion operation is done, check visually for the successful completion.

NOTE 2 Some electrofusion couplings are provided with ejectable pins or thermochromatic indicators which have the function of witnessing the satisfactory execution of the fusion (refer to manufacturer's instructions).

6.4.5 Jointing with flanges and backing rings

6.4.5.1 General

Joints with flange and backing rings are applicable to above-ground installations of PE and provide rigidly jointed pipeworks.

The pipe ends or fittings are connected to the flange adaptors by means of butt fusion or electrofusion coupling. The adaptors are tightened by compressing the flange rings by means of bolts and nuts.

6.4.5.2 Jointing recommendations

Ensure that the fusion flange adaptors are correctly aligned prior to connection. Insert the seal between the adaptors, set in all bolts, washers and nuts and tighten in correct sequence.

6.4.6 Jointing with compression joints

6.4.6.1 General

Joints with compression couplings are applicable to above-ground installations of PE and provide rigidly jointed pipeworks.

NOTE Compression couplings are designed to grip and seal onto the outer surface of a pipe or spigot end. They are not designed to compensate thermal movement within the pipework.

6.4.6.2 Jointing recommendations

Cut the pipe as required. Clean the end of the pipe with a clean cloth. Split the nut, the antifriction ring and the rubber seal over the pipe end and insert the pipe end fully into the coupling. Securely tighten the nut.

7 Special precautions

7.1 Concreting of thermoplastics systems within the building structure

7.1.1 General

Carefully follow the manufacturer's instructions, subject to any relevant local and/or national regulations.

Provided they are rigidly jointed (e.g. systems with fused joints) PE and PP components may be concreted-in without any special precaution (see Figure 39 in comparison with Figure 23).




Figure 39 — Example of concreted-in rigidly jointed PE or PP system

For the other situations with PE and PP systems, and for all systems made of the other materials, 7.1.2 or 7.1.3 apply, whichever is relevant according to the curing temperature of concrete, ambient or with post-heating. Take care not to exceed the recommended maximum cover height of concrete above the components which is given in Table 6.

Table 6 — Recommended maximum cover height of concrete

Material	Marking criteria	Recommended maximum cover height of concrete		
		at ambient temperature	with post heated concrete	
		m	at 50 °C m	at 70 °C m
ABS	B	0,5	no	no
	BD	1,5	0,5	no ^a
PE	S-16	1,0		0,5
	S-12,5	2,5		1,0
PP	B	0,5	no	no
	BD + S-16	1,5		0,5
	BD + S-14	2,5		1,0
PVC-C	S-25 or B	0,5	no	no
	S-16,7 or BD	3,0	1,25	no ^a
PVC-U	B	0,5	no	no
	BD	1,0	no	no
PVC-U with structured-wall pipes	$d_n \leq 125$ mm ^b unique series	1,0	no	no
SAN+PVC	S-25 or B	0,5	no	no
	S-16,7 or BD	2,0	0,75	no ^a

^a Post-heating between 50 °C and 70 °C is recommended with PE and PP systems only (see 7.1.3.1).
^b For $d_n \geq 140$ mm, use components as specified for BD application area in other associated System Standards and prefer those conforming to EN 13476-2 [8].

7.1.2 Inserting systems in concrete setting at ambient temperature

7.1.2.1 Attention is drawn to any relevant local and/or national regulations.

7.1.2.2 Fasten systems with ring seal assemblies to prevent floating and support them sufficiently to prevent deflection during pouring of the concrete.

7.1.2.3 During pouring and vibration of the concrete take great care to prevent damage of the pipework.

7.1.2.4 Protect the ring seal sockets with tape on the outside to prevent concrete entering the socket mouths. Cap or plug open pipes in order to prevent the entry of water or concrete.

7.1.2.5 Fix all connected pipes which are branched off in the same way as the pipe they are connected to in order to avoid displacements or bending forces.

7.1.2.6 When a run of pipework is jointed by a branch of smaller diameter, use an appropriate means of fixing the larger pipe close to the branch in order to protect against shearing of the smaller pipe.

7.1.2.7 Figure 40 shows how fixing to the concrete formwork may be carried out. It is recommended that the fixing brackets have a strength sufficient to hold the pipe in the correct position. For the distances between supports centres for concreted systems do not exceed the recommended maximum value, $L_{c,max}$, given in Table 7.

The pipe may also be fixed to the steel reinforcement.





Figure 40 — Typical fixing to the concrete formwork

Table 7 — Recommended maximum distance between supports centres for pipes to be concreted-in

Nominal outside diameter d_n mm	Distance between supports centres	
	Horizontal pipework $L_{c,max}$ m	Vertical pipework $L_{c,max}$ m
32	0,4	0,8
40	0,5	1,0
50	0,5	1,0
63	0,5	1,0
75	1,0	1,5
80	1,0	1,5
82	1,0	1,5
≥ 90	1,0	2,0

7.1.2.8 For pipes which are completely concreted-in, do not exceed the recommended maximum cover height of concrete given in Table 6 and do not install more than 3 m length without a fixed point in the concrete (see Figure 41). Sockets, electrofusion couplings and various types of fittings will act as fixed points in the concrete. A ring made of the same material as the pipe may be cement-welded or fused, as applicable, to the outside of the pipe in order to act as an extra fixed point when the pipe length exceeds 6 m.

NOTE Local regulation on noise protection may request additional protection and/or anchoring.



Key

- 1 socket with ring seal and expansion gap
- 2 anchor bracket fastened to concrete formwork


Figure 41 — Typical completely concreted-in pipe system

7.1.2.9 Install at least one ring seal socket between two fixed points to provide for the expansion of the pipes. To ensure free movement of the pipes in the ring seals, lubricate the spigot-ends of the pipes.

For expansion gaps conform to the recommendations for *E* in Table 2.

7.1.2.10 Always install partly concreted-in pipe systems with fixed points in the concrete ceiling or floor (see Figure 42).

Dimensions in millimetres



Key

- 1 floor
- 2 ceiling
- 3 pipe to be installed after concreting
- 4 sealing ring socket with expansion gap
- 5 expansion gap in this socket (example with double socket)
- 6 expansion gaps in double socket (example)
- 7 guide bracket or solvent cemented or fused ring to secure the double socket


Figure 42 — Typical partly concreted-in pipe systems

7.1.2.11 Pipes that are connected to partly concreted-in pipe systems between concrete floors and ceilings are often installed after the concreting.

The spigot or pipe end may end directly against the concrete formwork. A collar made of expanded polystyrene may be placed around the spigot or the pipe end as shown in Figure 43. Once the concrete has been established, remove the collar to enable connection of further pipework to the spigot end, as shown in Figure 44, where Detail a) is applicable to all non-rigidly jointed systems, and detail b) to rigidly jointed PE and PP systems.

Pipe ends in the upper part of the formwork may be arranged in the same way in order to avoid damage to pipes above the formwork during the concreting (see Figure 45).

Dimensions in millimetres




Key

- 1 ring of expanded polystyrene
- 2 formwork for the concrete

Figure 43 — How to arrange expanded polystyrene ring on spigot or pipe in the formwork

Dimensions in millimetres



a) Detail a): for non-rigidly jointed systems

b) Detail b): for PE and PP rigidly jointed systems


Key

- 1 extension of the spigot end
- 2 slip coupling
- 3 solvent cemented or fused ring to secure slip coupling

Key

- 1 anchor bracket
- 2 pipe with socket

Figure 44 — How to continue the installation under the concrete ceiling (Polystyrene ring and formwork removed)



Key

- 1 ring of expanded polystyrene
- 2 plug

Figure 45 — How to end a pipe against the upper part of the formwork (formwork removed)

7.1.2.12 When installation of partly concreted-in pipe systems is carried out under winter conditions, ensure that melted water does not flow into installed pipes and fittings in order to avoid damage caused by subsequent freezing of water in the pipework. This precaution is not applicable to PE systems.

7.1.3 Inserting systems into post-heated concrete

7.1.3.1 For post-heating at a maximum temperature of 50 °C, use only systems which are marked BD with the exclusion of PVC-U. For temperatures between 50 °C and 70 °C use only PE and PP components conforming to Table 6.

Attention is drawn to any relevant local and/or national regulations. Carefully follow the manufacturer's instructions, with a special attention to distances of support centres, and take the following precautions in addition to those of 7.1.2.

7.1.3.2 Do not let the temperature in the concrete at the location of the pipework rise above 50 °C or above 70 °C, whichever is relevant (see Table 6).

7.1.3.3 After finishing the heating treatment, let the pipework cool down slowly.

7.2 Foaming of thermoplastics systems

This subclause only applies to systems when they are prefabricated in factories.

Do not foam on site these systems unless allowed by national and/or local regulations.

Take care to ensure that pipes and fittings stay in initial position during the foaming operation.

Under certain circumstances, when higher temperatures than allowed for the material may occur, it may be necessary to cool the pipework, e.g. by means of cold water, in which case anchor the components to prevent displacement.

7.3 Prevention of additional stresses in pipework

Avoid misalignment of the pipework. When filling up the space between a hole in a wall and the pipe passing through that wall, take care not to push the pipe out of line.

8 Jointing to other materials or other constructions

8.1 General

Any joint of a thermoplastic component with components made of dissimilar materials should conform to functional requirements as given in the relevant associated system standard.

In all cases, follow the manufacturer's instructions for ensuring a leaktight and trouble-free joint.

8.2 Adhesive joints

When adhesive jointing dissimilar plastics materials, use only components having dimensions and tolerances on outside diameter very close to those of the other material components, and those types of adhesive that are compatible with both types of plastics: therefore that is only applicable to jointing to each other PVC-U, structured-wall PVC-U, ABS, PVC-C and SAN+PVC components.

8.3 Ring seal joints

In the case of jointing a ring seal socket made of a given basic thermoplastics material, use only components made from other materials having tolerances on the outside diameter of their spigot smaller than or equal to those of the basic material and having the socket lengths in accordance with the requirements for the other material.


EXAMPLE A PE ring seal socket is permitted to be jointed to a PVC-U spigot (provided socket and spigot length compatibility), but not a PVC-U socket to a PE spigot, because PE tolerances on d_e are larger than PVC-U tolerances on d_e .

NOTE Due to the possible change of the materials at extreme temperature attention is also drawn to the need for the selection of correct size, composition and hardness of ring seals for jointing dissimilar plastics materials.

8.4 Jointing to non-thermoplastics components

Carefully follow the manufacturer's instructions.


Figure 46 to Figure 49 are given as examples and do not cover the entire range of products that are available for the connection of thermoplastics pipes to pipes of non-thermoplastics materials (cast iron, brass, vitrified clay, vitreous china, etc.), but the most common only.



Key

- 1 other material
- 2 special flexible seal
- 3 thermoplastics


Figure 46 — Typical joint from spigot of other material



Key

- 1 other material
- 2 mastic
- 3 thermoplastics


Figure 47 — Alternative joint from spigot of other material



Key

- 1 thermoplastics
- 2 double seal
- 3 metal material

Figure 48 — Typical joint from socket of metal




Key

- 1 thermoplastics
- 2 ring seal
- 3 plastics coupling
- 4 other material

Figure 49 — Typical joint from thermoplastics pipe spigot to pipe spigot of other material

8.5 Adaptors

Manufacturers provide special adaptors for connecting thermoplastics pipes to components made from other materials (see Figure 50 as an example), including other plastics. In selecting the required adaptor, ensure that the recommended fitting will fulfil the performance requirements of the relevant associated system standards and accommodate the thermal movement; alternatively fit an expansion socket in close proximity.



Key

- 1 vitreous china pan
- 2 thermoplastics bent or straight connector
- 3 special flexible seal

Figure 50 — Typical joint from W-C pan spigot of vitreous china

9 Fire resistance of pipework

Attention is drawn to any relevant local and/or national regulations. If a fire stop sleeve is designed as a fixed point in a pipework, take account of that situation.

10 Testing and inspection of installations

10.1 Testing

Follow the general recommendations as given in EN 12056-5.

10.2 General inspection

Ensure compliance with the following recommendations:

- a) correct insertion at expansion joints;
- b) anchor and guide brackets are correctly placed and fixed;
- c) fire regulations or requirements are given due consideration;
- d) general drainage codes of practice and local and/or national regulations are given due consideration.

11 Maintenance and cleaning of installations

11.1 General

11.1.1 It is recommended that care be taken in the use of chemical descaling agents, which are often of a corrosive nature, and that materials used in the pipe system be clearly identified before treatment to ensure that the internal surfaces are not subjected to damaging chemical attack (see ISO/TR 10358 [14]).

11.1.2 It is recommended that hand-operated rods for removing blockages in discharge pipes be capable of passing through the systems without damaging the internal surfaces of pipes and fittings.

11.1.3 When using the mechanised rodding equipment, it is recommended that the pipework to be cleaned be thoroughly examined beforehand to enable selection of the appropriate cleaning attachments.

11.1.4 If it is desired to paint the pipework, do not use strong solvent based paints. Favour paints which can accommodate the thermal movement of the components.

11.2 Cleaning and descaling techniques

Conventional cleaning and descaling techniques can be applied to thermoplastics networks. Nevertheless, take special care when using kinetic ram for the following reasons:

A kinetic ram can be usefully employed for the removal of obstructions in branch pipes provided its function and its limitations are properly understood. The function of the gun is based on the principle that the impact of compressed air against a column of water behind a blockage will create a shock wave which is transmitted to the obstruction to dislodge and remove it.

A stubborn blockage can, however, produce a “blow-back” of the gun and injure the operator, or damage pipework and appliances not designed to withstand the pressure applied. Where there are open branches on the system, waste matter may be forced out of the openings and damage wall and ceiling decoration. It is recommended that the use of the gun on thermoplastics discharge installations be generally restricted to the removal of blockages consisting of compacted soft materials, for example, grease, soap residue and saturated paper.

12 Chemical resistance of thermoplastics systems

Thermoplastics are resistant to the effects of a large number of chemicals including alkalis and most acids but are attacked by some chemicals, most of which are organic solvents. Restricted use in industrial installations is permissible for many chemically contaminated waste waters, subject to limiting values for time and temperature equivalent to those of domestic washing machines if the manufacturer's instructions do not specify other limiting values of time and temperature. ISO/TR 10358 provides guidance on chemical resistance of thermoplastics and ISO/TR 7620 [11] for rubber materials.

13 Recycling of thermoplastics components of the system

Thermoplastic piping systems are fully recyclable and all cut-off during installation and post-consumer wastes should be collected and sent to the appropriate recycling circuits.

Bibliography

- [1] EN 1329-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 1: Specifications for pipes, fittings and the system*
- [2] EN 1451-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Polypropylene (PP) - Part 1: Specifications for pipes, fittings and the system*
- [3] EN 1453-1, *Plastics piping systems with structured wall-pipes for soil and waste discharge (low and high temperature) inside buildings - Unplasticized poly(vinyl chloride) (PVC-U) - Part 1: Specifications for pipes and the system*
- [4] EN 1455-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Acrylonitrile-butadiene-styrene (ABS) - Part 1: Requirements for pipes, fittings and the system*
- [5] EN 1519-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Polyethylene (PE) - Part 1: Specifications for pipes, fittings and the system*
- [6] EN 1565-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Styrene copolymer blends (SAN+PVC) - Part 1: Specifications for pipes, fittings and the system*
- [7] EN 1566-1, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Chlorinated poly(vinyl chloride) (PVC-C) - Part 1: Specifications for pipes, fittings and the system*
- [8] EN 13476-2, *Plastics piping systems for non-pressure underground drainage and sewerage - Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) - Part 2: Specifications for pipes and fittings with smooth internal and external surface and the system, Type A*
- [9] EN 14680, *Adhesives for non-pressure thermoplastic piping systems - Specifications*
- [10] EN 14814, *Adhesives for thermoplastic piping systems for fluids under pressure - Specifications*
- [11] ISO/TR 7620, *Rubber materials - Chemical resistance*
- [12] ISO 8283-2, *Plastics pipes and fittings - Dimensions of sockets and spigots for discharge systems inside buildings - Part 2: Polyethylene (PE)*
- [13] ISO 8283-4, *Plastics pipes and fittings - Dimensions of sockets and spigots for discharge systems inside buildings - Part 4: Acrylonitrile/butadiene/styrene (ABS)*
- [14] ISO/TR 10358, *Plastics pipes and fittings - Combined chemical-resistance classification table*

British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™