

PD IEC/TR 62354:2014



BSI Standards Publication

General testing procedures for medical electrical equipment

bsi.

...making excellence a habit.™

National foreword

This Published Document is the UK implementation of IEC/TR 62354:2014.

The UK participation in its preparation was entrusted by Technical Committee CH/62, Electrical Equipment in Medical Practice, to Subcommittee CH/62/1, Common aspects of Electrical Equipment used in Medical Practice.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.
Published by BSI Standards Limited 2014

ISBN 978 0 580 87366 9
ICS 11.040.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 October 2014.

Amendments issued since publication

Date	Text affected
-------------	----------------------



TECHNICAL REPORT

General testing procedures for medical electrical equipment

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XH**

ICS 11.040

ISBN 978-2-8322-1856-3

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	9
1 Scope and object.....	10
2 Normative references	10
3 Terms, definitions, abbreviations and acronyms.....	11
3.1 Terms and definitions.....	11
3.2 Abbreviations and acronyms	12
4 Types of tests.....	12
4.1 GENERAL	12
4.2 Visual inspection.....	13
5 State of the ME EQUIPMENT	13
6 Number of samples.....	13
7 Applicable test items to the clauses of IEC 60601-1	13
8 Sequence of tests.....	13
9 General testing condition.....	14
10 Power sources for tests	15
10.1 General.....	15
10.2 Connection to a separate power source	16
10.3 Connection to an external d.c. power source.....	16
10.4 Source of power for ME EQUIPMENT	16
10.5 SUPPLY MAINS for testing ME EQUIPMENT	16
11 Measurement and test equipment.....	17
11.1 General requirements	17
11.2 Accuracy.....	18
11.3 Safety criteria for selection	18
11.4 Calibration	18
12 Treatments of unit symbols and measured values.....	19
13 PROCEDURES for testing, including particular conditions	19
13.1 General.....	19
13.2 Tests to be performed by inspection	20
13.3 Measurements and tests performed on non-energized equipment.....	41
13.4 Measurements and tests for equipment that is operating.....	96
Annex A (informative) Sequence of testing.....	165
A.1 Sequence of testing (IEC 60601-1:1988).....	165
A.2 Sequence of testing (IEC 60601-1:2005).....	166
Annex B (informative) Information typically required for product safety testing (Guide)	168
B.1 Purpose	168
B.2 Description	168
B.3 Intended use environment.....	168
B.4 Construction	168
B.5 List of safety-related components and relevant approvals	168
B.6 Test system	168
B.7 Power	168
B.8 Grounding.....	169

B.9	Modes of operation; configurations	169
B.10	Failure modes	169
B.11	RISK ANALYSIS according with ISO 14971	169
B.12	Software	169
B.13	Auxiliary equipment	169
B.14	Transformers and chokes	169
Annex C (informative)	Testing and measuring equipment	170
Annex D (informative)	Suitable measuring supply circuits	171
Annex E (informative)	Preventive maintenance	174
E.1	General	174
E.2	Cleaning and disinfection	174
E.3	Preventive maintenance checklist	174
E.4	OPERATOR checks	174
Annex F (informative)	Test probes	175
Annex G (informative)	Index of tests (IEC 60601-1:2005 clauses order)	177
Annex H (informative)	Index of tests for an INTERNALLY POWERED EQUIPMENT – battery only – (IEC 60601-1:2005 clauses order)	179
Annex I (informative)	Index of tests (IEC 60601-1:2005 alphabetic order)	181
Annex J (informative)	Index of tests for an INTERNALLY POWERED EQUIPMENT – battery only – (IEC 60601-1:2005 alphabetic order)	183
Annex K (informative)	Production line tests	185
K.1	Production-line dielectric voltage-withstand test	185
K.2	Production-line grounding-continuity test	186
K.3	Production-line EARTH LEAKAGE CURRENT test	186
K.4	Recommended features for specific test equipment	186
Annex L (informative)	Evaluation of the laboratory power source characteristics	189
L.1	Purpose	189
L.2	Application	189
L.3	Definitions	190
L.4	Testing	191
Annex M (informative)	Traceability of calibrations and calibration intervals	194
M.1	Purpose	194
M.2	Traceability of calibrations	194
M.3	Calibration intervals for test equipment requiring calibration	194
Annex N (informative)	Guidance for preparation, attachment, extension, use of thermocouples and acceptance of thermocouple wire	196
N.1	General	196
N.2	Preparation	196
N.3	Placement	196
N.4	Attachment	197
N.5	Extension	198
N.6	Use	199
N.7	Acceptance of thermocouples wire	199
Annex O (informative)	Guideline for safe laboratory work	201
O.1	BASIC SAFETY guidelines for working with test instruments	201
O.2	Basic guidelines for performing safety tests	203
O.3	Basic guidelines regarding test personnel and test areas	205

O.4	Contents of a documented safe environment for working in a testing laboratory	206
	Bibliography.....	207
	Index of defined terms	209
	Figure 1 – Area of the bottom of an ENCLOSURE as specified in 11.3 b) 1)	37
	Figure 2 – Baffle	37
	Figure 3 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 1	51
	Figure 4 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 2	51
	Figure 5 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 3	52
	Figure 6 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 4	52
	Figure 7 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 5	52
	Figure 8 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 6	52
	Figure 9 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 7	53
	Figure 10 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 8	53
	Figure 11 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 9	54
	Figure 12 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 10	54
	Figure 13 – Human body test mass	73
	Figure 14 – Application of test voltage to bridged PATIENT CONNECTIONS (common mode) for DEFIBRILLATION-PROOF APPLIED PARTS	103
	Figure 15 – Application of test voltage to individual PATIENT CONNECTIONS (differential mode) for DEFIBRILLATION-PROOF APPLIED PARTS	104
	Figure 16 – Application of test voltage to test the delivered defibrillation energy (energy reduction test)	108
	Figure 17 – Example of a measuring device and its frequency characteristics	110
	Figure 18 – Measuring circuit for the EARTH LEAKAGE CURRENT of CLASS I equipment, with or without APPLIED PARTS	112
	Figure 19 – Measuring circuit for the TOUCH CURRENT	115
	Figure 20 – Measuring circuit for the PATIENT LEAKAGE CURRENT from the PATIENT CONNECTION to earth	117
	Figure 21 – Measuring circuit for the total PATIENT LEAKAGE CURRENT with all PATIENT CONNECTIONS of all APPLIED PARTS of the same type (TYPE B APPLIED PARTS, TYPE BF APPLIED PARTS or TYPE CF APPLIED PARTS) connected together	118
	Figure 22 – Measuring circuit for the PATIENT LEAKAGE CURRENT via the PATIENT CONNECTION(S) of an F-TYPE APPLIED PART to earth caused by an external voltage on the PATIENT CONNECTION(S)	120
	Figure 23 – Measuring circuit for the PATIENT LEAKAGE CURRENT from PATIENT CONNECTION(S) to earth caused by an external voltage on a metal ACCESSIBLE PART that is not PROTECTIVELY EARTHED	121
	Figure 24 – Measuring circuit for the PATIENT LEAKAGE CURRENT from PATIENT CONNECTION(S) to earth caused by an external voltage on a SIGNAL INPUT/OUTPUT PART	123
	Figure 25 – Measuring circuit for the PATIENT AUXILIARY CURRENT	125
	Figure 26 – Ratio between hydraulic test pressure and maximum permissible working pressure	129
	Figure 27 – Spark ignition test apparatus	136
	Figure 28 – Maximum allowable current I as a function of the maximum allowable voltage U measured in a purely resistive circuit in an OXYGEN RICH ENVIRONMENT	139

Figure 29 – Maximum allowable voltage U as a function of the capacitance C measured in a capacitive circuit used in an OXYGEN RICH ENVIRONMENT	139
Figure 30 – Maximum allowable current I as a function of the inductance L measured in an inductive circuit in an OXYGEN RICH ENVIRONMENT.....	140
Figure D.1 – Measuring supply circuit with one side of the SUPPLY MAINS at approximately earth potential.....	171
Figure D.2 – Measuring supply circuit with SUPPLY MAINS approximately symmetrical to earth potential.....	171
Figure D.3 – Measuring supply circuit for polyphase ME EQUIPMENT specified for connection to a polyphase SUPPLY MAINS	171
Figure D.4 – Measuring supply circuit for single-phase ME EQUIPMENT specified for connection to a polyphase SUPPLY MAINS	172
Figure D.5 – Measuring supply circuit for ME EQUIPMENT having a separate power supply unit or intended to receive its power from another equipment in an ME SYSTEM.....	172
Figure F.1 – Standard test finger	175
Figure F.2 – Test hook.....	176
Figure F.3 – Test pin.....	176
Figure F.4 – Ball-pressure test apparatus	176
Figure N.1 – Thermocouple preparation	196
Figure N.2 – Securing of thermocouples	197
Figure N.3 – Example of confinement of a thermocouple.....	198
Figure N.4 – Example where thermocouple connectors need not be used	199
Table 1 – Units outside the SI units system that may be used	19
Table 2 – Tests to be performed by inspection.....	20
Table 3 – NOMINAL cross-sectional area of conductors of a POWER SUPPLY CORD	31
Table 4 – Acceptable perforation of the bottom of an ENCLOSURE	38
Table 5 – Measurements and tests performed on non-energized equipment	41
Table 6 – Testing of cord anchorages	56
Table 7 – Acceptable gaps ^a	62
Table 8 – Drop height	87
Table 9 – Test torques for rotating controls.....	93
Table 10 – Measurements and tests for equipment that is operating	96
Table 11 – Allowable maximum temperatures for skin contact with ME EQUIPMENT APPLIED PARTS	147
Table 12 – Allowable maximum temperatures for ME EQUIPMENT parts that are likely to be touched.....	147
Table 13 – Allowable maximum temperatures of parts.....	148
Table 14 – Temperature limits of motor windings	148
Table 15 – Maximum motor winding steady-state temperature	149
Table 16 – Maximum allowable temperatures of transformer windings under overload and short-circuit conditions at 25 °C (± 5 °C) ambient temperature.....	149
Table 17 – Test current for transformers	162
Table C.1 – IEC 60601-1:1988+AMD 1:1991 and AMD 2:1995.....	170
Table D.1 – Legends of symbols for Figure D.1 to Figure D.5	173
Table L.1 – Method for testing a single phase laboratory power source.....	191

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**GENERAL TESTING PROCEDURES
FOR MEDICAL ELECTRICAL EQUIPMENT****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 62354, which is a technical report, has been prepared by subcommittee 62A: Common aspects of electrical equipment used in medical practice, of IEC technical committee 62: Electrical equipment in medical practice.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision intended to align the guidance in this technical report with Amendment 1 to IEC 60601:2005. Several tests have been updated and additional test procedures added. The following tests have been added or significantly revised:

- 13.2.1 RISK MANAGEMENT PROCESS
- 13.2.4 Durability and legibility of marking
- 13.2.5 Battery markings

- 13.2.8 POTENTIAL EQUALIZATION TERMINAL
- 13.2.14 USABILITY OF ME EQUIPMENT
- 13.3.1 Humidity preconditioning
- 13.3.2 Impedance of PE connection
- 13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
- 13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)
- 13.3.13 Castors and wheels (Force for propulsion, movement over a threshold)
- 13.3.14 Safety catch evaluation
- 13.3.17 Overflow
- 13.3.18 Spillage
- 13.3.23 Impact
- 13.3.14 Drop impact
- 13.3.25 Rough handling
- 13.3.27 Actuating parts of controls
- 13.3.28 Construction of transformers
- 13.4.1 ESSENTIAL PERFORMANCE – Functional
- 13.4.3 Voltage mismatch
- 13.4.4 Limitation of voltage, current or energy
- 13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection
- 13.4.6 Energy reduction
- 13.4.7 EARTH LEAKAGE CURRENT
- 13.4.9 PATIENT LEAKAGE CURRENT
- 13.4.14 Sound pressure level measurements
- 13.4.16 X-radiation (ionizing radiation) measurement
- 13.4.20 Interruption of power supply
- 13.4.28 Rechargeable battery overcharge/discharge
- 13.4.29 Mains transformers

This technical report is intended to be read in conjunction with IEC 60601-1:1988 (including the collateral provisions of IEC 60601-1-1:2000) and IEC 60601-1:2005 and IEC 60601-1:2005/AMD1:2012.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
62A/936/DTR	62A/947/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

In this technical report, the terms defined in Clause 2 of IEC 60601-1:1988 or Clause 3 of IEC 60601-1:2005 are printed in SMALL CAPITALS.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

IEC/TR 60513, *Fundamental aspects of safety standards for medical electrical equipment* published by IEC sub-committee 62A provided the basis for inclusion of the test methods for ME EQUIPMENT in the safety standards.

"Technical requirements and test methods are interrelated elements of product standards and should always be considered together.

Product standards should identify where medically informed judgements are required in deciding whether a particular requirement applies.

Wherever possible, the standards should contain test specifications for completely and clearly checking compliance with the technical requirements. In some cases, a compliance statement such as 'visual inspection', 'manual testing' or similar is adequate for this purpose if such a method gives an accurate assessment.

It should be easy to recognize which test methods apply to each technical requirement. Appropriate headings should designate the appropriate test and a reference should be made to the clause containing the requirement. This also applies for references which are made to other relevant test standards."

It was deemed necessary to support IEC 60601-1 with guidelines for general testing PROCEDURES for MEDICAL ELECTRICAL EQUIPMENT.

In developing the test PROCEDURES, the advice given in IEC/TR 60513 and ISO/IEC Guide 51 was considered as follows:

- a) test results should be reproducible within defined limits. When considered necessary, the test method should incorporate a statement as to its limit of uncertainty;
- b) where the sequence of tests can influence the results, the correct sequence should be specified.

There is also growing support for the idea that all the test PROCEDURES for ME EQUIPMENT should be found within one international standard.

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*, highlights the need for a single series of requirements covering test PROCEDURES.

IEC/TR 60513 includes a major new principle referring to testing:

"In specifying minimum safety requirements, provision is made for assessing the adequacy of the design PROCESS where this provides an appropriate alternative to the application of laboratory testing with specific pass/fail criteria, (e.g. in assessing the safety of new technologies such as programmable electronic systems)."

GENERAL TESTING PROCEDURES FOR MEDICAL ELECTRICAL EQUIPMENT

1 Scope and object

This technical report applies to MEDICAL ELECTRICAL EQUIPMENT (as defined in Subclauses 3.63 of IEC 60601-1:2005 and 2.2.15 of IEC 60601-1:1988), hereinafter referred to as ME EQUIPMENT.

The object of this technical report is to provide guidance on general testing PROCEDURES according to IEC 60601-1:1988 (including the collateral provisions of IEC 60601-1-1:2000) and IEC 60601-1:2005 and IEC 60601-1:2005/AMD1:2012.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60086-4, *Primary batteries – Part 4: Safety of lithium batteries*

IEC 60127-1, *Miniature fuses – Part 1: Definitions for miniature fuses and general requirements for miniature fuse-links*

IEC 60252-1, *AC motor capacitors – Part 1: General – Performance, testing and rating – Safety requirements – Guide for installation and operation*

IEC 60364-4-41, *Low voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60417, *Graphical symbols for use on equipment*. Available from: <http://www.graphical-symbols.info/equipment>

IEC/TR 60513, *Fundamental aspects of safety standards for medical electrical equipment*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999¹

IEC 60601-1:1988, *Medical electrical equipment – Part 1: General requirements for safety*²
IEC 60601-1:1998/AMD1:1991
IEC 60601-1:1998/AMD2:1995

IEC 60601-1:2005, *Medical electrical equipment – Part 1: General requirements for basic safety and essential performance*
IEC 60601-1:2005/AMD1:2012³

¹ A consolidated version 2.1 (2001) exists that includes IEC 60529:1989 and its Amendment 1:1999.

² The second edition of IEC 60601-1, cancelled and replaced by the third edition in 2005.

³ A consolidated version 3.1 (2012) exists that includes IEC 60601-1:2005 and its Amendment 1:2012.

IEC 60601-1-2, *Medical electrical equipment – Part 1-2: General requirements for basic safety and essential performance – Collateral Standard: Electromagnetic disturbances – Requirements and tests*

IEC 61010 (all parts), *Safety requirements for electrical equipment for measurement, control, and laboratory use*

IEC 61010-1, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*

IEC 61672-2, *Electroacoustics – Sound level meters – Part 2: Pattern evaluation tests*

IEC 62133, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary cells, and for batteries made from them, for use in portable applications*

ISO 17665-1, *Sterilization of health care products – Moist heat – Part 1: Requirements for the development, validation and routine control of a sterilization process for medical devices*

ISO 11135-1, *Medical devices – Validation and routine control of ethylene oxide sterilization⁴*

ISO 11137-1, *Sterilization of health care products – Radiation – Part 1: Requirements for development, validation and routine control of a sterilization process for medical devices*

ISO 14971:2007, *Medical devices – Application of risk management to medical devices*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

ISO 80000-1, *Quantities and units – Part 1: General*

3 Terms, definitions, abbreviations and acronyms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60601-1:1988 and IEC 60601-1:2005 apply.

NOTE 1 Where the terms “voltage” and “current” are used in this document, they mean the r.m.s. values of an alternating, direct or composite voltage or current unless stated otherwise.

NOTE 2 An index of defined terms is found beginning on page 209.

NOTE 3 When used in the body of this document, N/A means “Not applicable”.

⁴ Withdrawn and replaced by ISO 11135:2014.

3.2 Abbreviations and acronyms

Abbreviation	Term
a.c.	Alternating current
d.c.	Direct current
DUT	Device under test
MAR	Mean angle resolvable
MD	Measuring device
ME	MEDICAL ELECTRICAL
RH	Relative humidity
r.m.s.	Root mean square
SI	System international
SIP/SOP	SIGNAL INPUT/OUTPUT PART

4 Types of tests

4.1 GENERAL

“TYPE TESTS” are required for verifying the BASIC SAFETY and ESSENTIAL PERFORMANCE of the product design.

NOTE 1 The tests described in this technical report can also be used by the MANUFACTURER to ensure the quality of the product and the manufacturing PROCESS. See Annex I.

A test need not be carried out if analysis shows that the condition being tested has been adequately evaluated by other tests or methods.

The results of the RISK ANALYSIS should additionally be used to determine which combination(s) of simultaneous faults should be tested.

NOTE 2 The test results might render it necessary to revise the RISK ANALYSIS.

When testing the ME EQUIPMENT, relevant information provided by the MANUFACTURER in the instruction for use should be taken into account.

Before commencing testing, the ME EQUIPMENT under test (the device under test or DUT) should be disconnected from the SUPPLY MAINS. If not possible, special precautions should be taken to prevent HARM to the personnel performing the tests and measurements or other individuals who might be affected.

Connections such as data lines or functional earth conductors can act like PROTECTIVE EARTH CONNECTIONS. Such additional, but unintentional, PROTECTIVE EARTH CONNECTIONS can create measurement errors.

Unless otherwise specified in IEC 60601-1, ME EQUIPMENT is to be tested under the least favourable working conditions. The working conditions are specified in the ACCOMPANYING DOCUMENTS. The least favourable working conditions are to be documented for every test where they apply.

Considering the ambient temperature, humidity and pressure described in the technical description, tests should be performed at the worst-case extremes depending on the test and the effects of these parameters on the test results. If the test is not impacted by these parameters, then test can be conducted anywhere within the specified range.

4.2 Visual inspection

Covers and housings should be opened only:

- if required in the instructions for use for the ME EQUIPMENT, or
- if specified in this technical report, or
- if there is an indication of a HAZARD or HAZARDOUS SITUATION.

Special attention should be paid to the following:

- all fuses accessible from the outside should be marked (type, ratings) on the ME EQUIPMENT or marked by reference and specified in the ACCOMPANYING DOCUMENTS;
- the markings are legible and complete;
- any damage;
- relevant ACCESSORIES should be assessed together with the ME EQUIPMENT (e.g. DETACHABLE or FIXED POWER SUPPLY CORDS, PATIENT leads, tubing etc.);
- all required documentation, such as instructions for use, is present and complete and reflects the current revision of the ME EQUIPMENT.

5 State of the ME EQUIPMENT

Some tests specified in this document are conducted in the NORMAL CONDITION whilst others are conducted in SINGLE FAULT CONDITIONS.

NORMAL CONDITION and SINGLE FAULT CONDITIONS are described in both IEC 60601-1:1988 and IEC 60601-1:2005.

6 Number of samples

TYPE TESTS are performed on a representative sample of the item being assessed.

Multiple samples can be utilized simultaneously if the validity of the results is not significantly affected.

7 Applicable test items to the clauses of IEC 60601-1

Table 2, Table 5 and Table 10 relate the test PROCEDURES described in this technical report to the relevant subclauses of IEC 60601-1:2005. When applicable, these tables also provide a cross reference to the relevant subclauses of IEC 60601-1:1988.

Annex G and Annex H contain an index of the tests in this technical report sorted by the relevant subclause in IEC 60601-1:2005. Annex I and Annex J contain the lists sorted in alphabetical order by test title.

8 Sequence of tests

Unless stated otherwise, the tests in this technical report are to be sequenced in such a way so that the results of any test do not influence the results of other tests. Tests should, if applicable, be performed in the sequence indicated in Annex A, unless otherwise stated by particular standards.

However, this does not preclude the possibility of conducting a test that preliminary inspection suggests might cause failure.

The tests for radiation HAZARDS, biocompatibility, USABILITY, alarm systems, PEMS and electromagnetic compatibility can be performed independently from the tests specified in the present document.

The tests specified for ME SYSTEMS should be performed in the same sequence as the tests for ME EQUIPMENT.

9 General testing condition

The following general testing conditions should be applied:

- a) After the DUT has been set up for NORMAL USE, tests are carried out under the least favourable working conditions which are specified in the ACCOMPANYING DOCUMENTS.
- b) The DUT is to be shielded from other influences (for example, draughts) that might affect the validity of the tests.
- c) In cases where ambient temperatures cannot be maintained, the test conditions are to be consequently modified and results adjusted accordingly.
- d) Qualified personnel are to perform these tests. Qualifications include training on the subject, knowledge, experience, and acquaintance with the relevant technologies and regulations. The personnel should be able to assess safety and should be able to recognize possible consequences and HAZARDS arising from non-conforming ME EQUIPMENT
- e) ACCESSORIES for the ME EQUIPMENT, which can affect the safety of the DUT or the results of the measurements, should be included in the tests. ACCESSORIES included in the tests are to be documented.
- f) All tests are to be performed in such a manner that no unacceptable RISK arises for testing personnel, PATIENTS or other individuals.
- g) If not otherwise stated, all values for current and voltage are effective values (r.m.s.) or d.c. values as appropriate.
- h) All tests performed should be comprehensively documented. The documentation should contain as a minimum the following data:
 - identification of the testing body (e. g. company, department);
 - names of the persons, who performed the testing and the evaluation(s);
 - identification of the ME EQUIPMENT (e. g. type, serial number, inventory number) and the ACCESSORIES tested;
 - measurements (measured values, measuring method, measuring equipment, environmental conditions);
 - date and signature of the individual, who performed the evaluation; and
 - if applicable, the ME EQUIPMENT tested should be marked/identified accordingly.
- i) In addition to TYPE TESTS, the MANUFACTURER of the ME EQUIPMENT can establish the testing interval and the extent of testing for periodic inspection and has to disclose it in the ACCOMPANYING DOCUMENTS. In establishing the testing interval, the following considerations should be taken into account:
 - the level of RISK of the ME EQUIPMENT as described in the RISK MANAGEMENT FILE,
 - the frequency of its use,
 - the operating environment,
 - type of ME EQUIPMENT (STATIONARY, MOBILE, emergency), and
 - the frequency of occurrence of device failures.

If there is no information on the testing interval for periodic inspection in the ACCOMPANYING DOCUMENTS (e.g. for older ME EQUIPMENT), it can be established by a competent person. In defining the level of RISK, the above factors and the

recommendations of the MANUFACTURER should be taken into account. The testing interval for periodic inspection can be set in the range of 6 months to 36 months.

- j) In the event of the necessity for repairs or modifications after a failure or the likelihood of a failure during the sequence of tests, the testing laboratory and the supplier of the ME EQUIPMENT can agree, either upon the use of a new sample on which all relevant tests are to be carried out again or, preferably, upon making all the necessary repairs or modifications after which only relevant tests are repeated.
- k) Unless otherwise specified in IEC 60601-1, ME EQUIPMENT is to be tested under the least favourable working conditions. The working conditions are specified in the ACCOMPANYING DOCUMENTS. The least favourable working conditions shall be documented for every test where they apply.
- l) ME EQUIPMENT having operating values that can be adjusted or controlled by the OPERATOR is adjusted as part of the tests to values least favourable for the relevant test, but in accordance with the instructions for use.
- m) If the test results are influenced by the inlet pressure and flow or chemical composition of the cooling liquid, the test is to be carried out within the limits for these characteristics as prescribed in the technical description.
- n) Where cooling water is required, potable water is to be used.
- o) Except in special cases, such as PATIENT supports and waterbeds, contact with ME EQUIPMENT is supposed to be made with:
 - one hand, simulated for LEAKAGE CURRENT measurements by a metal foil of 10 cm × 20 cm (or less if the total ME EQUIPMENT is smaller);
 - one finger, straight or bent in a natural position, simulated by a standard test finger (Figure F.1) provided with a stop plate; or
 - an edge or slit that can be pulled outwards allowing subsequent entry of a finger, simulated by a combination of test hook (Figure F.2) and standard test finger.

10 Power sources for tests

10.1 General

- a) Where test results are influenced by deviations of the supply voltage from its RATED value, the effect of such deviations is to be taken into account.
- b) ME EQUIPMENT for a.c. only should be tested with a.c. at RATED frequency (if marked) ± 1 Hz for a RATED frequency between 0 Hz and 100 Hz and ± 1 % for a RATED frequency above 100 Hz. ME EQUIPMENT marked with a RATED frequency range is to be tested at the least favourable frequency within that range.
- c) ME EQUIPMENT designed for more than one RATED voltage, or for both a.c. and d.c., is to be tested in conditions related to the least favourable voltage and nature of supply, for example, number of phases (except for single-phase supply) and type of current. It might be necessary to perform some tests more than once in order to establish which supply configuration is least favourable.
- d) ME EQUIPMENT for d.c. only is to be tested with d.c. When performing the tests, the possible influence of polarity on the operation of the ME EQUIPMENT is to be taken into consideration.
- e) Unless otherwise specified by this technical report, ME EQUIPMENT is to be tested at the least favourable RATED voltage within the relevant range. It might be necessary to perform some of the tests more than once in order to establish the least favourable voltage.
- f) ME EQUIPMENT for which alternative ACCESSORIES or components specified by the MANUFACTURER are available is to be tested with those ACCESSORIES or components that give the least favourable conditions.
- g) If the instructions for use specify that ME EQUIPMENT is intended to receive its power from a separate power supply, it is to be connected to such a power supply.

10.2 Connection to a separate power source

If ME EQUIPMENT is specified for connection to a separate power source, other than the SUPPLY MAINS, either the separate power source should be considered as part of the ME EQUIPMENT and all relevant requirements of this standard should apply, or the combination should be considered as an ME SYSTEM.

NOTE What was formerly referred to, in the first and second editions of IEC 60601-1, as a "specified power supply" is now considered either as another part of the same ME EQUIPMENT or as another electrical equipment in an ME SYSTEM.

10.3 Connection to an external d.c. power source

If ME EQUIPMENT is specified for power supplied from an external d.c. power source, no HAZARD, other than absence of function, should develop when a connection with the wrong polarity is made and the ME EQUIPMENT should provide ESSENTIAL PERFORMANCE as described in the ACCOMPANYING DOCUMENTS when connection is subsequently made with the correct polarity.

NOTE The external d.c. power source can be a SUPPLY MAINS or another item of electrical equipment. In the latter case, the combination is considered to be an ME SYSTEM.

10.4 Source of power for ME EQUIPMENT

ME EQUIPMENT is either powered by an INTERNAL ELECTRICAL POWER SOURCE, specified for connection to a separate power supply, or is suitable for connection to SUPPLY MAINS, either independently or in combination, as long as only one connection to mains is provided. This is checked by inspection of the ACCOMPANYING DOCUMENTS.

10.5 SUPPLY MAINS for testing ME EQUIPMENT

SUPPLY MAINS used for testing ME EQUIPMENT have the following characteristics:

- voltage dips, short interruptions and voltage variations on the SUPPLY MAINS as described in IEC 60601-1-2;
- no voltage in excess of 110 % or lower than 90 % of the NOMINAL value between any of the conductors of the system or between any of these conductors and earth;
- voltages that are practically sinusoidal and forming a practically symmetrical supply system in case of polyphase supply;
- a frequency of not more than 1 kHz;
- a frequency deviation of ≤ 1 Hz from the NOMINAL value up to 100 Hz and ≤ 1 % from the NOMINAL value from 100 Hz to 1 kHz;
- the protective measures as described in IEC 60364-4-41.

NOTE If ME EQUIPMENT is intended to be operated from a SUPPLY MAINS with characteristics different from the SUPPLY MAINS described in this subclause, additional SAFETY measures might be necessary.

- a d.c. voltage (as measured by a moving coil meter or equivalent method) having a peak-to-peak ripple not exceeding 10 % of the average value.

Where peak-to-peak ripple exceeds 10 % of the average value, the peak voltage has to be applied.

The characteristics of electrical power source used to power the DUT should be evaluated as described in Annex L.

11 Measurement and test equipment

11.1 General requirements

- The measurement and test equipment should comply with requirements of the IEC 61010 series of standards.
- In NORMAL USE the measurement equipment should not expose the person doing the testing or other individuals to unacceptable RISKS.
- The accuracy of the measuring functions within the range marked or declared by the measurement equipment manufacturer should be specified in the test data sheet. See also 11.2.
- The measurement equipment used for the tests should be tested and calibrated at regular intervals according to the information given by its manufacturer and should be traceable to national or international standards. Calibration should be performed by a calibration laboratory with a quality management system in accordance with ISO/IEC 17025.
- For the tests, PROTECTIVE EARTH CONNECTIONS can be interrupted in the measuring devices, if protection against electric shock is guaranteed by another means of IEC 61010-1.
- In the measurement equipment, an electrical separation of the measurement circuits, including measuring device (MD), from the SUPPLY MAINS including its PROTECTIVE EARTH CONDUCTOR should be guaranteed.

Any connection to earth of the DUT can result in wrong measurement data. Therefore the set-up of the measurement equipment should ensure a galvanic separation from earth, or attention should be drawn to the necessity of isolated positioning of the DUT by an automatic warning or by a clearly visible marking.

- It is recommended to use dedicated test equipment (e.g. dielectric withstand tester, ground bonding and continuity tester, etc.).
- The test equipment should be capable of providing all voltages and currents needed for the range of tests to be performed (e.g. for dielectric testing: voltage and current; for ground bond: current and impedance).
- The test equipment should be easily adaptable to different test requirements. Most modern testers provide this flexibility through programmability plus an ability to recall previously stored test setups on demand.
- The test equipment should be designed so that normal variations in line voltage and connected load do not cause the output voltage and current measured at the DUT to rise above or fall below the levels required for the test. This improves test repeatability and greatly reduces inconsistencies in measurements.
- The test equipment should have a well-designed front panel with easily read digital displays of measurements, settings, and pass/fail indicators. Audible alarms are also desirable. An ability to hold an alarm condition after operator acknowledgment can be useful for later analysis of the fault. All panel items should be clearly marked so that the function of each is readily apparent to anyone looking at the test equipment for the first time.
- The START TEST button, where applicable, should be large, well marked, and protected in a way that prevents accidental activation of a test. The STOP TEST button, where applicable, should also be easily identified (preferably bright red) and placed so as to be quickly found in an emergency.
- Pushbuttons for setting, storing, or recalling test values, alarm limits, and test sequences should be clearly marked and easily operated by test personnel.
- Modern test equipment is equipped with some type of standard data communication interface for connection to remote data processing, computer, or control equipment. The typical interfaces are an IEEE-488 general-purpose interface bus and an RS232 serial communication line.

11.2 Accuracy

The accuracy of the measurement and test equipment measurement range should meet the following typical specifications:

- voltage up to 1 000 V (d.c. up to 1 kHz): $\pm 1,5$ %;
- voltage, 1 000 V and above (d.c. up to 20 kHz): ± 3 %;
- current up to 5 A (d.c. up to 60 Hz): $\pm 1,5$ %;
- current, 5 A and above (d.c. up to 5 kHz): $\pm 2,5$ %;
- LEAKAGE CURRENT: $\pm 3,5$ %;
- power above 1 W and up to 3 kW: ± 3 %;
- power factor: $\pm 0,05$ %;
- frequency: $\pm 0,2$ %;
- resistance: ± 5 %;
- temperature (thermocouple not included) below 100 °C: ± 2 °C;
- temperature (thermocouple not included) 100 °C up to 500 °C: ± 3 %;
- time, 1 s and above: ± 1 %;
- linear dimensions up to 1 mm: $\pm 0,05$ mm;
- linear dimensions, 1 mm up to 25 mm: $\pm 0,1$ mm;
- linear dimensions, 25 mm and above: $\pm 0,5$ %;
- mass, 100 g up to 5 kg: ± 2 %;
- mass, 5 kg and above: ± 5 %;
- force: ± 6 %;
- torque: ± 10 %;
- angles: ± 1 degree;
- relative humidity: ± 6 % RH;
- barometric air pressure: $\pm 0,01$ MPa;
- gas and fluid pressure (for static measurement): ± 5 %.

11.3 Safety criteria for selection

The measurement and test equipment should be selected so that the test operator cannot be accidentally subjected to hazardous voltages and currents such as those used for a dielectric strength test, a line voltage leakage test, or a protective earthing connection and continuity test. It is recommended to use measurement and test equipment which includes safety interlocks that provide protection by automatically shutting down the HIGH VOLTAGE output whenever a safety switch on the DUT is opened. Cables used for HIGH VOLTAGE output and ground clips should be flexible, well insulated, and able to be repeatedly plugged into and removed from the front panel over a long period of time without becoming frayed, worn, or ineffective.

11.4 Calibration

The reference standards (e.g. voltage, current, impedance) used by the equipment supplier for calibrating measurement and test equipment should be certified and traceable to national standards. This ensures sustained integrity of calibration accuracy and compliance with IEC/ISO 17025.

To establish uniform requirements for traceability of calibrations, calibration intervals and to ensure consistent and repeatable test results, reference the specifications included in Annex M.

12 Treatments of unit symbols and measured values

Numeric indications of parameters are to be expressed in SI units according to ISO 31 except the base quantities listed in Table 1. These units can be expressed in the indicated units, which are outside the SI units system.

Table 1 – Units outside the SI units system that may be used

(IEC 60601-1:2005 + IEC 60601-1:2005/AMD1:2012, Table 1)

Base quantity	Unit	
	Name	Symbol
Plane angle	Revolution	r
	Grade	gon or grade
	Degree	°
	Minute of angle	'
	Second of angle	"
Time	Minute	min
	Hour	h
	Day	d
Energy	Electron volt	eV
Volume	Litre	l ^a
Pressure of respiratory gases, blood, and other body fluids	Millimetres of mercury	mmHg
	Centimetres of water	cmH ₂ O
Pressure of gases	Bar	bar
	Millibar	mbar

^a For consistency, in international standards only the symbol "l" is used for litre, although the symbol "L" is also given in ISO 80000-1.

For application of SI units, their multiples and certain other units, ISO 80000-1 applies.

13 PROCEDURES for testing, including particular conditions

13.1 General

The following subclauses contain a framework for performing tests that are required by IEC 60601-1:2005. These are presented as a series of test PROCEDURES. They are divided into three groups:

- tests performed by inspection of the DUT;
- test performed with the DUT not energized; and
- tests performed with the DUT energized.

Each test PROCEDURE is written as a sheet describing:

- a) equipment needed for the test;
- b) safety precautions during the test;
- c) test sample preparation;
- d) test conditions;
- e) test set-up and PROCEDURE; and

f) presentation of the test results.

13.2 Tests to be performed by inspection

Table 2 lists those tests that are performed by inspection of the DUT.

Table 2 – Tests to be performed by inspection

Test per IEC/TR 62354		Clause in IEC 60601-1:1988	Clause in 60601-1:2005+AMD1:2012
No.	Description		
13.2.1	RISK MANAGEMENT PROCESS		4.2, 4.5
13.2.2	Ratings on critical components	56.1	4.8, 4.9, 11.3 and 15.4
13.2.3	Determination of APPLIED PARTS and ACCESSIBLE PARTS		4.6, 5.9, 8.4.2, 9.2.1
13.2.4	Durability and legibility of marking	6.1, 6.2	7.1.2, 7.1.3
13.2.5	Battery markings	6.8.2, 56.7	7.3.3, 15.4.3
13.2.6	PATIENT leads and PATIENT cables		8.5.2.3
13.2.7	Plugs, sockets		8.6.6
13.2.8	POTENTIAL EQUALIZATION TERMINAL	18	8.6.7
13.2.9	MAINS TERMINAL DEVICE	57.5 b)	8.11.4.2 e)
13.2.10	Sharp edges	23	9.3
13.2.11	HAZARDS associated with support systems	21.3	9.8.1, 9.8.3.1, 9.8.4, 9.8.5
13.2.12	Construction requirements for fire ENCLOSURE of ME EQUIPMENT		11.3
13.2.13	Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS	6.1, 6.2, 6.3, 6.4, 6.6, 6.7, 6.8	7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9
13.2.14	USABILITY of ME EQUIPMENT		12.2, 15.1, 7.1.1

13.2.1 RISK MANAGEMENT PROCESS

Standard(s) IEC 60601-1:2005+AMD1:2012	Subclause(s): 4.2, 4.5	13.2.1 RISK MANAGEMENT PROCESS
a) Equipment needed for the test: N/A, if not otherwise specified within the RISK MANAGEMENT FILE.		
b) Safety precautions during the test: According to specification in the RISK MANAGEMENT FILE.		
c) Test sample preparation: One representative test sample. If applicable according to the specification in the RISK MANAGEMENT FILE.		
d) Test conditions: If applicable according to the specification in the RISK MANAGEMENT FILE		
e) Test set-up and PROCEDURE: Inspection of the RISK MANAGEMENT FILE If applicable according to the specification in the RISK MANAGEMENT FILE.		
f) Presentation of the test results: Subclause 4.2.2: The MANUFACTURER has/does not have a policy for determining criteria for RISK acceptability; The MANUFACTURER has/ does not have a RISK MANAGEMENT plan for the particular ME EQUIPMENT or ME SYSTEM under consideration; and The MANUFACTURER has/has not prepared a RISK MANAGEMENT FILE containing the RISK MANAGEMENT RECORDS and other documentation required by this standard for the particular ME EQUIPMENT or ME SYSTEM under consideration. The documents need to be in accordance with ISO 14971. Subclause 4.2.3.1.a): The MANUFACTURER has/has not provided OBJECTIVE EVIDENCE that requirements outside of the IEC 60601-1 series are adequate. NOTE This clause is filled in within the RISK MANAGEMENT FILE only if the MANUFACTURER'S result indicates that requirements within IEC 60601-1 series are inadequate. Subclause 4.2.3.1.b): The MANUFACTURER has/has not provided RECORDS in the RISK MANAGEMENT FILE to demonstrate that, after applying the specific requirements of this standard, the acceptance criteria determined by the MANUFACTURER are satisfied. Subclause 4.2.3.1.c): The MANUFACTURER has/has not provided RECORDS in the RISK MANAGEMENT FILE demonstrate that the RESIDUAL RISK is acceptable using the criteria for RISK acceptability recorded in the RISK MANAGEMENT plan, i.e. no unacceptable RISK remains. Subclause 4.2.3.2 (if applicable): The MANUFACTURER has/has not provided RECORDS in the RISK MANAGEMENT FILE for HAZARDS or HAZARDOUS SITUATIONS that are identified for the particular ME EQUIPMENT or ME SYSTEM but are not specifically addressed in this standard or its collateral or particular standards. Subclause 4.5 (if applicable): The MANUFACTURER has/has not provided RECORDS in the RISK MANAGEMENT FILE that: – an alternative RISK CONTROL measure or test method is acceptable; – can demonstrate through scientific data or clinical opinion or comparative studies that: • the RESIDUAL RISK that results from applying the alternative RISK CONTROL measure or test method remains acceptable, and • is comparable to the RESIDUAL RISK that results from applying the requirements of this standard.		

13.2.2 Ratings on critical components

Standard(s): IEC 60601-1:2005		Subclause(s): 4.8, 4.9, 11.3 and 15.4		13.2.2 Ratings on critical components		
a) Equipment needed for the test: N/A						
b) Safety precautions during the test: N/A						
c) Test sample preparation: One representative test sample. No preparation necessary.						
d) Test conditions: Do not energize the DUT during this test.						
e) Test set-up and PROCEDURE: Examine the circuit diagrams for the DUT to identify any critical components. Identify the types and manufacturers of these components using the parts lists. Obtain the data sheets and/or drawings from each manufacturer that are required to assess whether these components are working within their specified ratings. If the operating conditions cannot be established from the circuit analysis, then determine these ratings based on other tests e.g. heating test, WORKING VOLTAGE etc. Do not check flammability ratings of materials unless the MANUFACTURER has implemented a fire ENCLOSURE. In that case, only subject materials to flammability rating testing (according to Subclause 11.3 of IEC 60601-1:2005) that are either part of the fire ENCLOSURE or are inside the fire ENCLOSURE. This assessment should include the flammability rating of all plastics (i.e. PCBs, connectors, fans, insulators, bobbins, relay housings, plastic fuse holders, sleeving, insulated cables, plastic ENCLOSURES etc.). Only plastics of sufficient size to influence the spread of fire need be assessed. Where several small amounts of a plastic are in the same vicinity then the cumulative effect should be taken into account.						
f) Presentation of the test results:						
TABLE: List of critical components						
Object/ Part No	MANUFACTURE R/ Trademark	Type / Model	Technical data	Operating within ratings (Y/N)	Standard	Mark(s) of conformity
TABLE: Resistance to fire						
Item	Material/type	Manufacturer	Declared rating	Approval		

13.2.3 Determination of APPLIED PARTS and ACCESSIBLE PARTS

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 4.6, 5.9, 8.4.2, 9.2.1	13.2.3 Determination of APPLIED PARTS and ACCESSIBLE PARTS
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Unjointed test finger 2) Jointed test finger (Figure F.1) 3) Test pin (Figure F.3) 4) Force gauge 5) Weight 6) Test hook (Figure F.2) 7) Watch (indicating seconds) 8) Test rod 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative test sample.</p> <p>No preparation necessary.</p>		
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Identify APPLIED PARTS by inspection of the ME EQUIPMENT and ACCOMPANYING DOCUMENTS. Determination of an ACCESSIBLE PART (electrical, hazardous moving, etc.) should be made using test probes (joined and/or rigid test finger, test pin, test hook, test rod). Refer also to Subclause 4.6 of IEC 60601-1:2005/AMD1:2012. 2) Apply the test fingers and pin without force unless a force is specified. Any parts that the test finger or test pin touches are considered to be accessible. 3) Apply the standard test finger in a bent or straight position: <ul style="list-style-type: none"> – to all positions of ME EQUIPMENT when operated as in NORMAL USE – if ME EQUIPMENT can be opened without the use of a TOOL or if the instructions for use describe opening, do this after opening ACCESS COVERS and removal of parts, including lamps, fuses and fuse holders. 4) Apply the standard test finger without appreciable force to all apertures in an attempt to contact hazardous parts (electrical or moving). Apply the test finger to the aperture's openings in every possible way. Do not tilt floor mounted ME EQUIPMENT that has a mass in any operational condition exceeding 45 kg. 5) Test ME EQUIPMENT which its technical description indicates should be mounted into a cabinet in its final mounting position. 6) Test openings into which the standard test finger cannot be put by inserting a straight, unjointed test finger with a force of 30 N. If the finger enters, repeat the test using the standard test finger by pushing the finger through the opening if necessary. 7) Insert the test hook in all relevant openings and the pull it with a force of 20 N for 10 s in a direction substantially perpendicular to the surface of the relevant opening. After applying the test hook, inspect the interior using the standard test finger. 8) Identify any additional parts that become accessible using the standard test finger and by inspection. 		

13.2.3 Determination of APPLIED PARTS and ACCESSIBLE PARTS (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 4.6, 5.9, 8.4.2, 9.2.1	13.2.3 Determination of APPLIED PARTS and ACCESSIBLE PARTS
<p>9) Conductive parts of actuating mechanisms of electrical controls that are accessible after removal of handles, knobs, levers and the like are regarded as ACCESSIBLE PARTS.</p> <p>10) Conductive parts of actuating mechanisms are not considered accessible if removal of handles, knobs, etc. requires the use of a TOOL and inspection of the MANUFACTURER'S RISK MANAGEMENT FILE demonstrates the relevant part is unlikely to become detached unintentionally during the useful life of the ME EQUIPMENT.</p> <p>11) Take any actions the OPERATOR should perform in NORMAL USE (with or without a TOOL) that increase the accessibility of parts (e.g. opening doors, removing covers, adjusting controls, replacing consumable material, removing parts).</p> <p>12) For rack- and panel-mounted ME EQUIPMENT, install the ME EQUIPMENT according to the MANUFACTURER'S instructions. For such ME EQUIPMENT, the OPERATOR is assumed to be in front of the panel.</p> <p>13) Other than contacts of plugs, connectors and socket outlets, the test pin does not contact parts other than those specified in Subclause 8.4.2 c) of IEC 60601-1:2005. Insert in all possible positions with a force up to 1 N.</p> <p>14) Openings in the top or for the adjustment of preset controls are such that access with the test rod does not contact parts other than those specified in Subclause 8.4.2 c) of IEC 60601-1:2005. Insert in all possible positions with a force up to 10 N. If the instructions for use specify a different TOOL for the adjustment of preset controls, repeat the test using that TOOL.</p>		
<p>f) Presentation of the test results:</p>		
<p>List of APPLIED PARTS:</p>		
<p>TABLE: APPLIED PARTS</p>		
<p>Location</p>		<p>Remarks</p>

13.2.4 Durability and legibility of marking

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 7.1.2, 7.1.3	13.2.4 Durability and legibility of marking
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Cloth rag 2) Stop watch/clock (indicating seconds) 3) Distilled water 4) Ethanol 96 % as defined in the European Pharmacopoeia as a reagent in the following terms: C₂H₆O (MW46.07). 5) Isopropyl alcohol – Isopropyl alcohol is defined in the European Pharmacopoeia as a reagent in the following terms: C₃H₈O (MW60.1). 6) Light regulation means 7) Lux meter 8) 1 m / 30° gauge 9) Protective gloves 		
<p>b) Safety precautions during the test:</p> <p>Perform this test in a well-ventilated area.</p> <p>Use appropriate protective gloves when conducting durability of markings test.</p>		
<p>c) Test sample preparation:</p> <p>One sample of marking nameplates attached to the DUT as specified by the MANUFACTURER.</p>		
<p>d) Test conditions:</p> <ol style="list-style-type: none"> 1) Consider the effect of NORMAL USE on markings while evaluating durability. 2) Do not energize the DUT during this test. 		
Marking location		
Use of marking		
Material		
Held by		
Applied surface material		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Durability: Perform the rubbing test using distilled water, methylated spirit and isopropyl alcohol. Rub the markings by hand without undue pressure: <ul style="list-style-type: none"> – first for 15 s with a cloth rag soaked with distilled water, – then for 15 s with a cloth rag soaked with methylated spirit, – and then 15 s with a cloth rag soaked with isopropyl alcohol. 2) Legibility: Position the DUT or its part in the OPERATOR'S intended viewing position, or at any point within the base of a cone subtended by an angle of 30° to the axis normal to the centre of the plane of the marking and at a distance of 1 m. Select the least favourable ambient luminance level in the range of 100 lx to 1 500 lx. The observer who has a visual acuity, corrected if necessary, of 0 on the log minimum angle of resolution (log MAR) scale or 6/6 (20/20), and is able to read N6 of the Jaeger test card, in normal room lighting conditions (approximately 500 lx), needs to correctly perceive the marking from their position. <p>The observer correctly perceives the marking from the viewpoint.</p>		

13.2.4 Durability and legibility of marking *(continued)*

Standard(s): IEC 60601-1:2005+AMD1:2012		Subclause(s): 7.1.2, 7.1.3		13.2.4 Durability and legibility of marking	
f) Presentation of the test results:					
TABLE: Durability and legibility of marking					
Marking	Legible (Y/N)	Curled (Y/N)	Edge lifted (Y/N)	Observation	
The marking was/was not damaged.					
The label was/was not easily removed.					

13.2.5 Battery markings

Standard(s) IEC 60601-1:2005	Subclause(s): 7.3.3	13.2.5 Batteries
a) Equipment needed for the test: N/A		
b) Safety precautions during the test: N/A		
c) Test sample preparation: One representative test sample. No preparation necessary.		
d) Test conditions: Do not energize the DUT during this test.		
e) Test set-up and PROCEDURE: Visual inspection		
<p>f) Presentation of the test results:</p> <p>The battery compartment was/was not marked with the type of battery and the mode of insertion (if applicable).</p> <p>The battery compartment was/was not designed to prevent the RISK of accidentally short-circuiting the battery.</p> <p>The battery compartment was/was not ventilated to minimize the RISK of accumulation and ignition when using batteries from which gases are likely to result in an unacceptable RISK if the gases escape during charging or discharging.</p> <p>The compartment for batteries intended to be changed only by SERVICE PERSONNEL with the use of a TOOL was/was not marked with an identifying marking referring to information provided in the ACCOMPANYING DOCUMENTS.</p> <p>The battery compartment was/was not marked with a warning indicating that only trained personnel can replace the batteries or fuel cells if the incorrect replacement would result in an unacceptable RISK.</p> <p>Identifying marking referring to the ACCOMPANYING DOCUMENTS was/was not provided.</p> <p>The design of the battery charging circuit does/does not prevent overcharging.</p> <p>The primary lithium batteries (cells and assemblies of cells) used in ME EQUIPMENT do/do not comply with the marking requirements of IEC 60086-4.</p> <p>The secondary lithium batteries (cells and assemblies of cells) used in ME EQUIPMENT do/do not comply with the marking requirements of IEC 62133.</p> <p>The INTERNAL ELECTRICAL POWER SOURCE in ME EQUIPMENT does/does not provide an appropriately RATED device that protects against fire due to excessive current if the cross-sectional area and layout of the internal wiring or the rating of connected components can give rise to a fire in case of a short circuit.</p> <p>Protective device(s) have/do not have the adequate breaking capacity to interrupt the maximum fault current (including short-circuit current) that can flow.</p> <p>Justification for omission of fuses or OVER-CURRENT RELEASES was/was not included in the RISK MANAGEMENT FILE.</p> <p>Means of preventing insertion or replacement of a battery incorrectly was/was not provided where an unacceptable RISK might occur.</p>		

13.2.6 PATIENT leads or PATIENT cables

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.5.2.3	13.2.6 PATIENT leads
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Calliper 2) Unjointed test finger 3) Dielectric strength tester 4) Force gauge 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative test sample. No preparation necessary.</p>		
<p>d) Test conditions:</p> <ul style="list-style-type: none"> 1) Do not energize the DUT during this test. 2) This test applies to any connector for electrical connections on a PATIENT lead or cable containing a conductive part that is not separated from all PATIENT CONNECTION(S) by one MEANS OF PATIENT PROTECTION for a WORKING VOLTAGE equal to the MAXIMUM MAINS VOLTAGE. "Said part" refers to the "...conductive part of the connector that is not separated from all PATIENT connections...." 		
<p>e) Test set-up and PROCEDURE:</p> <p>The connector should be constructed so that said part cannot become connected to earth or a possible hazardous voltage while the PATIENT CONNECTION(S) contacts the PATIENT.</p> <ul style="list-style-type: none"> 1) Verify whether said part comes into contact with a flat conductive plate. 2) Measure the AIR CLEARANCE between connector pins and a flat surface. 3) If said part can be plugged into a mains socket, said part should be protected from making contact with parts at MAINS VOLTAGE by at least one insulating means that provides a specified CREEPAGE DISTANCE and a dielectric strength of 1 500 V for 1 min. 4) Apply the straight unjointed test finger in the least favourable position against the access openings with a force of 10 N. 		
<p>f) Presentation of the test results:</p> <p>The said part did/did not come into contact with a flat conductive plate of not less than 100 mm diameter.</p> <p>The AIR CLEARANCE between connector pins and a flat surface was/was not at least 0,5 mm.</p> <p>If able to be plugged into a mains socket outlet, the insulating means did/did not provide a CREEPAGE DISTANCE of at least 1,0 mm.</p> <p>If able to be plugged into a mains socket outlet, there was/was no indication of dielectric breakdown between the said part and the insulating means.</p> <p>The rigid test finger did/did not make electrical contact with the said part.</p>		

13.2.7 Plugs, sockets

Standard(s): IEC 60601-1:2005	Subclause(s): 8.6.6	13.2.7 Plugs, sockets
a) Equipment needed for the test: 1) Callipers		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: One representative test sample. No preparation necessary.		
d) Test conditions: Do not energize the DUT during this test. This test applies where the connection between the SUPPLY MAINS and the DUT or between separate parts of the DUT that can be operated by the OPERATOR is made via a plug and socket device. This also applies if interchangeable parts are PROTECTIVELY EARTHED.		
e) Test set-up and PROCEDURE: Visual inspection and dimensional measurement of the connector pins.		
f) Presentation of the test results: The PROTECTIVE EARTH CONNECTION was/was not made before and interrupted after the supply connections were made or interrupted.		

13.2.8 POTENTIAL EQUALIZATION TERMINAL

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.6.7	13.2.8 POTENTIAL EQUALIZATION TERMINAL
a) Equipment needed for the test: N/A		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: One representative test sample. No preparation necessary.		
d) Test conditions: Do not energize the DUT during this test. This test applies to ME EQUIPMENT that provides a terminal for the connection of a POTENTIAL EQUALIZATION CONDUCTOR.		
e) Test set-up and PROCEDURE: Visual inspection.		
f) Presentation of the test results: The terminal was/was not accessible to the OPERATOR with the DUT in any of its possible NORMAL USE positions. Accidental disconnection was/was not avoided in NORMAL USE. The terminal does/does not allow the conductor to be detached without the use of a TOOL. The terminal was /was not used for a PROTECTIVE EARTH CONNECTION. The terminal was/was not marked with symbol IEC 60417-5021(2002-10). The instruction for use does/does not contain information on the function and use of the POTENTIAL EQUALIZATION CONDUCTOR together with a reference to the requirements of IEC 60601-1:2005 for ME SYSTEMS. The POWER SUPPLY CORD does /does not incorporate a POTENTIAL EQUALIZATION CONDUCTOR.		

13.2.9 MAINS TERMINAL DEVICE

Standard(s): IEC 60601-1:2005	Subclause(s): 8.11.4.2 e)	13.2.9 MAINS TERMINAL DEVICE																
a) Equipment needed for the test: 1) Calliper																		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.																		
c) Test sample preparation: Stripping of insulation.																		
d) Test conditions: Do not energize the DUT during this test.																		
e) Test set-up and PROCEDURE: 1) Strip 8 mm of insulation off of the end of a flexible conductor that has a cross-sectional area as specified in Table 3 and that is used for connection to a MAINS TERMINAL DEVICE. Table 3 – NOMINAL cross-sectional area of conductors of a POWER SUPPLY CORD (IEC 60601-1:2005, Table 17) <table border="1" data-bbox="435 947 1173 1366"> <thead> <tr> <th data-bbox="435 947 805 1052">RATED current (<i>I</i>) of ME EQUIPMENT A</th> <th data-bbox="805 947 1173 1052">NOMINAL cross-sectional area mm² Cu</th> </tr> </thead> <tbody> <tr> <td data-bbox="435 1052 805 1099">$I \leq 6$</td> <td data-bbox="805 1052 1173 1099">0,75</td> </tr> <tr> <td data-bbox="435 1099 805 1146">$6 < I \leq 10$</td> <td data-bbox="805 1099 1173 1146">1</td> </tr> <tr> <td data-bbox="435 1146 805 1193">$10 < I \leq 16$</td> <td data-bbox="805 1146 1173 1193">1,5</td> </tr> <tr> <td data-bbox="435 1193 805 1240">$16 < I \leq 25$</td> <td data-bbox="805 1193 1173 1240">2,5</td> </tr> <tr> <td data-bbox="435 1240 805 1288">$25 < I \leq 32$</td> <td data-bbox="805 1240 1173 1288">4</td> </tr> <tr> <td data-bbox="435 1288 805 1335">$32 < I \leq 40$</td> <td data-bbox="805 1288 1173 1335">6</td> </tr> <tr> <td data-bbox="435 1335 805 1366">$40 < I \leq 63$</td> <td data-bbox="805 1335 1173 1366">10</td> </tr> </tbody> </table> 2) Leave a single wire of the stranded conductor free and secure the rest of the conductor to the terminal to simulate a fully introduced conductor. 3) Bend the free wire in every possible direction without pulling back the insulating sheath and without making sharp bends around partitions. 4) Any contact between the free wire and any other part that short-circuits a MEANS OF PROTECTION constitutes a failure.			RATED current (<i>I</i>) of ME EQUIPMENT A	NOMINAL cross-sectional area mm ² Cu	$I \leq 6$	0,75	$6 < I \leq 10$	1	$10 < I \leq 16$	1,5	$16 < I \leq 25$	2,5	$25 < I \leq 32$	4	$32 < I \leq 40$	6	$40 < I \leq 63$	10
RATED current (<i>I</i>) of ME EQUIPMENT A	NOMINAL cross-sectional area mm ² Cu																	
$I \leq 6$	0,75																	
$6 < I \leq 10$	1																	
$10 < I \leq 16$	1,5																	
$16 < I \leq 25$	2,5																	
$25 < I \leq 32$	4																	
$32 < I \leq 40$	6																	
$40 < I \leq 63$	10																	

13.2.9 MAINS TERMINAL DEVICE (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 8.11.4.2 e)	13.2.9 MAINS TERMINAL DEVICE
f) Presentation of the test results:		
TABLE: MAINS TERMINAL DEVICE		
Conductor stripped:	Contact to other parts:	MEANS OF PROTECTION short-circuited: Yes/No

13.2.10 Sharp edges

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.3	13.2.10 Sharp edges
a) Equipment needed for the test: N/A		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: One representative sample with fully loaded options/ACCESSORIES, consisting of the complete ENCLOSURE in its normal position.		
d) Test conditions: Accessible edges or corners of the DUT, except those required for proper functioning of the ME EQUIPMENT were assessed. Do not energize the DUT during this test.		
e) Test set-up and PROCEDURE: Surfaces described below are judged for sharp edges.		
Surface	Material	Observations
f) Presentation of the test results:		
TABLE: Sharp edges		
Edge location	Unacceptable RISK present	
	<u>Yes/No</u>	
The edges and corners were/were not considered to be rounded and smooth.		
The HAZARDS related to sharp edges are/are not included in the RISK MANAGEMENT FILE.		

13.2.11 HAZARDS associated with support systems

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.8.1, 9.8.3.1, 9.8.4, 9.8.5	13.2.11 HAZARDS associated with support systems
<p>a) Equipment needed for the test: N/A</p>		
<p>b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation: One representative sample with fully loaded options/ACCESSORIES, consisting of the complete ENCLOSURE in its normal position.</p>		
<p>d) Test conditions: Do not energize the DUT during this test.</p>		
<p>e) Test set-up and PROCEDURE: The DUT is evaluated for HAZARDS associated with support systems based on visual inspection of the ME EQUIPMENT and on inspection of the documentation provided.</p>		
<p>f) Presentation of the test results:</p> <p>The construction of the support, suspension or actuation system is/is not designed based upon determination of TENSILE SAFETY FACTOR and the TOTAL LOAD.</p> <p>Means of attachment of ACCESSORIES are/are not designed such that any possibility of incorrect attachment that could result in an unacceptable RISK is avoided.</p> <p>The RISK ANALYSIS of support systems does/does not consider HAZARDS arising from static, dynamic, vibration, impact and pressure loading, foundation and other movements, temperature, environmental, manufacture and service conditions.</p> <p>All likely failure effects were/were not considered in the RISK ANALYSIS. These include excessive deflection, plastic deformation, ductile or brittle fracture, fatigue fracture, instability (buckling), stress-assisted corrosion cracking, wear, material creep, material deterioration and residual stresses resulting from the manufacturing PROCESSES, e.g. machining, assembling, welding, heat treatment or surface coating.</p> <p>The ACCOMPANYING DOCUMENTS contain/do not contain instructions on attachment of structures to a floor, wall, ceiling, etc. making adequate allowances for quality of the materials used to make the connection and list the required materials. Additionally advice/no advice on checking the adequacy of the surface of the structure to which the parts will be attached. Additionally, the ACCOMPANYING DOCUMENTS provide/do not provide instructions that once the MECHANICAL PROTECTIVE DEVICE has been activated, SERVICE PERSONNEL are to be called and the MECHANICAL PROTECTIVE DEVICE has to be replaced before the ME EQUIPMENT can be used again.</p> <p>The DUT is/is not marked properly.</p> <p>The DUT does/does not require a MECHANICAL PROTECTIVE DEVICE.</p> <p>Where required, the MECHANICAL PROTECTIVE DEVICE is/is not designed on the basis of TOTAL LOAD, which includes SAFE WORKING LOAD when applicable.</p>		

13.2.11 HAZARDS associated with support systems (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.8.1, 9.8.3.1, 9.8.4, 9.8.5	13.2.11 HAZARDS associated with support systems
<p>The MECHANICAL PROTECTIVE DEVICE has/does not have the TENSILE SAFETY FACTORS for all parts correct selected.</p> <p>The MECHANICAL PROTECTIVE DEVICE activates/does not activate before travel (movement) produces an unacceptable RISK.</p> <p>The MECHANICAL PROTECTIVE DEVICE takes into account/does not account for continuous activation and MECHANICAL PROTECTIVE DEVICE intended for single activation.</p> <p>It did/did not become obvious that the MECHANICAL PROTECTIVE DEVICE has been activated.</p> <p>The MECHANICAL PROTECTIVE DEVICE requires/does not require the use of a TOOL to be reset or replaced.</p> <p>Further use of the ME EQUIPMENT is/is not impossible until the MECHANICAL PROTECTIVE DEVICE has been replaced.</p> <p>The marking is/is not adjacent to the MECHANICAL PROTECTIVE DEVICE or so located that its relation to the MECHANICAL PROTECTIVE DEVICE is obvious to the person performing service or repair.</p> <p>There was / was no damage to the MECHANICAL PROTECTIVE DEVICE that would affect its ability to perform its intended function.</p> <p>Support system parts are/are not impaired by wear.</p>		


13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT

Standard(s): IEC 60601-1:2005	Subclause(s): 11.3	13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT																								
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Calliper 2) Metric gauge pins 3) Inclinator 																										
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																										
<p>c) Test sample preparation:</p> <p>One representative test sample.</p>																										
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>																										
<p>e) Test set-up and PROCEDURE:</p> <ul style="list-style-type: none"> 1) Flammability ratings of materials are to be checked only where the MANUFACTURER has implemented a fire ENCLOSURE and only if the materials used as part of the fire ENCLOSURE or inside of the fire ENCLOSURE are subject to flammability rating requirements according to Subclause 11.3 of IEC 60601-1:2005. Part of this assessment should include the flammability rating of all plastics (i.e. PCBs, connectors, fans, insulators, bobbins, relay housings, plastic fuse holders, sleeving, insulated cables, insulated wire, plastic ENCLOSURES, etc). <p>NOTE Only plastics of sufficient size to influence the spread of fire need be assessed Where several small amounts of a plastic are in the same vicinity then the cumulative effect should be taken into account.</p> <ul style="list-style-type: none"> 2) Inspect bottom and side ENCLOSURE openings in accordance with Subclause 11.3.b) 1) and 2) of IEC 60601-1:2005. 3) Inspect the ENCLOSURE and any baffle or flame barrier in accordance with Subclause 11.3 b) 3) of IEC 60601-1:2005. 																										
<p>f) Presentation of the test results:</p> <table border="1" data-bbox="323 1366 1302 1644"> <thead> <tr> <th colspan="4" data-bbox="323 1366 1302 1411"> TABLE: Resistance to fire </th> </tr> <tr> <th data-bbox="323 1411 491 1456"> Item </th> <th data-bbox="491 1411 683 1456"> Material/type </th> <th data-bbox="683 1411 946 1456"> Manufacturer </th> <th data-bbox="946 1411 1302 1456"> Flame rating </th> </tr> </thead> <tbody> <tr> <td data-bbox="323 1456 491 1500"></td> <td data-bbox="491 1456 683 1500"></td> <td data-bbox="683 1456 946 1500"></td> <td data-bbox="946 1456 1302 1500"></td> </tr> <tr> <td data-bbox="323 1500 491 1545"></td> <td data-bbox="491 1500 683 1545"></td> <td data-bbox="683 1500 946 1545"></td> <td data-bbox="946 1500 1302 1545"></td> </tr> <tr> <td data-bbox="323 1545 491 1590"></td> <td data-bbox="491 1545 683 1590"></td> <td data-bbox="683 1545 946 1590"></td> <td data-bbox="946 1545 1302 1590"></td> </tr> <tr> <td data-bbox="323 1590 491 1644"></td> <td data-bbox="491 1590 683 1644"></td> <td data-bbox="683 1590 946 1644"></td> <td data-bbox="946 1590 1302 1644"></td> </tr> </tbody> </table> <p>Insulated wire used within a fire ENCLOSURE has/does not have a flammability rating of FV-1 or better;</p> <p>Connectors, printed circuit boards and insulating material on which components are mounted have/do not have a flammability classification of FV-2 or better.</p>			TABLE: Resistance to fire				Item	Material/type	Manufacturer	Flame rating																
TABLE: Resistance to fire																										
Item	Material/type	Manufacturer	Flame rating																							

13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 11.3	13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT
----------------------------------	-----------------------	---

The bottom **has no openings/has openings** complying with Figure 1 constructed with baffles according to Figure 2 or is made of metal perforated according to Table 4 or is made with a metal screen with a mesh not exceeding 2 mm by 2 mm center to center and a wire diameter of at least 0,45 mm.




Key

- A Part or component of the ME EQUIPMENT that is considered to be a source of fire. This consists of an entire component or part of the ME EQUIPMENT if it is not otherwise shielded, or the unshielded portion of a component that is partially shielded by its casing.
- B Projection of the outline of A on the horizontal plane.
- C Inclined line that traces out the minimum area of the bottom and sides to be constructed as specified in 11.3 b) 1) and 11.3 b) 2). This line projects at a 5° angle from the vertical at every point around the perimeter of A and is oriented so as to trace out the maximum area.
- D Minimum area of the bottom to be constructed as specified in 11.3 b) 1) [of the General Standard].

Figure 1 – Area of the bottom of an ENCLOSURE as specified in 11.3 b) 1)

(IEC 60601-1:2005, Figure 39)



Y = twice X but never less than 25 mm

- ① Baffle plates (may be below the bottom of the ENCLOSURE)
- ② Bottom of the ENCLOSURE

Figure 2 – Baffle

(IEC 60601-1:2005, Figure 38)

13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 11.3</p>	<p>13.2.12 Construction requirements for fire ENCLOSURE of ME EQUIPMENT</p>
<p align="center">Table 4 – Acceptable perforation of the bottom of an ENCLOSURE (IEC 60601-1:2005, Table 25)</p>		
<p align="center">Minimum thickness mm</p>	<p align="center">Maximum diameter of holes mm</p>	<p align="center">Minimum spacing of holes centre to centre mm</p>
0,66	1,14	1,70 (233 holes/645 mm ²)
0,66	1,19	2,36
0,76	1,15	1,70
0,76	1,19	2,36
0,81	1,91	3,18 (72 holes/645 mm ²)
0,89	1,90	3,18
0,91	1,60	2,77
0,91	1,98	3,18
1,00	1,60	2,77
1,00	2,00	3,00
<p>Sides have no/have openings within the area that is included within the incline line C in Figure 1. The ENCLOSURE, any baffle or flame barrier is/is not made of metal (except magnesium) or non-metallic materials RATED FV-2 or better for TRANSPORTABLE ME EQUIPMENT and FV-1 or better for FIXED or STATIONARY ME EQUIPMENT. For constructions according to Table 4 and metal screen mesh, see above.</p>		

13.2.13 Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS

Standard(s) IEC 60601-1:2005+AMD1:2012	Subclause(s): 7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9	13.2.13 Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS
a) Equipment needed for the test: N/A		
b) Safety precautions during the test: N/A		
c) Test sample preparation: One representative test sample. No preparation necessary.		
d) Test conditions: Do not energize the DUT during this test. Evaluate the marking and the ACCOMPANYING DOCUMENTS provided with the DUT.		
e) Test set-up and PROCEDURE: Evaluate the markings on the DUT, the colours of insulation and indicators and controls, and the ACCOMPANYING DOCUMENTS provided with the DUT against the requirements in the standard.		
f) Presentation of the test results: 1) IEC 60601-1:1988: The markings on the outside of ME EQUIPMENT or ME EQUIPMENT parts do/do not satisfy the requirements of Subclause 6.1. The markings on the inside of ME EQUIPMENT or ME EQUIPMENT parts do/do not satisfy the requirements of Subclause 6.2. The marking of controls and instruments do/do not satisfy the requirements of Subclause 6.3. Any symbols do/do not satisfy the requirements of Subclause 6.4. The colours of the insulation of conductors do/do not satisfy the requirements of Subclause 6.5. The colours of indicator lights and controls do/do not satisfy the requirements of Subclause 6.7. The ACCOMPANYING DOCUMENTS do/do not satisfy the requirements of Subclause 6.8.		
2) IEC 60601-1:2005 + IEC 60601-1:2005/AMD1:2012: The markings on the outside of ME EQUIPMENT or ME EQUIPMENT parts do/do not satisfy the requirements of Subclause 7.2. The markings on the inside of ME EQUIPMENT or ME EQUIPMENT parts do/do not satisfy the requirements of Subclause 7.3. The marking of controls and instruments do/do not satisfy the requirements of Subclause 7.4. Any safety signs do/do not satisfy the requirements of Subclause 7.5. Any symbols do/do not satisfy the requirements of Subclause 7.6. The colours of the insulation of conductors do/do not satisfy the requirements of Subclause 7.7. The colours of indicator lights and controls do/do not satisfy the requirements of Subclause 7.8. The ACCOMPANYING DOCUMENTS do/do not satisfy the requirements of Subclause 7.9.		

13.2.14 USABILITY of ME EQUIPMENT

Standard(s) IEC 60601-1:2005+AMD1:2012	Subclause(s): 12.2, 15.1, 7.1.1	13.2.14 Usability of ME EQUIPMENT
a) Equipment needed for the test: N/A		
b) Safety precautions during the test: N/A		
c) Test sample preparation: No preparation necessary.		
d) Test conditions: N/A.		
e) Test set-up and PROCEDURE: Evidence of compliance with this subclause and all requirements of this standard referring to inspection of the USABILITY ENGINEERING file are satisfied if the MANUFACTURER has: <ul style="list-style-type: none"> – established a USABILITY ENGINEERING PROCESS; – established acceptance criteria for USABILITY; and – demonstrated that the acceptance criteria for USABILITY have been met. 		
f) Presentation of the test results: The MANUFACTURER has/has not elaborated a USABILITY ENGINEERING file. The MANUFACTURER has/has not elaborated a USABILITY specifications document. The MANUFACTURER has/has not established a USABILITY validation plan The MANUFACTURER has/has not identified known or foreseeable HAZARDS related to USABILITY, analysed these HAZARDS according ISO 14971 and are included in the RISK MANAGEMENT FILE.		

13.3 Measurements and tests performed on non-energized equipment

Table 5 lists those measurements and tests that are performed on a non-energized DUT.

Table 5 – Measurements and tests performed on non-energized equipment

Test per IEC/TR 62354		Clause in IEC 60601-1:1988	Clause in 60601-1:2005
No.	Description		
13.3.1	Humidity preconditioning	4.10, 44.5	5.7
13.3.2	Impedance of PE connection	18 f)	8.6.4
13.3.3	Dielectric strength	20.4	8.8.3
13.3.4	Ball pressure	59.2 b)	8.8.4.1
13.3.5	Resistance to environmental stress		8.8.4.2
13.3.6	Thermal cycling		8.9.3.4
13.3.7	CREEPAGE DISTANCES and AIR CLEARANCES	59.2	8.9.4
13.3.8	Strain relief (cord anchorage)	57.4 a)	8.11.3.5
13.3.9	Cord guard flexing (cord bending)	57.4 b)	8.11.3.6
13.3.10	Access to hazardous moving parts		9.2.1
13.3.11	Gaps		9.2.2.2
13.3.12	Instability(in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)	24	9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2
13.3.13	Castors and wheels (force for propulsion, movement over a threshold)		9.4.2.4.2, 9.4.2.4.3
13.3.14	Handle loading	21 c)	9.4.4
13.3.15	Safety catch evaluation	28.3	9.8.1, 9.8.2
13.3.16	Support loading	28.4	9.8.3
13.3.17	Overflow	44.2	11.6.2
13.3.18	Spillage	44.3	11.6.3
13.3.19	Leakage	44.4	11.6.4, 13.2.6
13.3.20	Ingress of water or particulate matter	44.6	11.6.5
13.3.21	Cleaning, sterilization and disinfection	44.7	11.6.6, 11.6.7
13.3.22	Push (rigidity)	21	15.3.2
13.3.23	Impact	21; 22	15.3.3
13.3.24	Drop impact	21.5; 21.6	15.3.4
13.3.25	Rough handling	21.6	15.3.5, 9.4.2.4.3
13.3.26	Mould stress relief		15.3.6
13.3.27	Actuating parts of controls (Knob pull and limitation of movement)	56.10 b) and c)	15.4.6.1, 15.4.6.2
13.3.28	Construction of transformers		15.5.3

13.3.1 Humidity preconditioning

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 5.7	13.3.1 Humidity preconditioning		
a) Equipment needed for the test:				
<p>1) Environment chamber with control over humidity in the range of (93 ± 3) % relative humidity (RH) and temperature in the range of (20 ± 2) °C to (30 ± 2) °C</p> <p>2) Relative humidity and temperature recording equipment</p>				
b) Safety precautions during the test:				
Use normal laboratory safety PROCEDURES during this test.				
c) Test sample preparation:				
<p>This test is to be applied only to those ME EQUIPMENT parts likely to be influenced by the climatic conditions that are simulated by the test.</p> <p>One representative test sample.</p> <p>Prior to conditioning, parts of the DUT (covers) that could be removed without the use of TOOLS were removed and separately placed in the chamber.</p> <p>During conditioning, cable entrances and/or a conduit opening were left open.</p> <p>Do not energize the DUT during this test.</p>				
d) Test conditions:				
A humidity chamber having relative humidity of 93 % ± 2 % is set to any convenient temperature (<i>T</i>) between 20 °C and 32 °C. The DUT, before being placed in the chamber, is brought to a temperature between <i>T</i> and (<i>T</i> + 4) °C and kept at this temperature for a minimum of 4 h.				
e) Test set-up and PROCEDURE:				
<p>1) Place the DUT in the humidity chamber and kept it there for:</p> <ul style="list-style-type: none"> - 2 days (48 h) for ordinary (IPX0) ME EQUIPMENT or ME EQUIPMENT parts. - 7 days (168 h) for IPX1 – IPX8 . - If the RISK MANAGEMENT PROCESS suggests that the ME EQUIPMENT might be exposed to high humidity for extended periods (such as ME EQUIPMENT intended for out-door use), the period should be extended appropriately (for IEC 60601-1:2005 only). <p>During this time the temperature of the air in the chamber is maintained at <i>T</i> ± 2 °C.</p> <p>2) While still in the humidity chamber, but after all parts have been placed back on the DUT, the dielectric strength test according to Subclause 13.3.3 of IEC 60601-1:2005 should be performed for a period of 1 min between applicable parts.</p> <p>3) Then the DUT is removed from the chamber, placed in a normal environment (temperature approximately <i>T</i>, humidity 45 % – 65 %) and 1 h later (for the IEC 60601-1:1988 only) LEAKAGE CURRENT tests are performed according to Subclauses 13.4.7 – 13.4.12 of IEC 60601-1:2005.</p>				
f) Presentation of the test results:TABLE: Humidity preconditioning				
Identification of ME EQUIPMENT and its parts/IP rating	Soak temperature °C	Soak humidity % RH	Soak duration h	Remarks

13.3.2 Impedance of PE connection

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.6.4	13.3.2 Impedance of PE connection		
<p>a) Equipment requested for the testing:</p> <ol style="list-style-type: none"> 1) Adjustable a.c. current source with a frequency of 50 Hz,60 Hz or d.c. and with a no-load voltage not exceeding 6 V, which is able to produce 25 A or 1,5 times the highest RATED current of the relevant circuit(s), whichever is greater ($\pm 10\%$) 2) Suitable voltmeter and ammeter 3) Assorted connectors and cables 4) Shunt, or 5) Ground bond tester 				
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p> <p>High current testing can cause excessive localized heating of conductive parts and possible burns. An operator wearing conductive jewellery needs to take precautions to ensure contact with the high current test circuit is prevented.</p>				
<p>c) Test sample preparation:</p> <p>One representative test sample.</p>				
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>				
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) A test current of 25 A or 1,5 times the highest RATED current of the relevant circuit(s), whichever is greater ($\pm 10\%$), from a current source with a frequency of 50 Hz , 60 Hz or d.c. and with a no-load voltage not exceeding 6 V, is passed for 5 s to 10 s through: <ul style="list-style-type: none"> – the PROTECTIVE EARTH TERMINAL or the protective earth contact in the APPLIANCE INLET or the protective earth pin in the MAINS PLUG and each PROTECTIVELY EARTHED part – each protectively earthed part or the MAINS PLUG of any DETACHABLE POWER SUPPLY CORD supplied or specified by the MANUFACTURER, when attached to the ME EQUIPMENT, and any part of the ME EQUIPMENT that is PROTECTIVELY EARTHED. <p>Where a DETACHABLE POWER SUPPLY CORD is neither supplied nor specified, test using a 3 m long cord of appropriate cross sectional area based on IEC 60601-1:2005+AMD1:2012 clause 8.11.3.3 and Table 17.</p> 2) The voltage drop between the earth terminal and the part to be earthed is measured, and the resistance between these two points is to be calculated. 3) The test instrument leads impedance should be considered. 				
<p>f) Presentation of the test results:</p>				
<p>TABLE: Impedance of PE connection</p>				
<p>Test location</p>	<p>Test current (I) A</p>	<p>Duration s</p>	<p>Measured voltage (U) V</p>	<p>Resistance (R) Ω</p>
<p>$R = U/I$</p> <p>The calculated resistance:</p> <p>() did not exceed 100 mΩ for PERMANENTLY INSTALLED ME EQUIPMENT, and for ME EQUIPMENT with an APPLIANCE INLET;</p> <p>() did not exceed 200 mΩ for ME EQUIPMENT with a NON-DETACHABLE POWER SUPPLY CORD.</p>				

13.3.3 Dielectric strength

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 8.8.3</p>	<p>13.3.3 Dielectric strength</p>
<p>a) Equipment needed for the test:</p> <p>Dielectric strength a.c. and/or d.c tester (HiPot) as appropriate.</p> <p>In order to ensure standardized control of test voltage in time, testers with program controlled test voltage are recommended. Manual adjustment of the test voltage in certain circumstances can be valuable.</p> <p>The test equipment should display the current measurement through the insulation.</p> <p>Alternatively, where needed, current can be measured using an ammeter in series providing it has sufficient protection against the HIGH VOLTAGE of the test. Adding series connected impedances can protect the ammeter from HIGH VOLTAGE. For older dielectric strength test equipment, any means to measure ramp time (stop watch, watch or clock) can be used.</p> <p>Provide elements ensure spatial separation between test operator and DUT located together with eventual auxiliary measuring devices in HIGH VOLTAGE area.</p>		
<p>b) Safety precautions during the test:</p> <p>The DUT, test equipment, test leads and any auxiliary equipment and components should not be accessible upon commencement of the HIGH VOLTAGE.</p> <p>Provide adequate markings and warnings at the testing location. Give special consideration to the possibility someone might come into contact with the HIGH VOLTAGE.</p> <p>Design the test station so that accidental touching of parts at HIGH VOLTAGE is not possible.</p> <p>Test operators should not be able to keep test probes in their hands during HIGH VOLTAGE activation.</p> <p>Put precautions in place to prevent conductive liquids from being near the test station.</p> <p>Take steps (including training) to ensure that the test operator is not distracted during the test. (Conversations with others or telephone calls for example).</p> <p>Test operator(s) are properly trained, authorized and physically/mentally able to perform the test.</p>		
<p>c) Test sample preparation:</p> <ol style="list-style-type: none"> 1) The configuration(s) of the DUT must allow all safety insulations to be tested according to the insulation diagram. 2) Observe standard requirements that allow for short-circuiting of either circuit side of the electrical test node and the removal of specified components. 3) When testing across more than one safety insulation, give consideration to the effects different impedances have on the safety insulation involved and over-voltage stressing of particular safety insulation in the test circuit path. In such test situations, a separate test of each safety insulation using the applicable dielectric strength test voltage might be necessary. 4) Tightly cover ENCLOSURES or their parts made of non-conductive material with foil. Place foil so that it does not bridge the safety insulation under test but does test all applicable areas. 5) The surface of cables and lead wires connected to the DUT should be treated as parts of the DUT ENCLOSURE. 6) The surface of mains power cords can be exempt from wrapping with foil and inclusion as an electrical test node based on relevant analysis of the component. 		

13.3.3 Dielectric strength (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.8.3	13.3.3 Dielectric strength		
<p>d) Test conditions:</p> <p>Connect test circuits (switches and relay contacts closed) and do not energize the DUT. If necessary (to prevent battery powered DUT's from being energized), use a solid piece of insulation to block one pole of the battery.</p> <p>Perform testing immediately after humidity preconditioning treatment, after any required sterilization PROCEDURE, and after reaching the steady state operating from the excessive temperature test.</p>				
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Prior to the test, discuss the equipment design, insulation diagram and appropriate test strategy with the MANUFACTURER. Determine the dielectric strength voltage and waveform to be applied across each safety insulation and circuit arrangement including any components to be removed and any circuits to be short-circuited. 2) Where appropriate, apply two MEANS OF PROTECTION according to IEC/TR 60513. 3) Perform the testing across the single MEANS OF PROTECTION safety insulation prior to the two MEANS OF PROTECTION safety insulation. 4) Perform each dielectric strength test in the sequence by applying not more than half the test voltage, then ramping the voltage over a 10 s period, holding for 1 min and ramping over a 10 s period to less than half the test voltage. 5) Breakdown (current that rapidly increases in an uncontrolled manner) constitutes a failure. Corona discharge or a single momentary flashover is not regarded as insulation breakdown. 6) Observing the linear relationship between a change in the dielectric strength test voltage to change in current through the safety insulation can provide useful information about the safety insulation. 				
<p>f) Presentation of the test results:</p> <p>There was/was no indication of dielectric breakdown.</p>				
<p>TABLE: Dielectric strength</p>				
Insulation under test (area from insulation diagram)	Insulation type: (BI-BASIC / SI-SUPPLEMENTARY / DI-DOUBLE / RI-REINFORCED) (for IEC 60601-1:1988) (Functional / one MOOP / two MOOP / one MOPP / two MOPP) (for IEC 60601-1:2005)	WORKING VOLTAGE V	Test voltage V	Remarks

13.3.4 Ball pressure

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.8.4.1	13.3.4 Ball pressure																																							
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Ball pressure apparatus (Figure F.4) 2) Heating cabinet with temperature measuring device 3) Calliper with magnifying feature or additional magnifying equipment 4) Watch/clock 5) Support for specimen with place to embed thermocouple 																																									
<p>b) Safety precautions during the test:</p> <p>No special safety precaution required.</p>																																									
<p>c) Test sample preparation:</p> <p>Special preparation of the insulating material might be necessary in order to be able to perform the test.</p> <p>The thickness of the material to be tested should be at least 2,5 mm (radius of the ball).</p>																																									
<p>d) Test conditions:</p> <p>The temperature in the heating cabinet should be brought up to a temperature related to the use of the insulating material. For example:</p> <ul style="list-style-type: none"> - 75 ± 2 °C or maximum ambient operating temperature specified in the technical description ± 2 °C plus the temperature rise that was determined during the test for normal heating (test 13.4.17) of the relevant part of the insulating material, whichever is the higher (for parts of the ENCLOSURE and other external insulating parts); or - 125 °C ± 2 °C or maximum ambient operating temperature specified in the technical description ± 2 °C plus the temperature rise that was determined during the test for normal heating (test 13.4.17) of the relevant part of the insulating material, whichever is the higher (for parts of insulating material which support uninsulated parts of the MAINS PART). 																																									
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) The heating cabinet is brought up to the pre-determined temperature. The cabinet temperature should be uniform and maintained for 1 h. 2) The insulating material to be tested is placed in the cabinet on a solid horizontal support. 3) The ball pressure apparatus is placed upon the insulating material to be tested. 4) The ball is withdrawn after 1 h and the diameter of the impression made by the ball is measured with a slide calliper. 																																									
<p>f) Presentation of the test results:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Part name</th> <th style="text-align: center;">Material</th> <th style="text-align: center;">Thickness mm</th> <th style="text-align: center;">Temperature rise during normal heating</th> <th style="text-align: center;">Temperature during test</th> <th style="text-align: center;">Diameter of impression</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>						Part name	Material	Thickness mm	Temperature rise during normal heating	Temperature during test	Diameter of impression																														
Part name	Material	Thickness mm	Temperature rise during normal heating	Temperature during test	Diameter of impression																																				

13.3.5 Resistance to environmental stress

Standard(s): IEC 60601-1:2005	Subclause(s): 8.8.4.2	13.3.5 Resistance to environmental stress
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) An oxygen cylinder with a capacity at least 10 times the volume of the test samples. The cylinder has the means to suspend the test sample and to be filled with oxygen and hold pressure of 2,1 MPa ± 70k Pa. 2) Commercial oxygen that is not less than 97 % pure. 3) Clock or watch to measure time. 4) A means to heat the test sample to 70 °C ± 2 °C. 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p> <p>Careful consideration to the handling of concentrated oxygen under pressure including the flammability of such mixture.</p>		
<p>c) Test sample preparation:</p> <p>Disassemble the DUT so that ceramic materials, beads and insulating material of heating conductors may be inspected.</p> <p>Acquire parts that are used for safety insulation and are made of natural latex rubber for the test.</p> <p>Suspend these parts within the oxygen cylinder.</p>		
<p>d) Test conditions:</p> <p>Prior to inspection of safety insulation parts, consider the MANUFACTURER'S recommendations for the environment and EXPECTED SERVICE LIFE including the wear of parts within the DUT that could result in the disposition of dust or conductive particles that could impact CREEPAGE DISTANCES OR AIR CLEARANCES.</p> <p>For insulation parts made of natural latex rubber provide an environment of oxygen at 2,1 MPa ± 70 kPa at a temperature of 70 °C ± 2 °C for 96 h.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Ceramic material not tightly sintered, and the like, and beads alone are checked by inspection, that they are not used as SUPPLEMENTARY OR REINFORCED INSULATION. 2) Insulating material in which heating conductors are embedded is also checked by inspection, that it is not used as two MEANS OF PROTECTION. 3) The CREEPAGE DISTANCES and AIR CLEARANCES of any MEANS OF PROTECTION are not to be reduced below the values specified in Subclause 8.9 of IEC 60601-1:2005 caused by environmental stresses including impairment by deposition of dirt or dust resulting from wear of parts. 4) Parts of natural latex rubber are aged in an atmosphere of oxygen under pressure. The samples are suspended freely in an oxygen cylinder, the effective capacity of the cylinder is at least 10 times the volume of the samples. The cylinder is filled with commercial oxygen not less than 97 % pure, to a pressure of 2,1 MPa ± 70 kPa. 5) The samples are kept in the cylinder at a temperature of 70 °C ± 2 °C for 96 h. Immediately afterwards, they are taken out of the cylinder and left at room temperature for at least 16 h. After the test, the samples are examined. Cracks visible to the naked eye constitute a failure. 		
<p>f) Presentation of the test results:</p> <p>Ceramic material not tightly sintered, and the like, and beads alone are not/are used as SUPPLEMENTARY OR REINFORCED INSULATION.</p> <p>Insulating material in which heating conductors are embedded is/is not used as TWO MEANS OF PROTECTION.</p> <p>Cracks visible to the naked eye were/were not found upon inspection of natural latex rubber after exposure to oxygen at pressure and temperature as specified herein.</p>		

13.3.6 Thermal cycling



Standard(s): IEC 60601-1:2005	Subclause(s): 8.9.3.4	13.3.6 Thermal cycling																		
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Environmental chamber 2) Dielectric strength tester 																				
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																				
<p>c) Test sample preparation:</p> <p>This test is to be applied only to ME EQUIPMENT containing insulating compound forming solid insulation between conductive parts and insulating compound forming a cemented joint with other insulating parts.</p>																				
<table border="1"> <thead> <tr> <th data-bbox="204 730 550 775">Insulating compound</th> <th data-bbox="550 730 1070 775">Description</th> <th data-bbox="1070 730 1396 775">Location</th> </tr> </thead> <tbody> <tr> <td data-bbox="204 775 550 819">1)</td> <td data-bbox="550 775 1070 819"></td> <td data-bbox="1070 775 1396 819"></td> </tr> <tr> <td data-bbox="204 819 550 864">2)</td> <td data-bbox="550 819 1070 864"></td> <td data-bbox="1070 819 1396 864"></td> </tr> </tbody> </table>	Insulating compound	Description	Location	1)			2)			<table border="1"> <thead> <tr> <th data-bbox="550 730 1070 775">Description</th> <th data-bbox="1070 730 1396 775">Location</th> </tr> </thead> <tbody> <tr> <td data-bbox="550 775 1070 819">1)</td> <td data-bbox="1070 775 1396 819"></td> </tr> <tr> <td data-bbox="550 819 1070 864">2)</td> <td data-bbox="1070 819 1396 864"></td> </tr> </tbody> </table>	Description	Location	1)		2)		<table border="1"> <thead> <tr> <th data-bbox="1070 730 1396 775">Location</th> </tr> </thead> <tbody> <tr> <td data-bbox="1070 775 1396 819">1)</td> </tr> <tr> <td data-bbox="1070 819 1396 864">2)</td> </tr> </tbody> </table>	Location	1)	2)
Insulating compound	Description	Location																		
1)																				
2)																				
Description	Location																			
1)																				
2)																				
Location																				
1)																				
2)																				
<p>One representative test sample.</p> <p>Do not energize the DUT during this test.</p>																				
<p>d) Test conditions:</p> <ul style="list-style-type: none"> 1) For situations where insulating compound forms solid insulation between conductive parts, a single finished sample is tested. The sample is subjected to the thermal cycling PROCEDURE, followed by humidity preconditioning according to Subclause 5.7 of IEC 60601-1:2005 for 48 h only and then followed by a dielectric strength test except that the test voltage is multiplied by 1,6. 2) For situations where insulating compound forms a cemented joint with other insulating parts, the reliability of the joint is checked by testing three samples. If a winding of solvent-based enamelled wire is used, it is replaced for the test by a metal foil or by a few turns of bare wire, placed close to the cemented joint. The three samples are then tested as follows. <ul style="list-style-type: none"> - One of the samples is subjected to the thermal cycling PROCEDURE. Immediately after the last period at highest temperature during thermal cycling it is subjected to a dielectric strength test except that the test voltage is multiplied by 1,6. - The other two samples are subjected to the thermal cycling PROCEDURE and after the last cycle, are subjected to humidity preconditioning according to Subclause 5.7 of IEC 60601-1:2005 for 48 h only, followed by a dielectric strength test except that the test voltage is multiplied by 1,6. 																				

13.3.6 Thermal cycling (continued)														
Standard(s): IEC 60601-1:2005	Subclause(s): 8.9.3.4	13.3.6 Thermal cycling												
<p>e) Test set-up and PROCEDURE:</p> <p>The sample is subjected 10 times to the following sequence of temperature cycles:</p> <table style="margin-left: 40px;"> <tr> <td style="padding-right: 20px;">68 h</td> <td style="padding-right: 20px;">at</td> <td>$T_1 \pm 2 \text{ }^\circ\text{C}$;</td> </tr> <tr> <td>1 h</td> <td>at</td> <td>$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;</td> </tr> <tr> <td>2 h</td> <td>at</td> <td>$0 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;</td> </tr> <tr> <td>not less than 1 h</td> <td>at</td> <td>$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$,</td> </tr> </table> <p>where T_1 is the higher of:</p> <ul style="list-style-type: none"> – 10 °C above the maximum temperature of the relevant part, or – 85 °C. <p>However, the 10 °C margin is not added if the temperature is measured by an embedded thermocouple.</p> <p>The period of time taken for the transition from one temperature to another is not specified, but the transition is permitted to be gradual.</p> <p>f) Presentation of the test results:</p> <p>The tests are followed by inspection, including sectioning, and measurement. Cracks or voids in the insulating compound such as would affect the homogeneity of the material constitute a failure.</p> <p>There were no/were cracks or voids found in the insulating compound.</p>			68 h	at	$T_1 \pm 2 \text{ }^\circ\text{C}$;	1 h	at	$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;	2 h	at	$0 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;	not less than 1 h	at	$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$,
68 h	at	$T_1 \pm 2 \text{ }^\circ\text{C}$;												
1 h	at	$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;												
2 h	at	$0 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$;												
not less than 1 h	at	$25 \text{ }^\circ\text{C} \pm 2 \text{ }^\circ\text{C}$,												





13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Standard gauges 2) Callipers with magnifying feature or additional magnifying equipment 3) Standard test finger (Figure F.1) 4) Test hook (Figure F.2) 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>Do not energize the DUT during this test.</p>		
<p>d) Test conditions:</p> <p>When determining AIR CLEARANCE or CREEPAGE DISTANCE to ACCESSIBLE PARTS, the accessible surface of an insulating ENCLOSURE is considered to be conductive as if it was covered by metal foil wherever it can be touched with a standard test finger.</p> <p>Any corner with included angle less than 80° is assumed to be bridged with an insulating link of 1 mm moved into the least favourable position (see Figure 6).</p> <p>Where the distance across the top of a groove is 1 mm or more, no CREEPAGE DISTANCE exists across the air space (see Figure 5).</p> <p>CREEPAGE DISTANCES and AIR CLEARANCES between parts moving relative to each other are measured with the parts in their least favourable positions.</p> <p>Computed CREEPAGE DISTANCE is never less than measured AIR CLEARANCE.</p> <p>Any air gap less than 1 mm wide is ignored when computing the total AIR CLEARANCE.</p> <p>Coatings of varnish, enamel or oxide are ignored. Coverings of any insulating material, however, are considered as insulation, if the covering is equivalent to a sheet of insulating material of equal thickness with respect to its electrical, thermal and mechanical properties.</p> <p>If CREEPAGE DISTANCES or AIR CLEARANCES for one or two MEANS OF PROTECTION are interrupted by one or more floating conductive parts, the minimum value specified in IEC 60601-1:2005 applies to the sum of the sections, except that distances less than 1 mm are not taken into consideration.</p> <p>The minimum spacing (X) for grooves transverse to the CREEPAGE DISTANCE in Figure 4 to Figure 6 and Figure 8 to Figure 12 (inclusive) that are considered a MEANS OF OPERATOR PROTECTION may be adjusted based on pollution degree if the minimum AIR CLEARANCE is 3 mm or more.</p> <p>The minimum width of the groove is:</p> <ul style="list-style-type: none"> - 0,25 mm for pollution degree 1; - 1,0 mm for pollution degree 2; - 1,5 mm for pollution degree 3. <p>If the specified minimum AIR CLEARANCE is less than 3 mm, the minimum spacing (X) for grooves transverse to the CREEPAGE DISTANCE is the lesser of:</p> <ul style="list-style-type: none"> - the relevant value specified in the previous paragraph, or - one third of the specified minimum AIR CLEARANCE. <p>The minimum spacing (X) for a groove transverse to a CREEPAGE DISTANCE that is considered a MEANS OF PATIENT PROTECTION is 1 mm for pollution degree 1 and pollution degree 2, and 1,5 mm for pollution degree 3.</p>		



13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
<p>In the case of a barrier placed on the surface of insulation or held in a recess, the CREEPAGE DISTANCES are measured over the barrier only if the latter is so affixed that dust and moisture cannot penetrate into the joint or recess.</p> <p>For a DUT provided with an APPLIANCE INLET, the measurements are made with an appropriate connector inserted. For other DUTs incorporating POWER SUPPLY CORDS, they are made with supply conductors of the largest cross-sectional area specified by the MANUFACTURER and also without conductors.</p> <p>Movable parts are placed in the least favourable position; nuts and screws with non-circular heads are tightened in the least favourable position.</p>		
<p>Creepage distances and air clearances through slots or openings in external parts are measured to the standard test finger. If necessary, a force is applied to any point on bare conductors and to the outside of metal enclosures in an endeavour to reduce the creepage distances and air clearances while taking the measurements.</p> <p>The force applied by means of a standard test finger has a value of: 2 N for bare conductors; 30 N for enclosures.</p> <p>Creepage distance and air clearances are measured after use of the test hook, if relevant.</p>		
<p>e) Test set-up and PROCEDURE:</p> <p>Compliance is checked by measurement taking into account the rules in Figure 3 to Figure 11 (inclusive). In each figure, the dashed line (---) represents AIR CLEARANCE and the shaded bar (▨) represents CREEPAGE DISTANCE.</p> <div style="display: flex; justify-content: space-between; align-items: flex-start;"> <div style="text-align: center;">  <p>IEC</p> </div> <div style="width: 40%;"> <p>Condition: Path under consideration is a flat surface.</p> <p>Rule: CREEPAGE DISTANCE and AIR CLEARANCE are measured directly across the surface.</p> </div> </div> <p style="text-align: center;">Figure 3 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 1 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 22)</p> <div style="display: flex; justify-content: space-between; align-items: flex-start;"> <div style="text-align: center;">  <p>IEC</p> </div> <div style="width: 40%;"> <p>Condition: Path under consideration includes a parallel- or converging-sided groove of any depth with a width less than X mm.</p> <p>Rule: CREEPAGE DISTANCE and AIR CLEARANCE are measured directly across the groove as shown.</p> </div> </div> <p style="text-align: center;">Figure 4 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 2 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 23)</p>		



13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES (continued)

Standard(s) IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
		<p>Condition: Path under consideration includes a parallel-sided groove of any depth and equal to or more than X mm.</p> <p>Rule: AIR CLEARANCE is the "line of sight" distance. CREEPAGE DISTANCE path follows the contour of the groove.</p>
<p>Figure 5 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 3 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 24)</p>		
		<p>Condition: Path under consideration includes a V-shaped groove with a width greater than X mm and an internal angle of less than 80 °.</p> <p>Rule: AIR CLEARANCE is the "line of sight" distance. CREEPAGE DISTANCE path follows the contour of the groove but "short-circuits" the bottom of the groove by a X mm link.</p>
<p>Figure 6 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 4 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 25)</p>		
		<p>Condition: Path under consideration includes a rib.</p> <p>Rule: AIR CLEARANCE is the shortest direct air path over the top of the rib. CREEPAGE DISTANCE path follows the contour of the rib.</p>
<p>Figure 7 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 5 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 26)</p>		
		<p>Condition: Path under consideration includes an uncemented joint with grooves less than X mm wide on each side.</p> <p>Rule: CREEPAGE DISTANCE and AIR CLEARANCE path are the "line of sight" distance shown.</p>
<p>Figure 8 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 6 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 27)</p>		

13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
 <p style="text-align: right; margin-right: 20px;">IEC</p>		<p>Condition: Path under consideration includes an uncemented joint with grooves equal to or more than X mm wide on each side.</p> <p>Rule: AIR CLEARANCE is the "line of sight" distance. CREEPAGE DISTANCE path follows the contour of the groove.</p>
<p>Figure 9 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 7 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012)</p>		
 <p style="text-align: right; margin-right: 20px;">IEC</p>		<p>Condition: Path under consideration includes an uncemented joint with a groove on one side less than 1 mm wide and the groove on the other side equal to or more than X mm wide.</p> <p>Rule: AIR CLEARANCE and CREEPAGE DISTANCE are as shown.</p>
<p>Figure 10 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 8 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 29)</p>		

13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;">  </div> <div style="width: 50%;"> <p>Condition: Gap between head of screw and wall of recess wide enough to be taken into account.</p> <p>Rule: The AIR CLEARANCE is the shortest distance to any point on the head of the screw. CREEPAGE DISTANCE path follows the surface.</p> </div> </div>		
<p align="center">Figure 11 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 9 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 30)</p>		
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;">  </div> <div style="width: 50%;"> <p>Condition: Gap between head of screw and wall of recess wide enough to be taken into account.</p> <p>Rule: Measurement of CREEPAGE DISTANCE is from screw to wall at any point where the distance is equal to X mm. The AIR CLEARANCE is the shortest distance to any point on the head of the screw</p> </div> </div>		
<p align="center">(IEC 60601-1:2005, Figure 30)</p>		
<p align="center">Figure 12 – CREEPAGE DISTANCE and AIR CLEARANCE – Example 10 (IEC 60601-1:2005+IEC 60601-1:2005/AMD1:2012, Figure 31)</p>		

13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.9.4	13.3.7 CREEPAGE DISTANCES and AIR CLEARANCES		
<p>f) Presentation of the test results:</p> <p>The results of the measurements are specified in the table.</p>				
TABLE: CREEPAGE DISTANCE and AIR CLEARANCE				
Insulation under test (area from insulation diagram)	Insulation type: (BI-BASIC / SI-SUPPLEMENTARY / DI-DOUBLE / RI-REINFORCED) (for IEC 60601-1:1988) (Functional / one MOOP / two MOOP / one MOPP/ two MOPP) (for IEC 60601-1:2005)	CREEPAGE DISTANCE mm	AIR CLEARANCE mm	Remarks

13.3.8 Strain relief (cord anchorage)

Standard(s): IEC 60601-1:2005	Subclause(s): 8.11.3.5	13.3.8 Strain relief (cord anchorage)												
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Spring balance, 30 N – 100 N 2) Device that allows the pull force to be applied on the cord sheath 3) Torque meter, 0,1 Nm – 0,35 Nm 4) Device that allows the torque to be applied on the cord 5) Scale and weight for determination of the mass of the DUT 6) Callipers 7) Radius gauges 														
<p>b) Safety precautions during the test:</p> <p>No special safety precaution required.</p>														
<p>c) Test sample preparation:</p> <p>The sample should be securely mounted. The power supply conductors are, if possible, disconnected from the terminals or from the MAINS CONNECTOR. Initial positions of the conductor ends were marked. A mark is made on the cord sheath at a distance of 20 mm from the cord anchorage.</p>														
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>														
<p>e) Test set-up and PROCEDURE:</p> <p>The cord was subjected 25 times to a pull indicated in Table 6. The pull was applied without jerks, each time for 1 s. The longitudinal displacement of the mark on the cord sheath was measured while the cord was subjected to the last pull. Immediately afterwards, the cord was subjected for 1 min to a torque value indicated in the table. After the test a movement of conductor ends was measured and recorded.</p> <p style="text-align: center;">Table 6 – Testing of cord anchorages (IEC 60601-1:2005, Table 18)</p> <table border="1" data-bbox="520 1352 1126 1554"> <thead> <tr> <th>Mass (<i>m</i>) of ME EQUIPMENT kg</th> <th>Pull N</th> <th>Torque Nm</th> </tr> </thead> <tbody> <tr> <td>$m \leq 1$</td> <td>30</td> <td>0,1</td> </tr> <tr> <td>$1 < m \leq 4$</td> <td>60</td> <td>0,25</td> </tr> <tr> <td>$m > 4$</td> <td>100</td> <td>0,35</td> </tr> </tbody> </table>			Mass (<i>m</i>) of ME EQUIPMENT kg	Pull N	Torque Nm	$m \leq 1$	30	0,1	$1 < m \leq 4$	60	0,25	$m > 4$	100	0,35
Mass (<i>m</i>) of ME EQUIPMENT kg	Pull N	Torque Nm												
$m \leq 1$	30	0,1												
$1 < m \leq 4$	60	0,25												
$m > 4$	100	0,35												

13.3.8 Strain relief (cord anchorage) (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 8.11.3.5	13.3.8 Strain relief (cord anchorage)		
<p>f) Presentation of the test results:</p> <p>It was/was not possible to push the cord back into the unit to such an extent that the cord or its conductors, or both, could be damaged or internal parts of the unit could be displaced.</p> <p>The cord did/did not slip in its anchorage.</p> <p>The cord sheath was/was not displaced by more than 2 mm.</p> <p>The conductor ends did/did not move more than 1 mm from their normally connected position.</p> <p>The PROTECTIVE EARTH CONDUCTOR was/was not subjected to strain as long as the phase conductors were in contact with their terminals.</p> <p>CREEPAGE DISTANCES and AIR CLEARANCES were/were not reduced below the values specified.</p> <p>The cord anchorage was/was not made of insulating material; or</p> <p>The cord anchorage was/was not made of metal but insulated from non-PROTECTIVELY EARTHED ACCESSIBLE PARTS by at least one MEANS OF PROTECTION; or</p> <p>The cord anchorage was/was not made of metal provided with an insulating lining, which is affixed to the cord anchorage or a flexible bushing that forms part of the cord guard specified in Subclause 8.11.3.6 of IEC 60601-1:2005 and the lining or bushing forms ONE MEANS OF PROTECTION.</p> <p>The cord anchorage does/does not clamp the cord via a screw that bears directly on the cord insulation.</p> <p>Screws, if any, that are used when replacing the POWER SUPPLY CORD do/do not serve to fix any component other than parts of the cord anchorage.</p>				
TABLE: Cord anchorages				
Cord under test	Mass of ME EQUIPMENT kg	Pull N	Torque Nm	Remarks

13.3.9 Cord guard flexing (Cord bending)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 8.11.3.6</p>	<p>13.3.9 Cord guard flexing (Cord bending)</p>
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Calliper 2) Weights 3) Cylinder of $1,5 \times$ diameter of cord 		
<p>b) Safety precautions during the test:</p> <p>No special safety precaution required.</p>		
<p>c) Test sample preparation:</p> <p>The sample should be securely mounted.</p>		
<p>d) Test conditions:</p> <p>Flat cords are bent in a direction perpendicular to the plane containing the axis of the cores.</p>		
<p>e) Test set-up and PROCEDURE:</p> <p>The unit is placed so that the axis of the cord guard, where the cord leaves it, is projected at an angle of 45° when the cord is free from stress. A mass in grams, equal to 10 times the square of the overall diameter (mm) of the cord, or for flat cords, the minor radius of the cord, is attached to the free end of the cord. Flat cords are bent in the plane of least resistance. Immediately after attaching the mass, the radius of curvature of the cord is measured.</p>		
<p>f) Presentation of the test results:</p> <p>Cord diameter (D): _____ mm.</p> <p>Weight attached: _____.</p> <p>Radius of curvature: _____.</p> <p>The radius of the curvature of the cord was/was not less than $1,5 \times D$.</p>		

13.3.10 Access to hazardous moving parts

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.2.1	13.3.10 Access to hazardous moving parts																											
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Standard test finger (Figure F.1) 2) Unjointed test finger 3) Force gauge 4) Test hook 5) Watch/clock 																													
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																													
<p>c) Test sample preparation:</p> <p>A sample, with all OPERATOR ACCESS COVERS removed.</p>																													
<p>d) Test conditions:</p> <p>This test applies to ME EQUIPMENT that contains hazardous moving parts.</p> <p>Do not energize the DUT during this test.</p>																													
<p>e) Test set-up and PROCEDURE:</p> <ul style="list-style-type: none"> 1) The test hook is inserted in each opening that might provide access to hazardous moving parts and is subsequently pulled with a force of 20 N for 10 s and in a direction substantially perpendicular to the surface in which the relevant opening is present. 2) The test finger is applied without appreciable force to all apertures in an attempt to contact or come into the path of hazardous moving parts. The test finger is applied in every possible position to the aperture's openings. Openings preventing the entry of the test finger are further tested by means of a straight unjointed version of the test finger, which is applied with a force of 30 N. If entry of the unjointed version is possible, the test with the articulated test finger is repeated with the finger being pushed through the aperture, if necessary. <p>The following apertures were evaluated:</p>																													
<table border="1"> <thead> <tr> <th data-bbox="204 1301 616 1350">Opening location</th> <th data-bbox="616 1301 1018 1350">Hazardous moving part</th> <th data-bbox="1018 1301 1396 1350">Remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	Opening location	Hazardous moving part	Remarks																										
Opening location	Hazardous moving part	Remarks																											









13.3.10 Access to hazardous moving parts (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.2.1	13.3.10 Access to hazardous moving parts
<p>f) Presentation of the test results:</p> <p>It was/was not possible to touch or come into the path of hazardous moving parts in OPERATOR access areas with the test finger.</p> <p>It was/was not unlikely that SERVICE PERSONNEL could unintentionally contact or come into the path of hazardous moving parts during servicing operations involving other parts of the ME EQUIPMENT.</p> <p>It was/was not possible to touch or come into the path of the following hazardous moving parts with the standard test finger:</p>		
TABLE: Touchable hazardous moving parts		
Location	Remarks	

13.3.11 Gaps

Standard(s): IEC 60601-1:2005	Subclause(s): 9.2.2.2	13.3.11 Gaps
a) Equipment required by the test: 1) Callipers 2) Steel rule, steel tape or other distance measuring device		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: A test sample with all ACCESSORIES, APPLIED PARTS and guards.		
d) Test conditions: The DUT is energized only to provide the minimum gap distance(s) then disconnected from power during gap measurement.		
e) Test set-up and PROCEDURE: Inspect for TRAPPING ZONES according to Table 7 considering various parts of the human body relative to the DUT and its associated parts.		
f) Presentation of the test results: It was/was not possible to touch hazardous moving parts within the TRAPPING ZONES.		
TABLE: Gaps		
Location	Remarks	

13.3.11 Gaps (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 9.2.2.2	13.3.11 Gaps	
Table 7 – Acceptable gaps ^a (IEC 60601-1:2005, Table 20)			
Part of body	Adult gap ^a mm	Children gap ^a mm	Illustration
Body	>500	>500	 IEC
Head	>300 or <120	>300 or <60	 IEC
Leg	>180	>180	 IEC
Foot	>120 or <35	>120 or <25	 IEC
Toes	>50	>50	 IEC
Arm	>120	>120	 IEC
Hand, wrist, fist	>100	>100	 IEC
Finger	> 25 or < 8	> 25 or < 4	 IEC
^a The values in this table are taken from ISO 13852:1996.			

13.3.12 Instability (in transport position; excluding transport;
from horizontal and vertical forces and from unwanted lateral movement)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Planes inclined 5° and 10° from the horizontal (larger than the base of the DUT) 2) 250 N strain gauge 3) 800 N weights 4) Scale (for weighing the DUT) 5) Inclinator or steel rules 6) Test floor surface that is hard and flat (i.e. concrete floor covered with 2 mm to 4 mm thick vinyl flooring material) 7) Steel ruler, steel tape or equivalent means to measure distances 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test. Use appropriate precautions and necessary test personnel considering the DUT overbalancing while moving.</p>		
<p>c) Test sample preparation:</p> <p>Prior to conducting the test, prepare the DUT in accordance with the ACCOMPANYING DOCUMENTS for transport condition. Always use worst-case loading and locating of drawers, doors, shelves, etc. within the MANUFACTURE'S specifications. The following should also be considered:</p> <ul style="list-style-type: none"> – The DUT is provided with all specified connection leads: the POWER SUPPLY CORD and any interconnecting cords. It is provided with the least favourable combination of possible detachable parts, ACCESSORIES and load as specified in NORMAL USE. – A DUT having an APPLIANCE INLET is provided with the specified DETACHABLE POWER SUPPLY CORD. – The connection leads are laid down on the inclined plane or positioned on holders attached to the DUT in the position most unfavourable for stability. – If castors/wheels are present, they are temporarily immobilized, if necessary by blocking, in their most disadvantageous position. – Doors, drawers, shelves and the like are placed in the most disadvantageous position and fully loaded or unloaded, whichever represents "worst case" as specified in the ACCOMPANYING DOCUMENTS. – A DUT having containers for liquids is tested with these containers completely or partly filled or empty, whichever is least favourable. – DUT carrying a PATIENT is loaded with maximum PATIENT weight, unloaded or loaded with a weight in between, whatever is considered the worst case. 		
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test. ME EQUIPMENT with APPLIED PARTS and ACCESSORIES and drawers, doors and shelves fully loaded as specified in the ACCOMPANYING DOCUMENTS.</p>		

13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement) *(continued)*

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2</p>	<p>13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)</p>
<p>e) Test set-up and PROCEDURE:</p> <p>1) Tilt test:</p> <p>The DUT is tilted 10° (on the plane inclined) from its intended upright position unless a warning notice is present. If a warning notice is present, the DUT is tilted 5° (on the plane inclined) from its intended upright position.</p> <p>NOTE For 10° tilt: (Distance lifted) = (Width of base) × (0,1736) = 10° For 5° tilt: (Distance lifted) = (Width of base) × (0,0875) = 5°</p> <p>This test applies to PORTABLE/TRANSPORTABLE ME EQUIPMENT that is intended to be placed on a surface such as a floor or table.</p> <p>Transport includes moving the DUT from room to room.</p> <p>2) Force test:</p> <p>The test applies to DUTs having a mass of greater than or equal to 25 kg other than FIXED DUTs intended to be used on the floor.</p> <p>The DUT and its parts are placed on a horizontal plane and a force equal to 15 % of its weight, but not more than 150 N, is applied in any direction, except directions with an upward component. Unless otherwise marked, the force is applied at any point of the DUT but not exceeding 1,5 m from the floor. The DUT is prevented from sliding on the floor by use of a horizontal obstruction that is fastened to the floor and does not exceed 20 mm height. If the application of the test force results in lateral movement of the DUT, increase the height of the obstruction to the minimum extent necessary to prevent lateral movement.</p> <p>() All jacks were put in place (if used under NORMAL CONDITIONS).</p> <p>() All doors and drawers, etc., which may be moved for servicing by the OPERATOR or by SERVICE PERSONNEL were placed in their most unfavourable position consistent with the installation instructions.</p> <p>The ME EQUIPMENT is prevented from sliding on the floor by a horizontal obstruction, not exceeding 20 mm height, which is fastened flat on the floor. If the application of the test force results in lateral movement of the ME EQUIPMENT, increase the height of the obstruction to the minimum extent necessary to prevent lateral movement.</p> <p>3) Downward force test:</p> <p>The floor-standing DUT is subjected to a downward force of 800 N. The force is applied at the point of maximum moment to any horizontal surface of at least 20 cm by at least 20 cm and that offers an obvious foothold or sitting surface, at a height up to 1 m from the floor. All doors, drawers, etc. are closed during this test. The downward force is applied with the complete flat surface of the test TOOL in contact with the DUT; the test TOOL is not required to be in full contact with uneven surfaces, e.g. corrugated or curved surfaces.</p> <p>4) Test for tilt caused by unwanted lateral movement:</p> <p>The MOBILE ME EQUIPMENT is placed in its transport position (or in the worst-case NORMAL USE position) with the SAFE WORKING LOAD in place and the locking device (e.g. brakes) activated, on a hard flat surface inclined at 10° or 5° from the horizontal plane. If castors are incorporated, they are positioned in their worst-case position.</p> <p>The ME EQUIPMENT (TRANSPORTABLE OR STATIONARY ME EQUIPMENT that is intended to be used on the floor) is placed on a horizontal plane with the SAFE WORKING LOAD in place and the locking device (e.g. brakes) activated. If castors are incorporated, they are positioned in their worst-case position. A force equal to 15 % of the weight of the DUT, but not more than 150 N, is applied in any direction, except a direction having an upward component, at the highest point of the ME EQUIPMENT but not exceeding 1,5 m from the floor.</p>		

13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement) *(continued)*

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)
---	--	---

f) Presentation of the test results:

1) **Tilt test:**

The tilt test was conducted at 5° or 10°.

Position of cables: _____

Position on the incline	Describe worst-case loading	Observation/Results

The DUT **did/did not** overbalance.

The DUT **did/did not** move unexpectedly to a degree that could present an unacceptable RISK to the PATIENT, OPERATOR or other person.

2) **Force test:**

Weight of DUT: _____ kg

Total force applied: _____ N

Force applied to: _____

Force also applied to: _____

Force applied	Location applied	Height from floor	Direction of force	Results

The DUT, any ACCESSORY, or any parts **did/did not** overbalance.

Applicable surfaces **are/are not** marked with a clearly legible warning of the RISK; _____ symbol used;

The following features for additional stabilization means were required:

13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement) *(continued)*

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2</p>	<p>13.3.12 Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)</p>
---	---	--

3) **Downward force test:**

Force applied to: _____

Force also applied to: _____

Force applied	Location applied	Height from floor	Results

A legible warning of the RISK of stepping or sitting **is/is not** provided on the DUT; _____ symbol used.

The DUT, any ACCESSORY, or any parts **did/did not** overbalance.

4) **Test for tilt caused by unwanted lateral movement**

Brakes **are/are not** normally activated and can only be deactivated by the continuous actuation of a control.

The DUT **is/is not** fitted with locking devices intended to prevent any unwanted lateral movement of the DUT or its parts in the transport position.

Following the initial elastic movement, initial creepage and initial pivoting of castors, any lateral movement of the MOBILE ME EQUIPMENT greater than 50 mm (in relation to the inclined plane) **did/did not** occur.

13.3.13 Castors and wheels (Force for propulsion, movement over a threshold)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.2.4.2, 9.4.2.4.3	13.3.13 Castors and wheels (Force for propulsion, movement over a threshold)
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Hard flat horizontal floor (vinyl covered concrete) 2) Force gauge with a range exceeding 200 N 3) Stop watch, watch or clock 4) Steel ruler or steel tape or equivalent means to measure distance 5) In place of 3) and 4) above, a means to measure the rate of linear movement 6) Threshold 10 mm ± 0,5 mm high and 80 mm wide with a radius of 2 mm ± 0,1 mm at the top edges 7) Scale (for weighing the DUT) 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test. Use appropriate precautions and necessary test personnel considering the DUT overbalancing while moving.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample of MOBILE ME EQUIPMENT in transport position with any SAFE WORKING LOAD in place as indicated in the ACCOMPANYING DOCUMENTS.</p>		
<p>d) Test conditions:</p> <p>ME EQUIPMENT, APPLIED PARTS and ACCESSORIES and means to fully load any drawers, doors, shelves as specified in the ACCOMPANYING DOCUMENTS.</p> <p>This test applies to a DUT where the specification does not state that more than one person is needed.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Force for propulsion: <p>Place the DUT on a hard flat horizontal floor (e.g. concrete floor covered with 2 mm to 4 mm thick vinyl flooring material).</p> <p>Force is applied at a height of 1 m above the floor or at the highest point on the DUT if its height is less than 1 m.</p> <p>The force needed to propel the DUT at a speed of 0,8 m/s ± 0,1 m/s is measured.</p> 2) Movement over a threshold: <p>The DUT (MOBILE ME EQUIPMENT exceeding 45 kg) is moved as in NORMAL USE 10 times in forward direction over (up and down) a solid vertical plane obstruction with a rectangular cross-section, 10 mm ± 0,5 mm high and 80 mm wide with a radius of 2 mm ± 0,1 mm at the top edges that is affixed flat on the floor. All wheels and castors are to impact the obstruction at a speed of 0,8 m/s ± 0,1 m/s for manual MOBILE ME EQUIPMENT, or for motor driven MOBILE ME EQUIPMENT, the maximum speed capable of being maintained. Manual MOBILE ME EQUIPMENT is propelled by force acting at its handle.</p> 		

13.3.13 Castors and wheels (Force for propulsion, movement over a threshold)
(continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.2.4.2, 9.4.2.4.3	13.3.13 Castors and wheels (Force for propulsion, movement over a threshold)
<p>f) Presentation of the test results:</p> <p>1) Force for propulsion:</p> <p>Total force applied: _____ N</p> <p>Force applied to: _____</p> <p>The force required to move the DUT does not/does exceed 200 N or the ACCOMPANYING DOCUMENTS specify that the DUT is to be moved by more than one person;</p> <p>2) Movement over a threshold:</p> <p>The DUT was/was not able to pass over the 10 mm high threshold.</p> <p>The DUT did/did not overbalance when passing over the 10 mm high threshold.</p> <p>After the test, there was/was no observable reduction of CREEPAGE DISTANCES OR AIR CLEARANCES.</p> <p>After the test, there was/was no observable access to hazardous electrical parts.</p> <p>After the test, there was/was no observable access to moving parts.</p>		

13.3.14 Handle loading

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.4	13.3.14 Handle loading
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Calliper 2) Weights or tension gauge 3) Scale (for weighing the DUT) 4) Means to uniformly distribute the weight over a 7 cm length at the centre of the handle 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample with fully loaded options/ACCESSORIES, consisting of the complete ENCLOSURE in its normal position.</p>		
<p>d) Test conditions:</p> <ul style="list-style-type: none"> () The ME EQUIPMENT is furnished with only one handle. () The ME EQUIPMENT is furnished with more than one handle but so designed that it might be carried by only one handle. () The force is distributed between the handles. The distribution of force was determined by calculation of the percentage of the ME EQUIPMENT mass sustained by each handle. <p>Do not energize the DUT during this test.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) The handles and their means of attachment are subjected to a force equal to four times the weight of the DUT in any direction of NORMAL USE and transport. 2) If more than one handle is furnished on PORTABLE DUT, the force should be distributed between the handles. The distribution of forces should be determined by measuring the percentage of the DUT weight sustained by each handle with the DUT in the normal carrying position. If the DUT is furnished with more than one handle but is so designed that it can readily be carried by only one handle, then each handle is to be capable of sustaining the total force. 3) The force is applied uniformly over a 7 cm length of the handle at the centre, starting at zero and gradually increasing so that the test value will be attained in 5 s to 10 s and maintained for a period of 1 min. 		

13.3.14 Handle loading (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.4.4	13.3.14 Handle loading
<p>f) Presentation of the test results:</p> <p>ME EQUIPMENT other than PORTABLE ME EQUIPMENT or its part with a mass of more than 20 kg that needs to be lifted in NORMAL USE or transport is/is not provided with suitable handling devices (for example handles, lifting eyes, etc.) or the ACCOMPANYING DOCUMENTS indicate the points where it can be lifted safely, unless the method of handling is obvious and no HAZARDS can develop when this is done.</p> <p>If the means for lifting are handles, they are/are not suitably placed to enable the ME EQUIPMENT or its part to be carried by two or more persons.</p> <p>ME EQUIPMENT specified by the MANUFACTURER as PORTABLE ME EQUIPMENT with a mass of more than 20 kg has/does not have one or more carrying-handles suitably placed to enable the ME EQUIPMENT to be carried by two or more persons. Check by inspection and carrying the DUT.</p> <p>Weight of DUT: _____ kg</p> <p>Number of handles tested: _____</p> <p>Force applied to each handle: _____ N</p> <p>Handle loading test:</p> <p>The handle(s) or other means did/did not support the weight.</p> <p>The handle or other means did not break/broke loose from the DUT.</p> <p>There was/was no permanent distortion, cracking or other evidence of breakage of the handle(s) or their attachment means.</p>		

13.3.15 Safety catch evaluation

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.8.1, 9.8.2	13.3.15 Safety catch evaluation				
a) Equipment needed for the test:						
1) Calliper						
2) Weights						
3) Tension gauge						
b) Safety precautions during the test:						
Use normal laboratory safety PROCEDURES during this test.						
c) Test sample preparation:						
Prior to performing these tests, the PATIENT support/suspension system is positioned horizontally in its most disadvantageous position in NORMAL USE.						
d) Test conditions:						
Do not energize the DUT during this test.						
e) Test set-up and PROCEDURE:						
1) The suspension system parts indicated in the table below (chain, cable, band, spring, belt, jack screw nut, pneumatic, hydraulic hoses, or the like) employed to support a load, are defeated by convenient means (cut or removed suddenly), thereby causing the maximum normal load to fall from the most adverse position permitted by the construction of the DUT and to activate a MECHANICAL PROTECTIVE DEVICE. The travel after such defeat is measured as well as other observed results that could affect the RISK of possible injury.						
2) If testing is needed to demonstrate compliance with 9.8.1 or 9.8.2, a test load equal to the TOTAL LOAD times the required TENSILE SAFETY FACTOR is gradually applied to the support assembly under test. The support assembly under test is to be in equilibrium after 1 min, or otherwise not result in an unacceptable RISK.						
It may be necessary to support assemblies that are connected to the assembly under test but do not require such a high safety factor, e.g. assembly under test requires TENSILE SAFETY FACTOR = 8 and assembly supporting it is designed with a TENSILE SAFETY FACTOR = 4. Use of additional support should be explained in the test report.						
The 1 min time period may need to be longer for materials which might have creep type problems, such as plastics or other non-metallic materials.						
TABLE: Suspension systems with safety devices						
Part defeated	Load supported	Safety device	Travelled distance	Can ME EQUIPMENT be used after the test?	Is it obvious that safety device activated?	Remarks
f) Presentation of the test results:						
There was/was no evidence of damage to a safety catch or other restraining means that would affect its ability to perform its intended function.						


13.3.16 Support loading

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.8.3	13.3.16 Support loading
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Calliper 2) Weights 3) Tension gauge 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>Prior to performing these tests, the PATIENT support/suspension system is positioned horizontally in its most disadvantageous position in NORMAL USE.</p>		
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ul style="list-style-type: none"> 1) Static forces: <ul style="list-style-type: none"> - A mass equal to two times 135 kg or two times the intended person load, whichever is greater, is applied to the footrest over an area of 0,1 m² for 1 min. After the test, if the footrest and its fixings shows any damage or deflection that could result in an unacceptable RISK this constitutes a failure. - A mass of 60 % of the part of the SAFE WORKING LOAD representing the PATIENT or OPERATOR, as defined in the instructions for use, or a minimum 80 kg, is placed on the support/suspension system with the centre of the load 60 mm from the outer edge of the support/suspension system for a time of at least 1 min. Any deflection of the support/suspension system that could result in an unacceptable RISK constitutes a failure. 2) Dynamic forces: <p>For the area of support/suspension where a PATIENT or OPERATOR can sit, a mass (as defined in Figure 13) equivalent to the SAFE WORKING LOAD representing the PATIENT or OPERATOR as defined in the instructions for use is dropped from a distance of 150 mm above the seat area. Any loss of function or structural damage that could result in an unacceptable RISK constitutes a failure.</p> 		

13.3.16 Support loading (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 9.8.3	13.3.16 Support loading
--	--------------------------------------	--------------------------------

Dimensions in mm



NOTE The top reservoir of the body upper-carriage module is formed of wood, metal or a similar material. The reservoir is intended to retain the appropriate human body mass, typically with high density material (e.g. lead). The bottom portion is foam. The resiliency or spring factor of the foam (ILD or IFD ratings) is not specified, as with a large mass being dropped, the foam properties are likely inconsequential. The foam is cylindrical, rather than spherical.

Figure 13 – Human body test mass

(IEC 60601-1:2005+AMD1:2012, Figure 33)

f) Presentation of the test results:

Item loaded	Area of load	Mass of load	Duration of load	Results

There **was /was no** damage to parts of the support system such as chains, clamps, cords, cord terminations and connections, belts, axles, pulleys and the like that affect protection against the RISK of injury to persons.

The support system **remained/did not remain** in equilibrium 1 min after application of the test load.

Foot rests/chairs **did not show/showed** signs of distortion or impending failure.

They **were/were not** capable of performing their intended function at the conclusion of the test.

13.3.16 Support loading *(continued)*

Standard(s): IEC 60601-1:2005	Subclause(s): 9.8.3	13.3.16 Support loading
Area tested	Weight Used	Results

13.3.17 Overflow

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.2	13.3.17 Overflow															
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Fluid measuring container 2) LEAKAGE CURRENTS measurement set-up 3) Dielectric strength tester 4) Equipment specified in subclause 13.3.13 (movement over a threshold as defined in subclause 9.4.2.4.3 of IEC 60601-1:2005+AMD1:2012) 5) Equipment to verify ESSENTIAL PERFORMANCE 																	
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																	
<p>c) Test sample preparation:</p> <p>This test should be applied only TO ME EQUIPMENT that incorporates a reservoir or liquid storage chamber that is liable to be overfilled or to overflow in NORMAL USE.</p>																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3" data-bbox="204 860 1386 904" style="text-align: center;">Liquid containers</th> </tr> <tr> <th data-bbox="204 904 609 949" style="width: 33%;">Description</th> <th data-bbox="609 904 1115 949" style="width: 33%;">Location</th> <th data-bbox="1115 904 1386 949" style="width: 33%;">Capacity</th> </tr> </thead> <tbody> <tr> <td data-bbox="204 949 609 994">1)</td> <td data-bbox="609 949 1115 994"></td> <td data-bbox="1115 949 1386 994"></td> </tr> <tr> <td data-bbox="204 994 609 1039">2)</td> <td data-bbox="609 994 1115 1039"></td> <td data-bbox="1115 994 1386 1039"></td> </tr> <tr> <td data-bbox="204 1039 609 1084">3)</td> <td data-bbox="609 1039 1115 1084"></td> <td data-bbox="1115 1039 1386 1084"></td> </tr> </tbody> </table> <p>One representative test sample.</p> <p>Do not energize the DUT during this test.</p>			Liquid containers			Description	Location	Capacity	1)			2)			3)		
Liquid containers																	
Description	Location	Capacity															
1)																	
2)																	
3)																	
<p>d) Test conditions:</p> <p>Liquid containers or reservoirs are completely filled unless restrictions on filling are provided in labelling and the instructions for use.</p>																	
<p>e) Test set-up and PROCEDURE:</p> <p>If warnings or safety notices regarding overfilling are marked on the TRANSPORTABLE ME EQUIPMENT, the liquid reservoir is filled to the indicated maximum level.</p> <p>If there is no warning or safety notice regarding overfilling marked on the TRANSPORTABLE ME EQUIPMENT, the liquid reservoir is filled completely and subsequently a further quantity equal to 15 % of the capacity of the reservoir is added poured in steadily over a period of 1 min.</p> <p>TRANSPORTABLE ME EQUIPMENT is subsequently tilted through an angle of 10° in the least favourable direction(s) (if necessary with refilling) starting from the position of NORMAL USE.</p> <p>MOBILE ME EQUIPMENT exceeding 45 kg is moved over a threshold as described in 9.4.2.4.3.</p> <p>After these PROCEDURES, the ME EQUIPMENT is to pass the appropriate dielectric strength and LEAKAGE CURRENT tests and is to show no signs of wetting of uninsulated electrical parts or electrical insulation of parts that could result in a HAZARDOUS SITUATION the loss of BASIC SAFETY or ESSENTIAL PERFORMANCE in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION (based on a visual inspection).</p>																	
<p>f) Presentation of the test results:</p> <p>Immediately following the overflow condition, the dielectric strength test and LEAKAGE CURRENT tests were repeated. The DUT was examined for signs of wetting of uninsulated live parts and/or electrical insulation.</p> <p>There was /was no indication of dielectric breakdown.</p> <p>LEAKAGE CURRENT testing remained/did not remain in compliance.</p> <p>There was /was no wetting of uninsulated electrical parts or electrical insulation of parts that could result in the loss of BASIC SAFETY or ESSENTIAL PERFORMANCE in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION (based on a visual inspection).</p>																	

13.3.18 Spillage

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.3	13.3.18 Spillage
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Fluid measuring container 2) LEAKAGE CURRENT measurement set-up 3) Dielectric strength tester 4) Equipment to verify ESSENTIAL PERFORMANCE 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>This test should be applied only to ME EQUIPMENT that handles liquids in NORMAL USE, including ME EQUIPMENT OR ME SYSTEMS used in an environment where the process has determined that spillage on the ME EQUIPMENT is likely to occur.</p> <p>One representative test sample.</p> <p>Do not energize the DUT during this test.</p>		
<p>d) Test conditions:</p> <p>The DUT is positioned as in NORMAL USE.</p>		
<p>e) Test set-up and PROCEDURE:</p> <p>A quantity of normal tap water is poured steadily on a point on the top of the DUT for a period of time and from a height based on the MANUFACTURER'S analysis from the RISK MANAGEMENT FILE.</p> <p>The type of liquid, volume, duration of the spill and location (point) should be determined through the RISK MANAGEMENT PROCESS to identify the least favourable configuration during NORMAL USE.</p> <p>After the test, the DUT is to pass the appropriate dielectric strength and LEAKAGE CURRENT tests and is to show no signs of wetting of uninsulated electrical parts or electrical insulation of parts that could result in the loss of BASIC SAFETY OR ESSENTIAL PERFORMANCE in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION (based on visual inspection).</p>		
<p>f) Presentation of the test results:</p> <p>Immediately following spillage, the dielectric strength test and LEAKAGE CURRENT tests were repeated. The DUT was examined for signs of wetting of uninsulated live parts and/or electrical insulation.</p> <p>There was /was no indication of dielectric breakdown.</p> <p>LEAKAGE CURRENT testing remained/did not remain in compliance.</p> <p>There was /was no wetting of uninsulated electrical parts or electrical insulation of parts that could result in the loss of BASIC SAFETY OR ESSENTIAL PERFORMANCE in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION (based on a visual inspection)..</p>		

13.3.19 Leakage

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.4, 13.2.6	13.3.19 Leakage												
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) LEAKAGE CURRENT measurement set-up 2) Dielectric strength tester 3) Pipette (IEC 60601-1:1988 only) 														
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>														
<p>c) Test sample preparation:</p> <p>This test should be applied only to ME EQUIPMENT interconnection of tubing for handling of liquids in NORMAL USE.</p>														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" data-bbox="204 745 1402 790" style="text-align: center;">Liquid tubing interconnection</th> </tr> <tr> <th data-bbox="204 790 815 835" style="text-align: center;">Description</th> <th data-bbox="815 790 1402 835" style="text-align: center;">Location</th> </tr> </thead> <tbody> <tr> <td data-bbox="204 835 815 880">1)</td> <td data-bbox="815 835 1402 880"></td> </tr> <tr> <td data-bbox="204 880 815 925">2)</td> <td data-bbox="815 880 1402 925"></td> </tr> <tr> <td data-bbox="204 925 815 969">3)</td> <td data-bbox="815 925 1402 969"></td> </tr> <tr> <td data-bbox="204 969 815 1014">4)</td> <td data-bbox="815 969 1402 1014"></td> </tr> </tbody> </table>			Liquid tubing interconnection		Description	Location	1)		2)		3)		4)	
Liquid tubing interconnection														
Description	Location													
1)														
2)														
3)														
4)														
<p>One representative test sample.</p> <p>Do not energize the DUT during this test.</p>														
<p>d) Test conditions:</p> <p>The DUT is positioned as in NORMAL USE.</p>														
<p>e) Test set-up and PROCEDURE:</p> <p>The type of liquid, volume, duration of the leakage and location (point) should be determined through the RISK MANAGEMENT PROCESS to identify the least favourable configuration during NORMAL USE.</p> <p>After the test, the DUT is to comply with all the requirements of IEC 60601-1:2005+AMD1:2012 for NORMAL CONDITION.</p> <p>Drops of water were applied by means of a pipette to couplings, to seals, to hoses and to other parts from which leakage might occur (IEC 60601-1:1988 only).</p> <p>Moving parts are to be in operation or at rest, whichever is least favourable (IEC 60601-1:1988 only).</p>														
<p>f) Presentation of the test results:</p> <p>Immediately following the overflow condition, the dielectric strength test and LEAKAGE CURRENT tests were repeated. The DUT was examined for signs of wetting of uninsulated live parts and/or electrical insulation.</p> <p>There was /was no indication of dielectric breakdown.</p> <p>LEAKAGE CURRENT testing remained/did not remain in compliance.</p> <p>There was/was no wetting of uninsulated electrical parts or electrical insulation of parts that could result in an unacceptable RISK.</p>														

13.3.20 Ingress of water or particulate matter

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.5	13.3.20 Ingress of water or particulate matter
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) IEC 60529 measurement set-up for IPX1 through IPX8 (for ingress of water) 2) IEC 60529 measurement set-up for IP1X through IP6X (for ingress of particulate matter) 3) LEAKAGE CURRENT measurement set-up 4) Dielectric strength tester 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>This test should be applied only to ME EQUIPMENT designed to give a specified degree of protection in accordance with the classification of IEC 60529 against harmful ingress of water or particulate matter.</p> <p>The first characteristic numeral indicates that:</p> <ul style="list-style-type: none"> – the ENCLOSURE provides protection of persons against access to hazardous parts by preventing or limiting the ingress of a part of the human body or an object held by a person; and simultaneously, – the ENCLOSURE provides protection of equipment against the ingress of solid foreign objects. <p>The second characteristic numeral indicates the degree of protection provided by ENCLOSURES with respect to harmful effects on the equipment due to the ingress of water.</p> <p>Unless otherwise specified, the test samples for each test should be clean and new, with all parts in place and mounted in the manner described by the MANUFACTURER.</p> <p>Do not energize the DUT during this test.</p>		
<p>d) Test conditions:</p> <p>Place the DUT in the least favourable position of NORMAL USE.</p>		
<p>e) Test set-up and PROCEDURE:</p> <p>IPX1 Test with a drip box in accordance with Figure 3 of IEC 60529:1998.</p> <p>Place the DUT level in its normal operating position on the turn table. Align the axis of the DUT approximately 100 mm from axis of the turn table. Rotate the table at a rate of 1 /min for at least 10 min. Ensure that the drip box is larger than the ENCLOSURE of the DUT, and that the support is smaller than the ENCLOSURE. Fix a wall or ceiling mounted DUT to a wooden board with dimensions equal to the size of the DUT's mounting surface. Set a flow rate of $1,0^{+0,5}_0$ mm/min.</p> <p>IPX2 Test with a drip box in accordance with Figure 3 of IEC 60529:1998.</p> <p>Place the DUT in its normal operating position on an inclinable surface. Incline the surface to 15° for at least 2,5 min in each of four FIXED positions of tilt (total of at least 10 min). Ensure that the drip box is larger than the ENCLOSURE of the DUT, and that the support is smaller than the ENCLOSURE. Fix a wall or ceiling mounted DUT to a wooden board with dimensions equal to the size of the DUT's mounting surface. Set a flow rate of $3,0^{+0,5}_0$ mm/min.</p>		

13.3.20 Ingress of water or particulate matter (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.5	13.3.20 Ingress of water or particulate matter
<p>IPX3 Test with either an oscillating tube according to Figure 4 or a spray head according to Figure 5 of IEC 60529:1998.</p> <p>Place the DUT on a non-perforated supporting surface in the centre of the spray pattern.</p> <p>When using an oscillating tube:</p> <ul style="list-style-type: none"> – Use a tube radius that is the appropriate size for the DUT ENCLOSURE, but not larger than 1 600 mm. Adjust the flow rate to produce 0,07 l/min ± 5 % per hole multiplied by the number of holes (Table 9 from IEC 60529:1998 details the total water flow rate when using the oscillating tubes). – Spray at an angle of ± 60° from vertical from a maximum distance of 200 mm. The time to complete one oscillation cycle (2 × 120 °) should be about 4 s. – Spray the DUT for 5 min, then turn the DUT 90° and spray for 5 min more (total of 10 min). <p>Use a spray head (rather than an oscillating tube) for ENCLOSURES that require a tube radius greater than 1 600 mm.</p> <ul style="list-style-type: none"> – Adjust the flow rate to produce 10 l/min ± 5 %. – Spray at an angle of ± 60° from vertical from a maximum distance of 200 mm. – Use the calculated surface area of the enclosure (excluding any mounting surface) to determine the duration of delivery. Spray for 1 min/m² of surface area, but for no less than 5 min. <p>The tube diameter was _____ mm radius, flow rate was _____ l/min.</p> <p>IPX4 Test with either an oscillating tube according to Figure 4 or a spray head according to Figure 5 of IEC 60529:1998.</p> <p>Place the DUT on a non-perforated supporting surface in the centre of the spray pattern.</p> <p>When using an oscillating tube:</p> <ul style="list-style-type: none"> – Use a tube radius that is the appropriate size for the DUT ENCLOSURE, but not larger than 1 600 mm. Adjust the flow rate to produce 0,07 l/min ± 5 % per hole multiplied by the number of holes (Table 9 from IEC 60529:1998 for the total water flow rate when using the oscillating tubes). – Spray at an angle of ± 180° from vertical from a maximum distance of 200 mm when using the oscillating tube. The time to complete one oscillation cycle (2 × 360°) should be about 12 s. – Spray the DUT for 5 min, then turn the DUT 90° and spray for 5 min more (total of 10 min). <p>Use a spray head (rather than an oscillating tube) for ENCLOSURES that require a tube radius greater than 1 600 mm.</p> <ul style="list-style-type: none"> – Adjust the flow rate to produce 10 l/min ± 5 %. – Spray at an angle of ± 180° from vertical from a maximum distance of 200 mm. – Use the calculated surface area of the enclosure (excluding any mounting surface) to determine the duration of delivery. Spray for 1 min/m² of surface area, but for no less than 5 min. <p>The DUT was/was not rotated during the test.</p> <p>The DUT was/was not operating during the test.</p> <p>The tube diameter was _____ mm radius; flow rate was _____ l/min.</p>		

13.3.20 Ingress of water or particulate matter (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.5	13.3.20 Ingress of water or particulate matter
<p>IPX5 Direct a water jet hose nozzle (reference Figure 6 from IEC 60529:1998) with an inside diameter of 6,3 mm at the DUT. Deliver a stream of water at a rate of 12,5 l/min (that has a 40 mm diameter core measured at 2,5 m from the end of the nozzle) at the DUT from a distance of 2.5 m to 3 m. Use the calculated surface area of the exposed DUT surface to determine the duration of spraying. Spray for 1 min/m² of the exposed DUT surface, but for no less than 3 min.</p> <p>IPX6 Direct a water jet hose nozzle (reference Figure 6 from IEC 60529:1998) with an inside diameter of 12,5 mm at the DUT. Deliver a stream of water at a rate of 100 l/min (that has a 120 mm diameter core measured at 2,5 m from the end of the nozzle) at the DUT from a distance of 2,5 m to 3 m. Use the calculated surface area of the exposed DUT surface to determine the duration of spraying. Spray for 1 min/m² of the exposed DUT surface, but for no less than 3 min.</p> <p>IPX7 Completely immerse the DUT (for at least 30 min) in water with a temperature within 5 °C of the temperature of the DUT. Place the DUT in the MANUFACTURER'S specified normal operating position that satisfies the following conditions:</p> <ul style="list-style-type: none"> - The lowest point of ENCLOSURES with a height less than 850 mm is 1 000 mm below the surface of the water. - The highest point of enclosures with a height equal to or greater than 850 mm is 150 mm below the surface of the water <p>IPX8 Completely immerse the DUT (that is designed to be continuously immersed in NORMAL USE) in water. The MANUFACTURER and users must agree on the test conditions, but those conditions must be more severe than those required for IPX7.</p> <p>Perform testing for the second characteristic numeral in fresh water. The actual protection may not be satisfactory if high pressure and/or solvents are used for cleaning.</p> <p>After testing, examine the DUT for signs of wetting of uninsulated live parts and/or electrical insulation.</p> <p>In general terms, if any water enters the ENCLOSURE, the DUT should show no signs of bridging of insulation (or electrical components) that could result in an unacceptable RISK in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION (based on a visual inspection) after the appropriate dielectric strength and LEAKAGE CURRENT tests are performed.</p> <p>IP1X Protected against access to hazardous parts with the back of a hand and against penetration of the ENCLOSURE by solid foreign objects of greater than or equal to 50 mm diameter. Apply the access probe (a sphere of 50^{+0,05}₀ mm diameter) with a force of 50 N ± 10 %.</p> <p>The probe did/did not pass through any applicable opening of the ENCLOSURE while maintaining adequate clearance.</p> <p>IP2X Protected against access to hazardous parts with a finger and against penetration of the ENCLOSURE by solid foreign objects of greater than or equal to 12,5 mm diameter. Apply the jointed test finger (12 mm diameter, 80 mm length) and the access probe (a sphere of 12,5^{+0,2}₀ mm diameter) with a force of 30 N ± 10 %.</p> <p>The probe did/did not pass through any applicable opening of the ENCLOSURE while maintaining adequate clearance.</p> <p>The jointed test finger may penetrate to its 80 mm length, but the stop face (the 50 mm × 20 mm cross section) must not pass through the opening. Starting from the straight position, bend both joints of the test finger successively through an angle of up to 90° with respect to the axis of the adjoining section of the finger and place the finger in every possible position.</p>		

13.3.20 Ingress of water or particulate matter (continued)

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 11.6.5</p>	<p>13.3.20 Ingress of water or particulate matter</p>
<p>IP3X Protected against access to hazardous parts with a TOOL and against penetration of the ENCLOSURE by solid foreign objects of greater than or equal to 2,5 mm diameter. Apply the access probe (a test rod of $2,5 \begin{smallmatrix} +0,05 \\ 0 \end{smallmatrix}$ mm diameter) with a force of 3 N ± 10%.</p> <p>The probe did/did not pass through any applicable opening of the ENCLOSURE while maintaining adequate clearance.</p> <p>IP4X Protected against access to hazardous parts with a wire and against penetration of the ENCLOSURE by solid foreign objects of greater than or equal to 1,0 mm diameter. Apply the access probe (a test wire of $1,0 \begin{smallmatrix} +0,05 \\ 0 \end{smallmatrix}$ mm diameter) with a force of 1 N ± 10 %.</p> <p>The probe did/did not pass through any applicable opening of the ENCLOSURE while maintaining adequate clearance.</p> <p>IP5X Protected against access to hazardous parts with a wire and limit the ingress of dust into the ENCLOSURE. Apply the access probe (a test wire of $1,0 \begin{smallmatrix} +0,05 \\ 0 \end{smallmatrix}$ mm diameter) with a force of 1 N ± 10 %.</p> <p>The probe did/did not pass through any applicable opening of the ENCLOSURE while maintaining adequate clearance.</p> <p>When tested according to Subclause 13.2 of IEC 60529:1989, deposits of dust into the ENCLOSURE did/did not interfere with DUT operation or result in unacceptable RISKS.</p> <p>The talcum powder used for this test did/did not accumulate in a quantity or at a location such that, along with any other kind of dust, might interfere with the correct DUT operation or impair safety. Dust was not deposited where it could lead to tracking along the CREEPAGE DISTANCES except for specific cases that are clearly described in the instructions for use.</p> <p>IP6X Protected against access to hazardous parts using a wire and limits the ingress of dust into the ENCLOSURE. Apply the access probe (a test wire of $1,0 \begin{smallmatrix} +0,05 \\ 0 \end{smallmatrix}$ mm diameter) with a force of 1 N ± 10 %.</p> <p>The probe did/did not pass through any applicable opening on the ENCLOSURE while maintaining adequate clearance.</p> <p>When tested according to Subclause 13.2 of IEC 60529:1989, deposits of dust were/were not observed inside the ENCLOSURE after the test.</p> <p>Push the access probe against or (in the case of the test for first characteristic numeral 2, inserted) through any openings of the ENCLOSURE with the force specified in Table 6 of IEC 60529:1989.</p>		

13.3.20 Ingress of water or particulate matter (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.5	13.3.20 Ingress of water or particulate matter
<p>f) Presentation of the test results:</p> <p>The DUT was tested for IP ___ or IPX ___ or IP ___ X</p> <p>If any water has entered the ENCLOSURE:</p> <p>Immediately after testing for the ingress of liquids or particulate matter, repeat the dielectric strength test and LEAKAGE CURRENTS tests.</p> <ul style="list-style-type: none"> - The particulate test apparatus did/did not fully penetrate the appropriate openings. - The particulate test apparatus did/did not maintain sufficient clearance from hazardous parts. - For IP5X, dust protection is/is not provided in accordance with Table 2 from IEC 60529:1998. - For IP6X, dust tightness is/is not provided in accordance with Table 2 from IEC 60529:1998. - An unacceptable RISK did not/did occur in NORMAL CONDITION and any applicable SINGLE FAULT CONDITION as determined by IEC 60601-1: 2005. - There were /were no indications of dielectric breakdown. 		
<ul style="list-style-type: none"> - The DUT continues/does not continue to pass LEAKAGE CURRENT tests. - The DUT continues/does not continue to operate correctly and BASIC SAFETY and ESSENTIAL PERFORMANCE was/was not impaired. - After any IPXN testing, inspection shows no signs/shows signs of wetting of safety insulation or electrical parts. - There was/was no water deposit on insulation parts that could lead to tracking along the CREEPAGE DISTANCES. - There was/was no water deposit that could reach live parts or windings not designed to operate when wet. - There was/was no water accumulation near any cable end or entry onto the cable. 		

13.3.21 Cleaning, sterilization and disinfection

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.6.6, 11.6.7	13.3.21 Cleaning, sterilization and disinfection			
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Cleaning agents or disinfectants or sterilizers (industrial moist heat sterilization or ethylene oxide sterilization or radiation sterilization) as specified in the instructions for use 2) Dielectric strength tester 3) LEAKAGE CURRENT measurement set-up 					
<p>b) Safety precautions during the test:</p> <p>Switch the ME EQUIPMENT ON or OFF during cleaning PROCEDURE in accordance with the instructions for use.</p>					
<p>c) Test sample preparation:</p> <p>Prepare the ME EQUIPMENT itself or parts of ME EQUIPMENT or APPLIED PARTS as described in the instructions for use.</p>					
<p>d) Test conditions:</p> <p>Cleaning or disinfection as described in the instructions for use, sterilization PROCESS according to standards ISO 17665-1 (industrial moist heat), ISO 11135-1 (ethylene oxide) or ISO 11137-1 (radiation).</p> <p>Environmental conditions as specified in the technical description.</p>					
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Clean and disinfect the ME EQUIPMENT, ACCESSORIES and APPLIED PARTS in accordance with the MANUFACTURERS' instructions (i.e. cleaning or disinfection materials and methods). If more than one material or method is listed, use each in turn. 2) Sterilize the ME EQUIPMENT, ACCESSORIES and APPLIED PARTS in accordance with the MANUFACTURERS' instructions. 3) After cleaning and sterilization, visually inspect the parts for damage that might result in an unacceptable RISK. Perform applicable dielectric strength tests and LEAKAGE CURRENT tests as described in this document. 					
<p>f) Presentation of the test results:</p> <p>Visually inspect any parts of the DUT exposed to the cleaning agent to verify that deterioration did not occur.</p> <p>List each item cleaned, disinfected or sterilized in the table below. Include the cleaning material and cleaning or sterilization method and the visual inspection results and compliance with dielectric strength and LEAKAGE CURRENT.</p>					
<p>TABLE: Cleaning, disinfection and sterilization</p>					
Item cleaned, disinfected or sterilized	Cleaning, disinfection or sterilization material	Cleaning, disinfection, or sterilization method	Visual inspection results	Dielectric strength results	LEAKAGE CURRENT results

13.3.22 Push (rigidity)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.3.2	13.3.22 Push (rigidity)															
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Force gauge 2) Dielectric strength tester 3) Watch 4) Scale (for weighing the DUT) 5) Callipers or gauge pins 																	
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																	
<p>c) Test sample preparation:</p> <p>One representative sample with fully loaded options/ACCESSORIES, consisting of the complete ENCLOSURE, or a portion thereof representing the largest unreinforced area, is supported in its normal position.</p>																	
<p>d) Test conditions:</p> <p>For ME EQUIPMENT with non-metallic ENCLOSURES, this test is performed at the maximum ambient temperature indicated in the technical description for NORMAL USE.</p> <p>Do not energize the DUT during this test.</p>																	
<p>e) Test set-up and PROCEDURE:</p> <p>External parts of an ENCLOSURE are subject to a steady force of 250 N ± 10 N for a period of 5 s, applied by means of a suitable test TOOL providing contact over a circular plane surface 30 mm in diameter.</p>																	
<p>f) Presentation of the test results:</p> <p>The ENCLOSURE was pushed at the points indicated below.</p>																	
<table border="1"> <thead> <tr> <th data-bbox="204 1267 614 1312">Material</th> <th data-bbox="614 1267 1018 1312">Pushed area</th> <th data-bbox="1018 1267 1402 1312">Observations</th> </tr> </thead> <tbody> <tr> <td data-bbox="204 1312 614 1357">1)</td> <td data-bbox="614 1312 1018 1357"></td> <td data-bbox="1018 1312 1402 1357"></td> </tr> <tr> <td data-bbox="204 1357 614 1402">2)</td> <td data-bbox="614 1357 1018 1402"></td> <td data-bbox="1018 1357 1402 1402"></td> </tr> <tr> <td data-bbox="204 1402 614 1447">3)</td> <td data-bbox="614 1402 1018 1447"></td> <td data-bbox="1018 1402 1402 1447"></td> </tr> <tr> <td data-bbox="204 1447 614 1491">4)</td> <td data-bbox="614 1447 1018 1491"></td> <td data-bbox="1018 1447 1402 1491"></td> </tr> </tbody> </table>			Material	Pushed area	Observations	1)			2)			3)			4)		
Material	Pushed area	Observations															
1)																	
2)																	
3)																	
4)																	
<p>There was /was no cracking of the ENCLOSURE that could cause an unacceptable RISK.</p> <p>There was /was no reduction of CREEPAGE DISTANCES and AIR CLEARANCES.</p> <p>There were /were no live parts that became accessible.</p> <p>Subject the appropriate MEANS OF PROTECTION(S) to the applicable dielectric strength test(s).</p> <p>There was /was not an indication of dielectric strength breakdown.</p>																	
<p>TABLE: Dielectric strength test</p>																	
<table border="1"> <thead> <tr> <th data-bbox="204 1771 858 1850">Location</th> <th data-bbox="858 1771 1174 1850">Test voltage V</th> <th data-bbox="1174 1771 1402 1850">Time</th> </tr> </thead> <tbody> <tr> <td data-bbox="204 1850 858 1895"></td> <td data-bbox="858 1850 1174 1895"></td> <td data-bbox="1174 1850 1402 1895"></td> </tr> <tr> <td data-bbox="204 1895 858 1939"></td> <td data-bbox="858 1895 1174 1939"></td> <td data-bbox="1174 1895 1402 1939"></td> </tr> <tr> <td data-bbox="204 1939 858 1984"></td> <td data-bbox="858 1939 1174 1984"></td> <td data-bbox="1174 1939 1402 1984"></td> </tr> </tbody> </table>			Location	Test voltage V	Time												
Location	Test voltage V	Time															

13.3.23 Impact

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.3.3	13.3.23 Impact															
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Steel sphere approximately 50 mm in diameter and with a mass of 500 g ± 25 g 2) Dielectric strength tester 3) Pendulum apparatus 4) Callipers or gauge pins. 																	
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																	
<p>c) Test sample preparation:</p> <p>One representative sample with fully loaded options/ACCESSORIES, consisting of the complete ENCLOSURE, or a portion thereof representing the largest unreinforced area, is supported in its normal position.</p> <p>Cathode ray tubes, flat panel displays and platen glass are excluded.</p>																	
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test. Support the DUT such that it is rigidly held in place during impact.</p>																	
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) The solid smooth steel ball is permitted to fall freely from a 1,3 m height once onto each relevant part of the ENCLOSURE (so as to strike the ENCLOSURE with an impact of 6,78 Nm). 2) To test vertical surfaces, the steel ball may be suspended by a cord and allowed to swing like a pendulum in order to apply a horizontal impact, dropping through a vertical distance of 1,3 m once against each relevant part of the ENCLOSURE. 																	
<p>f) Presentation of the test results:</p> <p>The ENCLOSURE was struck at the points indicated below.</p> <table border="1" data-bbox="228 1301 1366 1529"> <thead> <tr> <th data-bbox="228 1301 608 1350">Material</th> <th data-bbox="608 1301 987 1350">Impacted area</th> <th data-bbox="987 1301 1366 1350">Remarks</th> </tr> </thead> <tbody> <tr> <td data-bbox="228 1350 608 1395">1)</td> <td data-bbox="608 1350 987 1395"></td> <td data-bbox="987 1350 1366 1395"></td> </tr> <tr> <td data-bbox="228 1395 608 1440">2)</td> <td data-bbox="608 1395 987 1440"></td> <td data-bbox="987 1395 1366 1440"></td> </tr> <tr> <td data-bbox="228 1440 608 1485">3)</td> <td data-bbox="608 1440 987 1485"></td> <td data-bbox="987 1440 1366 1485"></td> </tr> <tr> <td data-bbox="228 1485 608 1529">4)</td> <td data-bbox="608 1485 987 1529"></td> <td data-bbox="987 1485 1366 1529"></td> </tr> </tbody> </table>			Material	Impacted area	Remarks	1)			2)			3)			4)		
Material	Impacted area	Remarks															
1)																	
2)																	
3)																	
4)																	

13.3.23 Impact (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 15.3.3	13.3.23 Impact
<p>After the test, the DUT or the DUT parts should not present an unacceptable RISK. There was /was no cracking of the ENCLOSURE that could cause an unacceptable RISK. There were /were no barriers damaged or loosened. There was /was no damage that could cause moving parts to become hazardous. There was /was no damage that could cause spread of fire. Subject the appropriate MEANS OF PROTECTION(S) to the applicable dielectric strength test(s). There was /was no indication of dielectric strength breakdown.</p>		
<p>TABLE: Dielectric strength test</p>		
Location	Test voltage V	Time

13.3.24 Drop impact

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.3.4	13.3.24 Drop impact								
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Hardwood surface 50 mm thick 2) Tape measure or steel rule 3) Dielectric strength tester 4) Callipers or gauge pins 										
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>										
<p>c) Test sample preparation:</p> <p>One representative sample with fully loaded options/ACCESSORIES, etc.</p>										
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>										
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) HAND-HELD DUT: The DUT, with any SAFE WORKING LOAD in place, is allowed to fall freely once from each of three different starting orientations encountered during NORMAL USE from the height at which the ME EQUIPMENT, ACCESSORY or ME EQUIPMENT part is used, or, if not defined in the ACCOMPANYING DOCUMENTS, from a height of 1 m, whichever is greater, onto a 50 mm ± 5 mm thick hardwood board (for example, hardwood > 600 kg/m³) lying flat on a concrete or a similar rigid base. 2) PORTABLE DUT: The DUT, with the SAFE WORKING LOAD in place, is lifted to a height as indicated in Table 5 above a 50 mm ± 5 mm thick hardwood board (for example, > 600 kg/m³) that lies flat on a concrete floor or a similar rigid base. The dimensions of the board should be at least that of the DUT. The DUT is dropped three times from each orientation in which it may be placed during NORMAL USE. <p style="text-align: center;">Table 8 – Drop height (IEC 60601-1:2005, Table 29)</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th data-bbox="403 1413 983 1503">Mass (<i>m</i>) of PORTABLE ME EQUIPMENT or PORTABLE ME EQUIPMENT parts kg</th> <th data-bbox="983 1413 1211 1503">Drop height cm</th> </tr> </thead> <tbody> <tr> <td data-bbox="403 1503 983 1554" style="text-align: center;">$m \leq 10$</td> <td data-bbox="983 1503 1211 1554" style="text-align: center;">5</td> </tr> <tr> <td data-bbox="403 1554 983 1606" style="text-align: center;">$10 < m \leq 50$</td> <td data-bbox="983 1554 1211 1606" style="text-align: center;">3</td> </tr> <tr> <td data-bbox="403 1606 983 1644" style="text-align: center;">$m > 50$</td> <td data-bbox="983 1606 1211 1644" style="text-align: center;">2</td> </tr> </tbody> </table>			Mass (<i>m</i>) of PORTABLE ME EQUIPMENT or PORTABLE ME EQUIPMENT parts kg	Drop height cm	$m \leq 10$	5	$10 < m \leq 50$	3	$m > 50$	2
Mass (<i>m</i>) of PORTABLE ME EQUIPMENT or PORTABLE ME EQUIPMENT parts kg	Drop height cm									
$m \leq 10$	5									
$10 < m \leq 50$	3									
$m > 50$	2									

13.3.24 Drop impact (continued)

Standard(s): IEC 60601-1:2005+ A1:2012	Subclause(s): 15.3.4	13.3.24 Drop impact
<p>f) Presentation of the test results:</p> <p>After the test, the DUT or DUT parts may not present any unacceptable RISK.</p> <p>The following are examples of items that are inspected after the test:</p> <ul style="list-style-type: none"> – Parts, which are hazardous live, have /have not become accessible. – ENCLOSURES show /show no cracks that could cause an unacceptable RISK. – AIR CLEARANCES are /are not less than their permitted values and the insulation of internal wiring remains undamaged. – Barriers have /have not been damaged or loosened. – There has been /has been no damage, which could cause moving parts to become hazardous. – There has been /has been no damage that could cause spread of fire. – There was/was no damage to the interior or exterior of the DUT. <p>Subject the appropriate MEANS OF PROTECTION(S) to the applicable dielectric strength test(s).</p> <p>There was/was no indication of dielectric strength breakdown.</p>		
TABLE: Dielectric strength test		
Location	Test voltage V	Time

13.3.25 Rough handling

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.3.5	13.3.25 Rough handling
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) A solid hardwood vertical obstacle having a width and thickness of 40 mm 2) A FIXED horizontal obstacle having a height of 40 mm 3) A FIXED horizontal descending step having a height of 40 mm 4) Means to measure the speed 5) Dielectric strength tester 6) Callipers or gauge pins 7) Scale (for weighing the DUT) 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test. Suitable precautions shall be taken to prevent over-balance caused by the rough handling stress/shock.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample of MOBILE ME EQUIPMENT in transport position, with any SAFE WORKING LOAD in place and in the most adverse condition permitted in NORMAL USE.</p>		
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Ascending step shock: The DUT is pushed three times in its normal direction of travel at a speed of 0,8 m/s ± 0,1 m/s, or, for a motor-driven DUT, at the maximum speed capable of being maintained, against a solid hardwood plane obstruction with a face of 40 mm that is rigidly attached to an otherwise flat floor. The direction of movement is perpendicular to the face of the obstacle. The DUT need not go over the 40 mm obstruction. 2) Descending step shock: The DUT is moved three times in its normal direction of travel at a speed of 0,8 m/s ± 0,1 m/s, or, for a motor-driven DUT, at the maximum speed capable of being maintained, in order to fall over a vertical step having a height of 40 mm affixed flat on a rigid base (e.g. concrete). The direction of movement is perpendicular to the face of the descending step. 3) Door frame shock: The DUT is moved three times in its normal direction of travel at a speed of 0,8 m/s ± 0,1 m/s, or, for motor driven MOBILE DUT, the maximum speed capable of being maintained, against a hardwood vertical obstacle having a width and thickness of 40 mm affixed to a vertical rigid support (e.g. concrete). The height of the vertical obstacle should be higher than the DUT contact point(s). The direction of movement is perpendicular to the face of the obstacle. 		

13.3.25 Rough handling (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.3.5, 9.4.2.4.3	13.3.25 Rough handling
<p>f) Presentation of the test results:</p> <p>After the tests, the DUT or DUT parts should not present an unacceptable RISK.</p> <p>The mechanical integrity of the DUT was/was not maintained during test 1).</p> <p>The mechanical integrity of the DUT was/was not maintained during test 2).</p> <p>The mechanical integrity of the DUT was/was not maintained during test 3).</p> <p>Measured CREEPAGE DISTANCES and AIR CLEARANCES were satisfactory/non-satisfactory after the tests.</p> <p>Visually inspect the DUT for any damage that might constitute an unacceptable RISK (e.g. ENCLOSURE openings that allow access to hazardous parts).</p> <p>Subject the appropriate MEANS OF PROTECTION to the applicable dielectric strength test(s).</p> <p>There was/was no indication of dielectric strength breakdown.</p>		
<p>TABLE: Dielectric strength test</p>		
<p>Location</p>	<p>Test voltage V</p>	<p>Time</p>

13.3.26 Mould stress relief

Standard(s): IEC 60601-1:2005	Subclause(s): 15.3.6	13.3.26 Mould stress relief	
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Circulating air oven with calibrated temperature measuring device 2) Calliper 3) Watch/clock 4) Finger probe, test pin, test hook, rigid finger. 			
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>			
<p>c) Test sample preparation:</p> <p>This test applies only to ME EQUIPMENT with ENCLOSURES of moulded or formed thermoplastic materials.</p> <p>One representative sample, consisting of the complete ENCLOSURE, or of the ENCLOSURE together with any supporting framework.</p> <p>For large ME EQUIPMENT, condition a portion of the ENCLOSURE representative of the complete assembly with regard to thickness and shape, including any mechanical support members.</p> <p>The selected samples are derived from portions of the ENCLOSURE based on the potential effects of mould stress relief, such as corners or where the moulding material must flow into restricted areas where cooling of the material could result in stresses.</p>			
<p>d) Test conditions:</p> <p>Do not energize the DUT during this test.</p>			
<p>e) Test set-up and PROCEDURE:</p> <p>Place the DUT in the circulating air oven at a temperature 10 °C higher than the maximum temperature observed on the ENCLOSURE during the heating test, but not less than 70 °C, for a period of 7 h, then permitted to cool to room temperature.</p> <p>NOTE Relative humidity need not be maintained at a specific value during this conditioning.</p>			
<p>f) Presentation of the test results:</p> <p>There is not to be any damage resulting in an unacceptable RISK, including warping, cracking, breaking or other alterations.</p> <p>There was/was no cracking of the ENCLOSURE that could cause an unacceptable RISK.</p> <p>There were /were no barriers damaged or loosened.</p> <p>There was/was no damage that could result in reduction of CREEPAGE DISTANCES and AIR CLEARANCES.</p> <p>There was/was no warping that enabled access to hazardous parts using the test pin, test finger and test hook.</p>			
<p>TABLE: Mould stress relief</p>			
Part under test	Oven temperature °C	Time h	Remarks

13.3.27 Actuating parts of controls (Knob pull and limitation of movement)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.4.6.1, 15.4.6.2	13.3.27 Actuating parts of controls (Knob pull and limitation of movement)
a) Equipment needed for the test: <ol style="list-style-type: none"> 1) Force gauge with a range of at least 60 N to 100 N 2) Chronometer (stop watch) 3) Torque meter with a range of at least 1,0 Nm to 6,0 Nm 4) Callipers or gauge pin 		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: The sample should be securely mounted.		
d) Test conditions: Do not energize the DUT during this test.		
e) Test set-up and PROCEDURE: <ol style="list-style-type: none"> 1) Where an axial pull is required in NORMAL USE, or is likely to be applied to the rotating or moveable parts of controls in NORMAL USE, an axial force of 60 N for electrical components and 100 N for other components was applied for 1 min to the OPERATOR accessible knobs indicated below and in a direction to affect their removal. During this test, no torque was applied. 2) For rotating controls and stops, the torques as shown in Table 9 are applied between the control knob and the shaft for not less than 2 s in each direction alternately. The test is repeated 10 times. The knob should not rotate with respect to the shaft.		

13.3.27 Actuating parts of controls (Knob pull and limitation of movement) (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.4.6.1, 15.4.6.2	13.3.27 Actuating parts of controls (knob pull and limitation of movement)																	
<p>Table 9 – Test torques for rotating controls (IEC 60601-1:2005, Table 30)</p> <table border="1" data-bbox="507 465 1086 913"> <thead> <tr> <th data-bbox="507 465 796 555">Gripping diameter (<i>d</i>) of control knob mm^a</th> <th data-bbox="796 465 1086 555">Torque Nm</th> </tr> </thead> <tbody> <tr> <td data-bbox="507 555 796 600">0 ≤ <i>d</i> < 23</td> <td data-bbox="796 555 1086 600">1,0</td> </tr> <tr> <td data-bbox="507 600 796 645">23 ≤ <i>d</i> < 31</td> <td data-bbox="796 600 1086 645">2,0</td> </tr> <tr> <td data-bbox="507 645 796 689">31 ≤ <i>d</i> < 41</td> <td data-bbox="796 645 1086 689">3,0</td> </tr> <tr> <td data-bbox="507 689 796 734">41 ≤ <i>d</i> < 56</td> <td data-bbox="796 689 1086 734">4,0</td> </tr> <tr> <td data-bbox="507 734 796 779">56 ≤ <i>d</i> ≤ 70</td> <td data-bbox="796 734 1086 779">5,0</td> </tr> <tr> <td data-bbox="507 779 796 824"><i>d</i> > 70</td> <td data-bbox="796 779 1086 824">6,0</td> </tr> <tr> <td colspan="2" data-bbox="507 824 1086 913"> ^a The gripping diameter (<i>d</i>) is the maximum width of a control knob regardless of its shape (e.g. control knob with pointer). </td> </tr> </tbody> </table>				Gripping diameter (<i>d</i>) of control knob mm ^a	Torque Nm	0 ≤ <i>d</i> < 23	1,0	23 ≤ <i>d</i> < 31	2,0	31 ≤ <i>d</i> < 41	3,0	41 ≤ <i>d</i> < 56	4,0	56 ≤ <i>d</i> ≤ 70	5,0	<i>d</i> > 70	6,0	^a The gripping diameter (<i>d</i>) is the maximum width of a control knob regardless of its shape (e.g. control knob with pointer).	
Gripping diameter (<i>d</i>) of control knob mm ^a	Torque Nm																		
0 ≤ <i>d</i> < 23	1,0																		
23 ≤ <i>d</i> < 31	2,0																		
31 ≤ <i>d</i> < 41	3,0																		
41 ≤ <i>d</i> < 56	4,0																		
56 ≤ <i>d</i> ≤ 70	5,0																		
<i>d</i> > 70	6,0																		
^a The gripping diameter (<i>d</i>) is the maximum width of a control knob regardless of its shape (e.g. control knob with pointer).																			
<p>f) Presentation of the test results:</p>																			
<table border="1"> <thead> <tr> <th data-bbox="228 965 448 1037">Type</th> <th data-bbox="448 965 762 1037">Knob location</th> <th data-bbox="762 965 1134 1037">Securement</th> <th data-bbox="1134 965 1366 1037">Force N</th> </tr> </thead> <tbody> <tr> <td data-bbox="228 1037 448 1081">1)</td> <td data-bbox="448 1037 762 1081"></td> <td data-bbox="762 1037 1134 1081"></td> <td data-bbox="1134 1037 1366 1081"></td> </tr> <tr> <td data-bbox="228 1081 448 1126">2)</td> <td data-bbox="448 1081 762 1126"></td> <td data-bbox="762 1081 1134 1126"></td> <td data-bbox="1134 1081 1366 1126"></td> </tr> <tr> <td data-bbox="228 1126 448 1178">3)</td> <td data-bbox="448 1126 762 1178"></td> <td data-bbox="762 1126 1134 1178"></td> <td data-bbox="1134 1126 1366 1178"></td> </tr> </tbody> </table>				Type	Knob location	Securement	Force N	1)				2)				3)			
Type	Knob location	Securement	Force N																
1)																			
2)																			
3)																			
<p>The knob did/did not rotate on the shaft to give an incorrect indication. The knob could/could not be removed and replaced in a way to give an incorrect indication. The knob did/did not break. The stop did/did not prevent additional rotation. An axial pull did/did not cause the knob to become displaced or caused unexpected change of the controlled parameter.</p>																			

13.3.28 Construction of transformers

Standard(s): IEC 60601-1:2005	Subclause(s): 15.5.3	13.3.28 Construction of transformers
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Standard gauges 2) Callipers with magnifying feature or additional magnifying equipment 3) Tools to dismantle the transformer 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>Do not energize the DUT during this test.</p>		
<p>d) Test conditions:</p> <p>See 13.3.7.</p>		
<p>e) Test set-up and PROCEDURE:</p> <p>See 13.3.7 for the general procedure.</p> <ul style="list-style-type: none"> – Means shall be provided to prevent displacement of end turns beyond the interwinding insulation. – If a protective earthed screen has only one turn, it shall have an insulated overlap of not less than 3 mm. The width of the screen shall be at least equal to the axial winding length of the primary winding. – The exit of the wires from the internal windings of toroidal transformers shall be provided with double sleeving complying with the requirements for two MEANS OF PROTECTION and having a total wall thickness of at least 0,3 mm, extending at least 20 mm outside the winding. – The insulation between primary and secondary windings shall comply with 8.8.2. – CREEPAGE DISTANCES and AIR CLEARANCES shall comply with 8.9.4 with the following exceptions: <ul style="list-style-type: none"> • Enamelled or lacquered winding wires are considered as contributing 1 mm each to the CREEPAGE DISTANCES specified in 8.9.4 for MEANS OF PATIENT PROTECTION. • CREEPAGE DISTANCES are measured through the joint between two parts of an insulation barrier, except when: <ul style="list-style-type: none"> – either the two parts forming the joint are bonded by heat sealing or other similar means at the place where this is of importance; or – the joint is completely filled with adhesive at the necessary places and the adhesive bonds to the surfaces of the insulating barrier so that humidity cannot be sucked into the joint. – CREEPAGE DISTANCES within moulded transformers are considered not to exist if it can be shown that no gas bubbles are present and the thickness of the insulation between enamelled or lacquered primary and secondary windings is at least 1 mm for reference voltages U not exceeding 250 V and increased proportionally for higher reference voltages. 		

13.3.28 Construction of transformers (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 15.5.3	13.3.28 Construction of transformers)		
<p>f) Presentation of the test results:</p> <p>Means was/was not provided to prevent displacement of end turns beyond the interwinding insulation.</p> <p>A protective earthed screen with only one turn had/had not an insulated overlap of not less than 3 mm.</p> <p>The width of the screen was/was not at least equal to the axial winding length of the primary winding.</p> <p>The exit of the wires from the internal windings of toroidal transformers was/was not provided with double sleeving complying with the requirements for two MEANS OF PROTECTION and having a total wall thickness of at least 0,3 mm, extending at least 20 mm outside the winding.</p> <p>The insulation between primary and secondary windings shall comply with 8.8.2.</p> <p>The results of the measurements are specified in the table.</p>				
TABLE: CREEPAGE DISTANCE and AIR CLEARANCE				
Insulation under test (area from insulation diagram)	Insulation type: (BI-BASIC / SI-SUPPLEMENTARY / DI-DOUBLE / RI-REINFORCED) (for IEC 60601-1:1988) (Functional / one MOOP / two MOOP / one MOPP / two MOPP) (for IEC 60601-1:2005)	CREEPAGE DISTANCE mm	AIR CLEARANCE mm	Remarks
Primary – secondary				
Primary – core				
Secondary – core				
Screen overlap				
Extension of sleeving				
Thickness of sleeving				
Thickness of bubble free moulding				

13.4 Measurements and tests for equipment that is operating

Table 10 lists those measurements and tests that are performed while the DUT is operating.

Table 10 – Measurements and tests for equipment that is operating

Test per IEC/TR 62354		Clause in IEC 60601-1:1988	Clause in 60601-1:2005
No.	Description		
13.4.1	ESSENTIAL PERFORMANCE – Functional		4.3
13.4.2	Power consumption (input) single phase and polyphase	7.1	4.11
13.4.3	Voltage mismatch		5.4 a), 8.1
13.4.4	Limitation of voltage, current or energy	15	8.4.3; 8.4.4
13.4.5	DEFIBRILLATION-PROOF APPLIED PART protection	17 h)	8.5.5.1
13.4.6	Energy reduction		8.5.5.2
13.4.7	EARTH LEAKAGE CURRENT	19.4 f)	8.7.4.5
13.4.8	TOUCH CURRENT	19.4 g)	8.7.4.6
13.4.9	PATIENT LEAKAGE CURRENT	19.4 h)	8.7.4.7, 8.7.4.9
13.4.10	PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART	19.4	8.7.4.7 b)
13.4.11	PATIENT LEAKAGE CURRENT with mains on SIP/SOP	19.4	8.7.4.7 c)
13.4.12	PATIENT AUXILIARY CURRENT	19.4 j)	8.7.4.8
13.4.13	WORKING VOLTAGE measurement	20.3	8.5.4, 8.10.4.1
13.4.14	Sound pressure level measurement		9.6.2.1
13.4.15	Hydrostatic pressure	45	9.7.5
13.4.16	X-radiation (ionizing radiation) measurement	29.2	10.1
13.4.17	Normal heating	42	11.1
13.4.18	Operation to a specified temperature	10.2.1, 4.5	5.3
13.4.19	Identification of source of ignition		11.2.2.1
13.4.20	Interruption of power supply	49	11.8
13.4.21	Limited power circuit		13.1.2
13.4.22	Failures of THERMOSTATS	52.5.2	13.2.4
13.4.23	Impairment of cooling	52.5.5, 52.5.10 c), 56.6	13.2.7
13.4.24	Locking of moving parts	52.5.6	13.2.8
13.4.25	Interruption or short circuit of motor capacitors	52.5.7	13.2.9
13.4.26	Motor running overload	52.5.10 f)	13.2.13.3 b), 13.2.13.4
13.4.27	Heating element overload	52.5.10	13.2.13.1, 13.2.13.2
13.4.28	Rechargeable battery overcharge/discharge		15.4.3
13.4.29	Mains transformers	57.9	15.5; 13.2.3

13.4.1 ESSENTIAL PERFORMANCE – Functional *(continued)*

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause: 4.3</p>	<p>13.4.1 ESSENTIAL PERFORMANCE – Functional</p>
<p>Demonstration of OBJECTIVE EVIDENCE could be done by functional test.</p>		
<p>TABLE: Functional Tests</p>		
<p>ESSENTIAL PERFORMANCE identified</p>	<p>Functional tests conducted or verification of provided documents</p>	<p>Observed outcome</p>

13.4.2 Power consumption (input) single phase and polyphase

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 4.11	13.4.2 Power consumption (input) single phase and polyphase																																				
<p>a) Equipment requested for the testing:</p> <ol style="list-style-type: none"> 1) Adjustable regulated a.c. power supply 1 – 270 V, 50/60 Hz, 15 A or other similar voltage and frequency depending on input RATING of ME EQUIPMENT 2) Suitable true r.m.s. or average responding, true r.m.s. calibrated voltmeters, ammeters 3) Power analyzer (broadband digital complex waveform VAW meter) 4) Suitable load resistors and/or optional ACCESSORIES 5) Assorted interconnection cables 																																						
<p>b) Safety precautions during the test:</p> <p>It is important to determine the correct type of power input circuit to use for the DUT. Use normal laboratory safety PROCEDURES during this test.</p>																																						
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES</p>																																						
<p>d) Test conditions:</p> <p>NORMAL CONDITION using maximum loading according to ACCOMPANYING DOCUMENTS (e.g. printers operating, batteries fast charging, cutting...).</p>																																						
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Connect normal load to the DUT and operate the DUT under the most severe conditions of NORMAL USE until the input has reached a stable value. 2) Measure and record the input current, power or volt-amperes at the lowest and highest RATED voltage (when provided as a range). Measure at each NOMINAL marked setting when scalable. Measure at the NOMINAL marked voltage when singular. <p>The steady state or average current is measured with a true r.m.s. reading instrument.</p> <p>RATED input power, if expressed in volt-amperes, is either measured with a volt-ammeter or determined as the product of the steady state current (measured as described above) and the supply voltage.</p>																																						
<p>f) Presentation of the test results:</p> <table border="1" data-bbox="225 1402 1366 1677"> <thead> <tr> <th colspan="6">TABLE: Power consumption</th> </tr> <tr> <th>Operating condition</th> <th>Voltage</th> <th>Frequency</th> <th>Current</th> <th>Power</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> <p>The DUT is/is not marked in accordance with Subclause 7.2.7 of IEC 60601-1:2005</p> <p>The measured input of the ME EQUIPMENT at RATED voltage and at operating settings specified by the MANUFACTURER is not to exceed the marked rating by more than 10 %.</p> <p>The measured input current/power did not exceed/exceeded 110 % of the DUT ratings.</p>			TABLE: Power consumption						Operating condition	Voltage	Frequency	Current	Power	Remarks																								
TABLE: Power consumption																																						
Operating condition	Voltage	Frequency	Current	Power	Remarks																																	

13.4.3 Voltage mismatch

Standard(s): IEC 60601-1:2005+AMD1:2014	Subclause: 5.4 a), 8.1	13.4.3 Voltage mismatch			
a) Equipment needed for the test:					
1) Dielectric strength tester					
2) Power supply capable of providing voltages specified on equipment ratings label					
b) Safety precautions during the test:					
Use normal laboratory safety PROCEDURES during this test.					
c) Test sample preparation:					
Make the relevant supply circuit available (see Annex D).					
d) Test conditions:					
NORMAL CONDITION					
e) Test set-up and PROCEDURE:					
1) A DUT provided with an OPERATOR adjustable voltage selector is mounted and OPERATED as intended.					
2) Place the DUT on a white tissue paper covered softwood surface and draped with a single layer of cheesecloth.					
3) The input voltage selector switch is set to the lowest voltage setting and is then energized from a source of supply equivalent to the highest RATED voltage value.					
4) The input voltage selector switch is set to the highest voltage setting, and is then energized from a source of supply equivalent to the lowest RATED voltage value.					
5) Tests that resulted in opening of components or component damage are followed by a dielectric strength test.					
f) Presentation of the test results:					
TABLE: Voltage mismatch					
Model	Sample No.	Test	Selector switch voltage setting	Applied voltage V	Remarks
There was/was no emission of flame or molten metal or insulation damage.					
There was/was no ignition or charring of cheesecloth.					
There was/was no glowing or flaming of the tissue paper.					


13.4.4 Limitation of voltage, current or energy

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.4.3, 8.4.4	13.4.4 Limitation of voltage, current or energy
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Digital storage scope with 100:1 probe (for adequate impedance, limiting discharge through scope) 2) Capacitance measuring device 3) Disconnection device (1 s switch box) 4) A variable source of AC power supply 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative test sample.</p>		
<p>d) Test conditions:</p> <p>Make the relevant supply circuit available (see Annex D).</p> <p>This test applies to ME EQUIPMENT intended to be connected to a power source by a plug and to ME EQUIPMENT which consists of internal capacitive circuits.</p> <p>Where appropriate, a d.c. input voltage equal to the peak of the RATED SUPPLY MAINS voltage may be used.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate the DUT at RATED voltage or at the upper limit of the RATED voltage range. 2) Disconnect the DUT from the power source with any relevant switch in the “On” and “Off” positions. 3) Either the DUT is disconnected from the power source by means of the plug, in which case the test is performed as many times as necessary to allow the worst case to be measured, or a triggering circuit is used to ensure that disconnection occurs at the peak of the supply voltage waveform.) It may be beneficial to measure the capacitance using a capacitance measurement device and then calculating the energy. 4) Any ACCESS COVERS preventing access to the capacitors, present in NORMAL USE are removed as quickly as normally possible. The voltage between the pins of the plug and between any pin and the ENCLOSURE is measured 1 s after disconnection with an instrument the internal impedance of which does not affect the test. If greater than 60 V, the energy is calculated with the formula $E = 0,5 \times CV^2$. 5) Measure or calculate the stored charge by any convenient method. The stored energy is calculated from the following equation: $J = 5 \times 10^{-7} CV^2$Where J is the stored energy in joules; C is the capacitance in microfarads; V is the voltage across the capacitor terminals. 6) Consider visual inspection and inspection of ACCOMPANYING DOCUMENTS. 		

13.4.4 Limitation of voltage, current or energy (continued)


<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 8.4.3, 8.4.4</p>	<p>13.4.4 Limitation of voltage, current or energy</p>		
<p>f) Presentation of the test results:</p>				
<p>TABLE: Residual voltage in attachment plug</p>				
<p>Voltage measured between:</p>		<p>Worst case measured voltage V</p>		
<p>Supply pins (pin 1 & pin 2)</p>				
<p>Line pin 1 and ENCLOSURE</p>				
<p>Line pin 2 and ENCLOSURE</p>				
<p>Line pin 1 and earth pin</p>				
<p>Line pin 2 and earth pin</p>				
<p>The highest voltage measurement did/did not exceed 60 V.</p>				
<p>TABLE: Residual voltage or energy in capacitors</p>				
<p>Capacitor and its location</p>	<p>Residual voltage V</p>	<p>Access time after disconnection s</p>	<p>Capacitance value µF</p>	<p>Stored charge µC</p>
<p>The residual voltage at the plug did/did not exceed 60 V.</p>				
<p>The stored charge at the plug does /does not exceed 45 µC.</p>				
<p>The residual voltage of internal capacitors after ACCESS COVERS have been removed does /does not exceed 60 V.</p>				
<p>The stored charge of internal capacitors after ACCESS COVERS have been removed does /does not exceed 45 µC.</p>				

13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection



IEC

13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection (continued)



13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection <i>(continued)</i>		
Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.5.5.1	13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection
<p>b) Safety precautions during the test:</p> <p>Defibrillators are designed to produce pulses on accessible electrodes. These pulses are potentially lethal. Only properly trained and authorised personnel should perform these tests.</p> <p>Before carrying out these tests, the ME EQUIPMENT, in particular HIGH VOLTAGE cables and electrodes, should be examined for damage and for anything that may affect the integrity of the insulation such as conductive gel. The test apparatus should be positioned to avoid the possibility of accidental contact by other persons. Defibrillators or similar HIGH VOLTAGE sources should not be left switched on and left unattended. Variable output voltage controls should always be set to the minimum value when not in use.</p>		
<p>c) Test sample preparation:</p> <p>The ME EQUIPMENT is energised unless inspection of the circuits shows that a de-energised state is the worst-case situation.</p>		
<p>d) Test conditions:</p> <p>During each test:</p> <ul style="list-style-type: none"> – Connect the PROTECTIVE EARTH CONDUCTOR of CLASS I ME EQUIPMENT to earth. Test CLASS I ME EQUIPMENT that is capable of operation without a SUPPLY MAINS, e.g. having an internal battery, again without its PROTECTIVE EARTH CONNECTION. – Cover insulating surfaces of APPLIED PARTS with metal foil or immersed the APPLIED PART in a 0,9 % saline solution. – Remove any external connection to a FUNCTIONAL EARTH TERMINAL. – Connect non-PROTECTIVELY EARTHED parts to a display device in turn at a point other than where energy is being measured. 		

13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection (continued)		
Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.5.5.1	13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection
<p>e) Test set-up and PROCEDURE:</p> <p>1) Common-mode test:</p> <p>Connect the DUT to the test circuit as shown in Figure 14. Connect all the non-PROTECTIVELY EARTHED or functionally earthed PATIENT connections of the DEFIBRILLATION-PROOF APPLIED PART together. Apply the test voltage to all the PATIENT CONNECTIONS of the DEFIBRILLATION-PROOF APPLIED PART to the combined connections. If an APPLIED PART has multiple functions, the test voltage is applied to all the PATIENT CONNECTIONS of one function at a time with the other functions disconnected.</p> <p>Measure the energy from the following parts in turn:</p> <ul style="list-style-type: none"> – The ENCLOSURE, including connectors in PATIENT leads and cables when connected to the ME EQUIPMENT (does not apply when disconnected from the DUT). – Any SIGNAL INPUT/OUTPUT PART. – Metal foil with an area at least as large as the base of the ME EQUIPMENT upon which the ME EQUIPMENT is placed. – PATIENT CONNECTIONS of any other APPLIED PART (whether or not classified as a DEFIBRILLATION-PROOF APPLIED PART). – Any unused or disconnected connections of the APPLIED PART under test or any function of the same APPLIED PART. <p>ME EQUIPMENT that is completely BODY-WORN is exempt from this requirement.</p> <p>2) Differential-mode test:</p> <p>Connect the DUT to the test circuit as shown in Figure 15 Connect all but one of the PATIENT connections of the DEFIBRILLATION-PROOF APPLIED PART together and then connect that to earth. Apply the test voltage to the remaining PATIENT CONNECTION.</p> <p>Do not perform the differential-mode test if the APPLIED PART consists of a single PATIENT connection.</p> <p>Where multiple APPLIED PARTS share a common PATIENT circuit and are not separated by the required CREEPAGE DISTANCE and AIR CLEARANCE, then treat all these APPLIED PARTS as DEFIBRILLATION-PROOF APPLIED PARTS.</p> <p>After the tests, and following any recovery time stated in the ACCOMPANYING DOCUMENTS, verify that the DUT continues to provide BASIC SAFETY and ESSENTIAL PERFORMANCE.</p> <p>During the tests:</p> <ul style="list-style-type: none"> – Except for PERMANENTLY INSTALLED ME EQUIPMENT, test the ME EQUIPMENT with and without the PROTECTIVE EARTH CONDUCTOR connected. – Cover insulating surfaces of APPLIED PARTS with metal foil or, where appropriate, immerse the APPLIED PART in a 0,9 % saline solution. – Any external connection to a FUNCTIONAL EARTH TERMINAL is removed; – Connect the ME EQUIPMENT to the SUPPLY MAINS and operated it in accordance with the ACCOMPANYING DOCUMENTS. <p>Measure the peak voltage and repeat each test with test voltage reversed.</p>		

13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.5.5.1	13.4.5 DEFIBRILLATION-PROOF APPLIED PART protection			
f) Presentation of the test results:					
TABLE: DEFIBRILLATION-PROOF APPLIED PARTS					
Test condition: Figure 14 or Figure 15	ACCESSIBLE PART of measurement	APPLIED PART with test voltage	Test voltage polarity	Voltage measured between Y1 and Y2 mV	Remarks
TABLE: Defibrillation-proof recovery time					
APPLIED PART with test voltage	Test voltage polarity	Recovery time from ACCOMPANYING DOCUMENT s	Measured recovery time s	Remarks	



13.4.6 Energy reduction

Standard(s) IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.5.5.2	13.4.6 Energy reduction
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Test circuits as shown in Figure 16 2) Means to evaluate d.c. energy delivered to a resistive (non inductive) load <div data-bbox="188 521 1394 1189" style="border: 1px solid black; padding: 10px;"> <p style="text-align: right;">IEC</p> </div> <p>Components</p> <p>S Switch for applying the test energy</p> <p>A, B Switch positions</p> <p>R_{CL} Current limiting resistor</p> <p>Components tolerated at $\pm 5\%$</p> <p style="text-align: center;">Figure 16 – Application of test voltage to test the delivered defibrillation energy (energy reduction test)</p> <p style="text-align: center;">(IEC 60601-1:2005+AMD1:2012, Figure 11)</p>		
<p>b) Safety precautions during the test:</p> <p>Defibrillators are designed to produce potentially lethal pulses on accessible electrodes. Only properly trained and authorised personnel should perform these tests.</p> <p>Before carrying out this test, examine the ME EQUIPMENT, in particular HIGH VOLTAGE cables and electrodes, should be examined for damage and for anything that may affect the integrity of the insulation such as conductive gel. Position the test apparatus to avoid the possibility of accidental contact by other persons. Do not leave defibrillators or similar HIGH VOLTAGE sources switched on and unattended. Always set variable output voltage controls to the minimum value when not in use.</p>		
<p>c) Test sample preparation:</p> <p>Energize the ME EQUIPMENT unless inspection of the circuits shows that a de-energised state is the worst-case situation.</p>		

13.4.6 Energy reduction (continued)

Standard(s): IEC 60601-1:2005+A1:2012	Subclause(s): 8.5.5.2	13.4.6 ENERGY REDUCTION																					
<p>d) Test conditions: Use ACCESSORIES such as cables, electrodes and transducers that are recommended in the instructions for use.</p>																							
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Connect the APPLIED PART OF PATIENT CONNECTION to the test circuit. The parts described in 8.5.5.1 a) are connected to earth (See 13.4.5 above for list of parts). 2) Charge capacitor <i>C</i> to 5 kV d.c. with switch <i>S</i> in position A. 3) Discharge capacitor <i>C</i> by actuating the switch <i>S</i> to position B, and evaluate the energy <i>E</i>₁ delivered to the 100 Ω load. Measure or calculate the energy by any convenient method. 4) Remove the ME EQUIPMENT under test from the test circuit and repeat steps 2) and 3) above, evaluating the energy <i>E</i>₂ delivered to the 100 Ω load. Apply the test voltage to each PATIENT CONNECTION OF APPLIED PART in turn, with all the remaining PATIENT CONNECTIONS of the same APPLIED part connected to earth (differential mode). 5) Other DEFIBRILLATOR PROOF APPLIED PARTS, if any, are tested separately, in turn. 6) Repeat the test with reverse test voltage. <p>NOTE Delivered energy can be expressed as:</p> $W_d = W_s \times R / (R + R_i)$ <p>where <i>W</i>_d is the delivered energy in J, <i>W</i>_s is the stored energy in J, <i>R</i> is the subject resistance (i.e. 100 Ω), <i>R</i>_i is the measuring device resistance in Ω.</p> <p><i>W</i>_s = <i>CU</i>² / 2, where <i>C</i> is the capacitance in farads (i.e. 32 × 10⁻⁶ F), <i>U</i> is the voltage applied to the capacitor (i.e. 5 kV).</p>																							
<p>f) Presentation of the test results:</p> <table border="1" data-bbox="226 1218 1366 1473"> <thead> <tr> <th colspan="4" data-bbox="226 1218 1366 1263">TABLE: Measured/calculated energy</th> </tr> <tr> <th data-bbox="226 1263 603 1335">APPLIED PART/connection</th> <th data-bbox="603 1263 906 1335">Measured/calculated energy (E1)</th> <th data-bbox="906 1263 1193 1335">Measured/calculated energy (E2)</th> <th data-bbox="1193 1263 1366 1335">% Reduction</th> </tr> </thead> <tbody> <tr> <td data-bbox="226 1335 603 1384"></td> <td data-bbox="603 1335 906 1384"></td> <td data-bbox="906 1335 1193 1384"></td> <td data-bbox="1193 1335 1366 1384"></td> </tr> <tr> <td data-bbox="226 1384 603 1433"></td> <td data-bbox="603 1384 906 1433"></td> <td data-bbox="906 1384 1193 1433"></td> <td data-bbox="1193 1384 1366 1433"></td> </tr> <tr> <td data-bbox="226 1433 603 1473"></td> <td data-bbox="603 1433 906 1473"></td> <td data-bbox="906 1433 1193 1473"></td> <td data-bbox="1193 1433 1366 1473"></td> </tr> </tbody> </table> <p>Measured / calculated energy E1: _____ J</p> <p>Measured / calculated energy E2: _____ J</p> <p>E1 is /is not at least 90 % of E2.</p>				TABLE: Measured/calculated energy				APPLIED PART/connection	Measured/calculated energy (E1)	Measured/calculated energy (E2)	% Reduction												
TABLE: Measured/calculated energy																							
APPLIED PART/connection	Measured/calculated energy (E1)	Measured/calculated energy (E2)	% Reduction																				


13.4.7 EARTH LEAKAGE CURRENT

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 8.7.4.5</p>	<p>13.4.7 EARTH LEAKAGE CURRENT</p>
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Voltmeter 2) Digital storage oscilloscope with true RMS feature 3) Variable source of AC power supply 4) Measuring device and its frequency characteristics as shown in Figure 17. <div style="display: flex; justify-content: space-around;"> <div data-bbox="215 694 774 1086" style="width: 45%;">  <p style="margin-top: 10px;"> R_1 10 kΩ \pm 5 %^{a)} R_2 1 kΩ \pm 1 %^{a)} C_1 0,015 μF \pm 5 % </p> <p style="text-align: center;">a) Measuring device</p> </div> <div data-bbox="861 582 1340 1086" style="width: 45%;">  <p style="text-align: center;">b) Frequency characteristics</p> </div> </div> <p style="text-align: center; margin-top: 20px;">NOTE The network and voltage measuring instrument above are replaced by the symbol MD in the following figures.</p> <ol style="list-style-type: none"> a) Non-inductive components b) Resistance \geq 1 MΩ and capacitance \leq 150 pF c) $Z(f)$ is the transfer impedance of the network, i.e. V_{out}/I_{in}, for a current of frequency f. <p style="text-align: center; margin-top: 20px;">Figure 17 – Example of a measuring device and its frequency characteristics (IEC 60601-1:2005+AMD1:2012, Figure 12)</p>		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>Place APPLIED PARTS, including PATIENT cords (when present) on an insulating surface with a dielectric constant of approximately 1 (for example, expanded polystyrene). Position the APPLIED PARTS approximately 200 mm above an earthed metal surface.</p> <p>Position the measuring supply circuit and the measuring circuit as far as possible away from unscreened power source leads. Avoid placing the ME EQUIPMENT on or near a large earthed metal surface.</p> <p>If the test results for the APPLIED PARTS can depend upon how those parts are placed on the insulating surface, repeat the test as needed to determine the worst possible positioning.</p> <p>If an isolating transformer is not used for LEAKAGE CURRENT measurements (e.g. when measuring LEAKAGE CURRENT for very high input power ME EQUIPMENT), connect the reference earth of the measuring circuits to protective earth of the SUPPLY MAINS.</p>		

13.4.7 EARTH LEAKAGE CURRENT (continued)

Standard(s): IEC 60601-1:2005+A1:2012	Subclause(s): 8.7.4.5	13.4.7 EARTH LEAKAGE CURRENT
<p>d) Test conditions:</p> <p>ME EQUIPMENT specified for connection to a SUPPLY MAINS is connected to an appropriate power source as shown in Figure 18. For single-phase ME EQUIPMENT, the polarity of the supply is reversible and tests are conducted at both polarities.</p> <p>Test the ME EQUIPMENT provided with a POWER SUPPLY CORD using this cord.</p> <p>Test the ME EQUIPMENT provided with an APPLIANCE INLET while connected to the measuring supply circuit via a DETACHABLE POWER SUPPLY CORD having a length of 3 m or a length and type specified by the MANUFACTURER.</p> <p>Test PERMANENTLY INSTALLED ME EQUIPMENT while connected to the measuring supply circuit by the shortest possible connection.</p> <p>The measuring device should load the source of LEAKAGE CURRENT or PATIENT AUXILIARY CURRENT with a resistive impedance of approximately 1 kΩ for d.c., a.c. and for composite waveforms with frequencies up to and including 1 MHz.</p> <p>If significant currents or current components with frequencies exceeding 1 kHz are likely to occur, measure these using other appropriate means such as a 1 kΩ non-inductive resistor and a suitable measuring instrument.</p> <p>The measuring instrument (voltmeter) is to have an input resistance of at least 1 MΩ and input capacitance of no more than 150 pF. It should indicate the true r.m.s. value of the voltage, being d.c., a.c. or a composite waveform having components with frequencies from 0,1 Hz up to and including 1 MHz, with an indicating error not exceeding ± 5 % of the indicated value.</p> <p>The scale may indicate the current through the measuring device including automatic evaluation of components with frequencies above 1 kHz.</p> <p>These requirements may be limited to a frequency range with an upper limit lower than 1 MHz if it can be proven (for example, by the use of an oscilloscope) that frequencies above such an upper limit do not occur in the measured current.</p> <p>The only SINGLE FAULT CONDITION for the EARTH LEAKAGE CURRENT is the interruption of one supply conductor at a time.</p> <p>In the case of FIXED ME EQUIPMENT that may have connections to earth through the building structure, the MANUFACTURER should specify a suitable test PROCEDURE and configuration for measurement of EARTH LEAKAGE CURRENT.</p> <p>Apply the values of the EARTH LEAKAGE CURRENT in any combination of the following conditions:</p> <ul style="list-style-type: none"> – At operating temperature following the humidity preconditioning treatment. – In NORMAL CONDITION and in the SINGLE FAULT CONDITIONS specified. – With the ME EQUIPMENT energized in stand-by condition and fully operating and with any switch in the MAINS PART in any position. – With the highest RATED supply frequency. – With a supply equal to 110 % of the highest RATED MAINS VOLTAGE. – After any required sterilization PROCEDURE (see IEC 60601-1:2005+AMD1:2012, 11.6.7) 		
<p>e) Test set-up and PROCEDURE:</p> <p>If the ME EQUIPMENT has more than one PROTECTIVE EARTH CONDUCTOR (for example one connected to the main ENCLOSURE and one to a separate power supply unit) then the current to be measured is the aggregate current that would flow into the protective earthing system of the installation.</p> <p>Measure the LEAKAGE CURRENTS that can flow in a FUNCTIONAL EARTH CONDUCTOR in non-PERMANENTLY INSTALLED ME EQUIPMENT.</p>		

13.4.7 EARTH LEAKAGE CURRENT (continued)



13.4.7 EARTH LEAKAGE CURRENT (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.7.4.5	13.4.7 EARTH LEAKAGE CURRENT		
f) Presentation of the test results:				
TABLE: LEAKAGE CURRENT				
Type of LEAKAGE CURRENT and test condition (including single faults)	Supply voltage V	Supply frequency Hz	Measured max. value µA	Remarks
(Record at least maximum measured value for each test and the specific conditions of the test circuit and equipment).				
Abbreviations suitable for the test report:				
ER – EARTH LEAKAGE CURRENT EN – ENCLOSURE LEAKAGE CURRENT P – PATIENT LEAKAGE CURRENT PM – PATIENT LEAKAGE CURRENT with mains on the APPLIED PARTS PSM – PATIENT LEAKAGE CURRENT with mains on SIP/SOPS PA – PATIENT AUXILIARY CURRENT MD – Measuring device TC – TOUCH CURRENT TPLC – Total PATIENT LEAKAGE CURRENT	A – After humidity conditioning B – Before humidity conditioning 1 – Switch closed or set to normal polarity 0 – Switch open or set to reversed polarity NC – NORMAL CONDITION SFC – SINGLE FAULT CONDITION			

13.4.8 TOUCH CURRENT

Standard(s): IEC 60601-1:2005	Subclause(s): 8.7.4.6	13.4.8 TOUCH CURRENT
<p>a) Equipment needed for the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 a)].</p>		
<p>b) Safety precautions during the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 b)].</p>		
<p>c) Test sample preparation: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 c)].</p>		
<p>d) Test conditions: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 d)].</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Measure with MD between earth and each part of the ENCLOSURE(s) that is not PROTECTIVELY EARTHED (see Figure 19). 2) Measure with MD between parts of the ENCLOSURE(s) that are not PROTECTIVELY EARTHED. 3) In the SINGLE FAULT CONDITION of interruption of any one PROTECTIVE EARTH CONDUCTOR, measure with MD between earth and any part of the ENCLOSURE(s) that is normally PROTECTIVELY EARTHED. Do not make separate measurements from more than one part that is PROTECTIVELY EARTHED. 4) An INTERNALLY POWERED ME EQUIPMENT is only investigated for TOUCH CURRENT between parts of the ENCLOSURE, not between the ENCLOSURE and earth. 5) If the ME EQUIPMENT has an ENCLOSURE or a part of the ENCLOSURE made of insulating material, apply metal foil of maximum 20 cm × 10 cm in intimate contact with the ENCLOSURE or relevant part of the ENCLOSURE. If the surface of the ENCLOSURE contacted by the PATIENT or OPERATOR is larger than 20 cm × 10 cm, increase the size of the foil to correspond to the area of contact. Shift the metal foil, if possible, to determine the highest value of the TOUCH CURRENT. The metal foil should not touch any metal parts of the ENCLOSURE that may be PROTECTIVELY EARTHED. However, metal parts of the ENCLOSURE that are not PROTECTIVELY EARTHED can be covered partly or totally by the metal foil. To measure the TOUCH CURRENT in the SINGLE FAULT CONDITION of interruption of a PROTECTIVE EARTH CONDUCTOR, arrange the metal foil to contact parts of the ENCLOSURE that are normally PROTECTIVELY EARTHED. The above apply also when measuring the TOUCH CURRENT between two pieces of metal foil placed on different parts of the DUT that may be contacted simultaneously. 6) ME EQUIPMENT with a SIGNAL INPUT/OUTPUT PART is, when required, additionally tested using transformer T₂. Set the voltage at the transformer T₂ to 110 % of the MAXIMUM MAINS VOLTAGE. Before applying the external voltage, identify the worst case pin configuration based on testing or circuit analysis. 		

13.4.8 TOUCH CURRENT (continued)


Standard(s): IEC 60601-1:2005	Subclause(s): 8.7.4.6	13.4.8 TOUCH CURRENT
<p>Key Measure (with S_7 closed if CLASS I equipment) under all possible combinations of positions of S_1, S_5, S_9, S_{10}, and S_{12}. S_1 open is SINGLE FAULT CONDITION. CLASS I equipment only: Measure with S_7 open (SINGLE FAULT CONDITION) and with S_1 closed under all possible combinations of S_5, S_9, S_{10} and S_{12}. For CLASS II equipment, the PROTECTIVE EARTH CONNECTION and S_7 are not used. Transformer T_2 is used if required.</p> <p align="center">Figure 19 – Measuring circuit for the TOUCH CURRENT (IEC 60601-1:2005+AMD1:2012, Figure 14)</p>		
<p>f) Presentation of the test results: See EARTH LEAKAGE CURRENT [test 13.4.7 f)].</p>		

13.4.9 PATIENT LEAKAGE CURRENT

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.7.4.7, 7.8.4.9	13.4.9 PATIENT LEAKAGE CURRENT
a) Equipment needed for the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 a)].		
b) Safety precautions during the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 b)].		
c) Test sample preparation: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 c)].		
d) Test conditions: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 d)].		
e) Test set-up and PROCEDURE: <ol style="list-style-type: none"> 1) Place an ENCLOSURE, other than an APPLIED PART, made of insulating material in any position of NORMAL USE upon a flat metal surface that is connected to earth with dimensions at least equal to the plane-projection of the ENCLOSURE. 2) Use metal foil to test an APPLIED PART consisting of a surface made of insulating material. Alternatively, immerse the APPLIED PART in a 0,9 % saline solution. If the surface of the APPLIED PART contacted by the PATIENT is larger than 20 cm × 10 cm, increase the size of the foil to correspond to the area of contact. Treat this metal foil or saline solution as the only PATIENT CONNECTION for the APPLIED PART. 3) If the PATIENT CONNECTION is formed by a fluid which contacts the PATIENT, replace the fluid with a 0,9 % saline solution. Place an electrode in the saline solution. Treat this electrode as the PATIENT CONNECTION for the APPLIED PART. 4) Measure the PATIENT LEAKAGE CURRENT (see Figure 20): <ul style="list-style-type: none"> – for TYPE B APPLIED PARTS from all PATIENT CONNECTIONS connected directly together, and for TYPE BF APPLIED PARTS, from and to all PATIENT CONNECTIONS of a single function, either connected directly together or loaded as in NORMAL USE; – for TYPE CF APPLIED PARTS, from and to every PATIENT CONNECTION in turn. If the instructions for use specifies alternatives for a detachable part of the APPLIED PART (for example, PATIENT leads and electrodes), measure the PATIENT LEAKAGE CURRENT with the least favourable specified detachable part. 5) Measure the total PATIENT LEAKAGE CURRENT from and to all PATIENT CONNECTIONS of all APPLIED PARTS of the same type (TYPE B APPLIED PARTS, TYPE BF APPLIED PARTS OR TYPE CF APPLIED PARTS) connected together (see Figure 21). NOTE Measurement of TOTAL PATIENT LEAKAGE CURRENT of TYPE B APPLIED PARTS is only necessary if there are two or more PATIENT CONNECTIONS that belong to different functions and that are not electrically connected directly together. If necessary, disconnect a functional earth before conducting this test. 		

13.4.9 PATIENT LEAKAGE CURRENT (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 8.7.4.7, 8.7.4.9	13.4.9 PATIENT LEAKAGE CURRENT
<p>6) If loading of the PATIENT CONNECTIONS of the APPLIED PART is specified by the MANUFACTURER, connect the MD to each PATIENT CONNECTION in turn with the load in place.</p> <p>7) ME EQUIPMENT with multiple PATIENT CONNECTIONS is investigated to ensure that the PATIENT LEAKAGE CURRENT and the PATIENT AUXILIARY CURRENT do not exceed the allowable values for NORMAL CONDITION while one or more PATIENT CONNECTIONS are:</p> <ul style="list-style-type: none"> - disconnected from the PATIENT; and - disconnected from the PATIENT and earthed. <p>Testing is performed if an examination of the ME EQUIPMENT circuit indicates that the PATIENT LEAKAGE CURRENT or the PATIENT AUXILIARY CURRENT can increase to excessive levels under the above conditions. Limit the actual measurements to a representative number of combinations.</p>		



Key

Measure (with S_7 closed if CLASS I ME EQUIPMENT) under all possible combinations of positions of S_1 , S_5 , S_{10} and S_{13} .

S_1 open is SINGLE FAULT CONDITION.

CLASS I ME EQUIPMENT only:

Measure with S_7 open (SINGLE FAULT CONDITION) and with S_1 closed under all possible combinations of S_5 , S_{10} and S_{13} .

For CLASS II ME EQUIPMENT, the PROTECTIVE EARTH CONNECTION and S_7 are not used.

Figure 20 – Measuring circuit for the PATIENT LEAKAGE CURRENT from the PATIENT CONNECTION to earth

(IEC 60601-1:2005+AMD1:2012, Figure 15)


13.4.9 PATIENT LEAKAGE CURRENT (continued)

<p>Standard(s): IEC 60601-1:2005+AMD1:2012</p>	<p>Subclause(s): 8.7.4.7</p>	<p>13.4.9 PATIENT LEAKAGE CURRENT</p>
<div style="text-align: center;">See Figure 17</div> <p style="text-align: center;">These connections will depend on the measurement being made. See Figure 15 through Figure 18 (inclusive)</p>		
<p>Key</p> <p>For the position of S₁, S₅, S₇ and S₁₀, see Figure 15, Figure 16, Figure 17 or Figure 18 in IEC 60601-1:2005.</p> <p>Figure 21 – Measuring circuit for the total PATIENT LEAKAGE CURRENT with all PATIENT CONNECTIONS of all APPLIED PARTS of the same type (TYPE B APPLIED PARTS, TYPE BF APPLIED PARTS or TYPE CF APPLIED PARTS) connected together</p> <p>(IEC 60601-1:2005+AMD1:2012, Figure 20)</p> <p>f) Presentation of the test results:</p> <p>See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 f)].</p>		

13.4.10 PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART

Standard(s): IEC 60601-1:2005	Subclause(s): 8.7.4.7 b)	13.4.10 PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART
a) Equipment needed for the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 a)].		
b) Safety precautions during the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 b)].		
c) Test sample preparation: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 c)].		
d) Test conditions: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 d)]. SINGLE FAULT CONDITION: 110 % of MAXIMUM MAINS VOLTAGE on F-TYPE APPLIED PART		
e) Test set-up and PROCEDURE: <ol style="list-style-type: none"> 1) Test ME EQUIPMENT WITH AN F-TYPE APPLIED PART with mains on the APPLIED PART (see Figure 22): <ul style="list-style-type: none"> – Connect SIGNAL INPUT/OUTPUT PARTS to earth, if not already permanently earthed in the ME EQUIPMENT. – Set the voltage at the transformer T_2 to 110 % of the MAXIMUM MAINS VOLTAGE. <p>For this measurement, connect non-PROTECTIVELY EARTHED metal ACCESSIBLE PARTS including PATIENT CONNECTIONS of other APPLIED PARTS (if present) to earth.</p> 2) ME EQUIPMENT with a PATIENT CONNECTION of a TYPE B APPLIED PART that is not PROTECTIVELY EARTHED or a TYPE BF APPLIED PART and with metal ACCESSIBLE PARTS that are not PROTECTIVELY EARTHED is additionally tested using the measuring circuit in Figure 23. 3) Set the voltage at the transformer T_2 to 110 % of the MAXIMUM MAINS VOLTAGE. <p>This test need not be conducted if it can be demonstrated that there is adequate separation of the parts involved.</p>		

13.4.10 PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART (continued)



13.4.10 PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 8.7.4.7 b)</p>	<p>13.4.10 PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART</p>
<p>Key Measure with S_1 closed (and with S_7 closed, if CLASS I ME EQUIPMENT) under all possible combinations of positions of S_5, S_9 and S_{10}. For CLASS II ME EQUIPMENT, the PROTECTIVE EARTH CONNECTION and S_7 are not used.</p> <p>Figure 23 – Measuring circuit for the PATIENT LEAKAGE CURRENT from PATIENT CONNECTION(s) to earth caused by an external voltage on a metal ACCESSIBLE PART that is not PROTECTIVELY EARTHED</p> <p>(IEC 60601-1:2005+AMD1:2012, Figure 18)</p>		
<p>f) Presentation of the test results: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 f)].</p>		

13.4.11 PATIENT LEAKAGE CURRENT with mains on SIP/SOP

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 8.7.4.7 c)</p>	<p>13.4.11 PATIENT LEAKAGE CURRENT with mains on SIP/SOP</p>
<p>a) Equipment needed for the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 a)].</p>		
<p>b) Safety precautions during the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 b)].</p>		
<p>c) Test sample preparation: See EARTH LEAKAGE CURRENT measurement method [(test 13.4.7 c)].</p>		
<p>d) Test conditions: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 d)]. SINGLE FAULT CONDITION: 110 % of MAXIMUM MAINS VOLTAGE on a SIGNAL INPUT/OUTPUT PART</p>		
<p>e) Test set-up and PROCEDURE: When ACCOMPANYING DOCUMENTS place no restrictions on other equipment which may be connected to the DUT (ME EQUIPMENT), and the DUT has SIP/SOPS, test the device with the MAXIMUM MAINS VOLTAGE on the SIP/SOP (see Figure 24). Set the voltage at the transformer T₂ to 110 % of the MAXIMUM MAINS VOLTAGE. Before applying the external voltage, identify the worst case pin configuration based on testing or circuit analysis.</p>		


13.4.11 PATIENT LEAKAGE CURRENT with mains on SIP/SOP (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 8.7.4.7 c)	13.4.11 PATIENT LEAKAGE CURRENT with mains on SIP/SOP
<p>Key Measure (with S_7 closed, if CLASS I ME EQUIPMENT) under all possible combinations of positions of S_1, S_5, S_9, S_{10} and S_{13} (S_1 open is SINGLE FAULT CONDITION). CLASS I ME EQUIPMENT only: Measure with S_7 open (SINGLE FAULT CONDITION) and with S_1 closed under all possible combinations of S_5, S_9, S_{10} and S_{13}. For CLASS II ME EQUIPMENT, the PROTECTIVE EARTH CONNECTION and S_7 are not used.</p> <p>Figure 24 – Measuring circuit for the PATIENT LEAKAGE CURRENT from PATIENT CONNECTION(S) to earth caused by an external voltage on a SIGNAL INPUT/OUTPUT PART (IEC 60601-1:2005+AMD1:2012, Figure 17)</p>		
<p>f) Presentation of the test results: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 f)].</p>		

13.4.12 PATIENT AUXILIARY CURRENT

Standard(s): IEC 60601-1:2005	Subclause(s): 8.7.4.8	13.4.12 PATIENT AUXILIARY CURRENT
a) Equipment needed for the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 a)].		
b) Safety precautions during the test: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 b)].		
c) Test sample preparation: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 c)].		
d) Test conditions: See EARTH LEAKAGE CURRENT measurement method test 13.4.7 d)].		
e) Test set-up and PROCEDURE: Test ME EQUIPMENT with an APPLIED PART according to Figure 25, using an appropriate measuring supply circuit unless the ME EQUIPMENT has only a single PATIENT CONNECTION. Measure the PATIENT AUXILIARY CURRENT between any single PATIENT CONNECTION and all other PATIENT CONNECTIONS, either connected directly together or loaded as specified by the MANUFACTURER. Measure PATIENT AUXILIARY CURRENT as NORMAL CONDITION values while one or more PATIENT CONNECTIONS are: <ul style="list-style-type: none"> – disconnected from the PATIENT; and – disconnected from the PATIENT and earthed. Only perform this test if examination of the DUT circuit indicates that the PATIENT AUXILIARY CURRENT can increase to excessive levels under the above conditions. Limit actual measurements to a representative number of combinations.		

13.4.12 PATIENT AUXILIARY CURRENT (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 8.7.4.8</p>	<p>13.4.12 PATIENT AUXILIARY CURRENT</p>
<div style="text-align: center;">  </div> <p style="text-align: right;">IEC</p> <p>Key Measure (with S₇ closed if CLASS I ME EQUIPMENT) under all possible combinations of positions of S₁, S₅, and S₁₀. S₁ open is SINGLE FAULT CONDITION. CLASS I ME EQUIPMENT only: Measure with S₇ open (SINGLE FAULT CONDITION) and with S₁ closed under all possible combinations of positions of S₅, and S₁₀. For CLASS II ME EQUIPMENT, the PROTECTIVE EARTH CONNECTION and S₇ are not used.</p> <p style="text-align: center;">Figure 25 – Measuring circuit for the PATIENT AUXILIARY CURRENT (IEC 60601-1:2005+AMD1:2012, Figure 19)</p>		
<p>f) Presentation of the test results: See EARTH LEAKAGE CURRENT measurement method [test 13.4.7 f)].</p>		

13.4.13 WORKING VOLTAGE measurement

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 8.5.4, 8.10.4.1</p>	<p>13.4.13 WORKING VOLTAGE measurement</p>
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Digital storage scope 2) True r.m.s voltmeter 3) Variable power source 4) Oscilloscope 		
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative test sample.</p> <p>Make the relevant supply circuit available (see Annex D).</p>		
<p>d) Test conditions:</p> <p>Treat unearthed accessible conductive parts as if they are earthed.</p> <p>If a transformer winding or other part is floating (it is not connected to a circuit which establishes its potential relative to earth), assume that winding or other part is earthed at the point where the highest WORKING VOLTAGE is obtained.</p> <p>For insulation between two transformer windings, use the highest voltage between any two points in the two windings, taking into account external voltages to which the windings are connected.</p> <p>For insulation between a transformer winding and another part, use the highest voltage between any point on the winding and the other part.</p> <p>Where DOUBLE INSULATION is used, determine the WORKING VOLTAGE across the BASIC INSULATION by imagining a short circuit across the SUPPLEMENTARY INSULATION, and vice versa. For DOUBLE INSULATION between transformer windings, assume the short circuit takes place at the point where the highest WORKING VOLTAGE is produced in the other insulation.</p> <p>When the WORKING VOLTAGE is determined by measurement, the input power supplied to the DUT should be at the RATED voltage or the voltage within the RATED voltage range which results in the highest measured value.</p> <p>Assume that the WORKING VOLTAGE between any point in the primary circuit and earth, and between any point in the primary circuit and a SECONDARY CIRCUIT, is the greater of the following:</p> <ul style="list-style-type: none"> - the RATED voltage or the upper voltage of the RATED voltage range; and - the measured voltage. <p>If starting pulses are used to ignite discharge lamps, the PEAK WORKING VOLTAGE is the peak value of the pulses with the lamp connected but before the lamp ignites. The r.m.s. WORKING VOLTAGE to determine minimum CREEPAGE DISTANCES is the voltage measured after the ignition of the lamp.</p> <p>Use the measured r.m.s. value for all waveforms.</p> <p>Do not consider non-repetitive transients (due, for example, to atmospheric disturbances).</p> <p>NOTE The resultant r.m.s. value of a waveform having an a.c. r.m.s. voltage "A" and a d.c. offset voltage "B" is given by the following formula:</p> $\text{r.m.s. value} = (A_2 + B_2)^{1/2}$		


13.4.13 WORKING VOLTAGE measurement (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 8.5.4, 8.10.4.1	13.4.13 WORKING VOLTAGE measurement	
<p>Because the minimum AIR CLEARANCES and electric strength test voltages depend on PEAK WORKING VOLTAGES, when determining these voltages, use the measured peak value for all waveforms including the peak value of any ripple (up to 10 %) on a d.c. voltage.</p> <p>Determine the WORKING VOLTAGE for each MEANS OF PROTECTION as follows.</p> <ul style="list-style-type: none"> – For d.c. voltages with superimposed ripple, the WORKING VOLTAGE is the average value (if the peak-to-peak ripple does not exceed 10 % of the average value) or the peak voltage (if the peak-to-peak ripple exceeds 10 % of the average value.) – The WORKING VOLTAGE for each MEANS OF PROTECTION forming DOUBLE INSULATION is the voltage to which the DOUBLE INSULATION as a whole is subjected. – For WORKING VOLTAGE involving a PATIENT CONNECTION not connected to earth, the situation in which the PATIENT is earthed (intentionally or accidentally) is regarded as a NORMAL CONDITION. – The WORKING VOLTAGE between the PATIENT CONNECTION(S) of an F-TYPE APPLIED PART and the ENCLOSURE is the highest voltage appearing across the insulation in NORMAL USE including earthing of any part of the APPLIED PART. – For DEFIBRILLATION-PROOF APPLIED PARTS, determine the WORKING VOLTAGE without regard to the possible presence of defibrillation voltages. – In the case of motors provided with capacitors where a resonance voltage may occur between the point where a winding and a capacitor are connected together on the one hand and any terminal for external conductors on the other hand, the WORKING VOLTAGE is equal to the resonance voltage. 			
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate the DUT at RATED voltage or at the upper limit of the RATED voltage range. 2) Connect a voltmeter and/or oscilloscope at the indicated location and measure and record the maximum voltage in the circuit. 			
<p>f) Presentation of the test results:</p> <p>The DUT is connected to _____ V a.c., _____ Hz or d.c. and operated normally. WORKING VOLTAGES between the following points are recorded.</p>			
<p>TABLE: WORKING VOLTAGE</p>			
<p>Measuring points</p>		<p>Measured voltage</p>	
<p>From</p>	<p>To</p>	<p>V, r.m.s.</p>	<p>V, peak</p>

13.4.14 Sound pressure level measurements

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 9.6.2.1	13.4.14 Sound pressure level measurement																														
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Semi-reverberant test room 2) Sound level meter conforming to IEC 61672-1 and IEC 61672-2, A-weighted, 60 dB – 150 dB range 																																
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>																																
<p>c) Test sample preparation:</p> <p>One representative test sample.</p>																																
<p>d) Test conditions:</p> <p>Ensure that any protective means described in ACCOMPANYING DOCUMENTS is in place during sound measurements.</p> <p>Operate the DUT under worst-case NORMAL CONDITION.</p>																																
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate the DUT at RATED voltage or at the upper limit of the RATED voltage range. 2) Position the DUT in the semi-reverberant test room, with a hard reflecting floor, at a position at least 3 m from any wall or any other object within the room. With all covers in place and in the closed position, operate the DUT under the maximum normal load conditions. When sound measurements in a test room are not feasible, measurements may be done in situ (e.g. for a large permanently installed ME EQUIPMENT). 3) During these operating modes, record the sound pressure measurements, above background, at both the OPERATOR'S normal position, relative to the DUT, and at a minimum distance of the PATIENT from any position of the DUT. 																																
<p>f) Presentation of the test results:</p> <p>Referenced background sound pressure measurement = _____ dBA</p>																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3" style="text-align: center; background-color: #e0e0e0;">TABLE: Maximum sound pressure</th> </tr> <tr> <th style="width: 33%; text-align: center;">Operating mode</th> <th style="width: 33%; text-align: center;">Maximum sound measured from OPERATOR'S normal position dBA</th> <th style="width: 33%; text-align: center;">Maximum sound measured 1 m from any position of DUT dBA</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>			TABLE: Maximum sound pressure			Operating mode	Maximum sound measured from OPERATOR'S normal position dBA	Maximum sound measured 1 m from any position of DUT dBA																								
TABLE: Maximum sound pressure																																
Operating mode	Maximum sound measured from OPERATOR'S normal position dBA	Maximum sound measured 1 m from any position of DUT dBA																														

13.4.15 Hydrostatic pressure

Standard(s): IEC 60601-1:2005	Subclause: 9.7.5	13.4.15 Hydrostatic pressure								
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Hydraulic pressure pump. 2) Calibrated hydraulic gauge (Pa) 3) Necessary hydraulic fluid <p>If unmarked pressure vessels and pipes cannot be hydraulically tested, substitute pneumatic pressure equipment and pneumatic media.</p>										
<p>b) Safety precautions during the test:</p> <p>Use normal laboratory safety PROCEDURES during this test. This test places parts under pneumatic pressure. Ensure that proper guards are in place to protect the OPERATOR from any possible burst.</p>										
<p>c) Test sample preparation:</p> <p>Adapt the pressure pump and gauge to the vessel to be tested.</p>										
<p>d) Test conditions:</p> <p>Perform this test if the vessel is subjected to a hydraulic pressure multiplied by volume greater than 200 kPa · l and to a pneumatic pressure greater than 50 kPa.</p>										
<p>e) Test set-up and PROCEDURE:</p> <p>Gradually raise the vessel's HYDRAULIC TEST PRESSURE to the MAXIMUM PERMISSIBLE WORKING PRESSURE multiplied by a factor obtained from the Figure 26, and maintain that pressure for 1 min.</p> <p>If unmarked pressure vessels or parts cannot be hydraulically tested, verify integrity by other suitable tests, e.g. pneumatic using suitable media at the same test pressure as for the hydraulic test.</p> <p>Leaks at gaskets are considered to be a failure if they occur at a pressure less than 40 % of the required test pressure or less than the MAXIMUM PERMISSIBLE WORKING PRESSURE, whichever is greater.</p> <p>Leakage is not allowed for pressure vessels intended for toxic, flammable or other dangerous substances.</p>										
 <table border="1"> <caption>Data points for Figure 26</caption> <thead> <tr> <th>Maximum Permissible Working Pressure (MPa)</th> <th>Multiplication Factor</th> </tr> </thead> <tbody> <tr> <td>0 to 1</td> <td>3.0</td> </tr> <tr> <td>1</td> <td>3.0</td> </tr> <tr> <td>30</td> <td>1.3</td> </tr> </tbody> </table>			Maximum Permissible Working Pressure (MPa)	Multiplication Factor	0 to 1	3.0	1	3.0	30	1.3
Maximum Permissible Working Pressure (MPa)	Multiplication Factor									
0 to 1	3.0									
1	3.0									
30	1.3									
<p align="center">Figure 26 – Ratio between hydraulic test pressure and maximum permissible working pressure</p> <p align="center">(IEC 60601-1:2005, Figure 32)</p>										

13.4.15 Hydrostatic pressure (continued)

Standard(s): IEC 60601-1:2005		Subclause: 9.7.5		13.4.15 Hydrostatic pressure			
f) Presentation of the test results:							
TABLE: Hydrostatic pressure							
Description of vessel or part tested	Hydraulic or pneumatic test H/P	MAXIMUM PERMISSIBLE WORKING PRESSURE	Volume of vessel or part	Multiplication factor	Calculated test pressure	40 % of calculate d test pressure	Remark
<p>The DUT did not burst/burst.</p> <p>There was/was no permanent deformation of the polymeric parts of the system.</p> <p>The DUT did not leak/leaked.</p>							

13.4.16 X-radiation (ionizing radiation) measurement

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 10.1	13.4.16 X- radiation (ionizing radiation) measurement																													
<p>a) Equipment needed for the test:</p> <p>1) Integrated radiation meter suitable for the energy of the emitted radiation or a radiation monitor of the ionizing chamber type with an effective area of 10 cm².</p>																															
<p>b) Safety precautions during the test:</p> <p>Special safety PROCEDURES for working in an X-ray environment.</p>																															
<p>c) Test sample preparation:</p> <p>One representative test sample.</p> <p>This test applies to ME EQUIPMENT not intended to produce X-radiation for diagnostic or therapeutic purposes that uses vacuum tubes excited by voltages exceeding 5 kV.</p>																															
<p>d) Test conditions:</p> <p>Ensure that any protective means described in the ACCOMPANYING DOCUMENTS are in place during X-radiation measurement.</p> <p>Operate the DUT under worst-case NORMAL CONDITION</p> <p>The ENCLOSURE is complete except for OPERATOR removable parts that were not interlocked.</p> <p>Adjust all OPERATOR and servicing controls for maximum X-radiation without impairing performance.</p>																															
<p>e) Test set-up and PROCEDURE:</p> <p>1) Operate the DUT at the most unfavourable RATED MAINS VOLTAGE.</p> <p>2) Using a radiation meter (the detector having an entry window with an area of approximately 10 cm²), make the X-radiation measurements (1 h averaged over any area of 10 cm² of which no linear dimension exceeds 5 cm) at a distance of 5 cm from any surface to which OPERATORS other than SERVICE PERSONNEL:</p> <ul style="list-style-type: none"> – can gain access without the use of a TOOL; or – are deliberately provided with the means of access; or – are instructed to enter regardless of whether or not a TOOL is needed to gain access. 																															
<p>f) Presentation of the test results:</p> <p>The maximum X-radiation was/was not less than 5 µGy/h adjusted for the level of background radiation.</p> <p>The actual maximum X-radiation was _____ µGy/h.</p>																															
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4" style="text-align: center;">TABLE: X-radiation</th> </tr> <tr> <th style="width: 25%;">Part under test</th> <th style="width: 25%;">Test condition</th> <th style="width: 15%;">Measured radiation µGy/h</th> <th style="width: 35%;">Remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				TABLE: X-radiation				Part under test	Test condition	Measured radiation µGy/h	Remarks																				
TABLE: X-radiation																															
Part under test	Test condition	Measured radiation µGy/h	Remarks																												

13.4.17 Normal heating

Standard(s): IEC 60601-1:2005	Subclause(s): 11.1	13.4.17 Normal heating
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature recorder 2) No. 30 AWG welded thermocouples compatible with the temperature recorder 3) Voltmeter 4) A dull black test corner with linear dimensions at least 115 % of the linear dimensions of the DUT 5) Adjustable regulated a.c. supply or other similar voltage and frequency source depending on the input RATING of equipment 6) Load resistors and/or optional ACCESSORIES 7) Ohmmeter 8) Material for fixing thermocouples (i.e. Loctite®⁵ 416, 417; tape) 9) Watch or any means to measure time 10) Any means to verify frequency 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p> <p>When connecting thermocouples and conducting the test, be careful when placing parts due to hazardous voltages. Also, consider the effects of voltage and frequency on the measurement device in regards to thermocouple placement.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample of the DUT and all optional ACCESSORIES and PATIENT APPLIED PARTS applied in such a way to enable maximum loading possible in NORMAL USE but with consideration of the specifications in the ACCOMPANYING DOCUMENTS.</p>		
<p>d) Test conditions:</p> <p>The black test corner consists of a draft-free corner with 20 mm plywood on the joining walls (at right angle), painted flat-black. A grid of holes, 7 mm in diameter, spaced 100 mm apart, covers the entire surface of the plywood making it resemble pegboard. Attach blackened copper or brass discs with thermocouples to the holes. Place these discs in enough holes to cover the surface area relative to the product being tested. The linear dimensions of the test corner must be at least 115 % of the linear dimensions of the DUT. Attach thermocouples to wall surfaces in hottest area of DUT ENCLOSURE. If it is necessary to use copper or brass disks, then attach the thermocouple to a 15 mm ± 5 mm dia, 1 mm ± 0,5 mm thick disk at hottest location.</p> <p>When thermocouples are used to determine the temperature of windings, reduce the temperature limits by 10 °C. In this case, the measurement is made by devices so chosen and positioned that they have a negligible effect on the temperature of the part under test.</p> <p>Determine the temperature of electrical insulation, other than that of windings, on the surface of the insulation at places where failure could cause:</p> <ul style="list-style-type: none"> – a short circuit, – bridging of a MEANS OF PROTECTION, – bridging of insulation, or – reduction of CREEPAGE DISTANCES or AIR CLEARANCES below the values specified for the insulation type. 		

⁵ Loctite® is the trade name of a product supplied by Henkel Corporation. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the product named. Equivalent products may be used if they can be shown to lead to the same results."

13.4.17 Normal heating (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 11.1	13.4.17 Normal heating
<p>Examples of places where temperatures might be measured include the point of separation of cores of a multicore cord and where insulated wires enter lamp holders.</p> <p>Suspend a HAND-HELD DUT in its normal position in still air.</p> <p>A DUT intended for installation in a cabinet or wall is built in as required by technical description, using dull black painted plywood walls, 10 mm thick when representing cabinet walls if the technical description so specifies and 20 mm thick when representing building walls.</p> <p>Operate a DUT having heating elements as in NORMAL USE with all heating elements energized, unless prevented by switching interlocks, at a supply voltage equal to 110 % of the maximum RATED voltage.</p> <p>Operate a motor-operated DUT under normal load and normal DUTY CYCLE at the least favourable voltage between 90 % of the minimum RATED voltage and 110 % of the maximum RATED voltage.</p> <p>Test combined heating and motor operated and other ME EQUIPMENT at 110 % of the maximum RATED voltage and at 90 % of the minimum RATED voltage.</p> <p>When modules are tested separately, the testing configuration should simulate the worst-case conditions of NORMAL USE that might affect the test result.</p> <p>For an acceptable use of thermocouples, refer to Annex N.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate the DUT in standby/quiescent mode until THERMAL STABILITY is reached. Then operate the DUT in NORMAL USE consecutive cycles until THERMAL STABILITY is again achieved, or for 7 h, whichever is shorter. Base the loading on the MANUFACTURER'S recommendations according to the ACCOMPANYING DOCUMENTS. The on and off periods for each cycle are the RATED on and off periods according to the MANUFACTURER'S ACCOMPANYING DOCUMENTS. 2) The preferred temperature method for windings is the resistance method. The value of temperature rise of a copper winding is calculated from the formula: $\Delta T = R_2 - R_1 / R_1 \times (234,5 + T_1) - (T_2 - T_1)$ <p>Where:</p> <ul style="list-style-type: none"> ΔT is the temperature rise in °C; R_1 is the resistance at the beginning of the test in Ω; R_2 is the resistance at the end of the test in Ω; T_1 is the room temperature at the beginning of the test in °C; T_2 is the room temperature at the end of the test in °C. <p>At the beginning of the test, windings are at room temperature.</p> <p>Take the resistance measurement as soon as possible after switching off and then periodically thereafter so that a curve of resistance against time can be plotted to determine the value at the instant of switching off.</p> 3) Determine the maximum temperature by making the measurement, calculating the temperature rise and adding it to the maximum permissible ambient temperature. When thermal regulating devices make this method inappropriate, justify alternative methods for measurements in the RISK MANAGEMENT FILE. <p>In some situations, it is preferable to make the measurements at the maximum permissible ambient temperature such that no calculation is necessary.</p> <p>When the resistance method is impractical to be used, the thermocouples are recommended.</p>		

13.4.17 Normal heating (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 11.1	13.4.17 Normal heating					
f) Presentation of the test results:							
TABLE: Normal temperature							
Supply voltage:		Test condition:					
Ambient temperature: °C		Duration of test:					
Measuring location	Measured temperature °C	Remarks					
COR – indicates measurements taken using change-of-resistance method							
During the test THERMAL CUT-OUTS did not operate/operated . Sealing or potting compound did not flow out/flowed out .							
TABLE: Temperature by change of resistance (COR) method							
Winding designation	T ₁ °C	R ₁ Ω	T ₂ °C	R ₂ Ω	ΔT °C	T=T ₂ +ΔT °C	Remarks

13.4.18 Operation to a specified temperature

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 5.3	13.4.18 Operation to a specified temperature
a) Equipment needed for the test: 1) Temperature probe 2) Environmental chamber		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: For the INTENDED USE in NORMAL CONDITION.		
d) Test conditions: 1) IEC 60601-1:1988 – Temperature between +10 °C and +40 °C – Humidity between 30 % and 75 % – Atmospheric pressure between 700 hPa and 1 060 hPa – Temperature of water at inlet of water cooled equipment not exceeding 25 °C 2) IEC 60601-1:2005 – Environmental conditions as specified by the MANUFACTURER Further test conditions as specified in the relevant clauses.		
e) Test set-up and PROCEDURE: 1) IEC 60601-1:1988 Carry out all tests, of which the test results depend on the maximum allowable ambient temperature (Clause 42 – Excessive temperatures and Clause 52 – Abnormal operation and fault conditions) either at the maximum allowable temperature specified by the MANUFACTURER (at 40 °C if not specified), or compensate for the temperatures, measured at an ambient temperature within the specified range, by calculation to the highest ambient temperature. 2) IEC 60601-1:2005+AMD1:2012 Carry out all tests, of which the test results depend on the maximum allowable ambient temperature, either at the maximum allowable temperature specified by the MANUFACTURER, or compensate for the temperatures, measured at an ambient temperature within the specified range, by calculation to the highest ambient temperature.		
f) Presentation of the test results: Document the ambient temperature, at which the tests were carried out for all relevant test clauses. As far as applicable, measured values are compensated either to the highest ambient temperature stated by the MANUFACTURER or to 40 °C.		

13.4.19 Identification of source of ignition

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 11.2.2.1</p>	<p>13.4.19 Identification of source of ignition</p>
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Spark ignition test apparatus in Figure 27 2) Oxygen source 3) Voltmeter 4) Ammeter 5) Voltage source/current source <div data-bbox="236 645 1340 1220" style="text-align: center;"> </div> <p style="text-align: center;">Figure 27 – Spark ignition test apparatus (IEC 60601-1:2005, Figure 34)</p>		
<p>b) Safety precautions during the test:</p> <p>Special safety PROCEDURES for working in an OXYGEN RICH ENVIRONMENT.</p>		
<p>c) Test sample preparation:</p> <p>This test determines whether a source of ignition exists.</p>		

13.4.19 Identification of source of ignition (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 11.2.2.1</p>	<p>13.4.19 Identification of source of ignition</p>
<p>d) Test conditions:</p> <p>For this test, use material sample for which a source of ignition exists.</p> <p>Consider the most unfavorable test conditions (oxygen concentration, electrical parameters, etc.) for the ME EQUIPMENT.</p> <p>SINGLE FAULT CONDITIONS related to OXYGEN RICH ENVIRONMENTS in conjunction with ME EQUIPMENT include the following:</p> <ul style="list-style-type: none"> – Failure of a ventilation system. – Failure of a barrier. – Failure of a component that creates a source of ignition. – Failure of insulation (whether solid material or spacing) providing the equivalent of at least one MEANS OF PATIENT PROTECTION but less than two MEANS OF PATIENT PROTECTION that could create a source of ignition. – Failure of a pneumatic component that results in leakage of oxygen-enriched gas. 		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Place two contact pins made of the material to be considered in opposition (see Figure 27). One pin has a diameter of 1 mm, the other a diameter of 3 mm. 2) Connect the electrical source to the pins as shown in Figure 28 to Figure 29. 3) Place a piece of cotton close to the contact surfaces of the two pins. Constantly flush the contacts with oxygen at a speed of less than 0,5 m/s via a tube. Move the cathode to the anode to close the contacts and pull it back to open them again. 4) Perform at least 300 trials before deciding that the sparks do not trigger ignition. If the sparks get smaller because of bad surfaces of the electrodes, clean the electrodes with a file. Replace the cotton if it gets black because of oxidization. 5) In Figure 29 and Figure 30, choose the resistance used to control current flowing into the inductor and the time constant for charging the capacitor so that it has minimal impact on the energy of the spark. Verify this by visual inspection without the capacitor in place or with the inductor shorted. 6) Check by inspection of the design and measurement or calculation of power, energy and temperature values in NORMAL CONDITION and SINGLE FAULT CONDITION if the electrical components in a compartment with an OXYGEN RICH ENVIRONMENT have power supplies with limited energy levels. 7) Measure the oxygen concentration long enough to ensure that the highest possible concentration of oxygen occurs. Select the least favourable control settings. Select the leaking conditions of oxygen to provide the minimum leak that the OPERATOR might detect (e.g. because of a failure of the function of the device). An oxygen concentration greater than 25 % in the presence of parts or components that could be a source of ignition, including at the moment energy is applied, constitutes a failure. 8) Check by inspection of the documentation provided by the MANUFACTURER including the RISK MANAGEMENT FILE if a compartment that contains parts or components that can be a source of ignition under a SINGLE FAULT CONDITION is separated from another compartment that contains an OXYGEN RICH ENVIRONMENT by sealing all joints and any holes for cables, shafts or for other purpose. 9) Only check if ignition occurs under SINGLE FAULT CONDITIONS within the ENCLOSURE, the fire self-extinguishes rapidly and no hazardous amount of toxic gases would reach the PATIENT. 		

13.4.19 Identification of source of ignition *(continued)*

Standard(s): IEC 60601-1:2005	Subclause(s): 11.2.2.1	13.4.19 Identification of source of ignition
---	----------------------------------	---




Figure 28 – Maximum allowable current I as a function of the maximum allowable voltage U measured in a purely resistive circuit in an OXYGEN RICH ENVIRONMENT

(IEC 60601-1:2005, Figure 35)




Figure 29 – Maximum allowable voltage U as a function of the capacitance C measured in a capacitive circuit used in an OXYGEN RICH ENVIRONMENT

(IEC 60601-1:2005, Figure 36)

13.4.19 Identification of source of ignition (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 11.2.2.1</p>	<p>13.4.19 Identification of source of ignition</p>
--	-----------------------------------	---




Figure 30 – Maximum allowable current I as a function of the inductance L measured in an inductive circuit in an OXYGEN RICH ENVIRONMENT

(IEC 60601-1:2005, Figure 37)

f) Presentation of the test results:

Identify the conditions under which the test was performed.

The situation with the highest voltage or current respectively and no ignition defines the upper limit. A safe upper limit is given by dividing the upper limit of voltage or current respectively by the safety margin factor of three.

NOTE The safety margin factor covers the uncertainty of sparking experiments and the variability of the underlying parameters like pressure or quality of cotton or of the contact materials.

13.4.20 Interruption of power supply

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 11.8	13.4.20 Interruption of power supply
a) Equipment needed for the test: 1) Test sample with relevant power supplies. 2) Equipment to verify ESSENTIAL PERFORMANCE		
b) Safety precautions during the test: Use normal laboratory safety PROCEDURES during this test.		
c) Test sample preparation: No special preparation.		
d) Test conditions: NORMAL CONDITION		
e) Test set-up and PROCEDURE: Interrupt and restore the power supply of the DUT, taking into account the different ME EQUIPMENT'S states. When interrupting and restoring the power supply, consider different operating modes and interruption durations including requirements from particular standards.		
f) Presentation of the test results: Interruption of the power supply did/did not result in the loss of BASIC SAFETY or ESSENTIAL PERFORMANCE.		

13.4.21 Limited power circuit

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause: 13.1.2	13.4.21 Limited power circuit	
a) Equipment needed for the test:			
<ul style="list-style-type: none"> 1) Adjustable load 2) Watt-meter 3) Watch (1 min) 			
b) Safety precautions during the test:			
Use normal laboratory safety PROCEDURES during this test.			
c) Test sample preparation:			
Make the relevant supply circuit available (see Annex D).			
d) Test conditions:			
NORMAL CONDITION			
e) Test set-up and PROCEDURE:			
Adapt the adjustable load to the supply circuit and set on 15 W. Adjust the test load as needed to continually draw 15 W.			
If the power dissipation is less than 15 W after 1 min, the circuit is limiting power dissipation to less than 15 W.			
f) Presentation of the test results:			
TABLE: Power dissipation			
Supply circuit to be examined	Power dissipation at the start of the test W	Power dissipation after 1 min W	Limited power circuit Yes/No

13.4.22 Failures of THERMOSTATS

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.4	13.4.22 Failure of THERMOSTATS
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature sensors (thermocouples) and recorder 2) Test corner 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES.</p>		
<p>d) Test conditions:</p> <p>Do not perform this test If an independent non-SELF-RESETTING THERMAL CUT-OUT is provided that prevents an unacceptable RISK in case of a failure in the THERMOSTAT.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Inspect the circuit diagram to determine whether short-circuiting or interrupting the THERMOSTAT is the less favourable test condition. Use that mechanism to short-circuit or interrupt the THERMOSTAT. 2) Place the DUT in the test corner. 3) Operate the DUT and record temperatures with the thermocouple method. 4) Operate the DUT at 90 % and 110 % of RATED voltage. 5) Test each THERMOSTAT by itself if multiple THERMOSTATS exist. 		
<p>f) Presentation of the test results:</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p> <p>Same result table as for normal heating in test 13.4.17 f) and same compliance criteria as in test 13.2.24 f).</p>		

13.4.23 Impairment of cooling

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 13.2.7	13.4.23 Impairment of cooling
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature sensors (thermocouples) and recorder 2) Accessories for blocking vent holes/grills, etc. 3) Test corner 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES.</p>		
<p>d) Test conditions:</p> <p>As for normal heating (test 13.4.17).</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Place the DUT in the test corner. 2) Impairment of cooling simulates one fault after the other, for example: <ul style="list-style-type: none"> – Lock or disconnect single ventilation fans, whichever is least favourable, consecutively. – Impair ventilation through openings in top and sides by covering those ENCLOSURE openings or positioning the DUT against walls of test corner. – Block filters. – Interrupt the flow of a cooling agent. 3) Operate the DUT with simulation of impairments of cooling. 4) Record temperatures using the thermocouple method. 		
<p>f) Presentation of the test results:</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p> <p>Same result table as for normal heating in test 13.4.17 f) and same compliance criteria as in test 13.2.24 f).</p>		

13.4.24 Locking of moving parts

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.8	13.4.24 Locking of moving parts
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature sensors (thermocouples) and recorder 2) Ohmmeter 3) Test corner 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES.</p>		
<p>d) Test conditions:</p> <p>Lock moving parts if:</p> <ul style="list-style-type: none"> – accessible moving parts can be jammed; or – the DUT can be operated while unattended (this includes ME EQUIPMENT which is automatically or remotely controlled); or – the DUT has one or more motors with a locked rotor torque smaller than the full load torque. <p>Only lock one moving part for DUT with more than one moving part as described above. If a SINGLE FAULT CONDITION can lock multiple motors, then lock all motors simultaneously.</p> <p>Do not test components, construction or the supply circuit if the power dissipation in SINGLE FAULT CONDITION is less than or equal to 15 W.</p> <p>Power the DUT with the least favourable voltage between 90 % and 110 % of the RATED voltage.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Place the DUT in the test corner. 2) Operate the DUT with all moving parts locked. 3) Operate a motor-operated DUT starting from a COLD CONDITION, at RATED voltage or at the upper limit of the RATED voltage range for the following periods of time: <ol style="list-style-type: none"> a) 30 s for: <ul style="list-style-type: none"> – HAND-HELD ME EQUIPMENT; – ME EQUIPMENT which has to be kept switched on by hand; or – ME EQUIPMENT which has to be kept under physical load by hand; b) for 5 min for other ME EQUIPMENT intended only for attended use (attended use excludes automated or remotely controlled ME EQUIPMENT that could operate when the OPERATOR is not present); c) for the maximum period of a timer, if such a device terminates the operation, for ME EQUIPMENT not listed under a) or b); d) for as long as necessary, to establish steady thermal conditions for all the remaining ME EQUIPMENT. 		

13.4.24 Locking of moving parts (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 13.2.8</p>	<p>13.4.24 Locking of moving parts</p>
<p>4) Determine the temperatures of windings with the ΔR measurement method (with an ohmmeter) at the end of a specified test period (for steady-state), or at the instant of operation of fuses, THERMAL CUT-OUTS, motor protective devices and the like.</p> <p>5) Record other temperatures using the thermocouple method.</p> <p>6) For motors located in circuits with a voltage not exceeding 42,4 V peak a.c. or 60 V d.c. and where difficulty is experienced in obtaining accurate temperature measurements due to the small size or design of the motor, cover the motor with a single layer of bleached cotton cheesecloth of approximately 40 g/m² (bleached cotton material, 26 m² to 28 m² per kg mass and 13 threads per cm in one direction and 11 threads per cm in the other).</p>		
<p>f) Presentation of the test results:</p> <p>There was/was no evidence of emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities.</p> <p>There was/was no evidence of deformation of ENCLOSURES to such an extent that compliance with IEC 60601-1:2005 is impaired.</p> <p>After the tests, there was/was no evidence that the setting of THERMAL CUT-OUTS and OVER-CURRENT RELEASES has not changed (by heating, vibration or other causes) sufficiently to affect their safety function.</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p> <p>There was/was no evidence of ignition of the cheesecloth.</p> <p>Temperatures of APPLIED PARTS did/did not exceed the allowed values from Table 11.</p> <p>Temperatures of parts likely to be touched did/did not exceed the allowable values from Table 12.</p> <p>Temperatures $T \times 1,5 - 12,5$ °C of other components and materials and other cases did/did not exceed the allowable values from Table 13.</p> <p>Temperatures of windings did/did not exceed the allowed values from the appropriate Table 14, Table 15 and Table 16.</p> <p>Limits for LEAKAGE CURRENT in SINGLE FAULT CONDITION were/were not exceeded.</p> <p>Limits for voltage from ACCESSIBLE PARTS including APPLIED PARTS were/were not exceeded.</p> <p>Use the same result table as for normal heating [test 13.4.17 f)].</p>		

13.4.24 Locking of moving parts (continued)

Standard(s): IEC 60601-1:2005		Subclause(s): 13.2.8		13.4.24 Locking of moving parts	
Table 11 – Allowable maximum temperatures for skin contact with ME EQUIPMENT APPLIED PARTS (IEC 60601-1:2005, Table 24)					
APPLIED PARTS of ME EQUIPMENT		Maximum temperature ^{a b} °C			
		Metal and liquids	Glass, porcelain, vitreous material	Moulded material, plastic, rubber, wood	
APPLIED PART having contact with the PATIENT for a time “t”	$t < 1 \text{ min}$	51	56	60	
	$1 \text{ min} \leq t < 10 \text{ min}$	48	48	48	
	$10 \text{ min} \leq t$	43	43	43	
<p>^a These temperature limit values are applicable for the healthy skin of adults. They are not applicable when large areas of the skin (10 % of total body surface or more) can be in contact with a hot surface. They are not applicable in the case of skin contact with over 10 % of the head surface. Where this is the case, appropriate limits shall be determined and documented in the RISK MANAGEMENT FILE.</p> <p>^b Where it is necessary for APPLIED PARTS to exceed the temperature limits of Table 24 in order to provide clinical benefit, the RISK MANAGEMENT FILE shall contain documentation showing that the resulting benefit exceeds any associated increase in RISK.</p>					
Table 12 – Allowable maximum temperatures for ME EQUIPMENT parts that are likely to be touched (IEC 60601-1:2005, Table 23)					
ME EQUIPMENT and its parts		Maximum temperature ^a °C			
		Metal and liquids	Glass, porcelain, vitreous material	Moulded material, plastic, rubber, wood	
External surfaces of ME EQUIPMENT that are likely to be touched for a time “t”	$t < 1 \text{ s}$	74	80	86	
	$1 \text{ s} \leq t < 10 \text{ s}$	56	66	71	
	$10 \text{ s} \leq t < 1 \text{ min}$ in	51	56	60	
	$1 \text{ min} \leq t$	48	48	48	
<p>^a These temperature limit values are applicable for touching the healthy skin of adults. They are not applicable when large areas of the skin (10 % of total body surface or more) can be in contact with a hot surface. This also applies in the case of skin contact with over 10 % of the head surface. Where this is the case, appropriate limits shall be determined and documented in the RISK MANAGEMENT FILE.</p>					

13.4.24 Locking of moving parts (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.8	13.4.24 Locking of moving parts
---	--------------------------------	--

Table 13 – Allowable maximum temperatures of parts
(IEC 60601-1:2005, Table 22)

Parts	Maximum Temperature °C
Insulation, including winding insulation ^a	
– of Class A Material	105
– of Class E Material	120
– of Class B Material	130
– of Class F Material	155
– of Class H Material	180
Parts with T marking	T ^b
Other components and materials	^c
Parts in contact with flammable liquid with flash-point of T °C	T-25
Wood	90

^a The classification of insulating materials is in accordance with IEC 60085. Any incompatibility of the materials of an insulating system that could reduce the maximum temperature limit of the system below the limits of the individual materials shall be considered.

^b T marking refers to the marked maximum operating temperature.

^c For each material and component, account shall be taken of the temperature ratings for each material or component to determine the appropriate maximum temperature. Each component shall be used in accordance with its temperature rating. Where doubt exists, the ball pressure test of 8.8.4.2 should be performed.

Table 14 – Temperature limits of motor windings

(IEC 60601-1:2005, Table 26)

Temperature in °C

Type of ME EQUIPMENT	Insulation class				
	Class A	Class B	Class E	Class F	Class H
ME EQUIPMENT provided with a timer and not intended for unattended use and ME EQUIPMENT to be operated for 30 s or 5 min	200	225	215	240	260
Other ME EQUIPMENT					
– if impedance-protected, maximum value	150	175	165	190	210
– if protected by protection devices that operate during the first hour, maximum value	200	225	215	240	260
– after the first hour, maximum value	175	200	190	215	235
– after the first hour, arithmetic average	150	175	165	190	210

NOTE The temperature limits in this table were derived from IEC 61010-1:2001.

13.4.24 Locking of moving parts (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.8	13.4.24 Locking of moving parts
---	--------------------------------	--

Table 15 – Maximum motor winding steady-state temperature

(IEC 60601-1:2005, Table 27)

Insulation class	Maximum temperature °C
A	140
B	165
E	155
F	180
H	200

Table 16 – Maximum allowable temperatures of transformer windings under overload and short-circuit conditions at 25 °C (± 5 °C) ambient temperature

(IEC 60601-1:2005, Table 31)

Parts	Maximum temperature °C
Windings and core laminations in contact therewith, if the winding insulation is:	
– of Class A material	150
– of Class B material	175
– of Class E material	165
– of Class F material	190
– of Class H material	210

13.4.25 Interruption or short circuit of motor capacitors

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 13.2.9</p>	<p>13.4.25 Interruption or short circuit of motor capacitors</p>
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature sensors (thermocouples) and recorder 2) Ohmmeter 3) Voltmeter 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES.</p>		
<p>d) Test conditions:</p> <p>Do not perform the test with a short-circuited capacitor if the motor is provided with a capacitor complying with the requirements for Class P2 capacitors according to IEC 60252-1 and the ME EQUIPMENT is not intended for unattended use (including automatic or remote control).</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate motors with a capacitor in the circuit of an auxiliary winding are operated: <ul style="list-style-type: none"> – with the capacitor short-circuited, or – open-circuited in turn. 2) Operate a motor-operated DUT starting from COLD CONDITION, at RATED voltage or at the upper limit of the RATED voltage range for the following periods of time: <ol style="list-style-type: none"> a) 30 s for: <ul style="list-style-type: none"> – HAND-HELD ME EQUIPMENT; – ME EQUIPMENT which has to be kept switched on by hand; or – ME EQUIPMENT which has to be kept under physical load by hand. b) For 5 min for other ME EQUIPMENT intended only for attended use (attended use excludes automated or remotely controlled ME EQUIPMENT that could operate when the OPERATOR is not present). c) For the maximum period of a timer, if such a device terminates the operation, for ME EQUIPMENT not listed under a) or b). d) For as long as necessary, to establish steady thermal conditions for all the remaining ME EQUIPMENT. 3) Determine the temperatures of windings with the ΔR measurement method (with an ohmmeter) at the end of a specified test period (for steady-state), or at the instant of operation of fuses, THERMAL CUT-OUTS, motor protective devices and the like. 4) Record other temperatures using the thermocouple method. 5) For motors located in circuits with a voltage not exceeding 42,4 V peak a.c. or 60 V d.c. and where difficulty is experienced in obtaining accurate temperature measurements due to the small size or design of the motor, cover the motor with a single layer of bleached cotton cheesecloth of approximately 40 g/m² (bleached cotton material, 26 m² to 28 m² per kg mass and 13 threads per cm in one direction and 11 threads per cm in the other). 6) Measure the voltage across the capacitor. 		

13.4.25 Interruption or short circuit of motor capacitors (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.9	13.4.25 Interruption or short circuit of motor capacitors
<p>f) Presentation of the test results:</p> <p>There was/was no evidence of emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities.</p> <p>There was/was no evidence of deformation of ENCLOSURES to such an extent that compliance with IEC 60601-1:2005 is impaired.</p> <p>After the tests, there was/was no evidence that the setting of THERMAL CUT-OUTS and OVER-CURRENT RELEASES has not changed (by heating, vibration or other causes) sufficiently to affect their safety function.</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p> <p>There was/was no evidence of ignition of the cheesecloth.</p> <p>Temperatures of APPLIED PARTS did/did not exceed the allowed values from Table 11.</p> <p>Temperatures of parts likely to be touched did/did not exceed the allowable values from Table 12.</p> <p>Temperatures $T \times 1,5 - 12,5$ °C of other components and materials and other cases did/did not exceed the allowable values from Table 13.</p> <p>Temperatures of windings did/did not exceed the allowed values from the appropriate Table 14, Table 15 and Table 16.</p> <p>Limits for LEAKAGE CURRENT in SINGLE FAULT CONDITION were/were not exceeded.</p> <p>Limits for voltage from ACCESSIBLE PARTS including APPLIED PARTS were/were not exceeded.</p> <p>Use the same result table as for normal heating [test 13.4.17 f)].</p>		

13.4.26 Motor running overload

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 13.2.13.3 b), 13.2.13.4</p>	<p>13.4.26 Motor running overload</p>
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Temperature sensors (thermocouples) and recorder 2) Ohmmeter 3) Voltmeter 4) Ammeter 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES</p>		
<p>d) Test conditions:</p> <p>Check motors for running overload protection if they are:</p> <ul style="list-style-type: none"> - intended to be remotely controlled or automatically controlled (by a single control device without redundant protection), or - likely to be operated continuously whilst unattended. <p>For ME EQUIPMENT containing motors as well as heating parts, perform testing at the prescribed voltage, with the motor part and the heating part operated simultaneously so as to produce the least favourable condition.</p> <p>Operate ME EQUIPMENT with three-phase motors with normal load, connected to a three-phase (SUPPLY MAINS) with one phase disconnected.</p> <p>Test consecutively if more than one of the tests is applicable for the same DUT.</p> <p>Only perform the running overload test for motors located in circuits with a voltage not exceeding 42,4 V peak a.c. or 60 V d.c. if a possibility of an overload occurring is determined by inspection or by review of the design. The test need not be performed, for example, where electronic drive circuits maintain a substantially constant drive current.</p>		
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Operate the DUT under normal load conditions at RATED voltage or at the maximum of the RATED voltage range, until steady thermal conditions are achieved (see the test for normal heating [test 13.4.17]). 2) Increase the load so that the current is increased in appropriate steps while the supply voltage being maintained at its original value. 3) When steady thermal conditions are established, increase the load. Progressively increase the load in appropriate steps until the overload protection operates, or until no further temperature rise is noted. 4) If the load cannot be changed in appropriate steps in ME EQUIPMENT, remove the motor from the DUT in order to perform the test. 5) ME EQUIPMENT RATED for short-time or intermittent operation other than: <ul style="list-style-type: none"> - HAND-HELD ME EQUIPMENT; - ME EQUIPMENT which has to be kept switched on by hand; - ME EQUIPMENT which has to be kept under physical load by hand; or - ME EQUIPMENT with a timer and a back-up system <p>is operated under normal load and at RATED voltage or at the upper limit of the RATED voltage range until the peak temperature does not increase by more than 5 °C in 1 h, or until the protective device operates.</p> 		

13.4.26 Motor running overload (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.13.3 b), 13.2.13.4	13.4.26 Motor running overload
<p>6) If in NORMAL USE a load-reducing device in ME EQUIPMENT operates, continue the test with the DUT running idle.</p> <p>7) OPERATE ME EQUIPMENT starting from the COLD CONDITION, at RATED voltage or at the upper limit of the RATED voltage range for the following periods of time:</p> <p>a) 30 s for:</p> <ul style="list-style-type: none"> – HAND-HELD ME EQUIPMENT; – ME EQUIPMENT which has to be kept switched on by hand; or – ME EQUIPMENT which has to be kept under physical load by hand; <p>b) for 5 min for other ME EQUIPMENT intended only for attended use (attended use excludes automated or remotely controlled ME EQUIPMENT that could operate when the OPERATOR is not present);</p> <p>c) for the maximum period of a timer, if such a device terminates the operation, for ME EQUIPMENT not listed under a) or b);</p> <p>d) for as long as necessary, to establish steady thermal conditions for all the remaining ME EQUIPMENT.</p> <p>8) Determine motor winding temperatures when THERMAL STABILITY conditions are established or immediately before the operation of the protective device.</p> <p>9) Determine temperatures of windings with the ΔR measurement method (with an ohmmeter) at the end of a specified test period (for steady-state), or at the instant of operation of fuses, THERMAL CUT-OUTS, motor protective devices and the like.</p> <p>10) Record other temperatures using the thermocouple method.</p> <p>11) For motors located in circuits with a voltage not exceeding 42,4 V peak a.c. or 60 V d.c. and where difficulty is experienced in obtaining accurate temperature measurements due to the small size or design of the motor, cover the motor with a single layer of bleached cotton cheesecloth of approximately 40 g/m² (bleached cotton material, 26 m² to 28 m² per kg mass and 13 threads per cm in one direction and 11 threads per cm in the other).</p>		
<p>f) Presentation of the test results:</p> <p>There was/was no evidence of emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities.</p> <p>There was/was no evidence of deformation of ENCLOSURES to such an extent that compliance with this standard is impaired.</p> <p>After the tests, there was/was no evidence that the setting of THERMAL CUT-OUTS and OVER-CURRENT RELEASES has not changed (by heating, vibration or other causes) sufficiently to affect their safety function.</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p> <p>There was/was no evidence of ignition of the cheesecloth.</p> <p>Temperatures of APPLIED PARTS did/did not exceed the allowed values from Table 11.</p> <p>Temperatures of parts likely to be touched did/did not exceed the allowable values from Table 12.</p> <p>Temperatures $T \times 1,5 - 12,5$ °C of other components and materials and other cases did/did not exceed the allowable values from Table 13.</p> <p>Temperatures of windings did/did not exceed the allowed values from the appropriate Table 14, Table 15 and Table 16.</p> <p>Limits for LEAKAGE CURRENT in SINGLE FAULT CONDITION were/were not exceeded.</p>		

13.4.26 Motor running overload *(continued)*

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.13.3 b), 13.2.13.4	13.4.26 Motor running overload
<p>Limits for voltage from ACCESSIBLE PARTS including APPLIED PARTS were/were not exceeded.</p> <p>Upon cooling to room temperature, the applicable dielectric strength tests did/did not reveal breakdown.</p> <p>Use the same result table as for normal heating [test 13.4.17 f)].</p>		

13.4.27 Heating element overload

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.13.1, 13.2.13.2	13.4.27 Heating element overload
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Voltmeter 2) Ampere meter 3) Ohmmeter 4) Temperature sensor (thermocouples) 5) Dielectric strength tester 6) Ball-pressure test apparatus (Figure F.4) 7) Test corner 		
<p>b) Safety precautions during the test:</p> <p>Suitable fire extinguisher</p> <p>Use normal laboratory safety PROCEDURES during this test.</p>		
<p>c) Test sample preparation:</p> <p>One representative sample loaded with all optional ACCESSORIES.</p>		
<p>d) Test conditions:</p> <p>This test applies to ME EQUIPMENT having thermostatically controlled heating elements:</p> <ul style="list-style-type: none"> – which are intended for built-in operation, or – for unattended operation, or – which have a capacitor not protected by a fuse or the like connected in parallel with the contacts of the THERMOSTAT. <p>Heating parts of ME EQUIPMENT are tested under all of the following conditions:</p> <ul style="list-style-type: none"> – as specified in the normal heating subclause of IEC 60601-1:2005 (Subclause 11.1) but without adequate heat discharge; – with the ME EQUIPMENT operated in NORMAL CONDITION; and – disabling any control which serves to limit the temperature, except a THERMAL CUT-OUT. <p>If the ME EQUIPMENT has more than one control, disable each in turn.</p> <p>Do not test components, construction or the supply circuit if the power dissipation in SINGLE FAULT CONDITION is less than or equal to 15 W.</p> <p>Power the DUT with a supply voltage of 90 % or 110 % of the RATED supply voltage whichever is the least favourable.</p> <p>For ME EQUIPMENT with short-time rating, the test duration should equal the RATED operating time.</p> <p>If, in any of the tests, a non-SELF-RESETTING THERMAL CUT-OUT operates, a heating element or an intentionally weak part ruptures, or if the current is otherwise interrupted before THERMAL STABILITY is established without the possibility of automatic restoration, the heating period is ended. However, if the interruption is due to the rupture of a heating element or of an intentionally weak part, repeat the test on a second sample. Open circuiting of a heating element or of an intentionally weak part in the second sample does not in itself entail a failure to comply. However, if either sample fails to comply with the conditions specified in Subclause 13.1.2 of IEC 60601-1:2005, it constitutes a failure.</p>		

13.4.27 Heating element overload (continued)

<p>Standard(s): IEC 60601-1:2005</p>	<p>Subclause(s): 13.2.13.1, 13.2.13.2</p>	<p>13.4.27 Heating element overload</p>
<p>e) Test set-up and PROCEDURE:</p> <ol style="list-style-type: none"> 1) Place the DUT in the test corner. 2) DUT's having heating elements are tested as follows: <ul style="list-style-type: none"> - For thermostatically controlled DUT's having heating elements that are intended for built-in or for unattended operation or that has a capacitor not protected by a fuse or the like connected in parallel with the contacts of the THERMOSTAT; by both tests described below. - For DUT's having heating elements RATED for non-CONTINUOUS OPERATION; by both tests described below. - For other DUT's having heating elements; but only the first test below. <p>NOTE If more than one of the tests below is applicable to the same DUT, these tests are performed consecutively.</p> 3) Test 1: <p>Test the DUT under the conditions for test 13.4.7, but without adequate heat discharge, at a supply voltage of 90 % or 110 % of the RATED supply voltage, whichever is least favourable.</p> <p>If a non-SELF-RESETTING THERMAL CUT-OUT operates, or if the current is otherwise interrupted without the possibility of automatic restoration before THERMAL STABILITY is established, the operating period is ended. If interruption of the current does not occur, the DUT is switched off as soon as THERMAL STABILITY is established and is allowed to cool to approximately room temperature.</p> <p>For DUT's RATED for non-CONTINUOUS OPERATION, the test duration should equal the RATED operating time.</p> 4) Test 2: <p>Test heating parts of the DUT with the DUT operated in NORMAL CONDITION, at the supply voltage 110 % of the RATED supply voltage and as specified in test 13.4.7. Meet the following test conditions:</p> <ul style="list-style-type: none"> - Disable control that serves to limit the temperature in NORMAL CONDITION, except a THERMAL CUT-OUT. - If the DUT has more than one control, disabled each in turn. - Operate the DUT at the RATED DUTY CYCLE until THERMAL STABILITY is achieved, irrespective of the RATED operating time. 		
<p>f) Presentation of the test results:</p> <p>There was/was no evidence of emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities.</p> <p>There was/was no evidence of deformation of ENCLOSURES to such an extent that compliance with IEC 60601-1:2005 is impaired.</p> <p>After the tests, there was/was no evidence that the setting of THERMAL CUT-OUTS and OVER-CURRENT RELEASES changed (by heating, vibration or other causes) sufficiently to affect their safety function.</p> <p>After the test, the insulation between the MAINS PART and the ENCLOSURE, when cooled down to approximately room temperature, did/did not withstand the relevant dielectric strength tests.</p> <p>For ME EQUIPMENT which is immersed in, or filled with, conducting liquid in NORMAL USE, immerse the sample in or fill it with the conducting liquid or water, as appropriate, for 24 h before performing the dielectric strength test.</p> <p>For SUPPLEMENTARY and REINFORCED INSULATION of thermoplastic materials, perform the ball-pressure test (test 13.3.4) at a temperature 25 °C higher than that measured during these tests.</p>		

13.4.27 Heating element overload (continued)

Standard(s): IEC 60601-1:2005	Subclause(s): 13.2.13.1, 13.2.13.2	13.4.27 Heating element overload
<p>Temperatures of APPLIED PARTS did/did not exceed the allowed values from Table 11.</p> <p>Temperatures of parts likely to be touched did/did not exceed the allowable values from Table 12.</p> <p>Temperatures $T \times 1,5 - 12,5$ °C of other components and materials and other cases did/did not exceed the allowable values from Table 13.</p> <p>Temperatures of windings did/did not exceed the allowed values from the appropriate Table 14, Table 15 and Table 16.</p> <p>Limits for LEAKAGE CURRENT in SINGLE FAULT CONDITION were/were not exceeded.</p> <p>Limits for voltage from ACCESSIBLE PARTS including APPLIED PARTS were/were not exceeded.</p> <p>Use the same result table as for normal heating [test 13.4.17 f)].</p>		

13.4.28 Rechargeable battery overcharge/discharge

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.4.3	13.4.28 Rechargeable battery overcharge/discharge
<p>a) Equipment needed for the test:</p> <ul style="list-style-type: none"> 1) Multimeter 2) Various test loads 3) Shorting box 4) D.C. ammeter 		
<p>b) Safety precautions during the test:</p> <p>Special laboratory safety PROCEDURES for work with batteries (i.e. lithium, etc.).</p> <p>RISK of explosion. Remove battery before performing test 2.</p>		
<p>c) Test sample preparation:</p> <p>One representative test sample</p> <p>Make the relevant supply circuit available (see Annex D).</p>		
<p>d) Test conditions:</p> <p>Battery overcharge/discharge test: Operate the DUT at RATED voltage or at the upper limit of the RATED voltage range with maximum normal load.</p> <p>Excessive current and voltage protection test: Remove the battery from the DUT</p> <p>Reversed battery connection test: NORMAL CONDITION</p>		
<p>e) Test set-up and PROCEDURE:</p> <ul style="list-style-type: none"> 1) Battery overcharge/discharge: Inspect the design documentation for the charging circuit and battery charging specifications to verify overcharging will not occur in NORMAL CONDITION and SINGLE FAULT CONDITION. If any doubt exists, fault those specific components and verify no unacceptable RISK occurs. 2) Excessive current and voltage protection: Inspect the battery supply circuit for the presence of protective means and the design documentation and RISK MANAGEMENT FILE. Verify that necessary fuse(s) or over-current protective means are in place and that the cross-sectional area of conductors are adequate to prevent source of fire HAZARDS. If any doubt exists, short circuit or open circuit those components that would enable maximum discharge current to flow and verify no unacceptable RISK occurs. 3) Reversed battery connection: Where it is possible to insert the battery with incorrect polarity, reverse the battery connections and energize the DUT. 4) The short circuit test between the positive pole and the negative pole of an INTERNAL ELECTRICAL POWER SOURCE in the area between the INTERNAL ELECTRICAL POWER SOURCE output contacts and the subsequent protection device may be omitted if two MEANS OF OPERATOR PROTECTION are provided. Alternatively, a short-circuit test shall not result in any of the HAZARDOUS SITUATIONS in 13.1.2. 		

13.4.28 Rechargeable battery overcharge/discharge (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.4.3	13.4.28 Rechargeable battery overcharge/discharge
<p>f) Presentation of the test results:</p> <p>Primary lithium batteries did/did not comply with the requirements of IEC 60086-4.</p> <p>Secondary lithium batteries did/did not comply with the requirements of IEC 62133.</p> <p>1) Battery overcharge/discharge and 2) Excessive current and voltage protection:</p> <p>There was/was no cracking, rupturing or bursting of the battery jacket that could result in OPERATOR contact with battery electrolyte.</p> <p>There was/was no explosion of the battery that could result in a RISK to persons.</p> <p>There was/was no emission of flame or explosion of molten metal outside the DUT.</p> <p>There was/was no emission of gases that could cause an unacceptable RISK.</p> <p>3) Reversed battery connection:</p> <p>There was/was no emission of flames, toxic gases, molten metal, and RISK of explosion.</p> <p>4) Short circuit test if applicable did/did not lead to any of the HAZARDOUS SITUATIONS in 13.1.2.</p>		

13.4.29 Mains transformers

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.5, 13.2.3	13.4.29 Mains transformers
<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Voltmeter 2) Adjustable regulated a.c. supply or other similar voltage and frequency source depending on the input rating of transformer 3) Load resistors or electronic load 4) Ohmmeter 5) Dielectric strength tester 		
<p>b) Safety precautions during the test:</p> <ol style="list-style-type: none"> 1) Suitable fire extinguisher 2) Use normal laboratory safety PROCEDURES during this test. 3) See test 13.3.3 b) for recommended safety precautions during dielectric strength testing. 		
<p>c) Test sample preparation:</p> <p>Representative transformer sample(s) connected and loaded accordingly.</p>		
<p>d) Test conditions:</p> <p>Test each winding in turn, with the following parameters at the most adverse value:</p> <ul style="list-style-type: none"> – primary voltage maintained between 90 % to 110 % of RATED voltage; – RATED input frequency; – loads on other windings as in NORMAL USE. <p>For windings that use the change-of-resistance measurements (COR) method, place thermocouples at all other locations. Measure initial ambient temperature and a cold resistance of the windings.</p> <p>Calculate the value of the temperature rise of a copper winding using the formula:</p> $\Delta T = \frac{R_2 - R_1}{R_1} (234,5 + T_1) - (T_2 - T_1)$ <p>where</p> <ul style="list-style-type: none"> ΔT is the temperature rise in °C; R_1 is the resistance at the beginning of the test in Ω; R_2 is the resistance at the end of the test in Ω; T_1 is the room temperature at the beginning of the test in °C; T_2 is the room temperature at the end of the test in °C. <p>At the beginning of the test, windings are to be at room temperature.</p> <p>When the resistance method is used, determine the resistance of windings at the end of the test by taking measurements as soon as possible after switching off, and then at short intervals so that a curve of resistance against time can be plotted to identify the value at the instant of switching off.</p> <p>Test each secondary winding in turn; load all other secondary windings as in NORMAL USE.</p> <p>Allow the DUT to cool to room temperature between tests.</p> <p>When thermocouples are used, reduce the temperature limits by 10 °C. In this case, the measurement is made by devices so chosen and positioned that they have a negligible effect on the temperature of the part under test.</p> <p>Windings with more than one protective device may require multiple overload tests in order to fully evaluate worst-case NORMAL USE loading and fusing.</p>		

13.4.29 Mains transformers (continued)

Standard(s): IEC 60601-1:2005+A1:2012	Subclause(s): 15.5, 13.2.3	13.4.29 Mains transformers
<p>e) Test set-up and PROCEDURE:</p> <p>1) Normal heating:</p> <p>a) The mains transformer is placed either on a softwood surface or in the appliance in the same location as that of the test for normal heating [test 13.4.17 d)].</p> <p>b) Connect the DUT to the a.c. power supply.</p> <p>c) Energize the DUT and set up for the NORMAL CONDITIONS for maximum load.</p> <p>d) Set a.c. supply voltage to + 10 % and – 10 % of the RATED voltage(s) or the extremes of the RATED voltage range(s).</p> <p>e) Operate the DUT until all temperatures have stabilized.</p> <p>f) Measure and record all temperatures including the room ambient.</p> <p>g) Temperatures of windings are determined with COR (change of resistance – ΔR) measurement method (or with an ohmmeter).</p> <p>h) Record other temperatures using the thermocouple method.</p> <p>i) The maximum temperature of a part is determined by measuring the temperature rise of the part under test and adding it to the maximum allowed ambient temperature of NORMAL USE as defined by the MANUFACTURER.</p> <p>2) Short circuit:</p> <p>Apply a short circuit or resistive load, as appropriate, at the ends of the windings or at the first point that can be short circuited.</p> <p>Short-circuit the output winding under test. Continue the test until the protective device operates or THERMAL STABILITY is achieved. For transformers not tested according to test 4) below, apply the short circuit directly across the output windings.</p> <p>3) Overload:</p> <p>Multiple overload tests may be needed to fully evaluate the worst-case NORMAL USE loading and fusing for windings with more than one protective device.</p> <p>Connect the unit to a supply specified in the overload table in Section f). Resistively load and operate the secondary under the test.</p> <p>Do not perform the overload test unless the protective device operated during the short circuit test.</p> <p>a) This step is omitted if, based on a review of the provided protective devices and their performance data, the current at which the first protective device operates can be determined.</p> <p>Load the winding under test to its NORMAL USE load until THERMAL STABILITY is reached. Progressively adjust the load in appropriate steps to approach the minimum current at which the protective device operates. Allow the windings to reach THERMAL STABILITY following each load adjustment, and record each load current value.</p> <p>Following operation of a protective device, perform step b).</p> <p>b) Shunt the protective device that operated in step a) above if it is external to the transformer. Load the winding under test based on the type of protective device as follows.</p> <ul style="list-style-type: none"> – Fuse in accordance with IEC 60127-1: 30 min at the appropriate test current specified in Table 17. – Fuses not in accordance with IEC 60127-1: 30 min at the current according to the characteristics supplied by the fuse manufacturer, specifically the 30 min clearing-time current. If no 30 min clearing-time current data is available, use the test current specified in Table 17 until THERMAL STABILITY is achieved. – Other protective device: until THERMAL STABILITY at a current just below the current that caused the device to operate in step a) above. 		

13.4.29 Mains transformers (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.5, 13.2.3	13.4.29 Mains transformers										
Table 17 – Test current for transformers												
(IEC 60601-1:2005, Table 32)												
<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th data-bbox="472 465 871 555">Marked value of RATED current (I) of protecting fuse-link A</th> <th data-bbox="871 465 1209 555">Ratio between test current and RATED current of the fuse-link</th> </tr> </thead> <tbody> <tr> <td data-bbox="472 555 871 600" style="text-align: center;">$I \leq 4$</td> <td data-bbox="871 555 1209 600" style="text-align: center;">2,1</td> </tr> <tr> <td data-bbox="472 600 871 645" style="text-align: center;">$4 < I \leq 10$</td> <td data-bbox="871 600 1209 645" style="text-align: center;">1,9</td> </tr> <tr> <td data-bbox="472 645 871 689" style="text-align: center;">$10 < I \leq 25$</td> <td data-bbox="871 645 1209 689" style="text-align: center;">1,75</td> </tr> <tr> <td data-bbox="472 689 871 719" style="text-align: center;">$I > 25$</td> <td data-bbox="871 689 1209 719" style="text-align: center;">1,6</td> </tr> </tbody> </table>			Marked value of RATED current (I) of protecting fuse-link A	Ratio between test current and RATED current of the fuse-link	$I \leq 4$	2,1	$4 < I \leq 10$	1,9	$10 < I \leq 25$	1,75	$I > 25$	1,6
Marked value of RATED current (I) of protecting fuse-link A	Ratio between test current and RATED current of the fuse-link											
$I \leq 4$	2,1											
$4 < I \leq 10$	1,9											
$10 < I \leq 25$	1,75											
$I > 25$	1,6											
<p>End this portion of the overload test at the specified time or after a second protective device opens.</p>												
<ul style="list-style-type: none"> – Load windings provided with an overcurrent protection to a test current specified in the table and operate them for the indicated test duration. Replace the overcurrent protector with links of negligible impedance. – Load windings protected by a THERMAL CUT-OUT to a stable winding temperature of approximately 85 % of the THERMAL CUT-OUT temperature indicated in the table. Increase the test current by 5 %. When steady thermal conditions are again established, increase the load is again. Continue these steps until the thermal protector operates. Record the highest stable temperatures in the table. 												
<p>Components intended to prevent overheating of the transformer during short circuit and overload [2) and 3) above] are included as part of the tests provided that</p>												
<ul style="list-style-type: none"> – the component is one with high-integrity characteristics, and – two MEANS OF OPERATOR PROTECTION are provided between the output contacts of the transformer up to the COMPONENT WITH HIGH-INTEGRITY CHARACTERISTICS 												
<p>Perform the tests under the conditions specified in test 13.4.17 d).</p>												
<p>The overload test may be applied after rectification.</p>												
<p>4) Transformer dielectric voltage withstand:</p>												
<p>This subclause is not applicable to transformers operating at a frequency above 1 kHz, which are tested in accordance with 8.8.3.</p>												
<p>Conduct this test after the humidity preconditioning treatment.</p>												
<p>Apply a test voltage across the winding indicated in the transformer dielectric strength table in Section f). Leave all other windings open.</p>												
<p>Connect the transformer designated neutral conductor to the core.</p>												
<p>Repeat the test with the other side of the primary winding connected to the core.</p>												
<p>The electrical insulation between the primary winding and other windings, screens and the core of a MAINS SUPPLY TRANSFORMER is presumed to have been investigated by the dielectric strength tests performed on the assembled ME EQUIPMENT. In this case the dielectric strength tests need not be repeated.</p>												
<p>The dielectric strength of the electrical insulation between turns and layers of each winding of a MAINS SUPPLY TRANSFORMER of ME EQUIPMENT should be such that after the humidity preconditioning treatment it passes the following tests.</p>												
<p>a) Test transformers having any winding with a RATED voltage less than or equal 500 V or RATED frequency less than or equal 60 Hz with a voltage across the winding of five times the RATED voltage or five times the upper limit of the RATED voltage range of that winding and a frequency not less than five times the RATED frequency.</p>												
<p>b) Test transformers having any winding with a rated voltage greater than 500 V or rated frequency greater than 60 Hz with a voltage across that winding of twice the rated voltage or twice the upper limit of the rated voltage range of that winding and a frequency not less than twice the rated frequency.</p>												

13.4.29 Mains transformers (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.5, 13.2.3	13.4.29 Mains transformers
<p>In the two cases above, however, the stress on the turn and layer insulation of any winding of the transformer should be such that the test voltage appearing at the winding with the highest RATED voltage does not exceed the test voltage specified for one MEANS OF PROTECTION, if the RATED voltage of such a winding is considered as the WORKING VOLTAGE. If this should occur, the test voltage on the primary winding should be reduced accordingly. The test frequency may be adapted to produce in the core approximately the magnetic induction present in NORMAL USE.</p> <ul style="list-style-type: none"> – Test three-phase transformers using a three-phase testing device or by three consecutive tests using a single-phase testing device. – The value of the test voltage with respect to the core and to any screen between primary and secondary windings is to be in accordance with the specification of the relevant transformer. If the primary winding has an identified connection point for the neutral of the SUPPLY MAINS, such a point should be connected to the core (and screen if present) unless the core (and screen) are specified for connection to an unearthed part of the circuit. To simulate this, the core (and screen) is connected to a source with an appropriate voltage and frequency with respect to the identified connection point. <p>If such a connection point has not been identified, connect side of the primary winding in turn to the core (and screen if present) unless the core (and screen) are specified for connection to an unearthed part of the circuit.</p> <p>To simulate this, connect the core (and screen) to a source with an appropriate voltage and frequency with respect to each side of the primary winding in turn.</p> <ul style="list-style-type: none"> – During the test, leave all windings not intended for connection to the SUPPLY MAINS unloaded (open circuit). For windings intended to be earthed at a point or to be operated with a point nearly at earth potential, connect that point to the core, unless the core is specified for connection to an unearthed part of the circuit. – Initially not more than half the prescribed voltage is to be applied. It is then raised over a period of 10 s to the full value, which is then maintained for 1 min, after which the voltage is reduced gradually and switched off. – Tests are not conducted at resonant frequencies. 		

f) Presentation of the test results:

TABLE: Transformer normal heating							
Winding designation	T_1 °C	R_1 Ω	T_2 °C	R_2 Ω	ΔT °C	$T = T_2 + \Delta T$ °C	Remarks

TABLE: Transformer short circuit						
Winding under test	Protection	Measured temperatures °C			Test duration	Remarks
		Primary	Secondary	Ambient		
						Supply voltage: ____

13.4.29 Mains transformers (continued)

Standard(s): IEC 60601-1:2005+AMD1:2012	Subclause(s): 15.5, 13.2.3	13.4.29 Mains transformers
--	-------------------------------	----------------------------

TABLE: Overload							
Winding under test	Protection	Measured temperatures °C			Test duration	Test current or THERMAL CUT-OUT temperature	Remarks
		Primary	Secondary	Ambient			
							Supply voltage: _____

TABLE: Transformer dielectric strength					
Transformer under test	Test voltage applied to	Test voltage	Test frequency	Secondary voltage	Remarks

During the tests windings **did/did not** open.

Unacceptable RISKS **did/did not** occur.

The maximum temperatures of windings **did/did not** exceed the values found in Table 16.

After the tests the transformer **passes/does not pass** appropriate dielectric strength tests.

During test 4) above there **was/was not** flashover or breakdown of any part of the insulation and there **was/was not** detectable deterioration.

Sealing or potting **did/did not** flow out.

During the test, THERMAL CUT-OUTS **did/did not** operate.

There **was/was no** emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities.

When tested in situ there **was/was no** deformation of ENCLOSURES to such an extent that mechanical strength was impaired.

Temperatures of DUT parts likely to be touched **did/did not** exceed the allowable values from Table 12.

LEAKAGE CURRENT limits **were/were not** exceeded.

Voltage of ACCESSIBLE PARTS **did/did not** exceed the allowable values.

NOTE 3 Ignore slight corona discharges, provided that they cease when the test voltage is temporarily dropped to a lower value, that this value is higher than the WORKING VOLTAGE and that the discharges do not provoke a drop in test voltage.

Annex A (informative)

Sequence of testing

A.1 Sequence of testing (IEC 60601-1:1988)

- A.1.1** General requirements
- A.1.2** Markings
- A.1.3** Power input
- A.1.4** Classification
- A.1.5** Limitation of voltage and/or energy
- A.1.6** ENCLOSURES and PROTECTIVE COVERS
- A.1.7** Separation
- A.1.8** Protective earthing, functional earthing and potential equalization
- A.1.9** Mechanical strength
- A.1.10** Moving parts
- A.1.11** Surfaces, corners and edges
- A.1.12** Stability and transportability
- A.1.13** Expelled parts
- A.1.14** Suspended masses
- A.1.15** Radiation HAZARDS
- A.1.16** Electromagnetic compatibility
- A.1.17** Pressure vessels and parts subject to PRESSURE
- A.1.18** Human errors
- A.1.19** Temperatures – Fire prevention
- A.1.20** Interruption of the power supply
- A.1.21** Accuracy of operating data and protection against incorrect output
- A.1.22** Abnormal operation, fault conditions, environmental tests*
- A.1.23** Continuous LEAKAGE CURRENTS and PATIENT AUXILIARY CURRENTS at operating temperature*
- A.1.24** Dielectric strength at operating temperature*

- A.1.25** Humidity preconditioning treatment*
- A.1.26** Dielectric strength test (**COLD CONDITION**)*
- A.1.27** LEAKAGE CURRENT after humidity preconditioning treatment*
- A.1.28** Overflow, spillage, leakage, humidity, ingress of liquids, cleaning, sterilization and disinfection*
- A.1.29** ENCLOSURES and covers
- A.1.30** Components and general assembly
- A.1.31** MAINS PARTS, components and layout
- A.1.32** Construction and layout
- A.1.33** CATEGORY AP and CATEGORY APG ME EQUIPMENT
- A.1.34** VERIFICATION of markings

NOTE The sequence of the tests marked by an * is described as mandatory in Annex C or IEC 60601-1:1988.

A.2 Sequence of testing (IEC 60601-1:2005)

- A.2.1** RISK MANAGEMENT PROCESS for ME EQUIPMENT or ME SYSTEMS and ESSENTIAL PERFORMANCE
- A.2.2** General requirements
- A.2.3** Classification of ME EQUIPMENT and ME SYSTEMS
- A.2.4** Determination of APPLIED PARTS and ACCESSIBLE PARTS
- A.2.5** ME EQUIPMENT identification, marking and documents
- A.2.6** Energy consumption (power input)
- A.2.7** Limitation of voltage, current or energy
- A.2.8** Separation of parts
- A.2.9** CREEPAGE DISTANCES and AIR CLEARANCES
- A.2.10** HAZARDS associated with moving parts
- A.2.11** HAZARD associated with surfaces, corners and edges
- A.2.12** Serviceability
- A.2.13** Accuracy of controls and instruments and protection against hazardous outputs
- A.2.14** Instability HAZARDS
- A.2.15** Noise, vibration and acoustic energy
- A.2.16** Interruption of the power supply / SUPPLY MAINS to ME EQUIPMENT
- A.2.17** Protective earthing, functional earthing and potential equalization of ME EQUIPMENT
- A.2.18** Excessive temperatures in ME EQUIPMENT
- A.2.19** LEAKAGE CURRENTS and PATIENT AUXILIARY CURRENTS at operating temperature
- A.2.20** Humidity preconditioning treatment
- A.2.21** Dielectric strength (COLD CONDITION)
- A.2.22** Defibrillation protection
- A.2.23** Expelled parts HAZARD
- A.2.24** Pressure vessels and parts subject to pneumatic and hydraulic pressure
- A.2.25** HAZARDS associated with support systems
- A.2.26** Mechanical strength

- A.2.27** HAZARDOUS SITUATIONS and fault conditions
- A.2.28** MAINS SUPPLY TRANSFORMERS of ME EQUIPMENT and transformers providing separation in accordance with 8.5
- A.2.29** ME EQUIPMENT components and general assembly
- A.2.30** MAINS PARTS, components and layout
- A.2.31** Insulation other than wire insulation
- A.2.32** Fire prevention and constructional requirements for fire ENCLOSURES of ME EQUIPMENT
- A.2.33** Overflow, spillage, leakage, ingress of water, cleaning, disinfection, sterilization and compatibility with substances used with the ME EQUIPMENT
- A.2.34** CATEGORY AP and CATEGORY APG ME EQUIPMENT
- A.2.35** VERIFICATION of markings

Annex B (informative)

Information typically required for product safety testing (Guide)

B.1 Purpose

The following information is useful when performing product safety and EMC testing. MANUFACTURERS may benefit from reviewing these requirements even if ME EQUIPMENT is only undergoing an initial evaluation.

B.2 Description

Brief description and INTENDED USE of the device under test (DUT), including the name and model number.

B.3 Intended use environment

- Where will the DUT be installed and used?
- In what environments of use (i.e. home, healthcare facility, transportation, outdoors) will it be found?

B.4 Construction

- Composition of DUT
- Assembly of DUT
- Auxiliary equipment
- What are its dimensions and weight?
- Is the floor loading reasonably well distributed?

B.5 List of safety-related components and relevant approvals

A list of all safety-related components (i.e. parts used in mains, radiation sources, protection means, critical materials, internal wiring). For all these components, request copies of relevant approvals and licenses from established test houses and certification bodies, with ratings (just copies of data sheets are not acceptable).

B.6 Test system

Block diagram of the test system (including the safety conception: insulation diagram) and supporting equipment. Diagram should show what is within and outside the test area. It should include cables, DUT, and peripherals. A mechanical assembly drawing with complete parts list.

B.7 Power

- What are the power requirements (line voltage, current and frequency) for the DUT and support equipment?
- How many power cords are there for the DUT and support equipment?
- What types of power connector are used?

B.8 Grounding

List any special grounding requirements.

B.9 Modes of operation; configurations

- User manual and sales brochures
- Drawing of markings
- How will the DUT be operated?
- How many modes will be tested?
- How many line voltages are required to be tested?
- When only one mode is to be tested, provide rationale for selecting that mode.
- How many DUT configurations will be tested? (Use typical installation practices or regulatory requirements.)
- I/O ports (SIP/SOP) and how will they be used?

B.10 Failure modes

Define what constitutes a failure for performance, and describe how errors are identified and monitored.

B.11 RISK ANALYSIS according with ISO 14971

B.12 Software

Software validation (including software specification requirements, software development requirements and software test plan with results of the tests).

B.13 Auxiliary equipment

List any equipment required to operate or serve as loads for the DUT (if applicable).

B.14 Transformers and chokes

- Installation schematic with RATED voltage, current, performance, colours/numbers of leads, wire diameters, integrated fuses
- Constructional drawing (cross section) with all parts numbered (e.g., core, core insulation, isolation, spacer, etc.)
- Part list with description of: material, manufacturer, mat.type/model, flameclass, UL-card or UL listing file number.
- Construction requirements
- Test samples: potted and unpotted

Annex C (informative)


Testing and measuring equipment

Table C.1 – IEC 60601-1:1988+AMD1:1991 and AMD2:1995

Clause	Test	Recommended test equipment
4	Humidity preconditioning	Humidity cabinet
6	Durability of markings	Cloth, distilled water, isopropyl alcohol and methylated spirit and a suitable timer/ stop watch
7	Power input	Suitable devices for the voltage, current/ power and frequency
10	Environmental conditions	Climate chamber controlling temperature and humidity, supply 1 phase and 3 phase variacs
15	Limitations voltage/ energy	Suitable oscilloscope recorder /set-up and RCL meter
16	ENCLOSURES and PROTECTIVE COVERS	Pull/push tester, test hook, test finger, test pin, test rod 4 mm and 12 mm
17	DEFIBRILLATOR-PROOF APPLIED PARTS	DEFIBRILLATION-PROOF APPLIED PART test box
18	Earth resistance	Earth resistance tester
19	LEAKAGE CURRENTS	Variac, V-meter, mV- meter, diverse circuits, memory scope with measurement functions, measuring device (MD), aluminium foil, isolation transformers
20	Dielectric strength test	HIGH-VOLTAGE tester, isolating transformer for HIGH-VOLTAGE tests
21	Mechanical strength	Impact hammers, weights, hard wood plate, balance
24	Stability tests	Inclinometer or trigonometric calculation (slope up to 10°)
25	Expelled parts	As per IEC 60065
29	X-radiation	Radiation meter
36	EMC requirements	EMC equipment
39	Common requirements AP and APG	Volt meter, test rod 4 mm, 12 mm , equipment resistance meter according to ISO 471 / ISO 1853 / ISO 2878
40	Requirements for CATEGORY AP ME EQUIPMENT	Same equipment as Clause 40 including special gases
41	Requirements for CATEGORY APG ME EQUIPMENT	Same equipment as Clause 40 including special gases
42	Heating tests	V-meter, A-meter, a.c./d.c., temperature indicator/ recorder suitable for this function, and thermocouples, test corner, 4 wire resistance unit
44	Spillage	Liquids, steriliant measuring cups, pipette, different liquids for cleaning, IP appliances, sterilisation to client specification, sterilisation with steam
45	Pressure	Pressure gauges
51	Hazardous output	Oscilloscope, same equipment as for Clause 42 above
52	Abnormal operation and fault conditions	Apparatus for ball pressure test, same equipment as for Clause 42 above
53	Environmental tests	Humidity chamber
56	Components	Counter, torque tester, weights
57	MAINS PART	Pull tester, different sizes of cables, winding tester for transformers, micrometer
59	Construction layout	Ball pressure test apparatus, micrometer/callipers, force gauge, multimeter, oven, apparatus for rubber ageing in oxygen.
Appendix F	Flammable mixtures	See also Clause 37 to 40 above, test apparatus

Annex D
 (informative)


Suitable measuring supply circuits



For legends, see Table D.1.

Figure D.1 – Measuring supply circuit with one side of the SUPPLY MAINS at approximately earth potential


(IEC 60601-1:2005, Figure F.1)



For legends, see Table D.1.

Figure D.2 – Measuring supply circuit with SUPPLY MAINS approximately symmetrical to earth potential


(IEC 60601-1:2005, Figure F.2)



For legends, see Table D.1.


Figure D.3 – Measuring supply circuit for polyphase ME EQUIPMENT specified for connection to a polyphase SUPPLY MAINS

(IEC 60601-1:2005, Figure F.3)



For legends, see Table D.1.

Figure D.4 – Measuring supply circuit for single-phase ME EQUIPMENT specified for connection to a polyphase SUPPLY MAINS
(IEC 60601-1:2005, Figure F.4)




For legends, see Table D.1.

Figure D.5 – Measuring supply circuit for ME EQUIPMENT having a separate power supply unit or intended to receive its power from another equipment in an ME SYSTEM

(IEC 60601-1:2005, Figure F.5)

Table D.1 – Legends of symbols for Figure D.1 to Figure D.5

①	ME EQUIPMENT ENCLOSURE
②	Separate power supply unit or other electrical equipment in an ME SYSTEM that supplies power to the ME EQUIPMENT
T ₁	Single- or polyphase isolation transformer with sufficient power rating and adjustable output voltage
V(1,2,3)	Voltmeter indicating r.m.s. value, using, if relevant and possible, one meter with a commutator switch
S ₁ , S ₂ , S ₃	Single-pole switches, simulating the interruption of a power supply conductor (SINGLE FAULT CONDITION)
S ₅	Commutator switch to reverse the polarity of the MAINS VOLTAGE
S ₈	Single pole switch simulating the interruption of a single PROTECTIVE EARTH CONDUCTOR to a separate power supply unit or other electrical equipment in an ME SYSTEM that supplies power to the ME EQUIPMENT (SINGLE FAULT CONDITION)
S ₁₀	Switch for connecting a FUNCTIONAL EARTH TERMINAL to the earthed point of the measuring supply system
P ₁	Sockets, plugs or terminals for the supply connection of the ME EQUIPMENT
P ₂	Sockets, plugs or terminals for the connection to a separate power supply or other electrical equipment in an ME SYSTEM that supplies power to the ME EQUIPMENT
FE	FUNCTIONAL EARTH TERMINAL
PE	PROTECTIVE EARTH TERMINAL
- - - -	Optional connection
	Reference earth (for LEAKAGE CURRENT and PATIENT AUXILLARY CURRENT measurements and for testing of DEFIBRILLATION-PROOF APPLIED PARTS, not connected to protective earth of the SUPPLY MAINS)

Annex E (informative)

Preventive maintenance

E.1 General

It is recommended that all ME EQUIPMENT should be appropriately maintained by a technically competent person. Maintenance comprises a range of activities including:

- preventive maintenance of the ME EQUIPMENT and ACCESSORIES;
- calibration of the main characteristics; and
- OPERATOR tasks associated with clinical use.

E.2 Cleaning and disinfection

Prior to the ME EQUIPMENT being serviced or repaired, it is recommended that the ME EQUIPMENT be cleaned and/or disinfected, and be free from any contamination that might HARM the person carrying out the maintenance. Appropriate disinfectants that do not damage the ME EQUIPMENT will normally be specified by the MANUFACTURER. The local disinfection policy should be consulted to assess the efficacy recommended of the disinfecting agent against the specific pathogen(s) concerned.

E.3 Preventive maintenance checklist

This checklist will normally be specified by the MANUFACTURER and undertaken by the supplier or other suitably qualified staff.

- Inspect and clean safety-related components
- Check and replace or replenish consumables
- Verify the correct operation of the ME EQUIPMENT
- Verify that the ME EQUIPMENT is electrically safe


E.4 OPERATOR checks

OPERATORS are advised to carry out a number of simple but useful checks prior to each clinical session. These can include

- checking the condition of the foot-switch cables and power cables for obvious signs of wear;
- inspecting the APPLIED PARTS for signs of damage and/or contamination;
- checking the emergency-off switch operation;
- checking the protective means for availability and integrity.

Annex F (informative)

Test probes



Linear dimensions in mm

Tolerances on dimensions without specific tolerances:

- 14° and 37° angles: $\pm 15'$
- on radii: $\pm 0,1$ mm
- on linear dimensions:
 - ≤ 15 mm: 0 mm
 - > 15 mm ≤ 25 mm: $\pm 0,1$ mm
 - > 25 mm: $\pm 0,3$ mm

Material of finger: heat-treated steel, for example.

Both joints of this finger can be bent through an angle of $90^{\circ}_{0^{\circ}}^{+10^{\circ}}$ but in one and the same direction only.

NOTE 1 Using the pin and groove solution is only one of the possible approaches in order to limit the bending angle to 90°. For this reason, dimensions and tolerances of these details are not given in the drawing. The actual design must insure a 90° bending angle with a 0° to + 10° tolerance.


NOTE 2 Dimensions in parentheses are for information only.

NOTE 3 The test finger is taken from IEC 60950-1 [5]⁶, Figure 2A. That test finger is based on IEC 61032 [8], Figure 2, test probe B. In some cases, the tolerances are different.

Figure F.1 – Standard test finger

(IEC 60601-1:2005, Figure 6)


⁶ Figures in square brackets refer to the Bibliography.



IEC

Figure F.2 – Test hook


(IEC 60601-1:2005+AMD1:2012, Figure 7)



IEC

Figure F.3 – Test pin

(IEC 60601-1:2005, Figure 8)



IEC

Figure F.4 – Ball-pressure test apparatus

(IEC 60601-1:2005, Figure 21)

Annex G (informative)

Index of tests (IEC 60601-1:2005 clauses order)

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
4.2, 4.5	RISK MANAGEMENT PROCESS	13.2.1	21
4.3	ESSENTIAL PERFORMANCE – Functional	13.4.1	97
4.8, 4.9, 11.3, 15.4	Ratings on critical components	13.2.2	22
4.11	Power consumption (input) single phase and polyphase	13.4.2	99
5.3	Operation to a specified temperature	13.4.18	135
5.7	Humidity preconditioning	13.3.1	42
4.6, 5.9, 8.4.2, 9.2.1	Determination of APPLIED PARTS and ACCESSIBLE PARTS	13.2.3	23
7.1.2, 7.1.3	Durability and legibility of marking	13.2.4	25
7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9	Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS	13.2.13	39
8.1	Voltage mismatch	13.4.3	100
7.3.3	Battery markings	13.2.5	27
8.4.3, 8.4.4	Limitation of voltage, current or energy	13.4.4	101
8.5.2.3	PATIENT leads and PATIENT cables	13.2.6	28
8.5.4, 8.10.4.1	WORKING VOLTAGE measurement	13.4.13	126
8.5.5.1	DEFIBRILLATION-PROOF APPLIED PART protection	13.4.5	103
8.5.5.2	Energy reduction	13.4.6	108
8.6.4	Impedance of PE connection	13.3.2	43
8.6.6	Plugs, sockets	13.2.7	29
8.6.7	POTENTIAL EQUALIZATION TERMINAL	13.2.8	30
8.7.4.5	EARTH LEAKAGE CURRENT	13.4.7	110
8.7.4.6	TOUCH CURRENT	13.4.8	114
8.7.4.7, 8.7.4.9	PATIENT LEAKAGE CURRENT	13.4.9	116
8.7.4.7 b)	PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART	13.4.10	119
8.7.4.7 c)	PATIENT LEAKAGE CURRENT with mains on SIP/SOP	13.4.11	122
8.7.4.8	PATIENT AUXILIARY CURRENT	13.4.12	124
8.8.3	Dielectric strength	13.3.3	44
8.8.4.1	Ball pressure	13.3.4	46
8.8.4.2	Resistance to environmental stress	13.3.5	47
8.9.3.4	Thermal cycling	13.3.6	48
8.9.4	CREEPAGE DISTANCES and AIR CLEARANCES	13.3.7	50
8.11.3.5	Strain relief (cord anchorage)	13.3.8	56
8.11.3.6	Cord guard flexing (Cord bending)	13.3.9	58
8.11.4.2 e)	MAINS TERMINAL DEVICE	13.2.9	31
9.2.1	Access to hazardous moving parts	13.3.10	59
9.2.2.2	Gaps	13.3.11	61

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
9.3	Sharp edges	13.2.10	33
9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)	13.3.12	63
9.4.2.4.2, 9.4.2.4.3	Castors and wheels (force for propulsion, movement over a threshold)	13.3.13	67
9.4.4	Handle loading	13.3.14	69
9.6.2.1	Sound pressure level measurement	13.4.14	128
9.7.5	Hydrostatic pressure	13.4.15	129
9.8.1, 9.8.2	Safety catch evaluation	13.3.15	71
9.8.1, 9.8.3.1, 9.8.4, 9.8.5	HAZARDS associated with support systems	13.2.11	34
9.8.3	Support loading	13.3.16	72
10.1	X-radiation (ionizing radiation) measurement	13.4.16	131
11.1	Normal heating	13.4.17	132
11.2.2.1	Identification of source of ignition	13.4.19	136
11.3	Construction requirements for fire ENCLOSURE of ME EQUIPMENT	13.2.12	36
11.6.2	Overflow	13.3.17	75
11.6.3	Spillage	13.3.18	76
11.6.4, 13.2.6	Leakage	13.3.19	77
11.6.5	Ingress of water or particulate matter	13.3.20	78
11.6.6, 11.6.7	Cleaning, sterilization and disinfection	13.3.21	83
11.8	Interruption of power supply	13.4.20	141
12.2, 15.1, 7.1.1	USABILITY	13.2.14	
13.1.2	Limited power circuit	13.4.21	142
13.2.4	Failures of THERMOSTATS	13.4.22	143
13.2.7	Impairment of cooling	13.4.23	144
13.2.8	Locking of moving parts	13.4.24	145
13.2.9	Interruption or short circuit of motor capacitors	13.4.25	150
13.2.13.3 b), 13.2.13.4	Motor running overload	13.4.26	152
13.2.13.1, 13.2.13.2	Heating element overload	13.4.27	155
15.3.2	Push (rigidity)	13.3.22	84
15.3.3	Impact	13.3.23	85
15.3.4	Drop impact	13.3.24	87
15.3.5, 9.4.2.4.3	Rough handling	13.3.25	89
15.3.6	Mould stress relief	13.3.26	91
15.4.3	Rechargeable battery overcharge/discharge	13.4.28	158
15.4.6.1, 15.4.6.2	Actuating parts of controls (knob pull and limitation of movement)	13.3.27	92
15.5, 13.2.3	Mains transformers	13.4.29	160

Annex H (informative)

Index of tests for an INTERNALLY POWERED EQUIPMENT – battery only – (IEC 60601-1:2005 clauses order)

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
4.2, 4.5	RISK MANAGEMENT PROCESS	13.2.1	21
4.3	ESSENTIAL PERFORMANCE – Functional	13.4.1	97
4.8, 4.9, 11.3, 15.4	Ratings on critical components	13.2.2	22
5.3	Operation to a specified temperature	13.4.18	135
5.7	Humidity preconditioning	13.3.1	42
4.6, 5.9, 8.4.2, 9.2.1	Determination of APPLIED PARTS and ACCESSIBLE PARTS	13.2.3	23
7.1.2, 7.1.3	Durability and legibility of marking	13.2.4	25
7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9	Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS	13.2.13	39
7.3.3	Battery markings	13.2.5	27
8.4.3, 8.4.4	Limitation of voltage, current or energy	13.4.4	101
8.5.2.3	PATIENT leads and PATIENT cables	13.2.6	28
8.5.5.1	DEFIBRILLATION-PROOF APPLIED PART protection	13.4.5	103
8.5.5.2	Energy reduction	13.4.6	108
8.6.6	Plugs, sockets	13.2.7	29
8.7.4.6	TOUCH CURRENT	13.4.8	114
8.7.4.7, 8.7.4.9	PATIENT LEAKAGE CURRENT	13.4.9	116
8.7.4.7 b)	PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART	13.4.10	119
8.7.4.7 c)	PATIENT LEAKAGE CURRENT with mains on SIP/SOP	13.4.11	122
8.7.4.8	PATIENT AUXILIARY CURRENT	13.4.12	124
8.8.3	Dielectric strength	13.3.3	44
8.8.4.1	Ball pressure	13.3.4	46
8.8.4.2	Resistance to environmental stress	13.3.5	47
8.9.3.4	Thermal cycling	13.3.6	48
8.9.4	CREEPAGE DISTANCES and AIR CLEARANCES	13.3.7	50
9.2.1	Access to hazardous moving parts	13.3.10	59
9.2.2.2	Gaps	13.3.11	61
9.3	Sharp edges	13.2.10	33
9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)	13.3.12	63
9.4.2.4.2, 9.4.2.4.3	Castors and wheels (force for propulsion, movement over a threshold)	13.3.13	67
9.4.4	Handle loading	13.3.14	69
9.6	Sound pressure level measurement	13.4.14	128
9.7.5	Hydrostatic pressure	13.4.15	129
9.8.1, 9.8.2	Safety catch evaluation	13.3.15	71

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
9.8.1, 9.8.3.1, 9.8.4, 9.8.5	HAZARDS associated with support systems	13.2.11	34
10.1	X-radiation (ionizing radiation) measurement	13.4.16	131
11.1	Normal heating	13.4.17	132
11.2.2	Identification of source of ignition	13.4.19	136
11.3	Construction requirements for fire ENCLOSURE of ME EQUIPMENT	13.2.12	36
11.6.2	Overflow	13.3.17	75
11.6.3	Spillage	13.3.18	76
11.6.4, 13.2.6	Leakage	13.3.19	77
11.6.5	Ingress of water or particulate matter	13.3.20	78
11.6.6, 11.6.7	Cleaning, sterilization and disinfection	13.3.21	83
11.8	Interruption of power supply	13.4.20	141
12.2, 15.1, 7.1.1	USABILITY	13.2.14	
13.2.4	Failures of THERMOSTATS	13.4.22	143
13.2.7	Impairment of cooling	13.4.23	144
13.2.8	Locking of moving parts	13.4.24	145
13.2.9	Interruption or short circuit of motor capacitors	13.4.25	150
13.2.13.3 b), 13.2.13.4	Motor running overload	13.4.26	152
13.2.13.1, 13.2.13.2	Heating element overload	13.4.27	155
15.3.2	Push (rigidity)	13.3.22	84
15.3.3	Impact	13.3.23	85
15.3.4	Drop impact	13.3.24	87
15.3.5, 9.4.2.4.3	Rough handling	13.3.25	89
15.3.6	Mould stress relief	13.3.26	91
15.4.3.3	Rechargeable battery overcharge/discharge	13.4.28	158
15.4.6.1, 15.4.6.2	Actuating parts of controls (knob pull and limitation of movement)	13.3.27	92

Annex I (informative)

Index of tests (IEC 60601-1:2005 alphabetic order)

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
9.2	Access to hazardous moving parts	13.3.10	59
15.4.6.1, 15.4.6.2	Actuating parts of controls (knob pull and limitation of movement)	13.3.27	92
8.8.4.1	Ball pressure	13.3.4	46
7.3.3	Battery markings	13.2.5	27
9.4.2.4.2	Castors and wheels (force for propulsion, movement over a threshold)	13.3.12	67
11.6.6; 11.6.7	Cleaning, sterilization and disinfection	13.3.21	83
11.3	Construction requirements for fire ENCLOSURE of ME EQUIPMENT	13.2.12	36
8.11.3.6	Cord guard flexing (cord bending)	13.3.9	58
8.9.4	CREEPAGE DISTANCES and AIR CLEARANCES	13.3.7	50
8.5.5.1	DEFIBRILLATION-PROOF APPLIED PART protection	13.4.5	103
4.6, 5.9; 8.4.2, 9.2.1	Determination of APPLIED PARTS and ACCESSIBLE PARTS	13.2.3	23
8.8.3	Dielectric strength	13.3.3	44
15.3.4	Drop impact	13.3.24	87
7.1.2; 7.1.3	Durability and legibility of marking	13.2.4	25
8.7.4.5	EARTH LEAKAGE CURRENT	13.4.7	110
8.5.5.2	Energy reduction	13.4.6	108
13.2.4	Failures of THERMOSTATS	13.4.22	143
4.3	ESSENTIAL PERFORMANCE – Functional	13.4.1	97
9.4.4	Handle loading	13.3.14	69
9.8.1, 9.8.3.1, 9.8.4, 9.8.5	HAZARDS associated with support systems	13.2.11	34
13.2.13.1; 13.2.13.2	Heating element overload	13.4.27	155
5.7	Humidity preconditioning	13.3.1	42
9.7.5	Hydrostatic pressure	13.4.15	129
11.2.2	Identification of source of ignition	13.4.19	136
15.3.3	Impact	13.3.23	85
13.2.7	Impairment of cooling	13.4.23	144
8.6.4	Impedance of PE connection	13.3.2	43
11.6.5	Ingress of water or particulate matter	13.3.20	78
9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)	13.3.11	63
11.8	Interruption of power supply	13.4.20	141
13.2.9	Interruption or short circuit of motor capacitors	13.4.25	150
11.6.4, 13.2.6	Leakage	13.3.19	77

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
8.4.3; 8.4.4	Limitation of voltage, current or energy	13.4.4	101
13.1.2	Limited power circuit	13.4.21	142
13.2.8	Locking of moving parts	13.4.24	145
8.11.4.2 e)	MAINS TERMINAL DEVICE	13.2.9	31
15.5; 13.2.3	Mains transformers	13.4.29	160
7.2, 7.3, 7.4, 7.5, 7.6, 7.7, 7.8, 7.9	Marking, conductor colours, indicator lights and controls and ACCOMPANYING DOCUMENTS	13.2.13	39
13.2.13.3 b), 13.2.13.4	Motor running overload	13.4.26	152
15.3.6	Mould stress relief	13.3.26	91
11.1	Normal heating	13.4.17	132
5.3	Operation to a specified temperature	13.4.18	135
11.6.2	Overflow	13.3.17	75
8.7.4.8	PATIENT AUXILIARY CURRENT	13.4.12	124
8.5.2.3	PATIENT leads and PATIENT cables	13.2.6	28
8.7.4.7, 8.7.4.9	PATIENT LEAKAGE CURRENT	13.4.9	116
8.7.4.7 b)	PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART	13.4.10	119
8.7.4.7 c)	PATIENT LEAKAGE CURRENT with mains on SIP/SOP	13.4.11	122
8.6.6	Plugs, sockets	13.2.7	29
8.6.7	POTENTIAL EQUALIZATION TERMINAL	13.2.8	30
4.11	Power consumption (input) single phase and polyphase	13.4.2	99
15.3.2	Push (rigidity)	13.3.22	84
4.8, 4.9, 11.3, 15.4	Ratings on critical components	13.2.2	22
15.4.3.3	Rechargeable battery overcharge/discharge	13.4.28	158
8.8.4.2	Resistance to environmental stress	13.3.5	47
4.2; 4.5	RISK MANAGEMENT PROCESS	13.2.1	21
15.3.5, 9.4.2.4.3	Rough handling	13.3.25	89
9.8.1, 9.8.2	Safety catch evaluation	13.3.15	71
9.3	Sharp edges	13.2.10	33
9.6.2.1	Sound pressure level measurement	13.4.14	128
11.6.3	Spillage	13.3.18	76
8.11.3.5	Strain relief (cord anchorage)	13.3.8	56
9.8.3	Support loading	13.3.16	72
8.9.3.4	Thermal cycling	13.3.6	48
8.7.4.6	TOUCH CURRENT	13.4.8	114
12.2, 15.1, 7.1.1	USABILITY	13.2.14	
8.1	Voltage mismatch	13.4.3	100
8.5.4; 8.10.4.1	WORKING VOLTAGE measurement	13.4.13	126
10.1	X-radiation (ionizing radiation) measurement	13.4.16	131

Annex J (informative)

Index of tests for an INTERNALLY POWERED EQUIPMENT – battery only – (IEC 60601-1:2005 alphabetic order)

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
9.2	Access to hazardous moving parts	13.3.10	59
15.4.6.1, 15.4.6.2	Actuating parts of controls (knob pull and limitation of movement)	13.3.27	92
8.8.4.1	Ball pressure	13.3.4	46
7.3.3	Battery markings	13.2.5	27
9.4.2.4.2	Castors and wheels (force for propulsion, movement over a threshold)	13.3.12	67
11.6.6, 11.6.7	Cleaning, sterilization and disinfection	13.3.21	83
11.3	Construction requirements for fire ENCLOSURE of ME EQUIPMENT	13.2.12	36
8.9.4	CREEPAGE DISTANCES and AIR CLEARANCES	13.3.7	50
8.5.5.1	DEFIBRILLATION-PROOF APPLIED PART protection	13.4.5	103
4.6, 5.9, 8.4.2, 9.2.1	Determination of APPLIED PARTS and ACCESSIBLE PARTS	13.2.3	23
8.8.3	Dielectric strength	13.3.3	44
15.3.4	Drop impact	13.3.24	87
7.1.2, 7.1.3	Durability and legibility of marking	13.2.4	25
8.5.5.2	Energy reduction	13.4.6	108
13.2.4	Failures of THERMOSTATS	13.4.22	143
9.4.2.4.2	Force of propulsion	13.3.12	67
4.3	ESSENTIAL PERFORMANCE – Functional	13.4.1	97
9.4.4	Handle loading	13.3.13	69
9.8.1, 9.8.3.1, 9.8.4, 9.8.5	HAZARDS associated with support systems	13.2.11	34
13.2.13.1, 13.2.13.2	Heating element overload	13.4.27	155
5.7	Humidity preconditioning	13.3.1	42
9.7	Hydrostatic pressure	13.4.15	129
11.2.2	Identification of source of ignition	13.4.19	136
15.3.3	Impact	13.3.23	85
13.2.7	Impairment of cooling	13.4.23	144
11.6.5	Ingress of water or particulate matter	13.3.20	78
9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.3.1, 9.4.3.2	Instability (in transport position; excluding transport; from horizontal and vertical forces and from unwanted lateral movement)	13.3.11	63
11.8	Interruption of power supply	13.4.20	141
13.2.9	Interruption or short circuit of motor capacitors	13.4.25	150
11.6.4, 13.2.6	Leakage	13.3.19	77
8.4.3, 8.4.4	Limitation of voltage, current or energy	13.4.4	101
13.2.8	Locking of moving parts	13.4.24	145

Clause in IEC 60601-1:2005	Test	Test number per IEC/TR 62354	Page
13.2.13.3 b), 13.2.13.4	Motor running overload	13.4.26	152
15.3.6	Mould stress relief	13.3.26	91
11.1	Normal heating	13.4.17	132
5.3	Operation to a specified temperature	13.4.18	135
11.6.2	Overflow	13.3.17	75
8.7.4.8	PATIENT AUXILIARY CURRENT	13.4.12	124
8.5.2.3	PATIENT leads and PATIENT cables	13.2.6	28
8.7.4.7, 8.7.4.9	PATIENT LEAKAGE CURRENT	13.4.9	116
8.7.4.7 b)	PATIENT LEAKAGE CURRENT with mains on F-TYPE APPLIED PART	13.4.10	119
8.7.4.7 c)	PATIENT LEAKAGE CURRENT with mains on SIP/SOP	13.4.11	122
8.6.6	Plugs, sockets	13.2.7	29
15.3.2	Push (rigidity)	13.3.22	84
4.8, 4.9, 11.3, 15.4	Ratings on critical components	13.2.2	22
15.4.3.3	Rechargeable battery overcharge/discharge	13.4.28	158
8.8.4.2	Resistance to environmental stress	13.3.5	47
4.2; 4.5	RISK MANAGEMENT PROCESS	13.2.1	21
15.3.5, 9.4.2.4.3	Rough handling	13.3.25	89
9.8.1, 9.8.2	Safety catch evaluation	13.3.15	71
9.3	Sharp edges	13.2.10	33
9.6.2.1	Sound pressure level measurement	13.4.14	128
11.6.3	Spillage	13.3.18	76
9.8	Support loading	13.3.16	72
8.9.3.4	Thermal cycling	13.3.6	48
8.7.4.6	TOUCH CURRENT	13.4.8	114
12.2, 15.1, 7.1.1	USABILITY	13.2.14	
10.1	X-radiation (ionizing radiation) measurement	13.4.16	131

Annex K (informative)

Production line tests

K.1 Production-line dielectric voltage-withstand test

- a) Each ME EQUIPMENT should withstand without an indication of unacceptable performance, as a routine production-line test, the application of a 40 Hz to 70 Hz potential or a d.c. potential of 1,414 times the stated a.c. value between
 - 1) the primary wiring, including connected components, and accessible dead metal parts that are likely to become energized; and
 - 2) primary and accessible low voltage (42,4 V peak or less) metal parts, including terminals; and, where applicable
 - 3) primary circuits and PATIENT-connected circuits. See also 20.2 in IEC 60601:1988.
- b) The product may be in a heated or unheated condition for the test.
- c) The test should be conducted when the product is complete (fully assembled). It is not intended that the appliance be unwired, modified or disassembled for the test.

Exception 1 Parts such as snap covers or friction-fit knobs that would interfere with performance of the test need not be in place.

Exception 2 The test may be performed before final assembly if the test represents that for the completed product.
- d) When the appliance employs a solid-state component that is not relied upon to reduce the RISK of an electric shock and that can be damaged by the dielectric potential, the test may be conducted before the component is electrically connected. The circuitry may be rearranged for the purpose of the test to minimize the likelihood of solid-state-component damage while retaining representative dielectric stress of the circuit.
- e) The test equipment, when adjusted for production-line testing, is to produce an output voltage that is not less than the factory test value specified, nor is the magnitude of the test voltage to be greater than 120 % of the specified test potential when the tester is used in each of the following conditions.
 - 1) If the test duration is 1 s, the output voltage is to be maintained within the specified range:
 - when only a voltmeter having an input impedance of at least 2 M Ω and a specimen of the product being tested are connected to the output terminals, and
 - when a relatively high resistance is connected in parallel with the voltmeter and the product being tested, and the value of the resistance is gradually reduced to the point where an indication of unacceptable performance just occurs.
 - 2) If the test duration is 1 min, the output voltage is to be maintained within the specified range, by manual or automatic means, throughout the 1 min duration of the test or until there is an indication of unacceptable performance.
- f) The specified control of the applied voltage, manual or automatic, should be maintained under conditions of varying line voltage. Higher test potentials may be used if the higher dielectric stress is not likely to adversely affect the insulating system of the product.
- g) In addition, the test equipment is to have the following features and characteristics.
 - 1) A means of indicating the test voltage that is being applied to the DUT. This may be accomplished by sensing the voltage at the test leads or by an equivalent means.
 - 2) An output voltage that:
 - has a sinusoidal waveform,
 - has a frequency that is within the range of 40 Hz – 70 Hz, and

- has a peak value of the waveform that is not to be less than 1,3 and not more than 1,5 times the r.m.s. value, or is a d.c. output.
- 3) A means of effectively indicating unacceptable performance. The indication is to be:
- auditory if it can be readily heard above the background noise level;
 - visual if it commands the attention of the OPERATOR; or
 - a device that automatically rejects an unacceptable product.
- If the indication of unacceptable performance is auditory or visual, the indication is to remain active and conspicuous until the test equipment is reset manually.
- 4) When the test equipment is adjusted to produce the test voltage and a resistance of 120 k Ω is connected across the output, the test equipment is to indicate an unacceptable performance within 0,5 s. A resistance of more than 120 k Ω may be used to produce an indication of unacceptable performance, if the MANUFACTURER elects to use a tester having higher sensitivity.
- h) There is not to be any transient voltage applied to the appliance under test that results in the instantaneous voltage applied to the product exceeding 120 % of the peak value of the test voltage that the MANUFACTURER elects to use for this test. This requirement applies for the entire duration of the test, including the time that the voltage is first applied to the product and the time that the voltage is removed from the product.
- i) During the test, a sufficient number of primary switching components should be in the on position so that all primary circuitry will be stressed. Both sides of the primary circuit of the appliance are to be connected to one terminal of the test equipment. The second equipment terminal is to be connected to accessible dead metal.

K.2 Production-line grounding-continuity test

- a) Each ME EQUIPMENT that has provision for grounding by FIXED wiring means or has a power-supply cord having a grounding conductor should be tested, as a routine production-line test, to determine grounding continuity is provided between the point of connection of the equipment grounding means (grounding blade of the attachment plug in the case of a PORTABLE appliance) and the accessible dead metal parts of the appliance that are likely to become energized.
- Exception: This test need not be conducted on appliances intended for permanent connection by FIXED wiring means if the construction does not employ bonding jumpers or grounding wiring to remote units.
- b) Only a single test need be made if the accessible metal selected is conductively connected to all other accessible metal.
- c) Any indicating device (e.g. ohmmeter) may be used to determine compliance with the grounding continuity requirement. See also IEC 61557-4.
- d) To evaluate the integrity of the earth connection, during the test the ground wire should be flexed along its length. If during the flexing, changes in continuity indication are observed, it should be assumed that the ground connection is damaged.

K.3 Production-line EARTH LEAKAGE CURRENT test

Measure EARTH LEAKAGE CURRENT in series with CLASS I ground pin or terminal.

K.4 Recommended features for specific test equipment

K.4.1 Hipot test equipment

The hipot test equipment should be provided with the following features.

- The ability to detect minimum current in a hipot test guards against a false positive indication when the ground circuit is open. Without this feature, a ground fault might be missed by the tester, causing unsafe product to be released for shipment to customers.
- To avoid damage to components in a DUT, the HIGH VOLTAGE output of the tester should be increased smoothly over the test range rather as an abrupt step change. A quality tester should provide this feature without introducing spikes or distortion in the a.c. waveform. The tester should provide easily programmable ramp and hold times for each test step.
- When a DUT fails a test, the tester should automatically save the test result and interrupt the test immediately to avoid potential damage to the DUT.
- In production environments, the ability to subtract LEAKAGE CURRENT due to test leads and test fixtures automatically from the instrument reading (automatic offset) can be a great convenience.
- Arc detection is an anticipatory tool that can be used to detect an impending fault before it occurs. The testers provide this feature by detecting the presence of high frequency transients in the current waveform. If such variations exceed a specified level and persist for more than 10 μ s, the tester should instantly alarm and interrupt the test. The DUT can then be examined off-line to find and correct the cause of the problem (rather than being scrapped after a failure occurs).

The ACCESSORIES typically needed for a hipot test are

- HIGH-VOLTAGE probes;
- HIGH-VOLTAGE probe guns (trigger operated);
- HIGH-VOLTAGE lead sets with various lengths of cable;
- corded product adapter fixture (to accept 2-prong or 3-prong line cords);
- foot switch to start/stop tests.

K.4.2 120 k Ω leakage impedance

A 120 k Ω resistance is specified to check operation of a hipot tester. This requirement is based on a maximum current flow of 10 mA when a voltage of 1 250 V is applied between the circuit of a DUT and ground. Using Ohm's Law, a voltage of 1 250 V divided by a current of 10 mA gives a resistance of 125 k Ω .

To verify that a given hipot tester meets this standard for leakage impedance, the user sets the output voltage to the desired value and then connects a 120 k Ω resistor across the output terminals. To be accepted, the tester should indicate a fault within 0,5 s. If it does not, the tester is not acceptable. The 120 k Ω value is the minimum value at which the tester should indicate a fault. It is common for most ME EQUIPMENT MANUFACTURERS to test their products with higher values of resistance, providing an extra margin of safety rather than testing right at the specified limit.

WARNING: Proper precautions and care must be exercised during the trip level VERIFICATION. A protective means must be used to connect the 120 k Ω resistor to the hipot output.

• Ground bond test equipment

Four-terminal Kelvin connections ensure maximum accuracy by preventing errors caused by measurement lead resistance. This feature is typically used to ensure accuracy of a ground bond test.

The tester ACCESSORIES typically needed for a ground continuity test are

- ground continuity lead set;
- power entry adapter cable for ground continuity tests.

K.4.3 LEAKAGE CURRENT test equipment

The measurement equipment for the direct measurement is to

- measure the current as true r.m.s., and
- guarantee that during the measurement, protection against electric shock is effective by suitable means from IEC 61010-1.

Annex L (informative)

Evaluation of the laboratory power source characteristics

(based on IEC 60320- CTL OP 110)

L.1 Purpose

L.1.1 The purpose of this annex is to establish a **PROCEDURE** for measuring laboratory power source characteristics.

L.1.2 The results of many tests on electrical products tested in accordance with product safety testing standards depends of the characteristics of electrical power source used to power the product under test. Some examples of how power source characteristics can affect test results are:

- a) Temperatures on electrical heat generating parts are affected by the voltage applied. In most cases an increase in voltage causes an increase in temperature. While, for some products, a decrease in voltage also results in an increase in temperature.
- b) The frequency of the power source can also affect temperatures on electrical heat-generating parts such as motors, transformers and solenoids.
- c) The harmonic distortion of a power source not only affects temperature of electrical heat-generating parts such as motors, transformers and solenoids, but also affects **LEAKAGE CURRENTS** for the product.

L.1.3 Accordingly, testing standards specify the voltage, frequency and wave shape of the power source to be used – for example 230 V, 50 Hz, sinusoidal power source. These specifications in the standard are made with the understanding that the specified characteristics are maintained as stated throughout the testing done. In the real world, however, a power source that meets these ideal specifications is not possible. Some standards recognize this and include tolerances for the power source specifications. While, other standards do not. This annex recommends default power source stability requirements to be followed when the test standard does not contain tolerances for the power source to be used. These power source stability requirements define the characteristics of real world power sources that can be used in the testing laboratory, so that laboratories can obtain consistent, uniform and repeatable results.

L.2 Application

L.2.1 The **PROCEDURE** described in this annex applies to measurement of laboratory power source voltage, frequency stability and total harmonic distortion (THD).

L.2.2 This guide applies to the following situations:

- testing is performed within the maximum **RATED** current/load capacity of the power source;
- normal operating conditions of the tested product.

L.2.3 The requirements apply to the stability of laboratory power sources only. The requirements do not address short circuit current testing, abnormal testing, switching testing and the like that relate to source capacity.

L.2.4 The power source stability requirements apply to the testing of products that are connected to ordinary branch circuits found in residences and businesses – for example 120 V, 15 and 20 A; 240 V, 15 A circuits in North America and 230 V, 10 and 15 A branch circuits in Europe.

L.3 Definitions

L.3.1 Definitions unique to this annex

- a) Automatic adjustment (power source) – Regulation of power source by electronic, electrical or mechanical means that automatically maintains the voltage and/or frequency at a prescribed value.
- b) Manual adjustment (power source) – Regulation of power source by manual adjustment of an autotransformer, tapped transformer with selector switch or similar means to maintain the voltage and/or frequency at a prescribed value.
- c) Robust power source – Power source of sufficient capacity to meet the power source stability requirements without the need for further regulation or adjustment.

L.3.2 Acronyms unique to this annex

- a) Maximum open circuit voltage, $V_{oc, max}$
- b) Minimum open circuit voltage, $V_{oc, min}$
- c) Maximum voltage loaded, $V_{ld, max}$
- d) Minimum voltage loaded, $V_{ld, min}$
- e) Current loaded, I_{ld}
- f) Voltage NOMINAL, V_{nom} = specified test voltage (e.g. 120 V, 230 V, 240 V)
- g) Maximum frequency open circuit, $F_{oc, max}$
- h) Minimum frequency open circuit, $F_{oc, min}$
- i) Maximum frequency loaded, $F_{ld, max}$
- j) Minimum frequency loaded, $F_{ld, min}$
- k) Maximum harmonic distortion open circuit, THD_{oc}
- l) Maximum harmonic distortion loaded, THD_{ld}

L.3.3 Equations unique to this annex

- a) Voltage regulation open circuit: $Reg_{V_{oc}} = [MAX(V_{oc, max} - V_{nom}; V_{nom} - V_{oc, min})/V_{nom}] \times 100 \%$
- b) Voltage regulation loaded: $Reg_{V_{ld}} = [MAX(V_{ld, max} - V_{nom}; V_{nom} - V_{ld, min})/V_{nom}] \times 100 \%$
- c) Frequency regulation open circuit: $Reg_{F_{oc}} = [MAX(F_{oc, max} - F_{nom}; F_{nom} - F_{oc, min})/F_{nom}] \times 100 \%$
- d) Frequency regulation loaded: $Reg_{F_{ld}} = [MAX(F_{ld, max} - F_{nom}; F_{nom} - F_{ld, min})/F_{nom}] \times 100 \%$
- e) Total harmonic distortion: $THD = SQRT(\text{sum of all squares of amplitude of all harmonic voltages/square of the amplitude of the fundamental voltage}) \times 100 \%$

NOTE Function MAX(value 1; value 2) returns the maximum of value 1 and value 2.

EXAMPLE In the calculation $MAX(V_{max} - V_{nom}; V_{nom} - V_{min})$ use the maximum value of either upper ($V_{max} - V_{nom}$) or the lower ($V_{nom} - V_{min}$).

L.4 Testing

Table L.1 – Method for testing a single phase laboratory power source

<p>a) Equipment needed for the test:</p> <ol style="list-style-type: none"> 1) Voltmeter 2) Ammeter 3) Frequency meter 4) Total harmonic distortion analyzer 5) Resistive loads
<p>b) Requirements:</p> <ol style="list-style-type: none"> 1) When not otherwise specified in the testing standard, use a power source that meets the following requirements: <ol style="list-style-type: none"> a) Voltage stability: $\pm 3\%$ maximum b) Frequency stability: $\pm 2\%$ maximum c) Total harmonic distortion (THD): 5 % maximum 2) Conditions are to be maintained at the point of testing. 3) Voltage regulation may be achieved by: <ol style="list-style-type: none"> a) Robust source – acceptable for all situations. b) Automatic adjustment – Acceptable for all normal operating conditions. May be used for abnormal conditions if regulator is sufficiently robust and fast-acting to handle demands under fault conditions. c) Manual adjustment –such as auto-transformer in conjunction with periodic voltage monitoring (for example every 15 minutes minimum) if load is constant. Cannot be used for fluctuating loads and abnormal tests.
<p>c) PROCEDURE:</p> <ol style="list-style-type: none"> 1) Method for single phase power source <ol style="list-style-type: none"> a) Measure the characteristics of electrical power sources representing electrical mains connections used in the testing laboratory at the point where tests are performed. Typically, this point is a test station receptacle or wiring terminals where the test setup is connected. b) Measure the power source voltage, frequency and harmonic distortion. c) While it is expected that the power source meet the required specifications throughout the duration of any testing performed, measurement of power source characteristics is normally made over a one-hour period in each of the open circuit and loaded conditions, unless there is reason to believe that measurements made over a longer period are necessary to establish conformance with the intent of the requirements. d) Initially measure the open-circuit voltage, frequency (50 or 60 Hz) and harmonic distortion of the power source over a period of one hour. The voltage shall be adjusted to one of the NOMINAL voltages used for testing, for example 120 V, 230 V, 240 V or 400 V. e) Afterwards, load the power source to the RATED maximum normal resistive load (continuous duty) for a period of one hour without readjustment of the power and measure the voltage, frequency and harmonic distortion. The power source shall comply with the requirements throughout the duration of the test.

Table L.1 (continued)

d) Presentation of the test results:

- 1) Records:
 - a) Records should be made and retained of measurements made, calculated values, location of measurements and conditions of measurements. Form 1 contains a suggested format for recording the data.
 - b) Records of the power distribution system should include wiring diagrams, identification of voltages, frequencies, number of phases, capacities, fuse/circuit breaker ratings and regulation equipment.
- 2) Values to be recorded/calculated:
 - a) Maximum open circuit voltage, $V_{oc, max}$
 - b) Minimum open circuit voltage, $V_{oc, min}$
 - c) Maximum voltage loaded, $V_{ld, max}$
 - d) Minimum voltage loaded, $V_{ld, min}$
 - e) Current loaded, $I_{ld, max}$
 - f) Voltage NOMINAL, $V_{nom} =$ specified test voltage (e.g. 120 V, 230 V, 240 V)
 - g) Maximum frequency open circuit, $F_{oc, max}$
 - h) Minimum frequency open circuit, $F_{oc, min}$
 - i) Maximum frequency loaded, $F_{ld, max}$
 - j) Minimum frequency loaded, $F_{ld, min}$
 - k) Maximum harmonic distortion open circuit, THD_{oc}
 - l) Maximum harmonic distortion loaded, THD_{ld}

Form 1

Power Source Stability Test:

Method

Power source stability characteristics were measured in accordance with IEC 60384-14:2010 CTL-OP 110.

Results

Location and characteristics:

Measured Quantity	Value
Voltage NOMINAL, $V_{nom} =$	
Maximum open circuit voltage, $V_{oc, max} =$	
Minimum open circuit voltage, $V_{oc, min} =$	
Current loaded, $I_{ld, max} =$	
Maximum voltage loaded, $V_{ld, max} =$	
Minimum voltage loaded, $V_{ld, min} =$	
Maximum frequency open circuit, $F_{oc, max} =$	
Minimum frequency open circuit, $F_{oc, min} =$	
Maximum frequency loaded, $F_{ld, max} =$	
Minimum frequency loaded, $F_{ld, min} =$	
Maximum harmonic distortion open circuit, $THD_{oc} =$	
Maximum harmonic distortion loaded, $THD_{ld} =$	
$Reg V_{oc} = [MAX(V_{oc, max} - V_{nom}; V_{nom} - V_{oc, min})/V_{nom}] \times 100 \% =$	
$Reg V_{ld} = [MAX(V_{ld, max} - V_{nom}; V_{nom} - V_{ld, min})/V_{nom}] \times 100 \% =$	
$Reg F_{oc} = [MAX(F_{oc, max} - F_{nom}; F_{nom} - F_{oc, min})/F_{nom}] \times 100 \% =$	
$Reg F_{ld} = [MAX(F_{ld, max} - F_{nom}; F_{nom} - F_{ld, min})/F_{nom}] \times 100 \% =$	

Test Equipment Used

Name	Manufacturer	Model	Range	Last Calibration	Next Calibration
Voltmeter					
Ammeter					
Frequency meter					
THD Analyzer					
Load				N/A	N/A

Date: _____

Tested by _____
 Name/Signature

Annex M (informative)

Traceability of calibrations and calibration intervals

(based on IEC 60730-1:2014, IEC 60730-2:2014)

M.1 Purpose

The purpose of this annex is to establish uniform requirements for traceability of calibrations and calibration intervals to ensure consistent and repeatable test results.

M.2 Traceability of calibrations

M.2.1 Calibrations should be regarded as being traceable if the calibrations are done by following the requirements of ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*, and by one of the following:

- a) The instrument was calibrated by a National Metrology Institute. An external calibration laboratory that is not accredited should only be used in the event that an accredited calibration laboratory is not available or practical to use.
- b) The instrument was calibrated by an ISO/IEC 17025 accredited calibration laboratory.
- c) The instrument was calibrated by an internal or external calibration laboratory assessed on an annual basis, by the Testing Laboratory, and found to comply with the requirements of ISO/IEC 17025. The assessments should be conducted by a qualified ISO/IEC 17025 assessor or metrologist.

Exception to a), b) and c) – For specialized instruments where no accredited calibration laboratory is available, the instrument may be calibrated by the instrument manufacturer provided that the calibration standards used are traceable to national or international units of measure, the traceability chain is identified and an estimation of uncertainty of measurement is included on the calibration certificate.

M.2.2 Calibrations should be made by an unbroken chain of comparisons to:

- a) Units of measure of the International System of Units (SI).
- b) Fundamental physical constants.
- c) Certified reference materials, in the event that (A) and (B) do not exist for the measurement property.

M.3 Calibration intervals for test equipment requiring calibration

M.3.1 All test equipment requiring calibration should undergo an initial calibration before being put into service. Thereafter, the maximum NOMINAL calibration interval should be:

- a) One year for electrical, electronic and mechanical test equipment.
- b) Three years for mechanical test equipment made of solid materials not subject to deterioration.
- c) As recommended by the manufacturer of the instrument.
- d) Test equipment that is "fail safe", in that failure would be evident to a user (with laboratory procedures requiring the user to check the equipment before use), may be put on the status of "initial calibration only (ICO)". Examples of the equipment that can be placed on ICO status are: steel rules, tape measures, weights 4,5 kg or more calibrated to $\pm 1\%$ tolerance, single piece steel probes greater than or equal to 3 mm diameter with blunt ends, graduate cylinder, thermometers, steel impact balls, steel or plastic probes with no moving parts and sufficient structural integrity so as to not deform.

M.3.2 Weights do not need to be calibrated if verified with a calibrated scale before each use. The VERIFICATION must be documented.

M.3.3 Test equipment that is delicate, subject to frequent usage or severe use conditions should be assigned shortened calibration intervals (e.g. 6 months, 3 months, weekly, before each use).

M.3.4 Infrequently used test equipment may be assigned the status of "calibrate before use" instead of a periodic calibration.

M.3.5 Calibration intervals may be extended based on the following if the reasons are documented:

- a) Passive electrical test equipment, such as current shunts, current transformers, potential transformers, may be extended to 3 years with good results for the initial calibration period and if not subject to severe use conditions.
- b) Weights may be extended to 5 years if there is a laboratory procedure that takes into account usage and has provision for physical examination and/or intermediate checks of the weights.
- c) Where there is sufficient calibration data to statistically establish a trend or based on experience of use of the test equipment to assure good measurement results for a longer period.

Annex N (informative)

Guidance for preparation, attachment, extension, use of thermocouples and acceptance of thermocouple wire

(based on IEC 60584-1:2003, IEC 60584-2:2003 and IEC 60584-3:2003)

N.1 General

This guidance establishes PROCEDURES for preparation, attachment, extension, use of thermocouples for temperature measurement and for acceptance of thermocouple wire.

This guidance applies to thermocouples for temperature measurement used for testing of electrical and similar products. This guidance describes recommended practices shown by experience to be useful. This guidance does not prohibit use of other practices that may also be valid and useful.

N.2 Preparation


N.2.1 Thermocouples should be prepared by staff trained in preparation of thermocouples.

N.2.2 Thermocouples are to be prepared as noted (see Figure N.1):

N.2.2.1 Inner insulation stripped back approximately 1,5 mm from tip.

N.2.2.2 Outer insulation, if any, stripped back approximately 15 mm from tip.

Dimensions in millimetres



IEC

NOTE Dimensions given are typical, not required.

Figure N.1 – Thermocouple preparation

The tip is to be joined by a single point weld. Other reliable and consistent methods of joining the thermocouple wires may be used.

N.3 Placement

Place the measuring thermocouple junction where the temperature is to be measured. The element must reach the same temperature as the part in question. Be cautious of possible electrical shock HAZARD and stress on the measuring equipment, if the thermocouple is

connected to live parts of if thermocouples are connected to parts of different polarity. It may be appropriate to place additional electrical insulating sleeving over the conductors (not the thermocouple junction).

N.4 Attachment

N.4.1 The thermocouple junction should be applied to be in intimate contact with the surface of the part to be measured in order to reach the same temperature as the part being measured. The thermocouple junction should be in good thermal contact with the part being measured. The method of attachment should be done in a way to have a minimal affect upon the temperatures measured.

N.4.2 Leads should be located in the same temperature environment as the bead itself.

N.4.2.1 Heat will be conducted along the thermocouple wire. Where the thermocouple junction is at a different temperature than the immediately adjacent leads, heat flow will take place for the leads to the junction or from the junction to the leads, and the best temperature measurement of the surface in contact with the junction will not be made.

N.4.2.2 This problem is minimized by thin leads. Generally, 0,320 mm (28 AWG) or 0,254 mm (30 AWG) thermocouples should be used.

N.4.3 Securing of thermocouples (see Figure N.2) – Several methods of securing thermocouples are tying, cementing, adhesive, peening, welding and soldering:


N.4.3.1 Tying – Tying with thread is used primarily for round items such as wire insulation.

N.4.3.2 Cement – Two examples are Kaolin powder mixed with sodium silicate solution in approximately equal proportions by volume and Cyanoacrylate adhesive (e.g. Henkel Sicomet). Cement is used to:

- Secure the thermocouple to the surface whose temperature is being measured.
- Provide a better thermal bond than would be obtained by a point contact of the junction with the surface.
- Reduce the surface area of the junction and leads exposed to air at a temperature different from that being measured.

N.4.3.3 The thermocouple should be secured in position prior to application of the cement.

N.4.3.4 In order to prevent loosening of the junction and separation of the cement, the cement should be allowed to thoroughly set before reassembling the unit under test.




IEC

Figure N.2 – Securing of thermocouples

N.4.3.5 Soldering is useful for attaching thermocouples to copper or other metal surfaces to which solder will adhere. The advantage of using solder is better thermal conductivity and greater mechanical security for the junction will be obtained than with cement.

N.4.3.6 It should be noted that the temperature would be sensed primarily at the point furthest from the junction where the solder bridges the thermocouple leads. Cold solder joints and excessive solder should be avoided.

N.4.3.7 Confinement (see Figure N.3) – Thermocouples can often be confined between layers of material or between metal and insulating materials and held in good thermal contact by pressure on the two surfaces.



IEC

Figure N.3 – Example of confinement of a thermocouple

N.4.3.8 Care should be exercised to see that a confined thermocouple or its junction does not cause a separation between normally mating surfaces, which would change the temperature distribution at the point being measured.

N.4.3.9 A groove or hole may be placed in one of the materials to accept the thermocouple and its leads to preclude the above condition.

N.4.3.10 A thermocouple should ordinarily be kept slightly recessed beneath the surface, to be certain that the temperature being measured is not that of the adjacent surface material.

N.4.3.11 Peening – The thermocouple junction may be placed in a cavity and the metal peened over.

N.4.3.12 Tape – Pressure sensitive tape conveniently holds thermocouple leads in place.

- Use as little tape as possible consistent with good mechanical securement of the thermocouple.
- Glass tape with thermosetting adhesive is useful for high temperature applications.
- Tape can be used to provide strain relief for the thermocouple.
- The tape should be located remote from the junction.

N.5 Extension

N.5.1 Connection – Where practical thermocouples should be connected directly to the temperature measuring instrument. Where it is not practical to connect thermocouples directly

to the instrument, thermocouple extension wires and connectors of the type for the thermocouples used should be employed.

N.5.2 Exception – Thermocouple connectors need not be used in the limited situation where the thermoelectric affects of the junctions made are nullified such as shown in Figure N.4 for feed through connectors. Thermocouple wires TC#1 and TC#2 are the same type. Connections are made to the same type of conductors (e.g. copper alloy). The temperatures T_1 and T_2 at the connections are the same.




Figure N.4 – Example where thermocouple connectors need not be used

N.5.3 The temperatures of the two reference (cold) junctions mentioned in the exceptions must be the same as each other and the same as the temperature measuring instrument. The junctions and instrument must be protected (shielded) from heat and cold air flows, sunshine, heat emission from the test sample, lamps, soldering irons, etc., which could result in a change in the temperature of the reference junctions.

N.6 Use

N.6.1 The type of thermocouples utilized should be used within the manufactured specification operating parameters for that type of thermocouple (e.g. temperature operating range).

N.6.2 Typically, Types J, K and T tolerance class 1 thermocouples are used for testing.

N.7 Acceptance of thermocouples wire

N.7.1 When ordering thermocouple wire, the thermocouple class or special limits requirements need to be specified when placing the purchase order.

N.7.2 The supplier of the wire should be required to provide a certificate of compliance with the specification. The certificate of compliance should include the results of the pre-shipment testing used to establish conformance. As a minimum, the testing should include one thermocouple made from the beginning of the reel of thermocouple wire and one made from the end of the reel.

N.7.3 Alternative 1 – the laboratory may perform testing on incoming thermocouple wire shipments.

N.7.4 Alternative 2 – the laboratory may perform testing on individual thermocouples.

N.7.5 Compliance should be based on measurements traceable to the International System of Units (SI) or National Institution of Technology (NIST) for USA.

N.7.6 Certificates of compliance and results of testing should be retained as part of the laboratory records.

Annex O (informative)

Guideline for safe laboratory work

O.1 BASIC SAFETY guidelines for working with test instruments

Some BASIC SAFETY guidelines for working with test instruments are outlined below:

- Read all safety and operating instructions before operating the instruments.
- Retain all safety and operating instructions for future reference.
- Adhere to all warnings on the instruments and in the operating instructions.
- Follow all operating and use instructions.
- Do not use the instruments near water and/or heat sources.
- Use the instruments only with a cart or stand that is recommended by or included as a part of the testing system by the manufacturer.
- Mount the instruments on a wall or ceiling only if is recommended by the manufacturer
- The instruments should be situated so that its location or position does not interfere with its proper ventilation. Do not install in a cabinet or other situation that may impede the flow of air through the ventilation openings.
- Connect the instruments only to the type of power source described in the operating instructions or as marked on the instruments.
- Take precautions to ensure that the grounding means of the instruments is not defeated.
- Position POWER SUPPLY CORDS so that they are not likely to be walked on or pinched by items placed upon or against them. Pay attention to cords at plugs, convenience receptacles, and the point where they enter and exit the instruments.
- Clean the instruments only as recommended by the manufacturer.
- Unplug the power cord of the instruments from the outlet when it will be left unused for a long time.
- Take care that objects do not fall and liquids are not spilled into the ENCLOSURE through openings.
- Do not operate instruments that have been dropped, or the ENCLOSURE has been damaged.
- Whenever it is likely that the normal operation of the equipment has been impaired, remove and separate it to prevent future operation. Have it properly repaired and recalibrated or replaced as appropriate. Normal operation is likely to be impaired if, for example, the instruments:
 - fails to perform the intended functions;
 - have visible damage;
 - has been subjected to prolonged storage under unfavorable conditions; or
 - has been subjected to severe transport stress.
- The instruments should be serviced only by qualified service personnel.
- All leads and cables which can be energised at dangerous voltages should be robustly insulated and properly terminated. All connections of conductors which can be energised at dangerous voltage should be electrically and mechanically robust to prevent conductors becoming accidentally exposed.
- Test equipment connecting leads, probes and connectors should be sufficiently protected to prevent accidental contact when being applied to and removed from live parts.
- Where practicable, place the equipment under test into interlocked ENCLOSURES. This allows connections to be made while the equipment is isolated.

- Where practicable, apply test leads while the equipment is isolated and then energize it. To make sure that the equipment is isolated, use a suitable isolating device that is:
 - appropriate and convenient for the INTENDED USE;
 - suitably located;
 - readily identifiable (e.g. by durable marking) as to which circuits or part of the test area is served;
 - provided with adequate means to prevent the supply isolator being switched on (either inadvertently, mistakenly, or by an unauthorised person).
- Where applicable, test equipment should be manufactured to IEC 61010.
- Mains powered equipment must be safe in its own right. The arrangements for connecting it to the DUT must also be safe.
- Insulation test instruments can generate HIGH VOLTAGES at their output and some have an option to limit the output current to a safe level (the generally accepted safe limited current is 3 mA).
- If accidental contact with the output conductors occurs, the RISK of injury will be minimized if these current levels are not exceeded.
- If higher current levels are necessary, use test probes fitted with control switches, or use interlocked ENCLOSURES to prevent access to the dangerous parts.
- The connecting leads of test equipment must provide adequate protection from electric shock.
- The tips of the HIGH VOLTAGE probes should be covered by retractable insulated sleeving.
- The test voltage may be applied by a switch built into the probe's insulated handles.
- It may be necessary to discharge safely any stored energy which may remain in the equipment after the test has been carried out before allowing any further contact with the equipment.
- Each item of equipment under test should be provided with its own test supply. These supplies should be from designated sockets or terminals provided with covers interlocked with the supply isolator. The supplies should have suitable system protection against overload and overcurrent in the event of faults, eg fuses.
- A separate isolating transformer should be used at every test bench. If this is not reasonably practicable, the same isolating transformer may be used for supplies to alternate benches, provided the RISK of referencing this supply to earth at any bench is properly controlled and the transformer does not then have an unacceptably high LEAKAGE CURRENT.
- The supply from the isolating transformer should be provided from a single socket outlet and clearly marked 'only for use for making live equipment under test'. The earth terminal of the socket outlet should be connected to a floating secondary of the isolating transformer (unearthed) such that an artificial ground (common) connection is made. The face plate of the socket should be made of insulating material. The DUT must be no unnecessarily exposed live parts.
- If isolation transformers are used to supply power to FIXED socket outlets as part of a distribution system for test supplies, the sockets should be of a different type to standard sockets, or of the polarized type, to ensure they are only used for the purpose intended.
- Recommend connecting oscilloscope(s), digital multimeter(s) and equivalent test equipment that are earth grounded, through isolation transformers with floating (unearthed) ground (common).

CAUTION: Connecting test equipment in this manner removes any protection against internal breakdown to the chassis. The test equipments internal insulation could become over-stressed when HIGH VOLTAGE measurements are being taken.

Consider locating such equipment within an insulated ENCLOSURE removing the possibility of touch during use.

- Don't try to fix electrical equipment if you don't thoroughly understand how it was supposed to work before it malfunctioned and if you don't know what voltage levels should and might be present.
- Never try to fix anything electrical when you are alone, even if you are familiar with what you are doing.
- Don't stretch electrical cords across aisles or doorways even in an "EMERGENCY".
- Don't use extension cords as a substitute for wiring additions or changes.
- THINK—before you act. Never work alone when conducting tests where lethal voltages are present.
- Don't try to go it alone. If you are unsure that something is correct or safe and you do not feel you can resolve it yourself—GET HELP.

O.2 Basic guidelines for performing safety tests

Some basic guidelines for performing safety tests are outlined below:

- Do not make any connections to a DUT unless you have verified that HIGH VOLTAGE is OFF.
- Never touch a DUT or its connections during a test.
- When connecting leads to the DUT, always connect the ground clip first.
- Never touch the metal of a HIGH VOLTAGE probe directly. Only touch the insulated parts.
- Use interlocked test fixtures only for all HIGH VOLTAGE hazardous tests.
- Verify all DUT connections before starting a test. Make sure that no other objects are near the DUT or the tester.
- When the DUT is CLASS I, any pre-existing BASIC INSULATION (MOOP) fault must be corrected before energizing the equipment through an isolating transformer. Failure to do so could cause a hazardous electrical shock in the event of simultaneous contact between the DUT ENCLOSURE and one of the poles of the isolated power source.
- The integrity of the PROTECTIVE EARTH CONDUCTOR of all PORTABLE/TRANSPORTABLE CLASS I DUTs must be evaluated after all testing has been completed to ensure that no earth faults are present before the equipment is used on a normal SUPPLY MAINS.
- Keep the area neat and uncluttered and avoid crossing test leads.
- Follow the prescribed PROCEDURE for each test exactly as written.
- Verify all setup conditions before starting a test and examine all leads for signs of wear.
- When performing a d.c. test, provide means to discharge any connection or device that may become disconnected during a test. This is necessary because unexpected, dangerous charges can build up during a test if a connection comes loose.
- On completion of a test, turn off the HIGH VOLTAGE. If the test was d.c., discharge the DUT for the prescribed time.
- Protective gloves and face shields should be used when handling samples which present a chemical HAZARD (i.e. polychlorinated biphenyl-PCB- in transformers and capacitors; beryllium oxide and selenium in semiconductors; free bromine, etc.)
- Do not use asbestos or part containing asbestos.
- Use proper protective wear such as breathing apparatus, face guards, eye wear, gloves, protective clothing where appropriate.
- Ensure that NO ONE touches the DUT immediately after the test until mains power to the DUT has been turned off.
- Check the conductivity of painted surfaces before use, for example, in black painted test corners, where there is the likelihood of live wires or thermocouples coming into contact with paint.

- Do not use carbon-tetrachloride for removing grease (it is toxic). Use a less harmful liquid, i.e. trichlorethane.
- The smell of ozone is a warning that precautions should be taken. Avoid staying in rooms where ozone is present for long periods. Testing of equipment producing ozone should be carried out in large and well ventilated rooms.
- When cutting cables with glass fibres, use personal protective gear (breathing apparatus, face guards, eye wear, gloves, protective clothing). For that matter, personal protective gear should be worn when doing any cutting, sawing, drilling, machining, etc.
- When conducting tests during simulated fault conditions (short circuits, open circuits) of components or insulation, protective wear and appropriate guards are necessary.
- Use protective shields if tests under simulated fault conditions can cause component explosion or cracking
- When introducing faults inside the equipment, use an isolating transformer that is toroidally wound to reduce additional mains impedance etc. The transformer must be somewhat "overdimensioned" as a rule.
- Do not try to charge any primary (nonrechargeable) cell or batteries.
- Do not crush, puncture, open, dismantle or otherwise mechanically interfere with or abuse cells or batteries.
- Do not store cells or batteries at temperatures above+ 60 °C.
- Do not short circuit cells or batteries unless under controlled test conditions and in an explosion-proof environment.
- Protect cell or battery terminations whenever they are not connected to a circuit.
- Unless cells or batteries are suitably insulated, they should not be:
 - carried in pockets with keys, coins or other metal objects;
 - put in metal drawers, filing cabinets etc;
 - mixed with other batteries; or
 - exposed to any other situation that may lead to a short circuit.
- Do not "flow solder" without the cell or battery manufacturer's permission.
- Do not connect cells to form a battery except where the arrangement has been approved by the cell manufacturer.
- Do not dispose of cells or batteries by burning;
- Do not encapsulate cells or batteries without approval of the cell or battery manufacturer.
- Do not replace ordinary primary or rechargeable cells or batteries with similar lithium cells or batteries of a different voltage.
- Do not install lithium cells or batteries next to a source of heat.
- Remove the battery if testing without the battery is possible.
- Do not remove the battery when the DUT is connected to the SUPPLY MAINS or when the SUPPLY MAINS has recently been disconnected! Wear a face shield or eye wear and a protective guard! Avoid the possibility of incorrect connections.
- If battery remains in the DUT during normal testing, do not work with the battery with the face unprotected!
- When conducting abnormal condition tests, where there is a RISK of the battery overheating, out gazing, leaking or exploding, because of over charging, fast charging, fast discharging or reverse charging or discharging, perform the test in a room void of staff and fitted with proper guards.
- If there is a fire, use a graphite-based, dry powder extinguisher or a suitable extinguisher designed for alkali metal fire, or drench with a fine spray of water.
- Avoid inhalation of fumes. Stay out of the contaminated area.

- Where there is RISK from simultaneous contact with hazardous conductors, do not assume that employees will be able to avoid accidental contact. Consider using temporary insulation which may be in the form of purpose-made screens or insulating sheets or shrouding (rigid or flexible). However, there may be a practical limit on the use of screens when testing compact electronic assemblies.

O.3 Basic guidelines regarding test personnel and test areas

Some basic guidelines regarding test personnel and test areas are outlined below:

- All test personnel must:
 - understand that the RISK of electric shock injury will still remain during the testing process, even with the use of earth-free test areas and/or isolating transformers;
 - fully understand the scenarios in which these electric shock injury RISKS can arise in the particular workplace(s);
 - be given adequate first-aid training, including cardiac pulmonary resuscitation (CPR) skills;
 - be trained on the safety PROCEDURES to be used in emergency situations;
 - be given training in the basic theory of electrical circuits—voltage, current, resistance, a.c. vs. d.c., Ohm's Law, and impedance;
 - fully understand importance of safety interlocks;
 - fully understand the HAZARDS of wearing metallic jewellery around electrical equipment and show how to interrupt power quickly in emergency situations;
 - hold regular meetings to review and update safety PROCEDURES and regulations;
 - be trained in the specific test PROCEDURES, using actual test setups wherever possible;
 - fully understand the object of each test, how it should be executed, and how to handle every normal and off-normal situation that may occur;
 - understands how much he or she can handle alone and when supervisory personnel should be called in for help;
- The test areas must:
 - be under the control of a responsible person;
 - be in an area set apart by barriers to prevent entry;
 - have suitable warnings provided at the entrance;
 - be accessible during testing only to authorized staff or people working under their direct supervision;
 - have suitable warning lights indicating that testing is in progress and other warning lights to indicate when it is safe to enter the area (duplicate red and green lights are often used);
 - have emergency-stop push buttons or equally effective means to cut all test supplies in the event of emergency;
 - have emergency controls prominently identified (NB: The emergency controls should not remove supplies to the general lighting in the area.);
 - display an electric shock poster, eg Electric shock: First-aid PROCEDURES at prominent locations, showing emergency arrangements, especially telephone numbers;
 - have good housekeeping arrangements, including adequate clear working space;
 - use a test bench made of insulating material with shrouded legs and framework to prevent the possibility of contact with earth while testing;

- have removed all pipes, radiators, structural steelwork, metal conduits, earthed electrical appliances, metallic socket outlets etc from within reach of the test bench, or permanently shroud them with insulating material to prevent contact;
- use soldering irons and task lighting to extra low voltage, supplied from an isolating transformer;
- have insulating rubber matting provided on the floor, kept clean and dry, and regularly tested, and large enough for the test operator to remain on it whether standing or seated during testing (NB: Chair legs may damage the matting.);
- when appropriate, use electrostatic discharge wrist straps incorporate with a suitable resistance (say 1 M Ω or more). The use of a wrist strap which directly connects the wearer to earth is not permissible;
- have guards or enclosures around a DUT made of nonconductive material and equipped with safety interlocks that interrupt all HIGH VOLTAGES when open;
- have arranged the interlocks so that test operators are never exposed to HIGH VOLTAGES under any conditions;
- have arranged the power line connections so that, except for emergency lighting, all power is interrupted by a single, well-marked, palm operated emergency switch located at the outside edge of the test area;
- be kept clean and neat and arranged the equipment so that it easy and safe for the operator to use.

O.4 Contents of a documented safe environment for working in a testing laboratory

The contents of a documented safe environment for working in a testing laboratory should minimally include:

- Who is authorised to undertake testing. Where appropriate, the proper method to access and utilize a test area. Who is not authorized to access the test area.
- Where temporary test areas are constructed, how this is to be done.
- Rules for isolating equipment and how the isolation is secured.
- The correct use of additional protection measures, for example flexible insulation, that have to be applied to the equipment under test while its covers are removed. If it is considered necessary to apply the insulation and remove covers while the equipment is live, this RISK should also be assessed.
- What form of power supply should be used to energise the equipment under test, particularly where use of the wrong method would compromise safety.
- What is expected of test personnel regarding the inspection of test equipment before use, and how defects are to be reported?
- The correct use of any warning devices that form part of the safety system at designated test areas.
- Instructions about what action should be taken in an emergency situation.

Bibliography

IEC 60065:2001, *Audio, video and similar electronic apparatus – Safety requirements*
IEC 60065:2001/AMD1:2005
IEC 60065:2001/AMD2:2019⁷

IEC 60320-1, *Appliance couplers for household and similar general purposes – Part 1: General requirements*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60884-1, *Plugs and socket-outlets for household and similar purposes – Part 1: General requirements*

IEC 60950-1:2001, *Information technology equipment – Safety – Part 1: General requirements*

IEC 61010-2-010:2003, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-010: Particular requirements for laboratory equipment for the heating of materials*

IEC 61010-031:2002, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61557-4:2007, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measurement or monitoring of protective measures – Part 4: Resistance of earth connection and equipotential bonding*

IEC TR 62296:2003, *Considerations of unaddressed safety aspects in the second edition of IEC 60601-1 and proposals for new requirements*

ISO/IEC Guide 51, *Safety aspects – Guidelines for their inclusion in standards*

ISO 471:1995⁸, *Rubber – Temperatures, humidities and times for conditioning and testing*

ISO 1853, *Conducting and dissipative rubbers, vulcanized or thermoplastic – Measurement of resistivity*

ISO 2878, *Rubber, vulcanized or thermoplastic – Antistatic and conductive products – Determination of electrical resistance*

ISO 5725-1:1994, *Accuracy (trueness and precision) of measurement methods and results – Part 1: General principles and definitions*

ISO 13852:1996⁹, *Safety of machinery – Safety distances to prevent danger zones being reached by the upper limbs*

⁷ This edition and its amendments have been withdrawn and replaced by Edition 8 (2014).

⁸ This standard was withdrawn on 7 September 2004 and is replaced by ISO 23529:2010.

⁹ This standard was withdrawn on 1 March 2008 and is replaced by ISO 13857:2008.

ASTM D149 – 97a(2013), *Standard Test Method for Dielectric Breakdown Voltage and Dielectric Strength of Solid Electrical Insulating Materials at Commercial Power Frequencies*

Index of defined terms

NOTE Where a different term was used in IEC 60601-1:1988, the second edition term is given in parentheses.

ACCESS COVER	IEC 60601-1:2005, 3.1
	IEC 60601-1:1988, 2.1.1
ACCESSIBLE PART	IEC 60601-1:2005, 3.2
	IEC 60601-1:1988, 2.1.22
ACCESSORY	IEC 60601-1:2005, 3.3
	IEC 60601-1:1988, 2.1.3
ACCOMPANYING DOCUMENT	IEC 60601-1:2005, 3.4
	IEC 60601-1:1988, 2.1.2
AIR CLEARANCE	IEC 60601-1:2005+AMD1:2012, 3.5
	IEC 60601-1:1988, 2.1.2
APPLIANCE INLET	IEC 60601-1:2005, 3.7
	IEC 60601-1:1988, 2.7.2
APPLIED PART	IEC 60601-1:2005, 3.8
	IEC 60601-1:1988, 2.1.5
BASIC INSULATION	IEC 60601-1:2005, 3.9
	IEC 60601-1:1988, 2.3.2
BASIC SAFETY	IEC 60601-1:2005, 3.10
CATEGORY AP (CATEGORY AP EQUIPMENT)	IEC 60601-1:2005, 3.11
	IEC 60601-1:1988, 2.2.2
CATEGORY APG (CATEGORY APG EQUIPMENT)	IEC 60601-1:2005, 3.12
	IEC 60601-1:1988, 2.2.3
CLASS I (CLASS I EQUIPMENT)	IEC 60601-1:2005, 3.13
	IEC 60601-1:1988, 2.2.4
CLASS II (CLASS II EQUIPMENT)	IEC 60601-1:2005, 3.14
	IEC 60601-1:1988, 2.2.5
COLD CONDITION	IEC 60601-1:2005, 3.16
	IEC 60601-1:1988, 2.10.1
COMPONENT WITH HIGH-INTEGRITY CHARACTERISTICS	IEC 60601-1:2005, 3.17
CREEPAGE DISTANCE	IEC 60601-1:2005, 3.19
	IEC 60601-1:1988, 2.3.3
DEFIBRILLATION-PROOF APPLIED PART	IEC 60601-1:2005, 3.20
	IEC 60601-1:1988, 2.1.27
DETACHABLE POWER SUPPLY CORD	IEC 60601-1:2005, 3.21
	IEC 60601-1:1988, 2.7.6
DOUBLE INSULATION	IEC 60601-1:2005, 3.23
	IEC 60601-1:1988, 2.3.4
DUTY CYCLE	IEC 60601-1:2005, 3.24
	IEC 60601-1:1988, 2.10.5
EARTH LEAKAGE CURRENT	IEC 60601-1:2005+AMD1:2012, 3.25
	IEC 60601-1:1988, 2.5.1

ENCLOSURE.....	IEC 60601-1:2005, 3.26 IEC 60601-1:1988, 2.1.6
ESSENTIAL PERFORMANCE	IEC 60601-1:2005+AMD1:2012, 3.27
F-TYPE ISOLATED APPLIED PART	IEC 60601-1:2005, 3.29 IEC 60601-1:1988, 2.1.7
FIXED (FIXED EQUIPMENT)	IEC 60601-1:2005+AMD1:2012, 3.30 IEC 60601-1:1988, 2.2.12
FUNCTIONAL EARTH TERMINAL	IEC 60601-1:2005, 3.35 IEC 60601-1:1988, 2.6.4
HAND HELD (HAND-HELD EQUIPMENT)	IEC 60601-1:2005+AMD1:2012, 3.37 IEC 60601-1:1988, 2.2.13
HARM.....	IEC 60601-1:2005+AMD1:2012, 3.38
HAZARD.....	IEC 60601-1:2005+AMD1:2012, 3.39
HAZARDOUS SITUATION	IEC 60601-1:2005+AMD1:2012, 3.40
HIGH VOLTAGE	IEC 60601-1:2005, 3.41 IEC 60601-1:1988, 2.4.1
HYDRAULIC TEST PRESSURE	IEC 60601-1:2005, 3.42 IEC 60601-1:1988, 2.11.1
INTENDED USE	IEC 60601-1:2005+AMD1:2012, 3.44
INTERNAL ELECTRICAL POWER SOURCE	IEC 60601-1:2005, 3.45 IEC 60601-1:1988, 2.1.9
INTERNALLY POWERED (INTERNALLY POWERED EQUIPMENT)	IEC 60601-1:2005, 3.46 IEC 60601-1:1988, 2.2.29
LEAKAGE CURRENT.....	IEC 60601-1:2005, 3.47 IEC 60601-1:1988, 2.5.3
MAINS CONNECTOR.....	IEC 60601-1:2005, 3.48 IEC 60601-1:1988, 2.7.10
MAINS PART	IEC 60601-1:2005+AMD1:2012, 3.49 IEC 60601-1:1988, 2.1.12
MAINS PLUG.....	IEC 60601-1:2005, 3.50 IEC 60601-1:1988, 2.7.11
MAINS SUPPLY TRANSFORMER	IEC 60601-1:2005, 3.51
MAINS TERMINAL DEVICE	IEC 60601-1:2005, 3.52 IEC 60601-1:1988, 2.7.12
MAINS VOLTAGE	IEC 60601-1:2005, 3.54 IEC 60601-1:1988, 2.4.2
MANUFACTURER.....	IEC 60601-1:2005+AMD1:2012, 3.55
MAXIMUM MAINS VOLTAGE	IEC 60601-1:2005, 3.56
MAXIMUM PERMISSIBLE WORKING PRESSURE	IEC 60601-1:2005, 3.57 IEC 60601-1:1988, 2.11.2
MEANS OF OPERATOR PROTECTION – MOOP	IEC 60601-1:2005, 3.58
MEANS OF PATIENT PROTECTION – MOPP	IEC 60601-1:2005, 3.59

MEANS OF PROTECTION – MOP.....	IEC 60601-1:2005, 3.60
MECHANICAL PROTECTIVE DEVICE	IEC 60601-1:2005, 3.62
ME EQUIPMENT	IEC 60601-1:2005, 3.63
	IEC 60601-1:1988, 2.2.15
ME SYSTEM	IEC 60601-1:2005, 3.64
	IEC 60601-1-1:2000, 2.201
MOBILE (MOBILE EQUIPMENT)	IEC 60601-1:2005+AMD1:2012, 3.65
	IEC 60601-1:1998, 2.2.16
NOMINAL	IEC 60601-1:2005, 3.69
	IEC 60601-1:1988, 2.12.3
NORMAL CONDITION.....	IEC 60601-1:2005, 3.70
	IEC 60601-1:1988, 2.10.7
NORMAL USE.....	IEC 60601-1:2005+AMD1:2012, 3.71
	IEC 60601-1:1988, 2.10.8
OBJECTIVE EVIDENCE	IEC 60601-1:2005+AMD1:2013,3.72
OPERATOR	IEC 60601-1:2005, 3.73
	IEC 60601-1:1988, 2.12.17
OVER-CURRENT RELEASE	IEC 60601-1:2005, 3.74
	IEC 60601-1:1988, 2.9.7
OXYGEN RICH ENVIRONMENT	IEC 60601-1:2005, 3.75
PATIENT	IEC 60601-1:2005+AMD1:2012, 3.76
	IEC 60601-1:1988, 2.12.4
PATIENT AUXILIARY CURRENT	IEC 60601-1:2005, 3.77
	IEC 60601-1:1988, 2.5.4
PATIENT CONNECTION.....	IEC 60601-1:2005, 3.78
	IEC 60601-1:1988, 2.1.23
PATIENT LEAKAGE CURRENT	IEC 60601-1:2005, 3.80
	IEC 60601-1:1988, 2.5.6
PEAK WORKING VOLTAGE	IEC 60601-1:2005+AMD1:2012, 3.81
PERMANENTLY INSTALLED (PERMANENTLY-INSTALLED EQUIPMENT).....	IEC 60601-1:2005, 3.84
	IEC 60601-1:1988, 2.2.17
PORTABLE (PORTABLE EQUIPMENT).....	IEC 60601-1:2005+AMD1:2012, 3.85
	IEC 60601-1:1988, 2.2.18
POWER SUPPLY CORD	IEC 60601-1:2005, 3.87
	IEC 60601-1:1988, 2.7.17
PROCEDURE	IEC 60601-1:2005+AMD1:2012, 3.88
PROCESS	IEC 60601-1:2005+AMD1:2012, 3.89
PROGRAMMABLE MEDICAL ELECTRICAL SYSTEM	IEC 60601-1:2005, 3.90
PEMS	
PROTECTIVE EARTH CONDUCTOR	IEC 60601-1:2005, 3.93
PROTECTIVE EARTH CONNECTION.....	IEC 60601-1:2005, 3.94
	IEC 60601-1:1988, 2.6.7

PROTECTIVE EARTH TERMINAL	IEC 60601-1:2005, 3.95
	IEC 60601-1:1988, 2.6.8
PROTECTIVELY EARTHED	IEC 60601-1:2005, 3.96
	IEC 60601-1:1988, 2.6.9
RATED	IEC 60601-1:2005, 3.97
	IEC 60601-1:1988, 2.12.8
RECORD	IEC 60601-1:2005+AMD1:2012, 3.98
REINFORCED INSULATION	IEC 60601-1:2005, 3.99
	IEC 60601-1:1988, 2.3.7
RESPONSIBLE ORGANIZATION (USER).....	IEC 60601-1:2005, 3.101
	IEC 60601-1:1988, 2.12.13
RISK	IEC 60601-1:2005+AMD1:2012, 3.102
RISK ANALYSIS	IEC 60601-1:2005+AMD1:2012, 3.103
RISK MANAGEMENT	IEC 60601-1:2005+AMD1:2012, 3.107
RISK MANAGEMENT FILE	IEC 60601-1:2005+AMD1:2012, 3.108
SAFE WORKING LOAD	IEC 60601-1:2005, 3.109
	IEC 60601-1:1988, 2.11.5
SECONDARY CIRCUIT	IEC 60601-1:2005, 3.110
SELF-RESETTING THERMAL CUT-OUT	IEC 60601-1:2005, 3.111
	IEC 60601-1:1988, 2.9.10
SERVICE PERSONNEL	IEC 60601-1:2005, 3.113
SIGNAL INPUT/OUTPUT PART	IEC 60601-1:2005, 3.115
SIP/SOP	IEC 60601-1:1988, 2.1.18
	IEC 60601-1:1988, 2.1.19
SINGLE FAULT CONDITION.....	IEC 60601-1:2005+AMD1:2012, 3.116
	IEC 60601-1:1988, 2.10.11
STATIONARY (STATIONARY EQUIPMENT)	IEC 60601-1:2005+AMD1:2012, 3.118
	IEC 60601-1:1988, 2.2.21
SUPPLEMENTARY INSULATION	IEC 60601-1:2005, 3.119
	IEC 60601-1:1988, 2.3.8
SUPPLY MAINS	IEC 60601-1:2005, 3.120
	IEC 60601-1:1988, 2.12.10
TENSILE SAFETY FACTOR.....	IEC 60601-1:2005, 3.121
THERMAL CUT-OUT	IEC 60601-1:2005, 3.124
	IEC 60601-1:1988, 2.9.12
THERMAL STABILITY	IEC 60601-1:2005, 3.125
THERMOSTAT	IEC 60601-1:2005, 3.126
	IEC 60601-1:1988, 2.9.13
TOOL	IEC 60601-1:2005, 3.127
	IEC 60601-1:1988, 2.12.12
TOTAL LOAD.....	IEC 60601-1:2005, 3.128
	IEC 60601-1:1988, 2.11.9

TOUCH CURRENT (ENCLOSURE LEAKAGE CURRENT)	IEC 60601-1:2005, 3.129
	IEC 60601-1:1988, 2.5.2
TRANSPORTABLE (TRANSPORTABLE EQUIPMENT)	IEC 60601-1:2005+AMD1:2012, 3.130
	IEC 60601-1:1988, 2.2.23
TYPE B APPLIED PART	IEC 60601-1:2005+AMD1:2012, 3.132
	IEC 60601-1:1988, 2.1.24
TYPE BF APPLIED PART	IEC 60601-1:2005+AMD1:2012, 3.133
	IEC 60601-1:1988, 2.1.25
TYPE CF APPLIED PART	IEC 60601-1:2005+AMD1:2012, 3.134
	IEC 60601-1:1988, 2.1.26
TYPE TEST	IEC 60601-1:2005, 3.135
USABILITY	IEC 60601-1:2005+AMD1:2012, 3.136
USABILITY ENGINEERING	IEC 60601-1:2005/AMD1:2012, 3.137
VERIFICATION	IEC 60601-1:2005+AMD1:2012, 3.138
WORKING VOLTAGE.....	IEC 60601-1:2005+AMD1:2012, 3.139



British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com

Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070

Email: copyright@bsigroup.com



...making excellence a habit.™