PD IEC/TR 62696:2011



BSI Standards Publication

Luminaires — Application of the IK code IEC 62262



National foreword

This Published Document is the UK implementation of IEC/TR 62696:2011.

The UK participation in its preparation was entrusted by Technical Committee CPL/34, Lamps and Related Equipment, to Subcommittee CPL/34/4, Luminaires.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 72599 9

ICS 29.140.40

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 July 2011.

Amendments issued since publication

Amd. No. Date Text affected



IEC/TR 62696

Edition 1.0 2011-04

TECHNICAL REPORT

Luminaires – Application of the IK code IEC 62262

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PRICE CODE

F

ICS 29.140.40

ISBN 978-2-88912-455-8

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LUMINAIRES – APPLICATION OF THE IK CODE IEC 62262

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 62696, which is a technical report, has been prepared by 34D: Luminaires, of IEC technical committee 34: Lamps and related equipment.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
34D/965/DTR	34D/1001/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- · reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version may be issued at a later date.

INTRODUCTION

The IK code detailing resistance to mechanical impact performance, given in IEC 62262, places responsibility on product standard committees to specify:

- definition of enclosure;
- impact test equipment to be used;
- number of samples to be tested;
- · conditions for test sample mounting;
- any preconditioning of the test sample;
- whether to be tested energised;
- whether to be tested with moving parts in motion;
- the number of impacts and their points of application.

Other aspects particular to consideration of luminaires may also be appropriate. For example:

- · acceptable/non-acceptable damage following impact;
- level of luminaire performance and operation to be maintained following impact.

LUMINAIRES – APPLICATION OF THE IK CODE IEC 62262

1 Scope

This Technical report covers the testing and classification of luminaires according to IEC 62262. The application of an IK rating to a luminaire is considered to be a performance issue and is not directly related to the safety provisions of IEC 60598 standards covering luminaire safety.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-75, Environmental Testing – Part 2-75: Tests Eh: Hammer Tests

IEC 60598 (all parts) - Luminaires

IEC 60598-1, Luminaires – General requirements and tests

IEC 62262, Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)

3 Conditions of testing

- **3.1** In general, testing is conducted in accordance with IEC 62262, having regard to the general test conditions specified by IEC 60598-1, Subclause 4.13, and the following conditions which are specific for the IK testing and rating of luminaires.
- **3.2** Impacts should not be applied through openings in the luminaire enclosure with an area less than 64 cm².

NOTE For example, no impact should be applied through the individual openings in optical controls (louvers) if their size is less than 64 cm^2 .

3.3 Luminaires should be tested fully assembled and installed for use.

Luminaires for ceiling or wall mounting should be mounted on a rigid wooden board.

Suspended luminaires should be tested as in normal use, with the minimum suspension length detailed by the manufacturer's instructions.

Luminaires to be installed on a pole, with or without a mast arm, should be installed on a rigid portion of the pole.

Floor mounted luminaires should be tested in a suitable rigid structure to simulate normal use.

- **3.4** Luminaires should not to be energised during test and no preconditioning of the luminaire sample is required.
- **3.5** Testing should be conducted on a single luminaire sample unless the results of impact testing of other areas of the luminaire could influence assessment of the result. Three impact blows should be applied to the point(s) of the luminaire considered to be the weakest.
- **3.6** Impact testing should be conducted using striking elements with head radius and material type as specified by IEC 60068-2-75. Spring hammer apparatus should be used for ratings up to and including IK06. For ratings IK07 and above, the use of pendulum or vertical hammer apparatus is acceptable, as most appropriate for the luminaire design and its intended installation.
- **3.7** Impact testing should be conducted with the luminaire in its intended mounting orientation whenever this is possible, and when this could affect the outcome of the test (e.g. for assessment of mounting surface fixing security). When impact testing of a ceiling-mounted luminaire is required from below the luminaire, and this is impractical, the luminaire may be rotated 90° (to a wall mounted position) for the purposes of this testing.
- **3.8** In cases where it may be impossible to carry out the impact test due to the luminaire construction, it is acceptable to use a specially-prepared luminaire to perform the test. For this situation, the modification should not impair the mechanical strength characteristics of the luminaire.

4 Conditions of acceptance

4.1 Safety of the luminaire is to be maintained as per the criteria given in IEC 60598-1, Subclause 4.13. Furthermore, the fixings of the luminaire to the mounting surface should remain secure. Non safety critical damage to the luminaire enclosure and optics is accepted, but no parts of the luminaire should become detached.

Acceptance is checked by visual inspection, and test/measurement where required.

4.2 Protection of the light source should be provided and basic functioning of the luminaire should be maintained.

Acceptance is checked by visual inspection and by operation of the luminaire following the test.



British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards -based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at bsigroup.com/standards or contacting our Customer Services team or Knowledge Centre.

Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at bsigroup.com/shop, where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to bsigroup.com/subscriptions.

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

PLUS is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit bsigroup.com/shop.

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email bsmusales@bsigroup.com.

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

Useful Contacts:

Customer Services

Tel: +44 845 086 9001

Email (orders): orders@bsigroup.com
Email (enquiries): cservices@bsigroup.com

Subscriptions

Tel: +44 845 086 9001

Email: subscriptions@bsigroup.com

Knowledge Centre

Tel: +44 20 8996 7004

Email: knowledgecentre@bsigroup.com

Copyright & Licensing

Tel: +44 20 8996 7070 Email: copyright@bsigroup.com

