

PD IEC/TS 62782:2016



BSI Standards Publication

# Photovoltaic (PV) modules — Cyclic (dynamic) mechanical load testing

**bsi.**

...making excellence a habit.™

### **National foreword**

This Published Document is the UK implementation of IEC/TS 62782:2016.

The UK participation in its preparation was entrusted to Technical Committee GEL/82, Photovoltaic Energy Systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016.

Published by BSI Standards Limited 2016

ISBN 978 0 580 82386 2

ICS 27.160

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 March 2016.

### **Amendments/corrigenda issued since publication**

<b>Date</b>	<b>Text affected</b>
-------------	----------------------

---



# TECHNICAL SPECIFICATION

---

## Photovoltaic (PV) modules – Cyclic (dynamic) mechanical load testing

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 27.160

ISBN 978-2-8322-3223-1

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions .....	6
4 Apparatus.....	6
5 Initial measurements.....	6
6 Procedure .....	7
7 Final measurements .....	7
8 Test report.....	8
Annex A (informative) Subsequent testing .....	9

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PHOTOVOLTAIC (PV) MODULES –  
CYCLIC (DYNAMIC) MECHANICAL LOAD TESTING**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62782, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/971/DTS	82/1014A/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

## PHOTOVOLTAIC (PV) MODULES – CYCLIC (DYNAMIC) MECHANICAL LOAD TESTING

### 1 Scope

This technical specification provides a test method for performing a cyclic (dynamic) mechanical load test in which the module is supported at the design support points and a uniform load normal to the module surface is cycled in alternating negative and positive directions. This test may be utilized to evaluate if components within the module including solar cells, interconnect ribbons and/or electrical bonds within the module are susceptible to breakage or if edge seals are likely to fail due to the mechanical stresses encountered during installation and operation. This test can be performed at any module temperature within the normal operating temperature range. Since the results have been determined to depend on the module temperature during the application of the load it is critical to maintain the module at a constant temperature during the performance of this test.

This technical specification has historically been applied to rigid modules. It cannot be applied to flexible modules unless they are designed to be mounted in a rigid manner. In which case, the cyclic (dynamic) mechanical load test can be applied to the flexible module in its rigid mounting system.

This test has been written as a standalone technical specification, but it is likely to be used in conjunction with other test standards. Typically, this test itself will not result in power loss, but when followed by additional stress tests like thermal cycling and humidity freeze, the damage done by the mechanical cycling results in power loss that would not have occurred due only to the thermal cycling and humidity freeze tests. For example, the transportation testing procedure (IEC 62759) includes the requirements for such a cyclic (dynamic) mechanical load test followed by 50 thermal cycles and 10 humidity freeze cycles.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 60904-12, *Photovoltaic devices – Part 12: Infrared thermography of photovoltaic modules*<sup>1</sup>

IEC TS 60904-13, *Photovoltaic devices – Part 13: Electroluminescence of photovoltaic modules*<sup>1</sup>

IEC 61215-1:2016, *Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1: Test requirements*

IEC 61215-2:2016, *Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures*

IEC TS 61836, *Solar photovoltaic energy systems – Terms, definitions and symbols*

---

<sup>1</sup> To be published.

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC TS 61836 apply.

### 4 Apparatus

The apparatus for this technical specification include:

- a) Equipment for performing the cyclic (dynamic) loading: this equipment shall be capable of applying a uniform load of  $1\,000\text{ Pa} \pm 100\text{ Pa}$  onto the module surface in both directions to simulate pressure and tensile loads at a rate between 3 and 7 cycles per minute. The prescribed load is of uniform pressure,  $P$ , and is most appropriately applied with a pressure of air or vacuum. If a piston system (or other non-uniform application) is used to load the module, the force each piston (or applicators) exert is  $F = PA/n$ , where  $A$  is the area of the module and  $n$  is the number of pistons. To ensure a similar effect to the module, the maximum, perpendicular, center-to-center distance between evenly loaded points shall be 20 cm or less. If one piston consists of multiple loading points this maximum distance refers to both the loading points within and between pistons. The maximum perpendicular distance between the module frame and an evenly loaded point shall also be 20 cm or less.
- b) Means for monitoring, throughout the test, the continuity of the internal circuit of each module.
- c) Means for monitoring the temperature of the module to an accuracy of  $\pm 2,0\text{ °C}$  and repeatability of  $\pm 0,5\text{ °C}$ . The temperature sensors shall be attached to the front or back surface of the module near the middle without interfering with the cyclic loading.
- d) Infrared (IR) camera and a constant current power supply capable of providing between one and two times the Standard Test Condition (STC) maximum power current of the module in the forward direction. (See future IEC TS 60904-12.)
- e) Electroluminescence (EL) equipment and a constant current power supply capable of providing between 0,1 and 1 times the STC short circuit current of the module in the forward direction. (See future IEC TS 60904-13.)

The IR and EL systems do not have to be capable of observing the module while it is under test. These tests can be performed independent of the cyclic (dynamic) load test equipment.

### 5 Initial measurements

The following measurements shall be performed on the test module before beginning the stress testing.

- a) Perform a visual inspection of the module in accordance with IEC 61215-2 MQT 01.
- b) Perform the initial module stabilization procedure in accordance with IEC 61215-2 MQT 19.1.
- c) Measure the maximum power performance of the module in accordance with IEC 61215-2 MQT 02.
- d) Perform an insulation test in accordance with IEC 61215-2 MQT 03.
- e) Perform a wet leakage current test in accordance with IEC 61215-2 MQT 15.
- f) Perform an EL scan of the module using a forward bias current between 0,1 and one times the STC short circuit current to identify cracked cells and other breaks in the cell junction. Note the observed broken cells, interconnects and/or electrical bonds or any additional anomalies observed in the test report (Clause 8k) as identified in future IEC TS 60904-13.



- g) Perform an IR scan of the module using a forward bias current between the STC maximum power current and twice the STC maximum power current to identify areas of localized heating. Note the observed areas of localized heating in the test report (Clause 8k) as identified in future IEC TS 60904-12.

If there is reason to use a current of more than  $I_{sc}$  in either the IR or EL test, check with the module manufacturer to determine that such a high current will not damage the module.

## 6 Procedure

- a) Equip the module so that the electrical continuity of the internal circuit can be monitored continuously during the test.
- b) Mount the module on the cyclic (dynamic) loading equipment using the method prescribed by the manufacturer including the mounting means (clips/clamps and any kind of fastener) and underlying support rails. If there are different possibilities each mounting method needs to be evaluated separately. For all mounting methods, mount the module in a manner where the distance between the fixing points is worst case, which is typically at the maximum distance.
- c) Set the module temperature at the desired level. Monitor the module temperature throughout the application of the cyclic loading. Maintain module temperature within  $\pm 2$  °C of the selected temperature during the application of the cyclic loading.
- d) Apply the cyclic (dynamic) mechanical load and cycle it 1 000 times using a maximum pressure of  $\pm 1\ 000$  Pa (with a tolerance of  $\pm 100$  Pa) and a rate between 3 and 7 cycles per minute. (Cycles being defined as one positive and one negative load application.)
- e) Monitor continuity throughout the test.

Measuring continuity requires only a small current flow (1% of  $I_{sc}$  would be more than adequate). However, there may be cases where it would be useful or interesting for the test to be performed with a higher current flow, up to the STC peak power current. If that is the case this fact should be noted in the test report (Clause 8 j). Such a test could end up causing arcing in broken cells or broken interconnects.

Cyclic (dynamic) mechanical load tests are normally performed in the laboratory at room temperature. However, there may be cases where it is of interest to perform the test at either lower temperatures to simulate stress during winter or at higher temperatures to simulate stress during summertime operation. Temperature ranges shall be limited by the minimum/maximum operating temperature of module and mounting materials under test (e.g. clip rubber, washers, etc.). The module temperature during the cyclic loading should be noted in the test report (Clause 8 j).

## 7 Final measurements

- a) Perform a visual inspection of the module in accordance with IEC 61215-2 MQT 01.
- b) Perform the final module stabilization procedure in accordance with IEC 61215-2 MQT 19.2.
- c) Measure the maximum power performance of the module in accordance with IEC 61215-2 MQT 02.
- d) Perform an insulation test in accordance with IEC 61215-2 MQT 03.
- e) Perform a wet leakage current test in accordance with IEC 61215-2 MQT 15.
- f) Perform an EL scan of the module using a forward bias current between 0,1 and one times the STC short circuit current to identify changes in the module using the guidance from future IEC TS 60904-13.
- g) Perform an IR scan of the module using a forward bias current between the STC peak power current and twice the STC peak power current to identify changes in the module using guidance from future IEC TS 60904-12.

Report all results including any changes noted in the module particularly the number of broken cells, broken interconnects and broken electrical connections observed.

The EL and IR scans are used for informational purposes only, not as requirements. As such, they should not impact the results of the visual inspection.

## 8 Test report

A report of the test shall be prepared by the test agency in accordance with ISO/IEC 17025. The report shall contain the detail specification for the specimens. Each certificate or test report shall include at least the following information:

- a) a title;
- b) name and address of the test laboratory and location where the tests were carried out;
- c) unique identification of the report and of each page;
- d) name and address of client, where appropriate;
- e) description and identification of the module(s) tested;
- f) characterization and condition of the test module;
- g) date of receipt of test module and date(s) of test, where appropriate;
- h) identification of test method used including a description of the equipment used to apply the uniform load;
- i) reference to sampling procedure, where relevant;
- j) any deviations from, additions to, or exclusions from, the test method and any other information relevant to a specific test, such as the specific mounting system used, environmental conditions, module temperature and current flow utilized during the test;
- k) measurements, examinations and derived results supported by tables, graphs, sketches and photographs as appropriate, including the maximum power loss after each test, the number of broken cells observed before and after each test and any other significant changes observed;
- l) indication if any of the following are observed after the cyclic (dynamic) mechanical load test sequence or after any subsequent tests as discussed in Annex A:
  - 1) interruption of current flow during the test (this interruption may be intermittent and in phase with the load cycling. If so, the test report should note on which cycle the interruption began and on which part of the cycle the interruption in current flow occurs);
  - 2) evidence of major visual defects, as defined in Clause 8 of IEC 61215-1:2016;
  - 3) a value of insulation resistance measured below the accepted value of  $40 \text{ M}\Omega \times \text{m}^2$  when measured at 500 V or maximum systems voltage, whichever is greater; or
  - 4) the wet leakage current measured insulation resistance times the area of the module shall not be less than  $40 \text{ M}\Omega \times \text{m}^2$ , when measured at 500 V or maximum systems voltage, whichever is greater;
- m) a statement of the estimated uncertainty of the test results (where relevant);
- n) a signature and title, or equivalent identification of the person(s) accepting responsibility for the content of the report, and the date of issue;
- o) where relevant, a statement to the effect that the results relate only to the items tested;
- p) a statement that the report shall not be reproduced except in full, without the written approval of the laboratory.

## **Annex A** (informative)

### **Subsequent testing**

While cyclic (dynamic) mechanical load testing often does damage to a PV module, there is usually minimal observed power loss after completion of the test. The use of subsequent stress tests has resulted in observed power loss. The following are two examples:

- a) If the cyclic (dynamic) mechanical load testing breaks cells and/or interconnect ribbons, subsequent exposure to 50 thermal cycles (MQT 11 from IEC 61215-2) and 10 humidity freeze cycles (MQT 12 from IEC 61215-2) can lead to significant loss in peak power.
- b) If the cyclic (dynamic) mechanical load testing damages the module's edge seal, subsequent exposure to damp heat testing (MQT 13 from IEC 61215-2) could result in moisture ingress and subsequent power loss.

Therefore, this technical specification can be used in conjunction with additional accelerated stress tests to evaluate the overall impact on module performance.

---





# British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

## About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

## Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at [bsigroup.com/standards](http://bsigroup.com/standards) or contacting our Customer Services team or Knowledge Centre.

## Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at [bsigroup.com/shop](http://bsigroup.com/shop), where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

## Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to [bsigroup.com/subscriptions](http://bsigroup.com/subscriptions).

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

**PLUS** is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit [bsigroup.com/shop](http://bsigroup.com/shop).

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email [bsmusales@bsigroup.com](mailto:bsmusales@bsigroup.com).

## Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

## Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

## Useful Contacts:

### Customer Services

**Tel:** +44 845 086 9001

**Email (orders):** [orders@bsigroup.com](mailto:orders@bsigroup.com)

**Email (enquiries):** [cservices@bsigroup.com](mailto:cservices@bsigroup.com)

### Subscriptions

**Tel:** +44 845 086 9001

**Email:** [subscriptions@bsigroup.com](mailto:subscriptions@bsigroup.com)

### Knowledge Centre

**Tel:** +44 20 8996 7004

**Email:** [knowledgecentre@bsigroup.com](mailto:knowledgecentre@bsigroup.com)

### Copyright & Licensing

**Tel:** +44 20 8996 7070

**Email:** [copyright@bsigroup.com](mailto:copyright@bsigroup.com)

## BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

