

---

---

**Acoustics — Laboratory tests on noise  
emission from appliances and equipment  
used in water supply installations —**

**Part 1:  
Method of measurement**

**AMENDMENT 1: Measurement uncertainty**

*Acoustique — Mesurage en laboratoire du bruit émis par les  
robinetteries et les équipements hydrauliques utilisés dans les  
installations de distribution d'eau —*

*Partie 1: Méthode de mesurage*

*AMENDEMENT 1: Incertitude de mesure*



Reference number  
ISO 3822-1:1999/Amd.1:2008(E)

© ISO 2008

**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO 3822-1:1999 was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*.

© ISO 2008. All rights reserved.



# **Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations —**

## **Part 1: Method of measurement**

### **AMENDMENT 1: Measurement uncertainty**

Add Annex D (overleaf).

## Annex D (informative)

### Measurement uncertainty

#### D.1 General

The measurement uncertainties associated with appliance sound pressure levels determined in accordance with this International Standard normally should be evaluated in accordance with ISO/IEC Guide 98-3<sup>1)</sup>. Due to the statistical nature of the sound pressure measurement, the type B approach defined in ISO/IEC Guide 98-3 should be used.

Unless more specific knowledge is available, the standard deviation of reproducibility derived from round robin tests is used as the best available estimate for the uncertainty.

The expanded measurement uncertainty of determinations of appliance sound pressure levels made in accordance with this International Standard, for a coverage probability of 95 % (coverage factor  $k = 2$ ) as defined in ISO/IEC Guide 98-3, should be taken to be  $2s_R$ , where  $s_R$  is the standard deviation of reproducibility, unless more specific knowledge is available, e.g. in the laboratory undertaking the measurements.

#### D.2 Standard deviation of reproducibility of octave band sound pressure levels

During the “2nd Round Robin Test Acoustics”, values of the standard deviation of reproducibility,  $s_R$ , were determined according to ISO 140-2<sup>2)</sup>. Values of  $s_R$  for the appliance sound pressure level  $L_{apn}$  are given in Table D.1.

**Table D.1 — Standard deviation of reproducibility,  $s_R$ ,  
determined according to ISO 140-2 for appliance sound pressure level  $L_{apn}$**

| Octave band mid-frequency | Standard deviation of reproducibility, $s_R$ |
|---------------------------|--|
| Hz                        | dB   |
| 125                       | 1,5  |
| 250                       | 1,0  |
| 500                       | 1,0  |
| 1 000                     | 1,0  |
| 2 000                     | 1,0  |
| 4 000                     | 1,0  |

- 1) ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*
- 2) ISO 140-2, *Acoustics — Measurement of sound insulation in buildings and of building elements — Part 2: Determination, verification and application of precision data*

### D.3 Standard deviation for the determination of $L_{ap}$

Following the specifications given in this annex, the standard deviation of repeatability,  $s_r$ , of the appliance sound pressure level  $L_{ap}$  is 0,5 dB. The standard deviation of reproducibility is 1,5 dB for a usual water supply appliance. The standard deviation of reproducibility can increase for appliances which produce very low sound pressure levels. The values given above have been determined by the "2nd Round Robin Test Acoustics".

---

---

**ICS 17.140.20; 91.140.60**

Price based on 3 pages