INTERNATIONAL STANDARD

ISO 7240-24

First edition 2010-03-01 **AMENDMENT 1** 2013-02-15

Fire detection and fire alarm systems— Part 24: Sound-system loudspeakers — AMENDMENT 1

Systèmes de détection d'incendie et d'alarme — Partie 24: Haut-parleurs pour systèmes d'alarme vocale AMENDEMENT 1



Reference number ISO 7240-24:2010/Amd.1:2013(E)



COPYRIGHT PROTECTED DOCUMENT

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Case postale 56 • CH-1211 Geneva 20 Tel. + 41 22 749 01 11 Fax + 41 22 749 09 47 E-mail copyright@iso.org Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO 7240-24:2012 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

Fire detection and fire alarm systems—

Part 24:

Sound-system loudspeakers —

AMENDMENT 1

Page 7, 4.5.2 b)

Replace the existing text with the following:

b) sensitivity for the stated reference axis (see 5.1.5), measured at $4\,m$, and (optionally) converted to $1\,m$ equivalent distance by adding $12\,dB$ to the value obtained at the measuring distance of $4\,m$. Where the sensitivity is also stated at $1\,m$, the manufacturer shall clearly indicate the measured sensitivity and the calculated sensitivity;

