

First edition
2004-08-15

AMENDMENT 1
2010-11-15

**Industrial fans — Determination of fan
sound power levels under standardized
laboratory conditions —**

**Part 1:
General overview**

AMENDMENT 1

*Ventilateurs industriels — Détermination des niveaux de puissance
acoustique des ventilateurs dans des conditions de laboratoire
normalisées —*

Partie 1: Présentation générale

AMENDEMENT 1



Reference number
ISO 13347-1:2004/Amd.1:2010(E)

© ISO 2010

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.



COPYRIGHT PROTECTED DOCUMENT

© ISO 2010

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO 13347-1:2004 was prepared by Technical Committee ISO/TC 117, *Fans*.

www.iso.org

Industrial fans — Determination of fan sound power levels under standardized laboratory conditions —

Part 1: General overview

AMENDMENT 1

Page 8, Clause 5, Note 4

Replace Note 4, i.e. “NOTE 4 Figures marked with “*” in Table 3 are not given in ISO 3743-2 and ISO 3744 but are for guidance only.”, with the following new text:

“Figures marked with “*” in Table 3 have only been added to ISO 3740:2000. For general purposes therefore, many existing rigs are designed to operate at a cut-off frequency of 100 Hz thus giving the octave bands of interest as those between 125 Hz and 8 000 Hz.

Many centrifugal fans have significant quantities of noise in the 63 Hz octave band and, for special purposes, it is permissible to extend the measurements to this band, provided the test environment and instrument accuracy are satisfactory over this extended range.

The uncertainty given for these low frequencies can only be achieved by exercising extreme care, and wherever possible, results should be restricted to octave bands of 125 Hz and above.”

Page 8, Clause 5

Re-number Note 5 as Note 4.

Re-number the subsequent notes.

ICS 17.140.20; 23.120

Price based on 1 page