INTERNATIONAL STANDARD

ISO 14617-11

First edition 2002-09-01

Graphical symbols for diagrams — Part 11: Devices for heat transfer and heat engines

Devices for heat transfer and heat engines

Symboles graphiques pour schémas —

Partie 11: Dispositifs pour échanges thermiques, et moteurs thermiques



Reference number ISO 14617-11:2002(E)

© ISO 2002

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

© ISO 2002

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.ch
Web www.iso.ch

Printed in Switzerland

Contents Page Forewordiv Introduction......v 1 2 3 4 5 Heat-exchangers of specified design......3 Cooling towers4 6 7 Heat pumps, refrigerators and freezers7 8 9 10 11

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this part of ISO 14617 may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 14617-11 was prepared by Technical Committee ISO/TC 10, *Technical product documentation*, Subcommittee SC 10, *Process plant documentation and tpd-symbols*.

ISO 14617 consists of the following parts, under the general title Graphical symbols for diagrams:

- Part 1: General information and indexes
- Part 2: Symbols having general application
- Part 3: Connections and related devices
- Part 4: Actuators and related devices
- Part 5: Measurement and control devices
- Part 6: Measurement and control functions
- Part 7: Basic mechanical components
- Part 8: Valves and dampers
- Part 9: Pumps, compressors and fans
- Part 10: Fluid power converters
- Part 11: Devices for heat transfer and heat engines
- Part 12: Devices for separating, purification and mixing
- Part 15: Installation diagrams and network maps

Other parts are under preparation.

Introduction

The purpose of ISO 14617 in its final form is the creation of a library of harmonized graphical symbols for diagrams used in technical applications. This work has been, and will be, performed in close cooperation between ISO and IEC. The ultimate result is intended to be published as a standard common to ISO and IEC, which their technical committees responsible for specific application fields can use in preparing International Standards and manuals.

Graphical symbols for diagrams —

Part 11:

Devices for heat transfer and heat engines

1 Scope

This part of ISO 14617 specifies graphical symbols for heat transfer and heat engines in diagrams.

For the fundamental rules of creation and application of graphical symbols in diagrams, see ISO 81714-1.

For an overview of ISO 14617, information on the creation and use of registration numbers for identifying graphical symbols used in diagrams, rules for the presentation and application of these symbols, and examples of their use and application, see ISO 14617-1.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of ISO 14617. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of ISO 14617 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 14617-1:2002, Graphical symbols for diagrams — Part 1: General information and indexes

ISO 14617-2:2002, Graphical symbols for diagrams — Part 2: Symbols having general application

ISO 81714-1:1999, Design of graphical symbols for use in the technical documentation of products — Part 1: Basic rules

3 Terms and definitions

For the purposes of this part of ISO 14617, the terms and definitions given in ISO 14617-1 and ISO 14617-2 apply.

4 Heat-exchangers, condensers

4.1 Symbols of a basic nature

4.1.1	301	Envelope (tank)
		See R301 (4.2.1).
4.1.2	2037	 Spray nozzle

4.1.3	2501	 Heating or cooling coil
4.1.4	2502	 Finned tube

4.2 Application rules for the symbols in 4.1

4.2.1	R301	Another shape may be used, for example, rectangular or circular. A specific shape shall be used if it is necessary to indicate a certain function or property associated with the shape of the envelope.
		The symbol shall be used only when the envelope is of significance for the primary function. For example, it should not be used to represent enclosures for the protection against ingress of dust and protection against contact with movable or electrically live parts. If necessary, the nature of the envelope shall be stated, for example, conductive material.

4.3 Symbol giving supplementary information

None.

4.4 Application rule for the symbol in 4.3

None.

4.5 Application examples

4.5.1	X2501		Heat-exchanger, condenser
4.5.2	X2502	301, 2501	Heat-exchanger with three flow paths
4.5.3	X2503	301, 2037	De-superheater, humidifier

4.5.4	X2504		Water-sprayed cooler
		301, 2037, 2501	
4.5.5	X2505		Air-fin cooler with induced draft
		101, 2302, 2502	

5 Heat-exchangers of specified design

5.1 Symbols of a basic nature

NOTE For the use of the symbols, see R2121 (5.2.1).

5.1.1	2511	Heat-exchanger with straight tubes (fixed-tube plates)
5.1.2	2512	Heat-exchanger of floating type
5.1.3	2513	Heat-exchanger with U-shaped tubes
5.1.4	2514	Heat-exchanger with coil-shaped tubes
5.1.5	2515	Heat-exchanger of double-pipe type

ISO 14617-11:2002(E)

5.1.6	2516	Heat-exchanger of plate type
5.1.7	2517	 Heat-exchanger of spiral type
5.1.8	2518	Regenerative pre-heater

5.2 Application rule for the symbols in 5.1

5.2.1	R2121	The symbols shall be used only when it is necessary to show the construction.
-------	-------	-------------------------------------------------------------------------------

5.3 Symbol giving supplementary information

None.

5.4 Application rule for the symbol in 5.3

None.

5.5 Application example

None.

6 Cooling towers

6.1 Symbol of a basic nature

6.1.1	2521	Cooling tower

6.2 Application rule for the symbol in 6.1

None.

6.3 Symbol giving supplementary information

None.

6.4 Application rule for the symbol in 6.3

None.

6.5 Application examples

6.5.1	X2521	2037, 2521	Cooling tower, humidifier
6.5.2	X2522	2302, 2521	Cooling tower with induced draft
6.5.3	X2523	2302, 2521	Cooling tower with forced draft

7 Boilers, steam generators, furnaces, and hot air generators

7.1 Symbols of a basic nature

7.1.1	2531	Boiler, steam generator
7.1.2	2532	Boiler with dome

7.1.3	2533	Furnace

7.2 Application rule for the symbols in 7.1

None.

7.3 Symbols giving supplementary information

7.3.1	IEC	13	Ionizing radiation type; nuclear type
7.3.2	2541		Fired type
7.3.3	IEC		Electric heating element type
7.3.4	IEC	\downarrow	Electric electrode type
7.3.5	IEC		Electric induction type
7.3.6	2501	7	Heat-exchanger type

Application rules for the symbols in 7.3

None.

7.5 Application examples

7.5.1	X2531	2531, 2541	Boiler, fired-type
7.5.2	X2532	2531, IEC	Nuclear reactor, hot-water type
7.5.3	X2533	2531, IEC	Boiler, electrode type

7.5.4	X2534		Boiler with superheater
		2501, 2532	
7.5.5	X2535		Steam generator
		2501, 2531	
7.5.6	X2536		Electrode furnace
		2533, IEC	
7.5.7	X2537		Fired heater
		301, 2541	

8 Heat pumps, refrigerators and freezers

8.1 Symbol of a basic nature

8.1.1	2551	θ*	Heat pump, refrigerator or freezer
			See R2551 (8.2.1).

8.2 Application rule for the symbol in 8.1

8.2.1	R2551	The asterisk shall be replaced with the applicable symbol from 8.3.
-------	-------	---------------------------------------------------------------------

8.3 Symbols giving supplementary information

8.3.1	130	* 1	Transition to a higher quantity level
8.3.2	131	*	Transition to a lower quantity level
8.3.3	132	* 🛊	Transition to a higher or lower quantity level

8.4 Application rule for the symbols in 8.3

None.

8.5 Application examples

8.5.1	X2551	Θ 🕈	Heat pump
		130, 2551	
8.5.2	X2552	$\boxed{\theta \; \blacklozenge}$	Refrigerator or freezer
		131, 2551	
8.5.3	X2553	Θ 🛊	Device serving as a heat pump or refrigerator
		132, 2551	

Steam and gas turbines

Symbols of a basic nature

9.1.1	2571	Steam turbine
9.1.2	2572	Steam turbine with centre inlet
9.1.3	2573	Gas turbine
9.1.4	2574	Jet motor

9.1.5	2575	Turbo-fan jet motor

9.2 Application rule for the symbols in 9.1

None.

9.3 Symbol giving supplementary information

None.

9.4 Application rule for the symbol in 9.3

None.

9.5 Application example

9.5.1	X2571		Steam turbine with centre inlet and outlet taps
		402, 2572	

10 Engines with reciprocating or rotary pistons

10.1 Symbols of a basic nature

10.1.1	2581	 Reciprocating steam engine
10.1.2	2582	Internal combustion engine

10.1.3	2583	External combustion engine
		EXAMPLE Sterling motor.

10.2 Application rule for the symbols in 10.1

None.

10.3 Symbol giving supplementary information

None.

10.4 Application rule for the symbol in 10.3

None.

10.5 Application examples

10.5.1	X2581	W	Internal combustion engine with reciprocating pistons
		241, 402, 2582	
10.5.2	X2582		Internal combustion engine with rotating pistons
		254, 402, 2582	

11 Miscellaneous

11.1 Symbol of a basic nature

11.1.1	2591)	Flare
		ζ,	
		ŀ	

11.2	Application	rule 1	for t	he sy	mbol	in	11	.1
------	-------------	--------	-------	-------	------	----	----	----

None.

11.3 Symbol giving supplementary information

None.

11.4 Application rule for the symbol in 11.3

None.

11.5 Application example

None.

ISO 14617-11:2002(E)

ICS 01.080.30

Price based on 11 pages

© ISO 2002 - All rights reserved