
**Ships and marine technology —
Identification colours for the content of
piping systems**

*Navires et technologie maritime — Couleurs pour l'identification du
contenu des systèmes de tuyauterie*



Reference number
ISO 14726:2008(E)

© ISO 2008

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.



COPYRIGHT PROTECTED DOCUMENT

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Colours	2
5 Design	6
Annex A (informative) Explanations for some media/functions	8
Annex B (informative) Standard colours and equivalent colour codes	12
Bibliography	13

.....

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 14726 was prepared by Technical Committee ISO/TC 8, *Ships and marine technology*, Subcommittee SC 3, *Piping and machinery*.

This first edition cancels and replaces ISO 14726-1:1999 and ISO 14726-2:2002, which have been technically revised.

Ships and marine technology — Identification colours for the content of piping systems

1 Scope

This International Standard specifies main colours and additional colours for identifying piping systems in accordance with the content or function on board ships and marine structures.

These colours can also be used for piping systems on drawings and diagrams.

This International Standard does not apply to piping systems for medical gases, industrial gases and cargo.

This International Standard can also be used for land installations.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60757, *Code for designation of colours*

CIE 015, *Colorimetry*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

main colour

colour used to indicate a group of similar media

3.2













additional colour

colour used in combination with the main colour to indicate a specific medium

4 Colours

The main colours represented in the electronic file of this International Standard are reference colours; colours of a similar shade and tone may also be used for marking pipes (see Table 1).

Table 1 — Chromaticity

Main colour	Letter code ^a	Co-ordinate points of chromaticity areas ^b								Luminance factor	Example
		1		2		3		4			
		<i>x</i>	<i>y</i>	<i>x</i>	<i>y</i>	<i>x</i>	<i>y</i>	<i>x</i>	<i>y</i>	β	
Black	BK	0,385	0,355	0,300	0,270	0,260	0,310	0,345	0,395	$\leq 0,03$	
Blue	BU	0,078	0,171	0,196	0,250	0,225	0,184	0,137	0,038	$\geq 0,05$	
Brown	BN	0,510	0,370	0,427	0,353	0,407	0,373	0,475	0,405	$\geq 0,04$	
Green	GN	0,313	0,682	0,313	0,453	0,209	0,383	0,013	0,486	$\geq 0,10$	
Grey	GY	0,350	0,360	0,300	0,310	0,290	0,320	0,340	0,370	$0,15 \leq \beta \leq 0,50$	
Maroon	MN	0,302	0,064	0,307	0,203	0,374	0,247	0,457	0,136	$\geq 0,10$	
Orange	OG	0,610	0,390	0,535	0,375	0,506	0,404	0,570	0,429	$\geq 0,25$	
Silver	SR	Luminance factor $\beta > 0,50$									
Red	RD	0,690	0,310	0,595	0,315	0,569	0,341	0,655	0,345	$\geq 0,07$	
Violet	VT	0,250	0,160	0,286	0,146	0,293	0,273	0,304	0,275	$0,10 \leq \beta \leq 0,36$	
White	WH	0,350	0,360	0,300	0,310	0,290	0,320	0,340	0,370	$\geq 0,75$	
Yellow	YE	0,522	0,477	0,470	0,440	0,427	0,483	0,465	0,534	$\geq 0,45$	

^a As given in IEC 60757.

^b CIE 1931 chromaticity co-ordinates for standard illuminant D65 and 45/0 or d/8 measurement geometry in accordance with CIE 015.

Table 2 — Main colours and media

Main colour	Medium
Black	Waste media ^a
Blue	Fresh water
Brown	Fuel
Green	Sea water ^b
Grey	Non-flammable gases
Maroon	Air and sounding pipes
Orange	Oils other than fuels
Silver	Steam
Red	Fire fighting
Violet	Acids, alkalis
White	Air in ventilation systems
Yellow	Flammable gases
^a Examples: black water, grey water, waste oil, exhaust gas. ^b For ships with mixed navigation (sea-river ships): all outside waters.	

Table 3 — Additional colours for different media or functions

Waste media	BK (main colour)
Black water	BK – BU – BK
Waste oil/used oil	BK – BN – BK
Bilge water	BK – GN – BK
Exhaust gas	BK – GY – BK
	BK – MN – BK
	BK – OG – BK
	BK – SR – BK
	BK – RD – BK
	BK – VT – BK
Grey water	BK – WH – BK
Sewage, contaminated	BK – YE – BK

Fresh water	BU (main colour)
	BU – BK – BU
Fresh water, sanitary	BU – BN – BU
Potable water	BU – GN – BU
Distillate	BU – GY – BU
	BU – MN – BU
Gas-turbine wash water	BU – OG – BU
Feed water	BU – SR – BU
	BU – RD – BU
Cooling fresh water	BU – VT – BU
Chilled water	BU – WH – BU
Condensate	BU – YE – BU

Fuel	BN (main colour)
Heavy fuel oil (HFO)	BN – BK – BN
Aviation fuel	BN – BU – BN
	BN – GN – BN
	BN – GY – BN
	BN – MN – BN
	BN – OG – BN
	BN – SR – BN
	BN – RD – BN
Biological fuel	BN – VT – BN
Gas-turbine fuel	BN – WH – BN
Marine diesel oil (MDO)	BN – YE – BN

Sea water	GN (main colour)
	GN – BK – GN
Decontamination water	GN – BU – GN
Sea water, sanitary	GN – BN – GN
	GN – GY – GN
	GN – MN – GN
	GN – OG – GN
	GN – SR – GN
	GN – RD – GN
Ballast water	GN – VT – GN
	GN – WH – GN
Cooling sea water	GN – YE – GN

Non-flammable gases	GY (main colour)
	GY – BK – GY
Oxygen	GY – BU – GY
Inert gas	GY – BN – GY
Nitrogen	GY – GN – GY
Refrigerant	GY – MN – GY
Compressed air LP (Low pressure)	GY – OG – GY
	GY – SR – GY
Compressed air HP (High pressure)	GY – RD – GY
Control air/regulating air	GY – VT – GY
Breathing air ^a	GY – WH – GY
Breathing gas ^a	GY – YE – GY

^a This marking is used in submarines for distribution systems of breathing air from cylinders.

Air and sounding pipes	MN (main colour)
Waste media	MN – BK – MN
Fresh water	MN – BU – MN
Fuel	MN – BN – MN
Sea water	MN – GN – MN
Non-flammable gases	MN – GY – MN
Oil other than fuels	MN – OG – MN
Steam	MN – SR – MN
Fire fighting	MN – RD – MN
Acids, alkalis	MN – VT – MN
Ventilation system	MN – WH – MN
Flammable gases	MN – YE – MN

Table 3 (continued)

Oils other than fuels	OG (main colour)
	OG – BK – OG
Thermal fluid	OG – BU – OG
	OG – BN – OG
Lubrication oil for gas turbines	OG – GN – OG
Hydraulic fluid	OG – GY – OG
	OG – MN – OG
Lubrication oil for steam turbines	OG – SR – OG
	OG – RD – OG
Lubrication oil for gears	OG – VT – OG
	OG – WH – OG
Lubrication oil for internal combustion engines	OG – YE – OG

Steam	SR (main colour)
Steam for heating purposes	SR – BK – SR
	SR – BU – SR
	SR – BN – SR
Driving steam	SR – GN – SR
	SR – GY – SR
	SR – MN – SR
	SR – OG – SR
	SR – RD – SR
	SR – VT – SR
Exhaust steam	SR – WH – SR
Supply steam	SR – YE – SR

Fire fighting/ fire protection	RD (main colour)
	RD – BK – RD
	RD – BU – RD
	RD – BN – RD
Fire-fighting water	RD – GN – RD
Fire-fighting gas	RD – GY – RD
	RD – MN – RD
Sprinkler water	RD – OG – RD
	RD – SR – RD
Spray water	RD – VT – RD
Fire-fighting powder	RD – WH – RD
Fire-fighting foam	RD – YE – RD

Acids, alkalis	VT (main colour)
	VT – BK – VT
	VT – BU – VT
	VT – BN – VT
	VT – GN – VT
	VT – GY – VT
	VT – MN – VT
	VT – OG – VT
	VT – SR – VT
	VT – RD – VT
	VT – WH – VT
	VT – YE – VT

Air in ventilation systems	WH (main colour)
Discharge air	WH – BK – WH
Mechanical supply air, cold	WH – BU – WH
Natural exhaust air	WH – BN – WH
Atmospheric air	WH – GN – WH
Mechanical exhaust air	WH – GY – WH
Decontaminated supply air	WH – MN – WH
Mechanical recirculated air	WH – OG – WH
Mechanical supply air, warm	WH – SR – WH
Smoke clearance	WH – RD – WH
Conditioned supply air	WH – VT – WH
Natural supply air	WH – YE – WH

Flammable gases	YE (main colour)
	YE – BK – YE
Hydrogen	YE – BU – YE
	YE – BN – YE
	YE – GN – YE
Acetylene	YE – GY – YE
	YE – MN – YE
	YE – OG – YE
	YE – SR – YE
	YE – RD – YE
Liquid gas	YE – VT – YE
	YE – WH – YE

5 Design

5.1 General

The colours may be

- applied to the pipeline as an adhesive tape or sign, or
- painted onto the pipeline in stripes.

Main colours may also be painted onto the pipeline on the total length.

The markings shall be so positioned that the colour stripes (tapes) are perpendicular to the axis of the pipe.

Additional colour markings may be added adjacent to a main colour marking on a pipe, when necessary, to distinguish between pipes marked with the same main colour listed in Table 2, but carrying different types of medium (for example, a pipe carrying marine diesel oil and another pipe carrying heavy fuel oil).

The area (or width) of additional colours shall be less than the area (or width) of main colours so that it is clearly apparent which are the main colours and which are additional colours.

The marking shall be readily visible. It shall be arranged in such a way that the additional colour is surrounded by the main colour.

Pipelines shall be marked as follows:

- once in each room, at least;
- at each penetration point in bulkheads, walls and decks;
- close to each valve;
- within a distance of 3 m to 5 m of the length of the pipeline, whereby the local conditions may require a more frequent marking due to pipe bends or the close proximity of pipes for different services.

Paints and adhesives of self-adhesive identification labels or coloured tapes shall neither attack nor damage the surface of the pipe components that are to be marked.

5.2 Marking of pipes with tapes

Pipes of up to 200 mm outer diameter:

- the tapes comprise the entire circumference of the pipes and are adhered at their ends by overlapping.

Pipes of more than 200 mm outer diameter:

- the tapes comprise about half the circumference of the pipes.

Pipes in bundles:

- shall be individually marked.

If the marking is not possible over the entire circumference, an abbreviation of the marking is admissible.

A common marking of several pipes with the same content or function is only admissible on collars.

5.3 Supplementary indications

Arrows to indicate the direction of flow in a pipe are recommended. Pipes with flow in opposite directions at different times may be marked with arrows pointing in opposite directions.

Additional marking by text is also recommended to signify unambiguously the content and/or function of the pipe. When additional markings by text are used, consideration should be given to the use of a language understood by the crew members whose responsibilities include being able to identify pipes and piping systems.

Annex A (informative)

Explanations for some media/functions

A.1 Waste media

A.1.1 Description

This includes all media that contain dirt or other foreign substances.

These media are described in A.1.2 to A.1.7.

A.1.2 Black water

Black water includes the following:

- a) sewage from all kinds of toilets, urinals and bidets;
- b) sewage from all kinds of medical areas (hospital, pharmacy, etc.) and from all wash-basins, bathing tubes and scuppers located in these areas;
- c) sewage from rooms with living animals;
- d) sewage that is a mixture of the types listed from a) to c).

A.1.3 Waste oil/used oil

Oil drained after admissible working hours, exceeding admissible analysis values or containing dirt or other foreign substances.

A.1.4 Bilge water

Water from all kinds of ship bilges.

A.1.5 Exhaust gas

Exhaust from combustion engines, boilers and thermal-fluid heaters.

A.1.6 Grey water

All kinds of sewage from sanitation rooms, provision rooms, ventilation rooms, cargo holds and decks, excluding black water.

A.1.7 Sewage, contaminated

All contaminated sewage, excluding black water and grey water.

A.2 Fresh water

A.2.1 Description

This includes water used either for human consumption or for engineering technical purposes, e.g. fresh water for cooling engines.

A.2.2 Fresh water types

Fresh water types include the following.

- a) Fresh water, sanitary: fresh water used in sanitation plants;
- b) Cooling fresh water: fresh water, with additional substances used for cooling purposes;
- c) Gas-turbine wash water: fresh water used for washing gas turbines;
- d) Feed water: water to feed a boiler;
- e) Distillate: chemically pure water;
- f) Potable water: water used for human consumption;
- g) Chilled water: water used as a heat carrier, e.g. in an air-conditioning plant;
- h) Condensate: condensed steam.

A.3 Fuel

Types of fuel include the following.

- a) Heavy fuel oil (HFO): e.g. fuel in accordance with ISO 8216-99, family R;
- b) Aviation fuel: fuel used for aircraft;
- c) Biological fuel: all fuels of biological origin;
- d) Gas-turbine fuel: fuel used for gas turbines;
- e) Marine diesel oil (MDO): e.g. fuel in accordance with ISO 8216-1, category DMC.

A.4 Sea water

A.4.1 Description

Sea water is water taken from outside the ship.

A.4.2 Sea-water types

Sea-water types include the following.

- a) Decontamination water: sea water used for decontamination purposes;
- b) Sea water, sanitary: sea water used for the sanitation plant;
- c) Ballast water: sea water used for stability, trimming, anti-rolling and rigidity purposes;
- d) Cooling sea water: sea water used for cooling purposes.

A.5 Non-flammable gases

Types of non-flammable gas include the following.

- a) Compressed air: air under pressure that is greater than that of the atmosphere;
- b) Refrigerant: substance used as a heat carrier for refrigeration purposes;
- c) Control air/regulation air: air used for control and regulation purposes;
- d) Breathing air: compressed air used in breathing-air cylinders;
- e) Breathing gas: compressed gas used in breathing-gas cylinders.

A.6 Oils other than fuel

A.6.1 Description

This includes natural and synthetic oils other than fuel.

A.6.2 Types

Types of oil other than fuel include the following.

- a) Thermal fluid: fluid used as a heat carrier in thermal-fluid heater systems;
- b) Lubrication oil for gas turbines: oil used for lubricating purposes in a gas-turbine plant;
- c) Hydraulic fluid: fluid used in hydraulic systems to transmit pressure or volumetric flow;
- d) Lubricating oil for steam turbines: oil used for lubricating purposes in a steam-turbine plant;
- e) Lubrication oil for gears: oil used for lubricating purposes in gears;
- f) Lubricating oil for internal-combustion engines: oil used for lubricating purpose in internal-combustion engines.

A.7 Steam

A.7.1 Description

Steam is described here as the vapour into which water is converted when heated to boiling point.

A.7.2 Types

Types of steam include the following.

- a) Steam for heating purposes: steam used for heating purposes;
- b) Driving steam: steam for steam turbines;
- c) Supply steam: steam that passes into an apparatus;
- d) Exhaust steam: steam that is returning from an apparatus.

A.8 Fire fighting/fire protection

Fire-fighting system types include the following.

- a) Fire-fighting water: water used for fire-fighting purposes;
- b) Fire-fighting gas: gas used for fire-fighting purposes (e.g. CO₂);
- c) Sprinkler water: water used for fire-fighting purposes in a sprinkler plant;
- d) Spray water: sea water used in spray and wash-down plants;
- e) Fire-fighting powder: powder used for fire-fighting purposes;
- f) Fire-fighting foam: foam used for fire-fighting purposes.

A.9 Air in ventilation systems

Types of air in ventilation systems include the following.

- a) Discharge air: air that is exhausted into the free atmosphere;
- b) Mechanical supply air, cold: cooled air with a temperature lower than room air temperature, mechanically supplied;
- c) Natural exhaust air: air that leaves a room without mechanical assistance;
- d) Atmospheric air: air in an outdoor atmosphere (fresh air);
- e) Mechanical exhaust air: air that leaves a room with mechanical assistance;
- f) Decontaminated supply air: air that is cleaned, for example to remove poisons or other life-threatening substances;
- g) Mechanical recirculated air: air that returns to a room, i.e. a part of the exhaust air;
- h) Mechanical supply air, warm: warmed air with a temperature higher than room air temperature, mechanically supplied;
- i) Smoke clearance: removal of smoke after a fire;
- j) Conditioned supply air: supply air that must be retained at a given temperature and humidity;
- k) Natural supply air: supply air that enters a room without mechanical assistance.

Annex B (informative)

Standard colours and equivalent colour codes

The colours of this International Standard are defined in accordance with CIE 015. This annex provides guidance for those countries that use other colour systems. Table B.1 contains the standard colours and their equivalent codes in other colour systems.

Table B.1 — Standard colours and equivalent colour codes

Main colour	Letter code	RAL	Pantone matching system® (PMS)	Munsell code
Black	BK	9005	Black	N1
Blue	BU	5015	2925C	2.5PB 3.5/10
Brown	BN	8001	154C	5YR 3.5/4
Green	GN	6018	362C	10GY 4/10
Grey	GY	7001	430C	N5
Maroon	MN	8015	490C	2.5RP 4/12
Orange	OG	2003	158C	2.5YR 6/14
Silver	SR	9006	877C	—
Red	RD	3000	1797C	7.5R 4/14
Violet	VT	4001	2685C	2.5P 4/11
White	WH	9010	White	N9.5
Yellow	YE	1021	116C	2.5Y 8/14

NOTE Additional colour codes may be used.

Bibliography

- [1] ISO 8216-1, *Petroleum products — Fuels (class F) — Classification — Part 1: Categories of marine fuels*
- [2] ISO 8216-99, *Petroleum products — Fuels (class F) — Classification — Part 99: General*

ICS 01.070; 47.020.30

Price based on 13 pages